



APPLICATION FOR PREAPPROVAL SPECIAL SEISMIC CERTIFICATION OF EQUIPMENT AND COMPONENTS

For Office Use Only

APPLICATION NO.

OSP – 0020 – 10

Check whether application is: NEW RENEWAL

1.0 Square D by Schneider Electric North America Philip Caldwell
Manufacturer *Manufacturer's Technical Representative*

1990 Sandifer Blvd, Seneca, SC 29678
Mailing Address

864-886-1471 philip.caldwell@us.schneider-electric.com
Telephone *E-mail Address*

2.0 M-Flex, S-Flex, E-Flex, PowerGard, ATS-48 Packaged AC Drives & Soft Starts
Product Name *Product Type*

See attached Product Range Summary
Product Model No (List all unique product identification numbers and/or serial numbers)

General Description: Drives and soft-starts use power electronic solid state switching devices to control speed or torque of common industrial squirrel case induction motors.

3.0 Square D by Schneider Electric North America Philip Caldwell
Applicant Company Name *Contact Person*

1990 Sandifer Blvd, Seneca, SC 29678
Mailing Address

864-886-1471 philip.caldwell@us.schneider-electric.com
Telephone *E-mail Address*

I hereby agree to reimburse the Office of Statewide Health Planning and Development for the actual costs incurred by the department for review.

Philip J. Caldwell
Signature of Applicant

2/3/2011
Date

Edison Expert
Title

Schneider Electric
Company Name

1/17



Registered Design Professional Preparing the Report

4.0 University of Alabama - Birmingham

Company Name

Lee Gholamreza Moradi

Contact Name

C41383

California License Number

4824 Sulphur Springs Rd, Hoover, AL 35226

Mailing Address

205-975-2718

Telephone

moradi@uab.edu

E-mail Address

California Licensed Structural Engineer Review and Acceptance of the Report

5.0 Forell-Elsesser Engineers, Inc.

Company Name

Marco Scanu, SE

Contact Name

S4454

California License Number

160 Pine St., 6th Flr., San Francisco, CA 94111

Mailing Address

415-837-0700

Telephone

m.scanu@forell.com

E-mail Address

Anchorage Pre-Approval

- 6.0 [] Anchorage is pre-approved under OPA- (Separate application for anchorage pre-approval is required)
[X] Anchorage is not Pre-approved

Certification Method

- 7.0 [X] Testing in accordance with: [X] ICC-ES AC-156 [] Other (Please Specify):
[] Analysis
[] Experience data
[] Combination of Testing, Analysis, and/or Experience Data (Please Specify):

Testing Laboratory (if applicable)

8.0 Wyle Laboratories Rod Thornberry

Company Name

Contact Name

7800 Hwy 20, Huntsville, AL 35806

Mailing Address

(256) 837-4411

Telephone

mark.orlowski@swri.org

E-mail:

2/17



Approval Parameters

9.0

Design in accordance with ASCE 7-05 Chapter 13: Yes No

Design Basis of Equipment or Components (Fp/Wp) = Floor-mounted: 1.43g;
Floor Mounted w/ Top Restraints: 1.88g
Wall-mounted: 1.88g

Sds (Spectral response acceleration at short period) = Floor-mounted: 1.91g;
Floor Mounted w/ Top Restraints: 2.50g
Wall-mounted: 2.50g

ap (In-structure equipment or component amplification factor) = 2.5

Rp (Equipment or component response modification factor) = 6.0

Ip (Importance factor) = 1.5

z/h (Height factor ratio) = 1.0

Equipment or Component fundamental period(s) = See Attachments

Building period limits (if any) = n/a

Overall dimensions and weight = See Attachments

Equipment or Components @ grade designed in accordance with ASCE 7-05 Chapter 15: Yes No

Design Basis of Equipment or Components (V/W) =

Sds (Spectral response acceleration at short period) =

S1 (Spectral response acceleration at 1 second period) =

R (Response modification coefficient)=1.0

Ωo (System overstrength factor) =1.0

Cd (Deflection amplification factor) =1.0

Ip (Importance factor) =1.5

Height to Center of Gravity above base =

Equipment or Component fundamental period(s) = Sec

Overall dimensions and weight (or range thereof) =

Tank(s) designed in accordance with ASME BPVC, 2007: Yes No

11.0 List of attachments supporting the special seismic certification of equipment or components:

- Test Report, Calculations, Drawings, Other (Please Specify): SE Acceptance Letter, Manufacturer's Catalog

11.0 OSHPD Approval (For Office Use Only)

Signature & Date

Chris Tokas, SHFR

Name & Title

2/3/2011

December 31, 2016

Approval Expiration Date

Sds (g) = See Section 9.0 z/h = 1.0

Special Seismic Certification Valid Up to

Condition of Approval (if any):

3/17

Square D – Packaged AC Drives and Soft Starts

Table 1A – Product Range Summary Drives & Soft Starts Wall Mounted

Square D by Schneider Electric – Packaged AC Drives & Soft Starts HP Rated Product Range Summary Rigid Wall Mounted					
HP	Width (in)	Depth (in)	Height (in)	Service Weight (lbs)	Notes
S-Flex Enclosed Drive Controller					
1 – 100	8 - 16	7 - 12	40 - 65	52 - 206	1, 2, 3
M-Flex Enclosed Drive Controller					
1 – 25	20 - 25	15	49 - 63	175 - 243	1, 2, 3, 4
E-Flex Enclosed Drive Controller					
1 – 100	14 - 36	13 - 17	35 - 67	83 - 247	1, 2, 3, 5, 6
ATS-48 Enclosed Soft Start Motor Controller					
3 – 150	18 - 25	14	33 - 63	110 - 200	1, 2, 3, 5, 6
Notes:					
1. Mild steel sheet metal construction					
2. Rigid wall mounted					
3. NEMA Type 1 enclosure					
4. NEMA Type 1A gasket/filtered enclosure					
5. NEMA Type 3R outdoor enclosure					
6. NEMA Type 12 dust/drip enclosure					

Table 1B – Product Range Summary Drives & Soft Starts Floor Mounted

Square D by Schneider Electric – Packaged AC Drives & Soft Starts HP Rated Product Range Summary Rigid Floor Mounted					
HP	Width (in)	Depth (in)	Height (in)	Service Weight (lbs)	Notes
M-Flex Enclosed Drive Controller					
15 - 500	20 - 35	21	95	170 - 969	1, 2, 3, 4, 6
PowerGard 18-Pulse Enclosed Drive Controller					
50 - 500	36 - 102	25	95	1603 - 3148	1, 2, 3, 4
ATS-48 Enclosed Soft Start Motor Controller					
60 – 600	20 – 63	20 – 33	95	200 - 1050	1, 2, 3, 5, 6
Notes:					
1. Mild steel sheet metal construction					
2. Rigid floor anchored – top-restraints are optional					
3. NEMA Type 1 enclosure					
4. NEMA Type 1A gasket/filtered enclosure					
5. NEMA Type 3R outdoor enclosure					
6. NEMA Type 12 dust/drip enclosure					



Table 2 – Resonant Frequency Summary

Test Size (HP)	Width (in)	Depth (in)	Height (in)	Tested Weight (lbs)	Dynamic Test	Resonant Frequency Summary		
						F-B (Hz)	S-S (Hz)	V (Hz)
500	85	20	91.5	2724	Test 52651-1 UUT	8.6	9.1	9.2
100	25	20	90	513	Test 54869R07 UUT3	8.4	8.8	8.8
500	65	20	91.5	1930	Test 51551-1 UUT1	7.6	7.8	22.0
500	48	27	95	3226	Test 53850-1 UUT3	5.3	5.2	7.1

Note: Resonant frequencies are shown only for units tested floor-mounted without top restraints.



OSP APPLICATION
 Square D – Packaged AC Drives and Soft Starts

Date: 2/2/2011

Table 3 – Test Summary

Test Size (HP)	Width (in)	Depth (in)	Height (in)	Tested Weight (lbs)	Dynamic Test	Mounting	S _{DS}
500	85	20	91.5	2724	Test 52651-1 UUT	Floor	1.91
100	25	16	66	354	Test 52651-2 UUT	Wall	2.50
40	14	12	64	200	Test 54869R07 UUT1	Wall	2.50
40	12	11	60	132	Test 54869R07 UUT2	Wall	2.58
100	25	20	90	513	Test 54869R07 UUT3	Floor	2.08
100	25	20	90	513	Test 54869R07 UUT3A	Floor w/ Top Restraints	2.50
20	12	13	40	80	Test 53850-1 UUT2	Wall	2.50
60	18	13	62	210	Test 51551-3 UUT1	Wall	2.50
100	35	16	66	296	Test 51551-3 UUT2	Wall	2.50
500	65	20	91.5	1930	Test 51551-1 UUT1	Floor	2.10
500	48	27	95	3226	Test 53850-1 UUT3	Floor	2.07
500	48	27	95	3226	Test 53850-1 UUT3A	Floor w/ Top Restraints	2.75



FORELL/ELSEESSER ENGINEERS, INC.
 Structural Engineers
 160 Pine Street, 6th Floor
 San Francisco, CA 94111

6/17

Floor Mount			
Test Size (HP)	Tested Weight (lbs)	Dynamic Test	Enclosure System
100	513	54869R07 UUT3	M-Flex Drive
450 & 40	2724	52651-1 UUT	MCC & E-Flex
500	1930	51551-1 UUT1	MCC & E-Flex
500	3226	53850-1 UUT3	PowerGuard Series C 18 Pulse Drive

Wall Mount			
Test Size (HP)	Tested Weight (lbs)	Dynamic Test	Enclosure System
20	80	53850-1 UUT2	S-Flex Drive
40	200	54869R07 UUT1, UUT2	S-Flex Drive
60	210	51551-3 UUT1	ATS48 Soft-Start, N1 (envelops ATS22)
100	296	51551-3 UUT2	E-Flex Drive, N3R
100	354	52651-2 UUT	E-Flex, N12



Wall mounted enclosed drives and soft-starts were shake table tested at or above an $S_{DS} = 2.46 g$ for $z/h = 1$. Floor mounted equipment is rigidly seismically anchored and was shake table tested at or above an $S_{DS} = 1.78 g$ for $z/h = 1$. In some floor mount cases a top lateral restraint was installed and the equipment shake table tested at or above an $S_{DS} = 2.46 g$ for $z/h = 1$.

Photo 3 - Addition of top lateral restraints for high level test demand.



Model 6 MCC-RSX Lineup

TEST REPORT #52651-1

8/17



EFlex-RSX Enclosure

TEST REPORT # 52651-2

9/17



UUT1 (RIGHT) AND UUT4 (LEFT) TEST SETUP

CONFIDENTIAL INFORMATION

10/17



UUT2 TEST SETUP

CONFIDENTIAL INFORMATION

11/17



UUT3 TEST SETUP

CONFIDENTIAL INFORMATION

12/17



UUT3A TEST SETUP
TWO TOP SUPPORTS

CONFIDENTIAL INFORMATION

13/17

UUT3 Configuration



UUT3 Configuration

UUT1 (Left) and UUT2 (Right) Configuration

TEST REPORT # 53850-1

14/17



UUT1 - ATS 48 (Right)
UUT2 - Drive 8839 (Left)

TEST REPORT # 51551-3

15/17

UUT1 and UUT2 are shown below and were tested concurrently.



Series I
UUT1 (Right) and UUT2 (Left)

TEST REPORT # 51551-1

16/17



UUT3 TEST SETUP WITH TOP RESTRAINTS

CONFIDENTIAL INFORMATION

17/7