



**OFFICE OF STATEWIDE HEALTH PLANNING AND DEVELOPMENT
FACILITIES DEVELOPMENT DIVISION**

**APPLICATION FOR OSHPD SPECIAL SEISMIC
CERTIFICATION PREAPPROVAL (OSP)**

OFFICE USE ONLY

APPLICATION #: OSP – 0108 – 10

OSHPD Special Seismic Certification Preapproval (OSP)

Type: New Renewal

Manufacturer Information

Manufacturer: Mitsubishi Electric US Cooling & Heating Division

Manufacturer's Technical Representative: Douglas Tucker

Mailing Address: 1340 Satellite Blvd., Suwanee, GA 30024

Telephone: (678) 376-2935 Email: DTucker@hvac.me.com

Product Information

Product Name: Mitsubishi Electric, City Multi

Product Type: Split AC, Heat Pumps, and Circuit Controllers

Product Model Number: (see attached list)

(List all unique product identification numbers and/or part numbers)

General Description: HVAC equipment including outdoor units, indoor units, and system branch controllers.

Mounting Description: Floor mounted, ceiling mounted, and wall mounted units.

Applicant Information

Applicant Company Name: Mitsubishi Electric US Cooling & Heating Division

Contact Person: Douglas Tucker

Mailing Address: 1340 Satellite Blvd., Suwanee, GA 30024


Telephone: (678) 376-2935 Email: DTucker@hvac.me.com

I hereby agree to reimburse the Office of Statewide Health Planning and Development review fees in accordance with the California Administrative Code, 2016.

Signature of Applicant:  Date: November 7, 2016

Title: Sr. Mgr., Building Code Compliance Company Name: Mitsubishi Electric US

"Access to Safe, Quality Healthcare Environments that Meet California's Diverse and Dynamic Needs"





**OFFICE OF STATEWIDE HEALTH PLANNING AND DEVELOPMENT
FACILITIES DEVELOPMENT DIVISION**

California Licensed Structural Engineer Responsible for the Engineering and Test Report(s)

Company Name: Buehler & Buehler Structural Engineers

Name: Scott R. Hooker California License Number: S3937

Mailing Address: 600 Q Street, Sacramento, CA 65811

Telephone: (916) 443-0303 Email: shooker@bbse.com

Supports and Attachments Preapproval

- Supports and attachments are preapproved under OPM- _____
(Separate application for OSHPD Preapproval of Manufacturer's Certification (OPM) of Supports and attachments is required)
- Supports and attachments are not preapproved

Certification Method

- Testing in accordance with: ICC-ES AC156
- Other (Please Specify): _____


Testing Laboratory

Company Name: Qualtech NP

Contact Name: Maria S. Nemier

Mailing Address: 4600 East Tech Drive, Cincinnati, OH 45245

Telephone: (513) 528-9292 Email: mnemier@curtisswright.com





**OFFICE OF STATEWIDE HEALTH PLANNING AND DEVELOPMENT
FACILITIES DEVELOPMENT DIVISION**

Seismic Parameters

Design in accordance with ASCE 7-10 Chapter 13: Yes No

Design Basis of Equipment or Components (F_p/W_p) = See attachment

S_{DS} (Design spectral response acceleration at short period, g) = See attachment

a_p (In-structure equipment or component amplification factor) = 2.5

R_p (Equipment or component response modification factor) = 6

Ω_0 (System overstrength factor) = 2.0

I_p (Importance factor) = 1.5

z/h (Height factor ratio) = 1

Equipment or Component Natural Frequencies (Hz) = See attachment

Overall dimensions and weight (or range thereof) = See attachment

Equipment or Components @ grade designed in accordance with ASCE 7-10 Chapter 15: Yes No

Design Basis of Equipment or Components (V/W) = _____

S_{DS} (Design spectral response acceleration at short period, g) = _____

S_{D1} (Design spectral response acceleration at 1 second period, g) = _____

R (Response modification coefficient) = _____

Ω_0 (System overstrength factor) = _____

C_d (Deflection amplification factor) = _____

I_p (Importance factor) = 1.5

Height to Center of Gravity above base = _____

Equipment or Component Natural Frequencies (Hz) = _____

Overall dimensions and weight (or range thereof) = _____

Tank(s) designed in accordance with ASME BPVC, 2015: Yes No

List of Attachments Supporting Special Seismic Certification

Test Report(s) Drawings Calculations Manufacturer's Catalog

Other(s) (Please Specify): Product Matrix, Certifications, and Labels


OSHPD Approval (For Office Use Only) – Approval Expires on December 31, 2022

Signature:  Date: November 16, 2017

Print Name: Timothy J. Piland Title: SSE

Special Seismic Certification Valid Up to : S_{DS} (g) = See Above z/h = 1

Condition of Approval (if applicable): _____





Special Seismic Certification
OSHPD Preapproval
Mitsubishi Product Line



Table 1. Certified Product List

Indoor Wall Mounted¹ ($S_{DS} = 2.00g$, $z/h = 1.00$, $F_p/W_p = 1.500$)

Model Number	Nominal Capacity	Tested/ Interpolated	Depth (in)	Width (in)	Height (in)	Operating Weight (lbs)
PKFY-P06NBMU-E	0.5 ton	UUT-14 (Q0028.0)	8 7/8	32 1/8	11 5/8	22
PKFY-P06	0.50 ton	interpolated	8 7/8	32 1/8	11 5/8	22
PKFY-P08	0.67 ton	interpolated	9 13/16	35 3/8	11 5/8	29
PKFY-P12	1.0 ton	interpolated	9 13/16	35 3/8	11 5/8	29
PKFY-P15	1.25 tons	interpolated	9 13/16	35 3/8	11 5/8	29
PKFY-P18	1.5 tons	interpolated	9 13/16	35 3/8	11 5/8	29
PKFY-P24	2.0 tons	interpolated	11 5/8	46 1/16	14 3/8	46
PKFY-P30	2.5 tons	interpolated	11 5/8	46 1/16	14 3/8	46
PKA-A12	1.0 tons	interpolated	9 13/16	35 3/8	11 5/8	29
PKA-A18	1.5 tons	interpolated	9 13/16	35 3/8	11 5/8	29
PKA-A24	2.0 tons	interpolated	11 5/8	46 1/16	14 3/8	46
PKA-A30	2.5 tons	interpolated	11 5/8	46 1/16	14 3/8	46
PKA-A36	3.0 tons	interpolated	11 5/8	46 1/16	14 3/8	46
PKA-A36KA	3.0 tons	UUT-13 (Q0028.0)	11 5/8	46 1/16	14 3/8	46

1. Certification level is limited to the lower rating (SDS and z/h) of either the Certified Component Tables as listed, or the internal subcomponents as listed on the Certified Subcomponent Tables.

Indoor Ceiling Cassette 1-Way¹ ($S_{DS} = 2.50g$, $z/h = 1.00$, $F_p/W_p = 1.875$)

Model Number	Nominal Capacity	Tested/ Interpolated	Depth (in)	Width (in)	Height (in)	Operating Weight (lbs) [Unit / Panel]
PMFY-P06NBMU-E	0.5 ton	UUT-15 (Q1619.0)	31 31/32	15 9/16	9 1/16	34 / 7
PMFY-P06	0.5 ton	interpolated	31 31/32	15 9/16	9 1/16	34 / 7
PMFY-P08	0.67 ton	interpolated	31 31/32	15 9/16	9 1/16	31 / 7
PMFY-P12	1.0 ton	interpolated	31 31/32	15 9/16	9 1/16	31 / 7
PMFY-P15	1.25 tons	interpolated	31 31/32	15 9/16	9 1/16	34 / 7
PMFY-P15NBMU-E	1.25 tons	UUT-16 (Q1619.0)	31 31/32	15 9/16	9 1/16	34 / 7

1. Certification level is limited to the lower rating (SDS and z/h) of either the Certified Component Tables as listed, or the internal subcomponents as listed on the Certified Subcomponent Tables.

Indoor Ceiling Cassette 4-Way¹ ($S_{DS} = 2.00g$, $z/h = 1.00$, $F_p/W_p = 1.500$)

Model Number	Nominal Capacity	Tested/ Interpolated	Depth (in)	Width (in)	Height (in)	Operating Weight (lbs) [Unit / Panel]
PLFY-P08	0.67 ton	extrapolated	33 3/32	33 3/32	10 3/16	42 / 11
PLFY-EP08	0.67 ton	extrapolated	33 3/32	33 3/32	10 3/16	46 / 11
PLFY-P12NBMU-E	1.0 ton	UUT-7 (Q0028.0)	33 3/32	33 3/32	10 3/16	49 / 13
PLFY-P12	1.0 ton	interpolated	33 3/32	33 3/32	10 3/16	49 / 13
PLFY-EP12	1.0 ton	interpolated	33 3/32	33 3/32	10 3/16	46 / 11
PLFY-P15	1.25 tons	interpolated	33 3/32	33 3/32	10 3/16	49 / 13
PLFY-EP15	1.25 tons	interpolated	33 3/32	33 3/32	10 3/16	46 / 11
PLFY-P18	1.5 tons	interpolated	33 3/32	33 3/32	10 3/16	51 / 13
PLFY-EP18	1.5 tons	interpolated	33 3/32	33 3/32	10 3/16	46 / 11
PLFY-P24	2.0 tons	interpolated	33 3/32	33 3/32	10 3/16	51 / 13
PLFY-EP24	2.0 tons	interpolated	33 3/32	33 3/32	10 3/16	55 / 11
PLFY-P30	2.5 tons	interpolated	33 3/32	33 3/32	10 3/16	51 / 13
PLFY-EP30	2.5 tons	interpolated	33 3/32	33 3/32	10 3/16	55 / 11
PLFY-P36	3.0 tons	interpolated	33 3/32	33 3/32	11 3/4	51 / 11
PLFY-EP36	3.0 tons	interpolated	33 3/32	33 3/32	11 3/4	55 / 11
PLFY-P48	4.0 tons	interpolated	33 3/32	33 3/32	11 3/4	55 / 11
PLFY-P48NEMU-E	4.0 tons	UUT-26 (Q1653.0)	33 3/32	33 3/32	11 3/4	55 / 11
PLFY-EP48	4.0 tons	interpolated	33 3/32	33 3/32	11 3/4	55 / 11
PLA-A12	1.0 ton	interpolated	33 1/16	33 1/16	10 3/16	49 / 13
PLA-A18	1.5 tons	interpolated	33 1/16	33 1/16	10 3/16	49 / 13
PLA-A24	2.0 tons	interpolated	33 1/16	33 1/16	10 3/16	51 / 13
PLA-A30	2.5 tons	interpolated	33 1/16	33 1/16	10 3/16	51 / 13
PLA-A36	3.0 tons	interpolated	33 1/16	33 1/16	11 3/4	55 / 13
PLA-A42	3.5 tons	interpolated	33 1/16	33 1/16	11 3/4	55 / 13
PLA-A42BA	3.5 tons	UUT-10 (Q0028.0)	33 1/16	33 1/16	11 3/4	55 / 13

1. Certification level is limited to the lower rating (SDS and z/h) of either the Certified Component Tables as listed, or the internal subcomponents as listed on the Certified Subcomponent Tables.



Special Seismic Certification
OSHDP Preapproval
Mitsubishi Product Line



Table 1. Certified Product List

Indoor Ceiling Concealed¹ ($S_{DS} = 2.00g$, $z/h = 1.00$, $F_p/W_p = 1.500$)

Model Number	Nominal Capacity	Tested/ Interpolated	Depth (in)	Width (in)	Height (in)	Operating Weight (lbs)
PEFY-P06-NMSU-E	0.5 ton	UUT-6 (Q0028.0)	27 9/16	31 1/8	7 7/8	42
PEFY-P06	0.50 ton	interpolated	27 9/16	31 1/8	7 7/8	42
PEFY-P08	0.67 ton	interpolated	27 9/16	31 1/8	7 7/8	42
PEFY-P12	1.0 ton	interpolated	27 9/16	31 1/8	7 7/8	46
PEFY-P15	1.25 tons	interpolated	35 7/16	29 7/32	14 31/32	98
PEFY-P18	1.5 tons	interpolated	35 7/16	29 7/32	14 31/32	100
PEFY-P24	2.0 tons	interpolated	35 7/16	29 7/32	14 31/32	100
PEFY-P27	2.25 tons	interpolated	35 7/16	39 3/8	14 31/32	111
PEFY-P30	2.5 tons	interpolated	35 7/16	39 3/8	14 31/32	111
PEFY-P36	3.0 tons	interpolated	35 7/16	47 1/4	14 31/32	155
PEFY-P48	4.0 tons	interpolated	35 7/16	47 1/4	14 31/32	155
PEFY-P54	4.5 tons	interpolated	35 7/16	47 1/4	14 31/32	155
PEFY-P72	6.0 tons	interpolated	44 1/8	49 1/4	18 9/16	214
PEFY-P96	8.0 tons	interpolated	44 1/8	49 1/4	18 9/16	221
PEFY-P96-NMHU-E	8.0 tons	UUT-1 (Q0028.0)	44 1/8	49 1/4	18 9/16	221
PEFY-AF1200CFM	9.3 tons	interpolated	55 1/8	49 1/4	18 9/16	287
PEFY-AF1200CFMR	9.3 tons	UUT-3 (Q0028.0)	55 1/8	49 1/4	18 9/16	309

1. Certification level is limited to the lower rating (SDS and z/h) of either the Certified Component Tables as listed, or the internal subcomponents as listed on the Certified Subcomponent Tables.

Multi-Position Air Handler² ($S_{DS} = 2.50g$, $z/h = 1.00$, $F_p/W_p = 1.875$)

Model Number	Nominal Capacity	Tested/ Interpolated	Depth (in)	Width (in)	Height (in)	Operating Weight (lbs)
PVfy-P12NAMU-E*	1.0 ton	UUT-19 (Q1619.0)	21 5/8	17	50 1/4	117
PVfy-P12	1.0 ton	interpolated	21 5/8	17	50 1/4	117
PVA-A12	1.0 ton	interpolated	21 5/8	17	50 1/4	113
PVfy-P18	1.5 tons	interpolated	21 5/8	17	50 1/4	113
PVA-A18	1.5 tons	interpolated	21 5/8	17	50 1/4	113
PVfy-P24	2.0 tons	interpolated	21 5/8	17	50 1/4	113
PVA-A24	2.0 tons	interpolated	21 5/8	21	54 1/4	141
PVfy-P30	2.5 tons	interpolated	21 5/8	21	54 1/4	141
PVA-A30	2.5 tons	interpolated	21 5/8	21	54 1/4	141
PVfy-P36	3.0 tons	interpolated	21 5/8	21	54 1/4	141
PVA-A36	3.0 tons	interpolated	21 5/8	25	59 1/2	172
PVA-A42	3.5 tons	interpolated	21 5/8	25	59 1/2	172
PVfy-P48	4.0 tons	interpolated	21 5/8	25	59 1/2	172
PVfy-P54	4.5 tons	interpolated	21 5/8	25	59 1/2	227
PVfy-P54NAMU-E*	4.5 tons	UUT-20 (Q1619.0)	21 5/8	25	59 1/2	227

1. PVA is a depopulated model PVfy (no LEV)

2. Certification level is limited to the lower rating (SDS and z/h) of either the Certified Component Tables as listed, or the internal subcomponents as listed on the Certified Subcomponent Tables.

BC Controllers¹ ($S_{DS} = 2.00g$, $z/h = 1.00$, $F_p/W_p = 1.875$, $F_p/W_p = 1.500$)

Model Number	Nominal Capacity	Tested/ Interpolated	Depth (in)	Width (in)	Height (in)	Operating Weight (lbs)
Sub BC						
CMB-P104NU-GM	10.5 tons	extrapolated	17 1/32	25 17/32	11 3/16	62
CMB-P108NU-GB	10.5 tons	extrapolated	17 1/32	25 17/32	11 3/16	82
CMB-P1016NU-HB	10.5 tons	extrapolated	17 1/32	43 1/4	11 3/16	136
Single BC						
CMB-P105NU-G	15.75 tons	UUT-9 (Q0028.0)	17 1/32	25 17/32	11 3/16	72
CMB-P106NU-G	15.75 tons	interpolated	17 1/32	25 17/32	11 3/16	76
CMB-P108NU-G	15.75 tons	interpolated	17 1/32	25 17/32	11 3/16	84
CMB-P1010NU-G	15.75 tons	interpolated	17 1/32	25 17/32	11 3/16	94
CMB-P1013NU-G	15.75 tons	interpolated	17 1/32	43 1/4	11 3/16	126
CMB-P1016NU-G	15.75 tons	interpolated	17 1/32	43 1/4	11 3/16	138
Main BC						
CMB-P108NU-GA	30.0 tons	interpolated	20 1/2	43 3/4	11 7/16	122
CMB-P1010NU-GA	30.0 tons	interpolated	20 1/2	43 3/4	11 7/16	132
CMB-P1013NU-GA	30.0 tons	interpolated	20 1/2	43 3/4	11 7/16	148
CMB-P1016NU-HA	36.0 tons	UUT-12 (Q0028.0)	20 1/2	43 3/4	11 7/16	162

1. Certification level is limited to the lower rating (SDS and z/h) of either the Certified Component Tables as listed, or the internal subcomponents as listed on the Certified Subcomponent Tables.



Special Seismic Certification
OSHPD Preapproval
Mitsubishi Product Line



Table 1. Certified Product List

Outdoor Heat Pump - (P-Series)

Model Number	Nominal Capacity	Tested/ Interpolated	Depth (in)	Width (in)	Height (in)	Operating Weight (lbs)	S _{DS} (g)	F _p / W _p
Outdoor Heat Pump - PUY & PUZ - Single Fan¹								
PUY-A12NHA3	1.0 ton	UUT-11 (Q0028.0)	11 13/16	31 1/2	23 5/8	90	2.00	1.500
PUY-A18	1.5 tons	interpolated	11 13/16	31 1/2	23 5/8	89	2.00	1.500
PUZ-A18	1.5 tons	interpolated	11 13/16	31 1/2	23 5/8	91	2.00	1.500
PUY-A24	2.0 tons	interpolated	13	37 3/8	37 1/8	163	2.00	1.500
PUZ-A24	2.0 tons	interpolated	13	37 3/8	37 1/8	165	2.00	1.500
PUY-A30	2.5 tons	interpolated	13	37 3/8	37 1/8	163	2.00	1.500
PUZ-A30	2.5 tons	interpolated	13	37 3/8	37 1/8	165	2.00	1.500
PUY-A36	3.0 tons	interpolated	13	37 3/8	37 1/8	163	2.00	1.500
PUZ-A36NHA3	3.0 tons	UUT-4 (Q0028.0)	13	37 3/8	37 1/8	165	2.00	1.500
Outdoor Heat Pump - PUY & PUZ - Double Fan¹								
PUZ-HA30	2.5 tons	interpolated	13	37 3/8	53 1/8	265	2.00	1.500
PUZ-HA36	3.0 tons	interpolated	13	37 3/8	53 1/8	265	2.00	1.500
PUY-A42	3.5 tons	interpolated	13	37 3/8	53 1/8	258	2.00	1.500
PUZ-A42	3.5 tons	interpolated	13	37 3/8	53 1/8	260	2.00	1.500
PUZ-HA42	3.5 tons	interpolated	13	41 5/16	52 11/16	287	2.00	1.500
Outdoor Heat Pump - PUMY-P36 to P48 - Double Fan¹								
PUMY-P36	3.0 tons	interpolated	13	41 11/32	52 11/16	269	2.00	1.500
PUMY-P48	4.0 tons	interpolated	13	41 11/32	52 11/16	269	2.00	1.500
PUMY-P48NHMU	4.0 tons	UUT-5 (Q0028.0)	13	37 7/16	53 3/16	287	2.00	1.500
Outdoor Heat Pump - PUMY-P60 - Double Fan¹								
PUMY-P60NKMU1	5.0 tons	UUT-27 (Q1653.0)	13	41 11/32	52 11/16	306	1.34	1.005

1. Certification level is limited to the lower rating (SDS and z/h) of either the Certified Component Tables as listed, or the internal subcomponents as listed on the Certified Subcomponent Tables.

Outdoor Heat Recovery / Heat Pump - Water-source³ (S_{DS} = 2.00g, z/h = 1.00, F_p/W_p = 1.500)

Model Number	Nominal Capacity	Tested/ Interpolated	Depth (in)	Width (in)	Height (in)	Operating Weight (lbs)
PQRY-P72TLMU-A	6.0 tons	UUT-24 (Q1619.0)	21 11/16	34 11/16	43 5/16	380
PQRY-P72YLMU-A	6.0 tons	interpolated	21 11/16	34 11/16	43 5/16	404
PQHY-P72TLMU-A	6.0 tons	interpolated	21 11/16	34 11/16	43 5/16	384
PQHY-P72YLMU-A	6.0 tons	interpolated	21 11/16	34 11/16	43 5/16	408
PQRY-P96TLMU-A	8.0 tons	interpolated	21 11/16	34 11/16	43 5/16	380
PQRY-P96YLMU-A	8.0 tons	interpolated	21 11/16	34 11/16	43 5/16	404
PQHY-P96TLMU-A	8.0 tons	interpolated	21 11/16	34 11/16	43 5/16	384
PQHY-P96YLMU-A	8.0 tons	interpolated	21 11/16	34 11/16	43 5/16	408
PQRY-P120TLMU-A	10.0 tons	interpolated	21 11/16	34 11/16	43 5/16	380
PQRY-P120YLMU-A	10.0 tons	interpolated	21 11/16	34 11/16	43 5/16	404
PQHY-P120TLMU-A	10.0 tons	interpolated	21 11/16	34 11/16	43 5/16	384
PQHY-P120YLMU-A	10.0 tons	interpolated	21 11/16	34 11/16	43 5/16	408
PQRY-P144TLMU-A	12.0 tons	interpolated	21 11/16	34 11/16	57 1/8	479
PQRY-P144YLMU-A	12.0 tons	interpolated	21 11/16	34 11/16	57 1/8	505
PQHY-P144TLMU-A	12.0 tons	interpolated	21 11/16	34 11/16	57 1/8	481
PQHY-P144YLMU-A	12.0 tons	interpolated	21 11/16	34 11/16	57 1/8	508
PQRY-P168TLMU-A	14.0 tons	interpolated	21 11/16	34 11/16	57 1/8	479
PQRY-P168YLMU-A	14.0 tons	interpolated	21 11/16	34 11/16	57 1/8	505
PQHY-P168TLMU-A	14.0 tons	interpolated	21 11/16	34 11/16	57 1/8	481
PQHY-P168YLMU-A	14.0 tons	interpolated	21 11/16	34 11/16	57 1/8	508
PQRY-P192TLMU-A	16.0 tons	interpolated	21 11/16	34 11/16	57 1/8	479
PQRY-P192YLMU-A	16.0 tons	interpolated	21 11/16	34 11/16	57 1/8	505
PQHY-P192TLMU-A	16.0 tons	interpolated	21 11/16	34 11/16	57 1/8	481
PQHY-P192YLMU-A	16.0 tons	interpolated	21 11/16	34 11/16	57 1/8	508
PQRY-P216TLMU-A	18.0 tons	interpolated	21 11/16	34 11/16	57 1/8	556
PQRY-P216YLMU-A	18.0 tons	interpolated	21 11/16	34 11/16	57 1/8	571
PQHY-P216TLMU-A	18.0 tons	interpolated	21 11/16	34 11/16	57 1/8	558
PQHY-P216YLMU-A	18.0 tons	interpolated	21 11/16	34 11/16	57 1/8	574
PQRY-P240TLMU-A	20.0 tons	interpolated	21 11/16	34 11/16	57 1/8	556
PQRY-P240YLMU-A	20.0 tons	interpolated	21 11/16	34 11/16	57 1/8	571
PQHY-P240TLMU-A	20.0 tons	interpolated	21 11/16	34 11/16	57 1/8	558
PQHY-P240YLMU-A	20.0 tons	UUT-25 (Q1653.0)	21 11/16	34 11/16	57 1/8	574

1. PQRY models have heat recovery capability (simultaneous heating and cooling)

2. PQHY models are standard heat pumps (heating-only or cooling-only)

3. Certification level is limited to the lower rating (SDS and z/h) of either the Certified Component Tables as listed, or the internal subcomponents as listed on the Certified Subcomponent Tables.



Special Seismic Certification
OSHPD Preapproval
Mitsubishi Product Line



Table 1. Certified Product List

Outdoor Heat Recovery / Heat Pump - Air-Source³ (S_{DS} = 2.50g, z/h = 1.00, F_p/W_p = 1.875)

Model Number	Nominal Capacity	Tested/ Interpolated	Depth (in)	Width (in)	Height (in)	Operating Weight (lbs)
PUHY-P72TKMU-A	6.0 tons	extrapolated	29 5/32	36 1/4	64 31/32	430
PUHY-P72TLMU-A	6.0 tons	UUT-22 (Q1619.0)	29 5/32	36 1/4	64 31/32	435
PUHY-P72YKMU-A	6.0 tons	interpolated	29 5/32	36 1/4	64 31/32	463
PURY-P72TLMU-A	6.0 tons	interpolated	29 5/32	36 1/4	64 31/32	444
PURY-P72YLMU-A	6.0 tons	interpolated	29 5/32	36 1/4	64 31/32	474
PUHY-P72YLMU-A	6.0 tons	interpolated	29 5/32	36 1/4	64 31/32	468
PURY-P72TKMU-A	6.0 tons	interpolated	29 5/32	48 1/16	64 31/32	503
PURY-P72YKMU-A	6.0 tons	interpolated	29 5/32	48 1/16	64 31/32	534
PURY-HP72TKMU-A-H	6.0 tons	interpolated	29 5/32	48 1/16	64 31/32	552
PURY-HP72YKMU-A	6.0 tons	interpolated	29 5/32	48 1/16	64 31/32	574
PURY-HP72YKMU-A-H	6.0 tons	interpolated	29 5/32	48 1/16	64 31/32	580
PURY-P96TLMU-A	8.0 tons	interpolated	29 5/32	48 1/16	64 31/32	503
PURY-P96YLMU-A	8.0 tons	interpolated	29 5/32	48 1/16	64 31/32	534
PUHY-P96TLMU-A	8.0 tons	interpolated	29 5/32	48 1/16	64 31/32	499
PUHY-P96YLMU-A	8.0 tons	interpolated	29 5/32	48 1/16	64 31/32	532
PUHY-P96TKMU-A	8.0 tons	interpolated	29 5/32	48 1/16	64 31/32	532
PUHY-P96YKMU-A	8.0 tons	interpolated	29 5/32	48 1/16	64 31/32	558
PURY-P96TKMU-A	8.0 tons	interpolated	29 5/32	48 1/16	64 31/32	538
PURY-P96YKMU-A	8.0 tons	interpolated	29 5/32	48 1/16	64 31/32	574
PURY-HP96TKMU-A-H	8.0 tons	interpolated	29 5/32	48 1/16	64 31/32	552
PURY-HP96YKMU-A	8.0 tons	interpolated	29 5/32	48 1/16	64 31/32	576
PURY-HP96YKMU-A-H	8.0 tons	interpolated	29 5/32	48 1/16	64 31/32	580
PUHY-P120TKMU-A	10.0 tons	interpolated	29 5/32	68 29/32	64 31/32	697
PUHY-P120YKMU-A	10.0 tons	interpolated	29 5/32	68 29/32	64 31/32	726
PURY-P120TKMU-A	10.0 tons	interpolated	29 5/32	68 29/32	64 31/32	715
PURY-P120YKMU-A	10.0 tons	interpolated	29 5/32	68 29/32	64 31/32	743
PURY-P120TLMU-A	10.0 tons	interpolated	29 5/32	68 29/32	64 31/32	695
PURY-P120YLMU-A	10.0 tons	interpolated	29 5/32	68 29/32	64 31/32	730
PURY-P120TLMU-A	10.0 tons	interpolated	29 5/32	68 29/32	64 31/32	671
PUHY-P120YLMU-A	10.0 tons	interpolated	29 5/32	68 29/32	64 31/32	706
PURY-P144TLMU-A	12.0 tons	interpolated	29 5/32	68 29/32	64 31/32	695
PURY-P144YLMU-A	12.0 tons	interpolated	29 5/32	68 29/32	64 31/32	730
PUHY-P144TLMU-A	12.0 tons	interpolated	29 5/32	68 29/32	64 31/32	671
PUHY-P144YLMU-A	12.0 tons	interpolated	29 5/32	68 29/32	64 31/32	706
PUHY-P144TKMU-A	12.0 tons	interpolated	29 5/32	68 29/32	64 31/32	697
PUHY-P144YKMU-A	12.0 tons	interpolated	29 5/32	68 29/32	64 31/32	726
PURY-P144TKMU-A	12.0 tons	interpolated	29 5/32	68 29/32	64 31/32	715
PURY-P144YKMU-A	12.0 tons	interpolated	29 5/32	68 29/32	64 31/32	743
PUHY-P168TLMU-A	14.0 tons	interpolated	29 5/32	68 29/32	64 31/32	673
PUHY-P168YLMU-A	14.0 tons	interpolated	29 5/32	68 29/32	64 31/32	702
PURY-P168TLMU-A	14.0 tons	interpolated	29 5/32	68 29/32	64 31/32	702
PURY-P168YLMU-A	14.0 tons	UUT-23 (Q1619.0)	29 5/32	68 29/32	64 31/32	730

1. PURY models have heat recovery capability (simultaneous heating and cooling)

2. PUHY models are standard heat pumps (heating-only or cooling-only)

3. Certification level is limited to the lower rating (SDS and z/h) of either the Certified Component Tables as listed, or the internal subcomponents as listed on the Certified Subcomponent Tables.



Special Seismic Certification
OSHPD Preapproval
Mitsubishi Product Line



Table 2. Certified Sub-Component List

PKFY and PKA Indoor Wall Mounted units ($S_{DS} = 2.00g$, $z/h = 1.00$, $F_p/W_p = 1.500$)

Certification level is limited to the lower rating (SDS and z/h) of either the Certified Component Tables as listed, or the internal subcomponents as listed on the Certified Subcomponent Tables.

Heat Exchanger				
<i>Description</i>	<i>Part Number</i>	<i>Manufacturer</i>	<i>Material</i>	<i>Interpolated / Included With Test</i>
Heat Exchanger	R05 Y05 480	Mitsubishi Electric	Copper & Aluminum	UUT-14
Heat Exchanger	T7W K37 480	Mitsubishi Electric	Copper & Aluminum	<i>interpolated</i>
Heat Exchanger	T7W K38 480	Mitsubishi Electric	Copper & Aluminum	<i>interpolated</i>
Heat Exchanger	T7W N11 480	Mitsubishi Electric	Copper & Aluminum	<i>interpolated</i>
Heat Exchanger	E17 520 620	Mitsubishi Electric	Copper & Aluminum	<i>interpolated</i>
Heat Exchanger	E17 518 620	Mitsubishi Electric	Copper & Aluminum	<i>interpolated</i>
Heat Exchanger	E17 519 620	Mitsubishi Electric	Copper & Aluminum	<i>interpolated</i>
Heat Exchanger	E17 522 620	Mitsubishi Electric	Copper & Aluminum	UUT-13

Fan Assembly (Fan motor + Line-Flow Fan)				
<i>Description</i>	<i>Part Number</i>	<i>Manufacturer</i>	<i>Material</i>	<i>Interpolated / Included With Test</i>
Fan Motor	T7W E41 762	Nidec Shibaura Corporation	Carbon Steel	UUT-14
Line-Flow Fan	R01 23A 114	Toray Industries	Styrene Acrylonitrile	UUT-14
Fan Motor	R01 E51 220	Nidec Shibaura Corporation	Carbon Steel	<i>interpolated</i>
Line-Flow Fan	R01 E42 114	Toray Industries	Styrene Acrylonitrile	<i>interpolated</i>
Fan Motor	E12 C92 300	Nidec Shibaura Corporation	Carbon Steel	UUT-13
Line-Flow Fan	E12 R79 302	Toray Industries	Styrene Acrylonitrile	UUT-13
Line-Flow Fan	E12 C92 302	Toray Industries	Styrene Acrylonitrile	UUT-13

Power PC Board				
<i>Description</i>	<i>Part Number</i>	<i>Manufacturer</i>	<i>Material</i>	<i>Interpolated / Included With Test</i>
Power Board	T7W E37 313	Shin-Asahi Electric	94V-0 Plastic	UUT-14

Control PC Board				
<i>Description</i>	<i>Part Number</i>	<i>Manufacturer</i>	<i>Material</i>	<i>Interpolated / Included With Test</i>
<i>Control Board</i>	E17 D91 447	Shin-Asahi Electric	94V-0 Plastic	UUT-13
Control Board	E17 H30 447	Shin-Asahi Electric	94V-0 Plastic	<i>interpolated</i>
Control Board	T7W C01 310	Shin-Asahi Electric	94V-0 Plastic	<i>interpolated</i>
Control Board	T7W E84 310	Shin-Asahi Electric	94V-0 Plastic	UUT-14
Control Board	T7W S03 310	Shin-Asahi Electric	94V-0 Plastic	<i>interpolated</i>

PMFY Indoor Ceiling Cassette 1-Way ($S_{DS} = 2.50g$, $z/h = 1.00$, $F_p/W_p = 1.875$)

Certification level is limited to the lower rating (SDS and z/h) of either the Certified Component Tables as listed, or the internal subcomponents as listed on the Certified Subcomponent Tables.

Heat Exchanger				
<i>Description</i>	<i>Part Number</i>	<i>Manufacturer</i>	<i>Material</i>	<i>Interpolated / Included With Test</i>
Heat Exchanger	T7W H08 480	Mitsubishi Electric	Copper & Aluminum	UUT-15
Heat Exchanger	T7W H09 480	Mitsubishi Electric	Copper & Aluminum	UUT-16

Fan Assembly				
<i>Description</i>	<i>Part Number</i>	<i>Manufacturer</i>	<i>Material</i>	<i>Interpolated / Included With Test</i>
Line Flow Fan	R01 E32 114	Toray Industries	Styrene Acrylonitrile	UUT-15, UUT-16
Fan Motor	R01 E49 220	Panasonic Corp.	Carbon Steel	UUT-15, UUT-16

Condensate Pump				
<i>Description</i>	<i>Part Number</i>	<i>Manufacturer</i>	<i>Material</i>	<i>Interpolated / Included With Test</i>
Condensate Pump	T7W E11 355	Saginomiya	ABS Plastic	UUT-15, UUT-16

Control Board				
<i>Description</i>	<i>Part Number</i>	<i>Manufacturer</i>	<i>Material</i>	<i>Interpolated / Included With Test</i>
Control Board	T7W C04 310	Shin-Asahi	94V-0 Plastic	UUT-15, UUT-16



Special Seismic Certification
OSHPD Preapproval
Mitsubishi Product Line



Table 2. Certified Sub-Component List

PLA and PLFY Indoor Ceiling Cassette 4-Way ($S_{DS} = 2.00g$, $z/h = 1.00$, $F_p/W_p = 1.500$)

Certification level is limited to the lower rating (SDS and z/h) of either the Certified Component Tables as listed, or the internal subcomponents as listed on the Certified Submcomponent Tables.

Heat Exchanger				
<i>Description</i>	<i>Part Number</i>	<i>extrapolated</i>	<i>Material</i>	<i>Interpolated / Included With Test</i>
Heat Exchanger	R01 N00 480	Mitsubishi Electric	Copper & Aluminum	UUT-7
Heat Exchanger	T7W L00 480	Mitsubishi Electric	Copper & Aluminum	<i>interpolated</i>
Heat Exchanger	T7W H86 480	Mitsubishi Electric	Copper & Aluminum	<i>interpolated</i>
Heat Exchanger	R01 N02 480	Mitsubishi Electric	Copper & Aluminum	<i>interpolated</i>
Heat Exchanger	T7W H61 480	Mitsubishi Electric	Copper & Aluminum	<i>interpolated</i>
Heat Exchanger	T7W L01 480	Mitsubishi Electric	Copper & Aluminum	<i>interpolated</i>
Heat Exchanger	R01 N03 480	Mitsubishi Electric	Copper & Aluminum	<i>interpolated</i>
Heat Exchanger	T7W H88 480	Mitsubishi Electric	Copper & Aluminum	<i>interpolated</i>
Heat Exchanger	R01 N05 480	Mitsubishi Electric	Copper & Aluminum	<i>interpolated</i>
Heat Exchanger	R01 AE3 480	Mitsubishi Electric	Copper & Aluminum	UUT-10
Heat Exchanger	T7W H96 480	Mitsubishi Electric	Copper & Aluminum	<i>interpolated</i>
Heat Exchanger	R01 L55 480	Mitsubishi Electric	Copper & Aluminum	UUT-26

Fan Motor				
<i>Description</i>	<i>Part Number</i>	<i>Manufacturer</i>	<i>Material</i>	<i>Interpolated / Included With Test</i>
Fan Motor	R01 E59 220	Panasonic Corporation	Carbon Steel	UUT-7
Fan Motor	R01 E66 220	Panasonic Corporation	Carbon Steel	UUT-10
Fan Motor	R01 E44 220	Panasonic Corporation	Carbon Steel	<i>interpolated</i>
Fan Motor	T7W L02 220	Nidec Techno	Carbon Steel	UUT-26

Turbo Fan				
<i>Description</i>	<i>Part Number</i>	<i>Manufacturer</i>	<i>Material</i>	<i>Interpolated / Included With Test</i>
Turbo Fan	R01 E39 114	Toray Industries Inc.	Styrene Acrylonitrile	UUT-7
Turbo Fan	R01 E34 114	Toray Industries Inc.	Styrene Acrylonitrile	UUT-10
Turbo Fan	R01 E46 114	Toray Industries Inc.	Styrene Acrylonitrile	UUT-26

Control Board				
<i>Description</i>	<i>Part Number</i>	<i>Manufacturer</i>	<i>Material</i>	<i>Interpolated / Included With Test</i>
Control Board	T7W C03 310	Shin-Asahi	94V-0 Plastic	UUT-7
Control Board	T7W C19 310	Shin-Asahi	94V-0 Plastic	UUT-10
Control Board	T7W M00 310	Seiryo-Technica	94V-0 Plastic	UUT-26

Condensate Pump				
<i>Description</i>	<i>Part Number</i>	<i>Manufacturer</i>	<i>Material</i>	<i>Interpolated / Included With Test</i>
Condensate Pump	T7W E14 355	Fujikoki Corporation	ABS Plastic	UUT-7/UUT-10
Condensate Pump	R01 E19 355	Fujikoki Corporation	ABS Plastic	UUT-26



Special Seismic Certification
OSHPD Preapproval
Mitsubishi Product Line



Table 2. Certified Sub-Component List

PEFY Indoor Ceiling Concealed (SDS = 2.00g, z/h = 1.00, Fp/Wp = 1.500)

Certification level is limited to the lower rating (SDS and z/h) of either the Certified Component Tables as listed, or the internal subcomponents as listed on the Certified Submcomponent Tables.

Heat Exchanger				
<i>Description</i>	<i>Part Number</i>	<i>Manufacturer</i>	<i>Material</i>	<i>Interpolated / Included With Test</i>
Heat Exchanger	E17 402 620	Mitsubishi Electric	Copper & Aluminum	UUT-6
Heat Exchanger	E17 403 620	Mitsubishi Electric	Copper & Aluminum	interpolated
Heat Exchanger	E17 405 620	Mitsubishi Electric	Copper & Aluminum	interpolated
Heat Exchanger	U41 003 480	Mitsubishi Electric	Copper & Aluminum	interpolated
Heat Exchanger	U41 004 480	Mitsubishi Electric	Copper & Aluminum	interpolated
Heat Exchanger	U41 005 480	Mitsubishi Electric	Copper & Aluminum	interpolated
Heat Exchanger	U41 006 480	Mitsubishi Electric	Copper & Aluminum	interpolated
Heat Exchanger	U41 007 480	Mitsubishi Electric	Copper & Aluminum	interpolated
Heat Exchanger	R61 618 480	Mitsubishi Electric	Copper & Aluminum	interpolated
Heat Exchanger	R61 Y38 483	Mitsubishi Electric	Copper & Aluminum	UUT-1
Heat Exchanger - MAIN	R61 326 480	Mitsubishi Electric	Copper & Aluminum	UUT-3
Heat Exchanger - RE-HEAT	R61 327 480	Mitsubishi Electric	Copper & Aluminum	UUT-3

Fan Motor				
<i>Description</i>	<i>Part Number</i>	<i>Manufacturer</i>	<i>Material</i>	<i>Interpolated / Included With Test</i>
Fan Motor	E17 319 300	Nidec Shibaura Co.	Carbon Steel	UUT-6
Fan Motor	U41 002 220	Nidec Shibaura Co.	Carbon Steel	interpolated
Fan Motor	U41 003 220	Nidec Shibaura Co.	Carbon Steel	interpolated
Fan Motor	U41 004 220	Nidec Shibaura Co.	Carbon Steel	interpolated
Fan Motor	R61 Y47 221	Nidec Shibaura Co.	Carbon Steel	UUT-1
Fan Motor	R61 205 220	SANSO Electric Co.	Carbon Steel	UUT-3
Line-Flow Fan	R61 022 114	Sirocco	Carbon Steel	UUT-3
Line-Flow Fan	R61 023 114	Sirocco	Carbon Steel	UUT-3

PC Board				
<i>Description</i>	<i>Part Number</i>	<i>Manufacturer</i>	<i>Material</i>	<i>Interpolated / Included With Test</i>
PC Board	E17 472 447	Shirai Electronic Co. Ltd.	94V-0 Plastic	UUT-6
PC Board	U41 003 280	Shirai Electronic Co. Ltd.	94V-0 Plastic	interpolated
PC Board	R61 182 280	Shirai Electronic Co. Ltd.	94V-0 Plastic	interpolated
PC Board	R61 181 280	Shirai Electronic Co. Ltd.	94V-0 Plastic	UUT-1
PC Board	R63 140 280	Shirai Electronic Co. Ltd.	94V-0 Plastic	interpolated
PC Board	U41 001 280	Shirai Electronic Co. Ltd.	94V-0 Plastic	interpolated
PC Board	U41 002 280	Shirai Electronic Co. Ltd.	94V-0 Plastic	interpolated
PC Board	R61 226 280	Shirai Electronic Co. Ltd.	94V-0 Plastic	UUT-3



Special Seismic Certification
OSHPD Preapproval
Mitsubishi Product Line



Table 2. Certified Sub-Component List

PVFX and PVA Multi-Position Fan Coil Unit ($S_{DS} = 2.50g$, $z/h = 1.00$, $F_p/W_p = 1.875$)

Certification level is limited to the lower rating (SDS and z/h) of either the Certified Component Tables as listed, or the internal subcomponents as listed on the Certified Subcomponent Tables.

Heat Exchanger				
<i>Description</i>	<i>Part Number</i>	<i>Manufacturer</i>	<i>Material</i>	<i>Interpolated / Included With Test</i>
Heat Exchanger	U41 011 480	Mitsubishi Electric	Copper & Aluminum	UUT-19
Heat Exchanger	U41 015 480	Mitsubishi Electric	Copper & Aluminum	interpolated
Heat Exchanger	U41 016 480	Mitsubishi Electric	Copper & Aluminum	interpolated
Heat Exchanger	U41 017 480	Mitsubishi Electric	Copper & Aluminum	interpolated
Heat Exchanger	U41 012 480	Mitsubishi Electric	Copper & Aluminum	interpolated
Heat Exchanger	U41 013 480	Mitsubishi Electric	Copper & Aluminum	interpolated
Heat Exchanger	U41 014 480	Mitsubishi Electric	Copper & Aluminum	UUT-20

Fan Motor				
<i>Description</i>	<i>Part Number</i>	<i>Manufacturer</i>	<i>Material</i>	<i>Interpolated / Included With Test</i>
Fan Motor	U41 003 128	Nidec Shibaura Co.	Carbon Steel	UUT-19
Fan Motor	U41 004 128	Nidec Shibaura Co.	Carbon Steel	interpolated
Fan Motor	U41 005 128	Nidec Shibaura Co.	Carbon Steel	UUT-20

Fan Case				
<i>Description</i>	<i>Part Number</i>	<i>Manufacturer</i>	<i>Material</i>	<i>Interpolated / Included With Test</i>
Fan Case	U41 008 129	Mitsubishi Electric	Carbon Steel	UUT-19
Fan Case	U41 005 129	Mitsubishi Electric	Carbon Steel	interpolated
Fan Case	U41 006 129	Mitsubishi Electric	Carbon Steel	interpolated
Fan Case	U41 007 129	Mitsubishi Electric	Carbon Steel	interpolated
Fan Case	U41 009 129	Mitsubishi Electric	Carbon Steel	interpolated
Fan Case	U41 010 129	Mitsubishi Electric	Carbon Steel	UUT-20

PCA Assy				
<i>Description</i>	<i>Part Number</i>	<i>Manufacturer</i>	<i>Material</i>	<i>Interpolated / Included With Test</i>
PCA Assy	U41 008 280	Shirai Electronics	94V-0 Plastic	interpolated
PCA Assy	U41 007 280	Shirai Electronics	94V-0 Plastic	UUT-19 and UUT-20

PCA Power				
<i>Description</i>	<i>Part Number</i>	<i>Manufacturer</i>	<i>Material</i>	<i>Interpolated / Included With Test</i>
PCA Power	U41 001 281	Shirai Electronics	94V-0 Plastic	UUT-19
PCA Power	U41 002 281	Shirai Electronics	94V-0 Plastic	interpolated
PCA Power	U41 003 281	Shirai Electronics	94V-0 Plastic	UUT-20



Special Seismic Certification
OSHPD Preapproval
Mitsubishi Product Line



Table 2. Certified Sub-Component List

BC Controllers ($S_{DS} = 2.00g$, $z/h = 1.00$, $F_p/W_p = 1.500$)

Certification level is limited to the lower rating (SDS and z/h) of either the Certified Component Tables as listed, or the internal subcomponents as listed on the Certified Submcomponent Tables.

Linear Expansion Valve				
<i>Description</i>	<i>Part Number</i>	<i>Manufacturer</i>	<i>Material</i>	<i>Interpolated / Included With Test</i>
Linear Expansion Valve	R61 008 401	Mitsubishi Electric	Brass	UUT-12
Linear Expansion Valve	R63 R23 401	Mitsubishi Electric	Brass	UUT-9

Solenoid Valve Coil				
<i>Description</i>	<i>Part Number</i>	<i>Manufacturer</i>	<i>Material</i>	<i>Interpolated / Included With Test</i>
Solenoid Valve Coil	R61 2A1 243	Fujikoki Corp.	Copper	UUT-9, UUT-12

Solenoid Valve				
<i>Description</i>	<i>Part Number</i>	<i>Manufacturer</i>	<i>Material</i>	<i>Interpolated / Included With Test</i>
Solenoid Valve	R63 4F3 232	Fujikoki Corp.	Brass	UUT-9, UUT-12
Solenoid Valve	R63 Y07 232	Fujikoki Corp.	Brass	UUT-9, UUT-12

Control Board				
<i>Description</i>	<i>Part Number</i>	<i>Manufacturer</i>	<i>Material</i>	<i>Interpolated / Included With Test</i>
Control Board	R63 044 280	Shikibo Electric	94V-0 Plastic	UUT-9, UUT-12

Relay Board Assy				
<i>Description</i>	<i>Part Number</i>	<i>Manufacturer</i>	<i>Material</i>	<i>Interpolated / Included With Test</i>
Relay Board Assy	R63 M82 280	Shikibo Electric	94V-0 Plastic	UUT-9, UUT-12



Special Seismic Certification
OSHPD Preapproval
 Mitsubishi Product Line



Table 2. Certified Sub-Component List

Outdoor Heat Pump - (P-Series)

Certification level is limited to the lower rating (SDS and z/h) of either the Certified Component Tables as listed, or the internal subcomponents as listed on the Certified Subcomponent Tables.

Heat Exchanger						
Description	Part Number	Manufacturer	Material	Interpolated / Included With Test	S _{DS} (g)	F _p / W _p
PUY & PUZ - Single Fan						
Heat Exchanger	R01 H33 408	Mitsubishi Electric	Copper & Aluminum	UUT-11	2.00	1.500
Heat Exchanger	T7W E57 408	Mitsubishi Electric	Copper & Aluminum	interpolated	2.00	1.500
Heat Exchanger	T7W E59 408	Mitsubishi Electric	Copper & Aluminum	interpolated	2.00	1.500
Heat Exchanger	T7W E60 408	Mitsubishi Electric	Copper & Aluminum	UUT-4	2.00	1.500
PUY & PUZ - Double Fan						
Heat Exchanger	R01 H01 408	Mitsubishi Electric	Copper & Aluminum	interpolated	2.00	1.500
Heat Exchanger	T7W E61 408	Mitsubishi Electric	Copper & Aluminum	interpolated	2.00	1.500
PUMY-P36 to P48 - Double Fan						
Heat Exchanger	T7W E41 408	Mitsubishi Electric	Copper & Aluminum	UUT-5	2.00	1.500
PUMY-P60 - Double Fan						
Heat Exchanger	R01 H37 408	Mitsubishi Electric	Copper & Aluminum	UUT-27	1.34	1.005
Compressor						
Description	Part Number	Manufacturer	Material	Interpolated / Included With Test	S _{DS} (g)	F _p / W _p
PUY & PUZ - Single Fan						
Compressor	T92 577 280	Siam Compressor	Carbon Steel	UUT-11	2.00	1.500
Compressor	T92 508 801	Siam Compressor	Carbon Steel	UUT-4	2.00	1.500
PUY & PUZ - Double Fan						
Compressor	T97 415 790	Siam Compressor	Carbon Steel	interpolated	2.00	1.500
Compressor	T92 415 767	Siam Compressor	Carbon Steel	interpolated	2.00	1.500
PUMY-P36 to P48 - Double Fan						
Compressor	T97 415 779	Siam Compressor	Carbon Steel	UUT-5	2.00	1.500
PUMY-P60 - Double Fan						
Compressor	T97 415 789	Siam Compressor	Carbon Steel	UUT-27	1.34	1.005
Fan Motor						
Description	Part Number	Manufacturer	Material	Interpolated / Included With Test	S _{DS} (g)	F _p / W _p
PUY & PUZ - Single Fan						
Fan Motor	R01 E52 221	Panasonic Corporation	Carbon Steel	UUT-11	2.00	1.500
Fan Motor	T7W E27 763	Panasonic Corporation	Carbon Steel	UUT-4	2.00	1.500
PUY & PUZ - Double Fan						
Fan Motor	T7W E27 763	Panasonic Corporation	Carbon Steel	interpolated	2.00	1.500
Fan Motor	R01 E57 221	Panasonic Corporation	Carbon Steel	interpolated	2.00	1.500
PUMY-P36 to P48 - Double Fan						
Fan Motor	R01 E57 221	Panasonic Corporation	Carbon Steel	UUT-5	2.00	1.500
PUMY-P60 - Double Fan						
Fan Motor	R01 E46 221	Panasonic Corporation	Carbon Steel	UUT-27	1.34	1.005
Printed Circuit Board						
Description	Part Number	Manufacturer	Material	Interpolated / Included With Test	S _{DS} (g)	F _p / W _p
PUY & PUZ - Single Fan						
Control Board	T7W F22 315	Shin-Asahi Electric	94V-0 Plastic	UUT-11	2.00	1.500
Control Board	T7W F00 315	Shin-Asahi Electric	94V-0 Plastic	UUT-4	2.00	1.500
PUY & PUZ - Double Fan						
Control Board	T7W F07 315	Shin-Asahi Electric	94V-0 Plastic	interpolated	2.00	1.500
Control Board	T7W F14 315	Shin-Asahi Electric	94V-0 Plastic	interpolated	2.00	1.500
PUMY-P36 to P48 - Double Fan						
Control Board	T7W F23 315	Shin-Asahi Electric	94V-0 Plastic	UUT-5	2.00	1.500
PUMY-P60 - Double Fan						
Control Board	T7W F23 315	Shin-Asahi Electric	94V-0 Plastic	UUT-27	1.34	1.005



Special Seismic Certification
OSHPD Preapproval
Mitsubishi Product Line



Table 2. Certified Sub-Component List cont

Outdoor Heat Pump - (P-Series) cont

Certification level is limited to the lower rating (SDS and z/h) of either the Certified Component Tables as listed, or the internal subcomponents as listed on the Certified Subcomponent Tables.

Inverter Board					SDS (g)	F _p / W _p
Description	Part Number	Manufacturer	Material	Interpolated / Included With Test	SDS (g)	F _p / W _p
PUY & PUZ - Single Fan						
Inverter Board	T7W E80 315	Shin-Asahi Electric	94V-0 Plastic	UUT-11	2.00	1.500
Inverter Board	T7W E39 313	Shin-Asahi Electric	94V-0 Plastic	UUT-4	2.00	1.500
PUY & PUZ and PUMY-P36 to P48 - Double Fan						
Inverter Board	R01 E72 313	Shin-Asahi Electric	94V-0 Plastic	UUT-5	2.00	1.500
PUMY-P60 - Double Fan						
Inverter Board	R01 E72 313	Shin-Asahi Electric	94V-0 Plastic	UUT-27	1.34	1.005
M-Net Board						
Description	Part Number	Manufacturer	Material	Interpolated / Included With Test	SDS (g)	F _p / W _p
PUMY-P36 to P48 - Double Fan						
M-Net Board	R04 311	Kyosha Co., Ltd	94V-0 Plastic	UUT-5	2.00	1.500
PUMY-P60 - Double Fan						
M-Net Board	R01 E04	Kyosha Co., Ltd	94V-0 Plastic	UUT-27	1.34	1.005
Reversing Valve						
Description	Part Number	Manufacturer	Material	Interpolated / Included With Test	SDS (g)	F _p / W _p
PUZ - Single Fan						
Reversing Valve	R01 E28 403	Saginomiya	Brass	UUT-4	2.00	1.500
PUY & PUZ and PUMY-P36 to P48 - Double Fan						
Reversing Valve	R01 E36 403	Fujikoki	Brass	UUT-5	2.00	1.500
PUMY-P60 - Double Fan						
Reversing Valve	R01 E36 403	Fujikoki	Brass	UUT-27	1.34	1.005
Accumulator						
Description	Part Number	Manufacturer	Material	Interpolated / Included With Test	SDS (g)	F _p / W _p
PUZ - Single Fan						
Accumulator	T7W E22 440	Mitsubishi Electric	Carbon Steel	UUT-11	2.00	1.500
Accumulator	R01 E57 440	Mitsubishi Electric	Carbon Steel	UUT-4	2.00	1.500
PUY & PUZ - Double Fan						
Accumulator	R01 E58 440	Mitsubishi Electric	Carbon Steel	interpolated	2.00	1.500
Accumulator	R01 E60 440	Mitsubishi Electric	Carbon Steel	interpolated	2.00	1.500
PUMY-P36 to P48 - Double Fan						
Accumulator	R01 E44 440	Mitsubishi Electric	Carbon Steel	UUT-5	2.00	1.500
PUMY-P60 - Double Fan						
Accumulator	R01 E67 440	Mitsubishi Electric	Carbon Steel	UUT-27	1.34	1.005



Special Seismic Certification
OSHDP Preapproval
Mitsubishi Product Line



Table 2. Certified Sub-Component List

PQRY (Outdoor Heat Recovery Heat Pump - water source) ($S_{DS} = 2.00g$, $z/h = 1.00$, $F_p/W_p = 1.500$)

PQHY (Outdoor Heat Pump - water source) ($S_{DS} = 2.00g$, $z/h = 1.00$, $F_p/W_p = 1.500$)

Certification level is limited to the lower rating (SDS and z/h) of either the Certified Component Tables as listed, or the internal subcomponents as listed on the Certified Subcomponent Tables.

Compressor				
<i>Description</i>	<i>Part Number</i>	<i>Manufacturer</i>	<i>Material</i>	<i>Interpolated / Included With Test</i>
Scroll Compressor	R69 130 478	Mitsubishi Electric	Carbon Steel	UUT-24
Scroll Compressor	R69 103 478	Mitsubishi Electric	Carbon Steel	interpolated
Scroll Compressor	R69 125 478	Mitsubishi Electric	Carbon Steel	interpolated
Scroll Compressor	R69 118 478	Mitsubishi Electric	Carbon Steel	interpolated
Scroll Compressor	R69 135 478	Mitsubishi Electric	Carbon Steel	interpolated
Scroll Compressor	R69 133 478	Mitsubishi Electric	Carbon Steel	UUT-25

Accumulator				
<i>Description</i>	<i>Part Number</i>	<i>Manufacturer</i>	<i>Material</i>	<i>Interpolated / Included With Test</i>
Accumulator assy.	R61 127 484	Meiwa Co. Ltd.	Carbon Steel	UUT-24
Accumulator assy.	R61 125 484	Meiwa Co. Ltd.	Carbon Steel	UUT-25

Heat Exchanger				
<i>Description</i>	<i>Part Number</i>	<i>Manufacturer</i>	<i>Material</i>	<i>Interpolated / Included With Test</i>
Heat Exchanger	R61 987 480	Alfa Laval Inc.	Copper & Aluminum	UUT-24
Heat Exchanger	R61 990 480	Alfa Laval Inc.	Copper & Aluminum	interpolated
Heat Exchanger	R61 A02 480	Alfa Laval Inc.	Copper & Aluminum	interpolated
Heat Exchanger	R61 991 480	Alfa Laval Inc.	Copper & Aluminum	UUT-25

INV Heat Exchanger				
<i>Description</i>	<i>Part Number</i>	<i>Manufacturer</i>	<i>Material</i>	<i>Interpolated / Included With Test</i>
INV Heat Exchanger	R61 928 480	Mitsubishi Electric	Copper & Aluminum	UUT-24 and UUT-25

Four Way Valve				
<i>Description</i>	<i>Part Number</i>	<i>Manufacturer</i>	<i>Material</i>	<i>Interpolated / Included With Test</i>
Four Way Valve	R61 013 403	Saginomiya	Brass	UUT-24 and UUT-25

Control Board				
<i>Description</i>	<i>Part Number</i>	<i>Manufacturer</i>	<i>Material</i>	<i>Interpolated / Included With Test</i>
Control Board	R61 358 280	Shin-Asahi Electric	94V-0 Plastic	UUT-24
Control Board	R61 371 280	Shin-Asahi Electric	94V-0 Plastic	interpolated
Control Board	R61 339 280	Shin-Asahi Electric	94V-0 Plastic	interpolated
Control Board	R61 340 280	Shin-Asahi Electric	94V-0 Plastic	UUT-25

INV Board				
<i>Description</i>	<i>Part Number</i>	<i>Manufacturer</i>	<i>Material</i>	<i>Interpolated / Included With Test</i>
INV Board	R61 353 280	Shin-Asahi Electric	94V-0 Plastic	UUT-24
INV Board	R61 355 280	Shin-Asahi Electric	94V-0 Plastic	interpolated
INV Board	R61 188 280	Shin-Asahi Electric	94V-0 Plastic	interpolated
INV Board	R61 341 280	Shin-Asahi Electric	94V-0 Plastic	interpolated
INV Board	R61 385 280	Shin-Asahi Electric	94V-0 Plastic	interpolated
INV Board	R61 372 280	Shin-Asahi Electric	94V-0 Plastic	UUT-25



Special Seismic Certification
OSHPD Preapproval
Mitsubishi Product Line



Table 2. Certified Sub-Component List

PUHY (Outdoor Heat Pump - air source) and PURY (Outdoor Heat Recovery Heat Pump - air source) ($S_{DS} = 2.50g$, $z/h = 1.00$, $F_p/W_p = 1.875$)

Certification level is limited to the lower rating (SDS and z/h) of either the Certified Component Tables as listed, or the internal subcomponents as listed on the Certified Subcomponent Tables.

Compressor				
<i>Description</i>	<i>Part Number</i>	<i>Manufacturer</i>	<i>Material</i>	<i>Interpolated / Included With Test</i>
Scroll Compressor	R69 126 478	Mitsubishi Electric	Carbon Steel	UUT-22
Scroll Compressor	R69 130 478	Mitsubishi Electric	Carbon Steel	interpolated
Scroll Compressor	R69 127 478	Mitsubishi Electric	Carbon Steel	interpolated
Scroll Compressor	R69 103 478	Mitsubishi Electric	Carbon Steel	interpolated
Scroll Compressor	R69 128 478	Mitsubishi Electric	Carbon Steel	interpolated
Scroll Compressor	R69 129 478	Mitsubishi Electric	Carbon Steel	interpolated
Scroll Compressor	R69 125 478	Mitsubishi Electric	Carbon Steel	interpolated
Scroll Compressor	R69 118 478	Mitsubishi Electric	Carbon Steel	UUT-23

Heat Exchanger				
<i>Description</i>	<i>Part Number</i>	<i>Manufacturer</i>	<i>Material</i>	<i>Interpolated / Included With Test</i>
Heat Exchanger assy.	R61 929 480	Mitsubishi Electric	Copper & Aluminum	UUT-22
Heat Exchanger assy.	R61 930 480	Mitsubishi Electric	Copper & Aluminum	interpolated
Heat Exchanger assy.	R61 931 480	Mitsubishi Electric	Copper & Aluminum	interpolated
Heat Exchanger assy.	R61 933 480	Mitsubishi Electric	Copper & Aluminum	interpolated
Heat Exchanger assy.	R61 935 480	Mitsubishi Electric	Copper & Aluminum	interpolated
Heat Exchanger assy.	R61 936 480	Mitsubishi Electric	Copper & Aluminum	interpolated
Heat Exchanger assy.	R61 937 480	Mitsubishi Electric	Copper & Aluminum	UUT-23
Heat Exchanger assy.	R61 939 480	Mitsubishi Electric	Copper & Aluminum	UUT-23

Fan Motor				
<i>Description</i>	<i>Part Number</i>	<i>Manufacturer</i>	<i>Material</i>	<i>Interpolated / Included With Test</i>
Fan Motor	R61 267 220	Nidec TECNO Motor	Carbon steel	UUT-22
Fan Motor	R61 268 220	Nidec TECNO Motor	Carbon steel	UUT-23

Accumulator				
<i>Description</i>	<i>Part Number</i>	<i>Manufacturer</i>	<i>Material</i>	<i>Interpolated / Included With Test</i>
Accumulator	R61 041 484	Meiwa Co. Ltd.	Carbon Steel	UUT-22
Accumulator	R61 091 484	Meiwa Co. Ltd.	Carbon Steel	interpolated
Accumulator	R61 037 484	Meiwa Co. Ltd.	Carbon Steel	interpolated
Accumulator	R61 089 484	Meiwa Co. Ltd.	Carbon Steel	UUT-23

Reversing Valve				
<i>Description</i>	<i>Part Number</i>	<i>Manufacturer</i>	<i>Material</i>	<i>Interpolated / Included With Test</i>
Reversing Valve	R61 013 403	Saginomiya	Brass	UUT-22 and UUT-23

Control Board				
<i>Description</i>	<i>Part Number</i>	<i>Manufacturer</i>	<i>Material</i>	<i>Interpolated / Included With Test</i>
PC Board Matl.	R61 342 280	Shin-Asahi Electric	94V-0 Plastic	UUT-22
PC Board Matl.	R61 347 280	Shin-Asahi Electric	94V-0 Plastic	interpolated
PC Board Matl.	R61 352 280	Shin-Asahi Electric	94V-0 Plastic	interpolated
PC Board Matl.	R61 354 280	Shin-Asahi Electric	94V-0 Plastic	UUT-23

UUT-1 Test Summary

Testing Lab: QualTech NP
 Testing Report: Q0028.00
 Testing Unit Num: Q0028-01-01-01

Model Number	Tonnage	Operating Weight (lbs)	Mounting	Excitation Direction	Frequency* (Hz)	Length (in)	Width (in)	Height (in)	
PEFY-P96-NMHU-E	8.0	221	Ceiling Mounted	X	Front - Back	N/A	44 1/8	49 1/4	18 9/16
				Y	Side - Side	N/A			
				Z	Vertical	N/A			

* Frequencies are for units prior to ICC ES AC-156 testing.
 Model Number is based on nomenclature from the 2014 Catalog

Attachment Method	Suspended with 3/8"Ø hanger rods and (2) 1/8"Ø cable braces per corner (8 total).	Seismic Parameters							
		Building Code	Test Criteria	S _{DS} (g)	z/h	Horizontal (g)		Vertical (g)	
						A _{FLX-H}	A _{RIG-H}	A _{FLX-V}	A _{RIG-V}
		CBC 2016	AC 156	2.00	1.0	3.20	2.40	1.33	0.53



Notes: The UUTs were full of contents during the test.
 Unit maintained structural integrity and remained functional per manufacture requirements after shake table test

UUT-1 Summary Tested Sub-Component

Sub-Component	Part Number	Manufacturer	Material
Heat Exchanger	R61 Y38 483	Mitsubishi Electric	Copper & Aluminum
Fan Motor	R61 Y47 221	Nidec Shibaura Co.	Carbon Steel
PCA Power	R61 181 280	Shirai Electronic Co. Ltd.	94V-0 Plastic

UUT-3 Test Summary

Testing Lab:	QualTech NP
Testing Report:	Q0028.00
Testing Unit Num:	Q0028-03-01-01

Model Number	Tonnage	Operating Weight (lbs)	Mounting	Excitation Direction	Frequency* (Hz)	Length (in)	Width (in)	Height (in)	
PEFY-AF1200CFMR	9.3	309	Ceiling Mounted	X	Front - Back	N/A	55 1/8	49 1/4	18 9/16
				Y	Side - Side	N/A			
				Z	Vertical	N/A			

* Frequencies are for units prior to ICC ES AC-156 testing.
 Model Number is based on nomenclature from the 2014 Catalog

Attachment Method	Suspended with 1/2"Ø hanger rods and (2) 1/8"Ø cable braces per corner (8 total).	Seismic Parameters							
		Building Code	Test Criteria	S _{Ds} (g)	z/h	Horizontal (g)		Vertical (g)	
						A _{FLX-H}	A _{RIG-H}	A _{FLX-V}	A _{RIG-V}
		CBC 2016	AC 156	2.00	1.0	3.20	2.40	1.33	0.53



Notes: The UUTs were full of contents during the test.
 Unit maintained structural integrity and remained functional per manufacture requirements after shake table tes

UUT-3 Summary Tested Sub-Component

Sub-Component	Part Number	Manufacturer	Material
Heat Exchanger	R61 326 480	Mitsubishi Electric	Copper & Aluminum
Heat Exchanger Re-heat	R61 327 480	Mitsubishi Electric	Copper & Aluminum
Fan Motor	R61 205 220	SANSO Electric Co.	Carbon Steel
Line-Flow Fan	R61 022 114	Sirocco	Carbon Steel
Line-Flow Fan	R61 023 114	Sirocco	Carbon Steel
PCA Board	R61 226 280	Shirai Electronic Co. Ltd.	94V-0 Plastic

UUT-4 Test Summary

Testing Lab: QualTech NP
 Testing Report: Q0028.00
 Testing Unit Num: Q0028-04-01-01

Model Number	Tonnage	Operating Weight (lbs)	Mounting	Excitation Direction	Frequency* (Hz)	Length (in)	Width (in)	Height (in)	
PUZ-A36NHA3	3.0	165	Base Mounted	X	Front - Back	6.7	13	37 3/8	37 1/8
				Y	Side - Side	>33.3			
				Z	Vertical	>33.3			

* Frequencies are for unit interpolated
 Model Number is based on nomenclature from the 2014 Catalog

Attachment Method	Rigid base mounted with (4) 3/8"Ø SAE grade 5 bolts.	Seismic Parameters							
		Building Code	Test Criteria	S _{Ds} (g)	z/h	Horizontal (g)		Vertical (g)	
						A _{FLX-H}	A _{RIG-H}	A _{FLX-V}	A _{RIG-V}
		CBC 2016	AC 156	2.00	1.0	3.20	2.40	1.33	0.53



Notes: The UUTs were full of contents during the test.
 Unit maintained structural integrity and remained functional per manufacture requirements after shake table tes

UUT-4 Summary Tested Sub-Component

Sub-Component	Part Number	Manufacturer	Material
Heat Exchanger	T7W E60 408	Mitsubishi Electric	Copper & Aluminum
Compressor	T92 508 801	Siam Compressor	Carbon Steel
Fan Motor	T7W E27 763	Panasonic Corp.	Carbon Steel
Control Board	T7W F00 315	Shin-Asahi Electric	94V-0 Plastic
Inverter Board	T7W E39 313	Shin-Asahi Electric	94V-0 Plastic
Reversing Valve	R01 E28 403	Saginomiya	Brass
Accumulator	R01 E57 440	Mitsubishi Electric	Carbon Steel

UUT-5 Test Summary

Testing Lab:	QualTech NP
Testing Report:	Q0028.00
Testing Unit Num:	Q0028-05-01-01

Model Number	Tonnage	Operating Weight (lbs)	Mounting	Excitation Direction	Frequency* (Hz)	Length (in)	Width (in)	Height (in)	
PUMY-P48NHMU	4.0	287	Base Mounted	X	Front - Back	3.7	13	37 7/16	53 3/16
				Y	Side - Side	6.2			
				Z	Vertical	>33.3			

* Frequencies are for units prior to ICC ES AC-156 testing.
Model Number is based on nomenclature from the 2014 Catalog

Attachment Method	Rigid base mounted with (4) 3/8"Ø SAE grade 5 bolts.	Seismic Parameters							
		Building Code	Test Criteria	S _{Ds} (g)	z/h	Horizontal (g)		Vertical (g)	
						A _{FLX-H}	A _{RIG-H}	A _{FLX-V}	A _{RIG-V}
		CBC 2016	AC 156	2.00	1.0	3.20	2.40	1.33	0.53



Notes: The UUTs were full of contents during the test.
Unit maintained structural integrity and remained functional per manufacture requirements after shake table tes

UUT-5 Summary Tested Sub-Component

Sub-Component	Part Number	Manufacturer	Material
Heat Exchanger	T7W E41 408	Mitsubishi Electric	Copper & Aluminum
Compressor	T97 415 779	Siam Compressor	Carbon Steel
Fan Motor (2)	R01 E57 221	Panasonic Corp.	Carbon Steel
Control Board	T7W F23 315	Shin-Asahi Electric	94V-0 Plastic
Inverter Board	R01 E72 313	Shin-Asahi Electric	94V-0 Plastic
M-Net Board	R04 311	Kyosha Co.	94V-0 Plastic
Reversing Valve	R01 E36 403	Fujioka Corp	Brass
Accumulator	R01 E44 440	Mitsubishi Electric	Carbon Steel

UUT-6 Test Summary

Testing Lab: QualTech NP
 Testing Report: Q0028.00
 Testing Unit Num: Q0028-06-01-01

Model Number	Tonnage	Operating Weight (lbs)	Mounting	Excitation Direction	Frequency* (Hz)	Length (in)	Width (in)	Height (in)	
PEFY-P06NMSU-E	0.5	42	Ceiling Mounted	X	Front - Back	N/A	27 9/16	31 1/8	7 7/8
				Y	Side - Side	N/A			
				Z	Vertical	N/A			

* Frequencies are for units prior to ICC ES AC-156 testing.
 Model Number is based on nomenclature from the 2014 Catalog

Attachment Method	Suspended with 1/2"Ø hanger rods and (2) 1/8"Ø cable braces per corner (8 total).	Seismic Parameters							
		Building Code	Test Criteria	S _{Ds} (g)	z/h	Horizontal (g)		Vertical (g)	
						A _{FLX-H}	A _{RIG-H}	A _{FLX-V}	A _{RIG-V}
		CBC 2016	AC 156	2.00	1.0	3.20	2.40	1.33	0.53



Notes: The UUTs were full of contents during the test.
 Unit maintained structural integrity and remained functional per manufacture requirements after shake table tes

UUT-6 Summary Tested Sub-Component

Sub-Component	Part Number	Manufacturer	Material
Heat Exchanger	E17 402 620	Mitsubishi Electric	Copper & Aluminum
Fan Motor	E17 319 300	Nidec Shibaura Co.	Carbon Steel
PCA Control	E17 472 447	Shirai Electronic Co. Ltd.	94V-0 Plastic

UUT-7 Test Summary

Testing Lab: QualTech NP
 Testing Report: Q0028.00
 Testing Unit Num: Q0028-07-01-01

Model Number	Tonnage	Operating Weight (lbs)	Mounting	Excitation Direction	Frequency* (Hz)	Length (in)	Width (in)	Height (in)	
PLFY-P12NBMU-E	1.0	49	Ceiling Mounted	X	Front - Back	N/A	33 3/32	33 3/32	10 3/16
				Y	Side - Side	N/A			
				Z	Vertical	N/A			

* Frequencies are for units prior to ICC ES AC-156 testing.
 Model Number is based on nomenclature from the 2014 Catalog

Attachment Method	Suspended with 3/8"Ø hanger rods and (2) 1/8"Ø cable braces per corner (8 total).	Seismic Parameters							
		Building Code	Test Criteria	S _{Ds} (g)	z/h	Horizontal (g)		Vertical (g)	
						A _{FLX-H}	A _{RIG-H}	A _{FLX-V}	A _{RIG-V}
		CBC 2016	AC 156	2.00	1.0	3.20	2.40	1.33	0.53



Notes: The UUTs were full of contents during the test.
 Unit maintained structural integrity and remained functional per manufacture requirements after shake table tes

UUT-7 Summary Tested Sub-Component

Sub-Component	Part Number	Manufacturer	Material
Heat Exchanger	R01 N00 480	Mitsubishi Electric	Copper & Aluminum
Fan Motor	R01 E59 220	Panasonic Corporation	Carbon Steel
Turbo Fan	R01 E39 114	Toray Industries Inc.	Styrene Acrylonitrile
Control Board	T7W C03 310	Shin-Asahi	94V-0 Plastic
Condensate Pump	T7W E14 355	Fujikoki Corporation	ABS Plastic

UUT-9 Test Summary

Testing Lab: QualTech NP
 Testing Report: Q0028.00
 Testing Unit Num: Q0028-09-01-01

Model Number	Tonnage	Operating Weight (lbs)	Mounting	Excitation Direction	Frequency* (Hz)	Length (in)	Width (in)	Height (in)	
CMB-P105NU-G	15.8	72	Ceiling Mounted	X	Front - Back	N/A	17 1/32	25 17/32	11 3/16
				Y	Side - Side	N/A			
				Z	Vertical	N/A			

* Frequencies are for units prior to ICC ES AC-156 testing.
 Model Number is based on nomenclature from the 2014 Catalog

Attachment Method	Suspended with 1/2"Ø hanger rods and (2) 1/8"Ø cable braces per corner (8 total).	Seismic Parameters							
		Building Code	Test Criteria	S _{Ds} (g)	z/h	Horizontal (g)		Vertical (g)	
						A _{FLX-H}	A _{RIG-H}	A _{FLX-V}	A _{RIG-V}
		CBC 2016	AC 156	2.00	1.0	3.20	2.40	1.33	0.53



Notes: The UUTs were full of contents during the test.
 Unit maintained structural integrity and remained functional per manufacture requirements after shake table tes

UUT-9 Summary Tested Sub-Component

Sub-Component	Part Number	Manufacturer	Material
Linear Expansion Valve	R63 R23 401	Mitsubishi Electric	Brass
Solenoid Valve Coil	R61 2A1 243	Fujikoki Corp	Copper
Solenoid Valve	R63 4F3 232	Fujikoki Corp	Brass
Solenoid Valve	R63 Y07 232	Fujikoki Corp	Brass
Control Board	R63 044 280	Shikibo Electric	94V-0 Plastic
Relay Board Assy	R63 M82 280	Shikibo Electric	94V-0 Plastic

UUT-10 Test Summary

Testing Lab: QualTech NP
 Testing Report: Q0028.00
 Testing Unit Num: Q0028-10-01-01

Model Number	Tonnage	Operating Weight (lbs)	Mounting	Excitation Direction	Frequency* (Hz)	Length (in)	Width (in)	Height (in)	
PLA-A42BA	3.5	55	Ceiling Mounted	X	Front - Back	N/A	33 1/16	33 1/16	11 3/4
				Y	Side - Side	N/A			
				Z	Vertical	N/A			

* Frequencies are for units prior to ICC ES AC-156 testing.
 Model Number is based on nomenclature from the 2014 Catalog

Attachment Method	Suspended with 3/8"Ø hanger rods and (2) 1/8"Ø cable braces per corner (8 total).	Seismic Parameters							
		Building Code	Test Criteria	S _{Ds} (g)	z/h	Horizontal (g)		Vertical (g)	
						A _{FLX-H}	A _{RIG-H}	A _{FLX-V}	A _{RIG-V}
		CBC 2016	AC 156	2.00	1.0	3.20	2.40	1.33	0.53



Notes: The UUTs were full of contents during the test.
 Unit maintained structural integrity and remained functional per manufacture requirements after shake table tes

UUT-10 Summary Tested Sub-Component

Sub-Component	Part Number	Manufacturer	Material
Heat Exchanger	R01 AE3 480	Mitsubishi Electric	Copper & Aluminum
Fan Motor	R01 E66 220	Panasonic Corporation	Carbon Steel
Turbo Fan	R01 E34 114	Toray Industries Inc.	Styrene Acrylonitrile
Control Board	T7W C19 310	Shin-Asahi	94V-0 Plastic
Condensate Pump	T7W E14 355	Fujikoki Corporation	ABS Plastic

UUT-11 Test Summary

Testing Lab: QualTech NP
 Testing Report: Q0028.00
 Testing Unit Num: Q0028-11-01-01

Model Number	Tonnage	Operating Weight (lbs)	Mounting	Excitation Direction	Frequency* (Hz)	Length (in)	Width (in)	Height (in)	
PUY-A12NHA3	1.0	90	Base Mounted	X	Front - Back	16.5	11 13/16	31 1/2	23 5/8
				Y	Side - Side	18.6			
				Z	Vertical	>33.3			

* Frequencies are for units prior to ICC ES AC-156 testing.
 Model Number is based on nomenclature from the 2014 Catalog

Attachment Method	Rigid base mounted with (4) 3/8"Ø SAE grade 5 bolts.	Seismic Parameters							
		Building Code	Test Criteria	S _{DS} (g)	z/h	Horizontal (g)		Vertical (g)	
						A _{FLX-H}	A _{RIG-H}	A _{FLX-V}	A _{RIG-V}
		CBC 2016	AC 156	2.00	1.0	3.20	2.40	1.33	0.53



Notes: The UUTs were full of contents during the test.
 Unit maintained structural integrity and remained functional per manufacture requirements after shake table tes

UUT-11 Summary Tested Sub-Component

Sub-Component	Part Number	Manufacturer	Material
Heat Exchanger	R01 H33 408	Mitsubishi Electric	Copper & Aluminum
Compressor	T92 577 280	Siam Compressor	Carbon Steel
Fan Motor	R01 E52 221	Panasonic Corp.	Carbon Steel
Control Board	T7W F22 315	Shin-Asahi Electric	94V-0 Plastic
Inverter board	T7W E80 315	Shin-Asahi Electric	94V-0 Plastic
Accumulator	T7W E22 440	Mitsubishi Electric	Carbon Steel

UUT-12 Test Summary

Testing Lab: QualTech NP
Testing Report: Q0028.00
Testing Unit Num: Q0028-12-01-01

Model Number	Tonnage	Operating Weight (lbs)	Mounting	Excitation Direction		Frequency* (Hz)	Length (in)	Width (in)	Height (in)
CMB-P1016NU-HA	36.0	162	Ceiling Mounted	X	Front - Back	N/A	20 1/2	43 3/4	11 7/16
				Y	Side - Side	N/A			
				Z	Vertical	N/A			

* Frequencies are for units prior to ICC ES AC-156 testing.
Model Number is based on nomenclature from the 2014 Catalog

Attachment Method	Suspended with 1/2"Ø hanger rods and (2) 1/8"Ø cable braces per corner (8 total).	Seismic Parameters							
		Building Code	Test Criteria	S _{Ds} (g)	z/h	Horizontal (g)		Vertical (g)	
						A _{FLX-H}	A _{RIG-H}	A _{FLX-V}	A _{RIG-V}
		CBC 2016	AC 156	2.00	1.0	3.20	2.40	1.33	0.53



Notes: The UUTs were full of contents during the test.
Unit maintained structural integrity and remained functional per manufacture requirements after shake table tes

UUT-12 Summary Tested Sub-Component

Sub-Component	Part Number	Manufacturer	Material
Linear Expansion Valve	R61 008 401	Mitsubishi Electric	Brass
Solenoid Valve Coil	R61 2A1 243	Fujikoki Corp.	Copper
Solenoid Valve	R63 4F3 232	Fujikoki Corp.	Brass
Solenoid Valve	R63 Y07 232	Fujikoki Corp.	Brass
Control Board	R63 044 280	Shikibo Electric	94V-0 Plastic
Relay Board Assy	R63 M82 280	Shikibo Electric	94V-0 Plastic

UUT-13 Test Summary

Testing Lab: QualTech NP
 Testing Report: Q0028.00
 Testing Unit Num: Q0028-13-01-01

Model Number	Tonnage	Operating Weight (lbs)	Mounting	Excitation Direction	Frequency* (Hz)	Length (in)	Width (in)	Height (in)	
PKA-A36KA	3.0	46	Wall Mounted	X	Front - Back	N/A	11 5/8	46 1/16	14 3/8
				Y	Side - Side	N/A			
				Z	Vertical	N/A			

* Frequencies are for units prior to ICC ES AC-156 testing.
 Model Number is based on nomenclature from the 2014 Catalog

Attachment Method	(5) #10 bolts secure units backing to wall. Unit clips into mfr provided backing plate.	Seismic Parameters							
		Building Code	Test Criteria	S _{Ds} (g)	z/h	Horizontal (g)		Vertical (g)	
						A _{FLX-H}	A _{RIG-H}	A _{FLX-V}	A _{RIG-V}
		CBC 2016	AC 156	2.00	1.0	3.20	2.40	1.33	0.53



Notes: The UUTs were full of contents during the test.
 Unit maintained structural integrity and remained functional per manufacture requirements after shake table tes

UUT-13 Summary Tested Sub-Component

Sub-Component	Part Number	Manufacturer	Material
Heat Exchanger	E17 522 620	Mitsubishi Electric	Copper & Aluminum
Fan Motor	E12 C92 300	Nidec Shibaura Co	Carbon Steel
Line-Flow Fan	E12 R79 302	Toray Industries	Styrene Acrylonitrile
Line-Flow Fan	E12 C92 302	Toray Industries	Styrene Acrylonitrile
Control PC Board	E17 D91 447	Shin-Asahi Electric	94V-0 Plastic


UUT-14 Test Summary

Testing Lab: QualTech NP
 Testing Report: Q0028.00
 Testing Unit Num: Q0028-14-01-01

Model Number	Tonnage	Operating Weight (lbs)	Mounting	Excitation Direction	Frequency* (Hz)	Length (in)	Width (in)	Height (in)	
PKFY-P06NBMU-E	0.5	22	Wall Mounted	X	Front - Back	N/A	8 7/8	32 1/8	11 5/8
				Y	Side - Side	N/A			
				Z	Vertical	N/A			

* Frequencies are for units prior to ICC ES AC-156 testing.
 Model Number is based on nomenclature from the 2014 Catalog

Attachment Method	(5) #10 bolts secure units backing to wall. Unit clips into mfr provided backing plate.	Seismic Parameters							
		Building Code	Test Criteria	S _{Ds} (g)	z/h	Horizontal (g)		Vertical (g)	
						A _{FLX-H}	A _{RIG-H}	A _{FLX-V}	A _{RIG-V}
		CBC 2016	AC 156	2.00	1.0	3.20	2.40	1.33	0.53



Notes: The UUTs were full of contents during the test.
 Unit maintained structural integrity and remained functional per manufacture requirements after shake table tes

UUT-14 Summary Tested Sub-Component

Sub-Component	Part Number	Manufacturer	Material
Heat Exchanger	R05 Y05 480	Mitsubishi Electric	Copper & Aluminum
Fan Motor	T7W E41 762	Nidec Shibaura Co	Carbon Steel
Line-Flow Fan	R01 23A 114	Toray Industries	Styrene Acrylonitrile
Power PC Board	T7W E37 313	Shin-Asahi Electric	94V-0 Plastic
Control PC Board	T7W E84 310	Shin-Asahi Electric	94V-0 Plastic


UUT-15 Test Summary

Testing Lab: QualTech NP
 Testing Report: Q1619.00
 Testing Unit Num: Q1619-01-01-01

Model Number	Tonnage	Operating Weight (lbs)	Mounting	Excitation Direction	Frequency* (Hz)	Length (in)	Width (in)	Height (in)	
PMFY-P06NBMU-E	0.5	41	Ceiling Mounted	X	Front - Back	N/A	31 31/32	15 9/16	9 1/16
				Y	Side - Side	N/A			
				Z	Vertical	N/A			

* Frequencies are for units prior to ICC ES AC-156 testing.
 Model Number is based on nomenclature from the 2014 Catalog

Attachment Method	Suspended with (4) - 3/8"Ø rods with stiffeners. Each corner has (2) 1/8"Ø cable braces (8 total).	Seismic Parameters							
		Building Code	Test Criteria	S _{Ds} (g)	z/h	Horizontal (g)		Vertical (g)	
						A _{FLX-H}	A _{RIG-H}	A _{FLX-V}	A _{RIG-V}
		CBC 2016	AC 156	2.50	1.0	4.00	3.00	1.67	0.67



Notes: The UUTs were full of contents during the test.
 Unit maintained structural integrity and remained functional per manufacture requirements after shake table test

UUT-15 Summary Tested Sub-Component

Sub-Component	Part Number	Manufacturer	Material
Heat Exchanger	T7W H08 480	Mitsubishi Electric	Copper & Aluminum
Line Flow Fan	R01 E32 114	Toray Industries	Styrene Acrylonitrile
Fan Motor	R01 E49 220	Panasonic Corporation	Carbon Steel
Condensate Pump	T7W E11 355	Saginomiya	ABS Plastic
Control Board	T7W C04 310	Shin-Asahi	94V-0 Plastic
Intake Grille	T7W E06 691	UMG ABS Ltd.	ABS, HB plastic

UUT-16 Test Summary

Testing Lab: QualTech NP
 Testing Report: Q1619.00
 Testing Unit Num: Q1619-02-01-01

Model Number	Tonnage	Operating Weight (lbs)	Mounting	Excitation Direction		Frequency* (Hz)	Length (in)	Width (in)	Height (in)
PMFY-P15NBMU-E	1.3	41	Ceiling Mounted	X	Front - Back	N/A	31 31/32	15 9/16	9 1/16
				Y	Side - Side	N/A			
				Z	Vertical	N/A			

* Frequencies are for units prior to ICC ES AC-156 testing.
 Model Number is based on nomenclature from the 2014 Catalog

Attachment Method	Suspended with (4) - 3/8"Ø rods with stiffeners. Each corner has (2) 1/8"Ø cable braces (8 total).	Seismic Parameters							
		Building Code	Test Criteria	S _{DS} (g)	z/h	Horizontal (g)		Vertical (g)	
						A _{FLX-H}	A _{RIG-H}	A _{FLX-V}	A _{RIG-V}
		CBC 2016	AC 156	2.50	1.0	4.00	3.00	1.67	0.67



Notes: The UUTs were full of contents during the test.
 Unit maintained structural integrity and remained functional per manufacture requirements after shake table test

UUT-16 Summary Tested Sub-Component

Sub-Component	Part Number	Manufacturer	Material
Heat Exchanger	T7W H09 480	Mitsubishi Electric	Copper & Aluminum
Line Flow Fan	R01 E32 114	Toray Industries	Styrene Acrylonitrile
Fan Motor	R01 E49 220	Panasonic Corporation	Carbon Steel
Condensate Pump	T7W E11 355	Saginomiya	94V-0 Plastic
Control Board	T7W C04 310	Shin-Asahi	94V-0 Hard Plastic
Intake Grille	T7W E06 691	UMG ABS Ltd.	ABS, HB plastic

UUT-19 Test Summary

Testing Lab: QualTech NP
 Testing Report: Q1619.00
 Testing Unit Num: Q1619-05-01-01

Model Number	Tonnage	Operating Weight (lbs)	Mounting	Excitation Direction	Frequency* (Hz)	Length (in)	Width (in)	Height (in)	
PVFY-P12NAMU-E	1.0	117	Ceiling Mounted	X	Front - Back	N/A	21 5/8	17	50 1/4
				Y	Side - Side	N/A			
				Z	Vertical	N/A			

* Frequencies are for units prior to ICC ES AC-156 testing.
 Model Number is based on nomenclature from the 2014 Catalog

Attachment Method	(1) P1000 Unistrut platform with P1356 fitting which is hung from (4) 3/8"Ø rods stiffeners. (2) 1/8"Ø cable braces each corner (8 total).	Seismic Parameters							
		Building Code	Test Criteria	S _{Ds} (g)	z/h	Horizontal (g)		Vertical (g)	
						A _{FLX-H}	A _{RIG-H}	A _{FLX-V}	A _{RIG-V}
		CBC 2016	AC 156	2.50	1.0	4.00	3.00	1.67	0.67



Notes: The UUTs were full of contents during the test.
 Unit maintained structural integrity and remained functional per manufacture requirements after shake table test

UUT-19 Summary Tested Sub-Component

Sub-Component	Part Number	Manufacturer	Material
Heat Exchanger	U41 011 480	Mitsubishi Electric	Copper & Aluminum
Fan Motor	U41 003 128	Nidec Shibaura Co.	Carbon Steel
Fan Case	U41 008 129	Mitsubishi Electric	Carbon Steel
PCA Assy	U41 007 280	Shirai Electronics	94V-0 Plastic
PCA Power	U41 001 281	Shirai Electronics	94V-0 Plastic

UUT-20 Test Summary

Testing Lab: QualTech NP
 Testing Report: Q1619.00
 Testing Unit Num: Q1619-06-01-01

Model Number	Tonnage	Operating Weight (lbs)	Mounting	Excitation Direction	Frequency* (Hz)	Length (in)	Width (in)	Height (in)	
PVFY-P54NAMU-E	4.5	227	Ceiling Mounted	X	Front - Back	N/A	21 5/8	25	59 1/2
				Y	Side - Side	N/A			
				Z	Vertical	N/A			

* Frequencies are for units prior to ICC ES AC-156 testing.
 Model Number is based on nomenclature from the 2014 Catalog

Attachment Method	(1) P1000 Unistrut platform with P1356 fitting which is hung from (4) 3/8"Ø rods stiffeners. (2) 1/8"Ø cable braces each corner (8 total).	Seismic Parameters							
		Building Code	Test Criteria	S _{Ds} (g)	z/h	Horizontal (g)		Vertical (g)	
						A _{FLX-H}	A _{RIG-H}	A _{FLX-V}	A _{RIG-V}
		CBC 2016	AC 156	2.50	1.0	4.00	3.00	1.67	0.67



Notes: The UUTs were full of contents during the test.
 Unit maintained structural integrity and remained functional per manufacture requirements after shake table test

UUT-20 Summary Tested Sub-Component

Sub-Component	Part Number	Manufacturer	Material
Heat Exchanger	U41 014 480	Mitsubishi Electric	Copper & Aluminum
Fan Motor	U41 005 128	Nidec Shibaura Co.	Carbon Steel
Fan Case	U41 010 129	Mitsubishi Electric	Carbon Steel
PCA Assy	U41 007 280	Shirai Electronics	94V-0 Plastic
PCA Power	U41 003 281	Shirai Electronics	94V-0 Plastic

UUT-22 Test Summary

Testing Lab: QualTech NP
 Testing Report: Q1619.00
 Testing Unit Num: Q1619-08-01-01

Model Number	Tonnage	Operating Weight (lbs)	Mounting	Excitation Direction	Frequency* (Hz)	Length (in)	Width (in)	Height (in)	
PUHY-P72TLMU-A	6.0	432	Base Mounted	X	Front - Back	6.8	29 5/32	36 1/4	64 31/32
				Y	Side - Side	>33.3			
				Z	Vertical	>33.3			

* Frequencies are for units prior to ICC ES AC-156 testing.
 Model Number is based on nomenclature from the 2014 Catalog

Attachment Method	Rigid base mounted with (4) 1/2"Ø ASTM A307 bolts	Seismic Parameters							
		Building Code	Test Criteria	S _{Ds} (g)	z/h	Horizontal (g)		Vertical (g)	
						A _{FLX-H}	A _{RIG-H}	A _{FLX-V}	A _{RIG-V}
		CBC 2016	AC 156	2.50	1.0	4.00	3.00	1.67	0.67



Notes: The UUTs were full of contents during the test.
 Unit maintained structural integrity and remained functional per manufacture requirements after shake table test

UUT-22 Summary Tested Sub-Component

Sub-Component	Part Number	Manufacturer	Material
Compressor	R69 126 478	Mitsubishi Electric	Carbon Steel
Heat Exchanger	R61 929 480	Mitsubishi Electric	Copper & Aluminum
Fan Motor	R61 267 220	Nidec TECNO Motor	Carbon Steel
Accumulator	R61 041 484	Meiwa Co. Ltd.	Carbon Steel
Reversing Valve x2	R61 013 403	Saginomiya	Brass
PC Board Mat'l	R61 342 280	Shin-Asahi Electric	94V-0 Plastic

UUT-23 Test Summary

Testing Lab: QualTech NP
 Testing Report: Q1619.00
 Testing Unit Num: Q1619-09-01-01

Model Number	Tonnage	Operating Weight (lbs)	Mounting	Excitation Direction	Frequency* (Hz)	Length (in)	Width (in)	Height (in)	
PURY-P168YLMU-A	14.0	720	Base Mounted	X	Front - Back	>33.3	26 5/32	68 29/32	64 31/32
				Y	Side - Side	6.0			
				Z	Vertical	>33.3			

* Frequencies are for units prior to ICC ES AC-156 testing.
 Model Number is based on nomenclature from the 2014 Catalog

Attachment Method	Rigid base mounted with (6) 1/2"Ø ASTM A307 bolts	Seismic Parameters							
		Building Code	Test Criteria	S _{Ds} (g)	z/h	Horizontal (g)		Vertical (g)	
						A _{FLX-H}	A _{RIG-H}	A _{FLX-V}	A _{RIG-V}
		CBC 2016	AC 156	2.50	1.0	4.00	3.00	1.67	0.67



Notes: The UUTs were full of contents during the test.
 Unit maintained structural integrity and remained functional per manufacture requirements after shake table test

UUT-23 Summary Tested Sub-Component

Sub-Component	Part Number	Manufacturer	Material
Compressor	R69 118 478	Mitsubishi Electric	Carbon Steel
Heat Exchanger	R61 937 480	Mitsubishi Electric	Copper & Aluminum
Heat Exchanger	R61 939 480	Mitsubishi Electric	Copper & Aluminum
Fan Motor x2	R61 268 220	Nidec TECNO Motor	Carbon Steel
Accumulator	R61 089 484	Meiwa Co. Ltd.	Carbon Steel
Reversing valve x2	R61 013 403	Saginomiya	Brass
PC Board Mat'l.	R61 354 280	Shin-Asahi Electric	94V-0 Plastic

UUT-24 Test Summary

Testing Lab: QualTech NP
 Testing Report: Q1619.00
 Testing Unit Num: Q1619-10-01-01

Model Number	Tonnage	Operating Weight (lbs)	Mounting	Excitation Direction	Frequency* (Hz)	Length (in)	Width (in)	Height (in)	
PQRY-P72TLMU-A	6.0	392	Base Mounted	X	Front - Back	>33.3	21 11/16	34 11/16	43 5/16
				Y	Side - Side	26.2			
				Z	Vertical	>33.3			

* Frequencies are for units prior to ICC ES AC-156 testing.
 Model Number is based on nomenclature from the 2014 Catalog

Attachment Method	Rigid base mounted with (4) 3/8"Ø ASTM A307 bolts	Seismic Parameters							
		Building Code	Test Criteria	S _{Ds} (g)	z/h	Horizontal (g)		Vertical (g)	
						A _{FLX-H}	A _{RIG-H}	A _{FLX-V}	A _{RIG-V}
		CBC 2016	AC 156	2.50	1.0	4.00	3.00	1.67	0.67



Notes: The UUTs were full of contents during the test.
 Unit maintained structural integrity and remained functional per manufacture requirements after shake table test

UUT-24 Summary Tested Sub-Component

Sub-Component	Part Number	Manufacturer	Material
Scroll compressor	R69 130 478	Mitsubishi Electric	Carbon Steel
Accumulator assy	R61 127 484	Meiwa Co. Ltd.	Carbon Steel
Heat exchanger	R61 987 480	Alfa Laval Inc	Copper & Aluminum
INV heat exchanger assy	R61 928 480	Mitsubishi Electric	Copper & Aluminum
Four way valve	R61 013 403	Saginomiya	Brass
Control Board	R61 358 280	Shin-Asahi Electric	94V-0 Plastic
INV Board	R61 353 280	Shin-Asahi Electric	94V-0 Plastic

UUT-25 Test Summary

Testing Lab: QualTech NP
 Testing Report: Q1653.00
 Testing Unit Num: Q1653-03-01-02

Model Number	Tonnage	Operating Weight (lbs)	Mounting	Excitation Direction	Frequency* (Hz)	Length (in)	Width (in)	Height (in)	
PQHY-P240YLMU-A	20.0	588	Base Mounted	X	Front - Back	5.8	21 11/16	34 11/16	57 1/8
				Y	Side - Side	31.2			
				Z	Vertical	14.6			

* Frequencies are for unit; interpolated
 Model Number is based o interpolated

Attachment Method	Rigid base mounted with (4) 1/2"Ø ASTM A307 bolts	Seismic Parameters							
		Building Code	Test Criteria	S _{Ds} (g)	z/h	Horizontal (g)		Vertical (g)	
						A _{FLX-H}	A _{RIG-H}	A _{FLX-V}	A _{RIG-V}
		CBC 2016	AC 156	2.00	1.0	3.20	2.40	1.33	0.53



Notes: The UUTs were full of contents during the test.
 Unit maintained structural integrity and remained functional per manufacture requirements after shake table test

UUT-25 Summary Tested Sub-Component

Sub-Component	Part Number	Manufacturer	Material
Scroll compressor	R69 133 478	Mitsubishi Electric	Carbon Steel
Accumulator assy	R61 125 484	Meiwa Co. Ltd.	Carbon Steel
Heat exchanger	R61 991 480	Alfa Laval Inc	Copper & Aluminum
INV heat exchanger assy	R61 928 480	Mitsubishi Electric	Copper & Aluminum
Four way valve	R61 013 403	Saginomiya	Brass
Control board	R61 340 280	Shin-Asahi Electric	94V-0 Plastic
INV board	R61 372 280	Shin-Asahi Electric	94V-0 Plastic

UUT-26 Test Summary

Testing Lab:	QualTech NP
Testing Report:	Q1653.00
Testing Unit Num:	Q1653-01-01-01

Model Number	Tonnage	Operating Weight (lbs)	Mounting	Excitation Direction	Frequency* (Hz)	Length (in)	Width (in)	Height (in)	
PLFY-P48NEMU-E	4.0	60	Ceiling Mounted	X	Front - Back	N/A	33 3/32	33 3/32	11 3/4
				Y	Side - Side	N/A			
				Z	Vertical	N/A			

* Frequencies are for units prior to ICC ES AC-156 testing.
Model Number is based on nomenclature from the 2014 Catalog

Attachment Method	Suspended with (4) 3/8"Ø rods with stiffeners. Each corner has (2) 1/8"Ø cable braces (8 total).	Seismic Parameters							
		Building Code	Test Criteria	S _{Ds} (g)	z/h	Horizontal (g)		Vertical (g)	
						A _{FLX-H}	A _{RIG-H}	A _{FLX-V}	A _{RIG-V}
		CBC 2016	AC 156	2.50	1.0	4.00	3.00	1.67	0.67



Notes: The UUTs were full of contents during the test.
Unit maintained structural integrity and remained functional per manufacture requirements after shake table test

UUT-26 Summary Tested Sub-Component

Sub-Component	Part Number	Manufacturer	Material
Heat Exchanger	R01 L55 480	Mitsubishi Electric	Copper & Aluminum
Fan Motor	T7W L02 220	Nidec Techno	Carbon Steel
Turbo Fan	R01 E46 114	Toray Industries Inc.	Styrene Acrylonitrile
Control Board	T7W M00 310	Seiryo-Technica	94V-0 Plastic
Condensate Pump	R01 E19 355	Fujikoki Corporation	ABS Plastic

UUT-27 Test Summary

Testing Lab:	QualTech NP
Testing Report:	Q1653.00
Testing Unit Num:	Q1653-02-01-02

Model Number	Tonnage	Operating Weight (lbs)	Mounting	Excitation Direction	Frequency* (Hz)	Length (in)	Width (in)	Height (in)	
PUMY-P60NKMU1	5.0	304	Base Mounted	X	Front - Back	6.8	13	41 11/32	52 11/16
				Y	Side - Side	31.0			
				Z	Vertical	>33.3			

* Frequencies are for units prior to ICC ES AC-156 testing.
Model Number is based on nomenclature from the 2014 Catalog

Attachment Method	Rigid base mounted with (4) 1/2"Ø ASTM A307 bolts.	Seismic Parameters							
		Building Code	Test Criteria	S _{DS} (g)	z/h	Horizontal (g)		Vertical (g)	
						A _{FLX-H}	A _{RIG-H}	A _{FLX-V}	A _{RIG-V}
		CBC 2016	AC 156	1.34	1.0	2.14	1.61	0.89	0.36



Notes: The UUTs were full of contents during the test.
Unit maintained structural integrity and remained functional per manufacture requirements after shake table test



UUT-27 Summary Tested Sub-Component

Sub-Component	Part Number	Manufacturer	Material
Heat Exchanger	R01 H37 408	Mitsubishi Electric	Copper & Aluminum
Compressor	T97 415 789	Siam Compressor	Carbon Steel
Fan Motor (2)	R01 E46 221	Panasonic Corp.	Carbon Steel
Control Board	T7W F23 315	Shin-Asahi Electric	94V-0 Plastic
Inverter board	R01 E72 313	Shin-Asahi Electric	94V-0 Plastic
M-Net Board	R01 E04	Kyosha Co., Ltd.	94V-0 Plastic
Reversing valve	R01 E36 403	Fujikoki Corp	Brass
Accumulator	R01 E67 440	Mitsubishi Electric	Carbon Steel





Model Number Nomenclature

Outdoor unit




Model Number Nomenclature




Model Number Nomenclature

INDOOR UNIT





Outdoor unit







Model Number Nomenclature





Model Number Nomenclature






Special Seismic Certification
OSHPD Preapproval Mitsubishi
Product Line



Model Number Nomenclature



FOR REFERENCE ONLY