

Title: President

### DEPARTMENT OF HEALTH CARE ACCESS AND INFORMATION **FACILITIES DEVELOPMENT DIVISION**

## OFFICE USE ONLY APPLICATION FOR HCAI SPECIAL SEISMIC CERTIFICATION PREAPPROVAL (OSP) APPLICATION #: OSP-0272 **HCAI Special Seismic Certification Preapproval (OSP)** Type: New Renewal **Manufacturer Information** Manufacturer: ClimateCraft, Inc. Manufacturer's Technical Representative: Andrew Hills Mailing Address: 518 North Indiana Ave., Oklahoma City, OK 73106 Telephone: (405) 415-9230 Email: ahills@climatecraft.com **Product Information** Product Name: Air Handling Units Product Type: Fans Product Model Number: FanMatrix General Description: Matrix fan towers consisting of four HSS 3"x3"x1/8" columns, with 11 gauge horizontal braces on three sides (located at the fans), 11 gauge seismic punched square, and 5/8" column base plates with internal vibration isolators. Mini Tower consisted of: 4 - HSS 2"x2"x1/8" columns, with 11 gauge horizontal braces on three sides with internal vibration isolators. Mounting Description: Rigid, Floor Mounted None Tested Seismic Enhancements: **Applicant Information** Applicant Company Name: The VMC Group Contact Person: John Giuliano Mailing Address: 113 Main Street, Bloomingdale, NJ 07403 Telephone: (973) 838-1780 Email: john.giuliano@thevmcgroup.com



STATE OF CALIFORNIA – HEALTH AND HUMAN SERVICES AGENCY



# DEPARTMENT OF HEALTH CARE ACCESS AND INFORMATION FACILITIES DEVELOPMENT DIVISION

California Licensed Structural Engineer Responsible for the Engineering and Test Report(s)
Company Name: THE VMC GROUP
Name: Kenneth Tarlow California License Number: S2851
Mailing Address: 980 9th Street, 16th Floor, Sacramento, CA 95814
Telephone: (832) 627-2214 Email: ken.tarlow@thevmcgroup.com
Certification Method
☐ GR-63-Core
Other (Please Specify):
EOR CODE CO.
Testing Laboratory
Company Name: CLARK TESTING LABORATORY, INC.
Contact Person: Devon Lohr
Mailing Address: 1801 Route 51, Jefferson Hills PA 15025
Telephone: (412) 387-1026
Company Name: ENVIRONMENTAL TESTING LABORATORIES, INC. (ETL)
Contact Person: Paul E. Little DATE: 07/18/2023
Mailing Address: 11034 Indian Trail, Dallas TX 75229-3513
Telephone: (972) 247-9657 Email: paul@etldallas.com

HC/

STATE OF CALIFORNIA - HEALTH AND HUMAN SERVICES AGENCY



# DEPARTMENT OF HEALTH CARE ACCESS AND INFORMATION FACILITIES DEVELOPMENT DIVISION

Seismic Parameters	
Design Basis of Equipment or Components	(Fp/Wp) = 4.34
SDS (Design spectral response accele	eration at short period, g) = 1.93
ap (Amplification factor) =	2.5
R <sub>P</sub> (Response modification factor) =	2.0
$\Omega_0$ (System overstrength factor) =	2.0
Ip (Importance factor) =	1.5
z/h (Height ratio factor) =	1
Natural frequencies (Hz) =	See Attachment
Overall dimensions and weight =	See Attachment

HCAI A	pproval (For Office Use Only) Approval Expires on 07/	18/2029	
Date:	7/18/2023 OSP-0272	12	
Name:	Timothy Piland	Title:	Senior Structural Engineer
Special S	Seismic Certification Valid Up to: SDS (g) = 1.93	z/h =	1
Conditio	n of Approval (if applicable): DATE 07/18/202	23	





STATE OF CALIFORNIA – HEALTH AND HUMAN SERVICES AGENCY

**Table 1a - Certified Components - MiniTower Fan Tower Arrays** 

Motor HP Fan Diameter	3	5	7.5	10	Fan Tower Manufacturer	UUT
10"	Χ	Χ	Х	Χ		UUT-06
11"	Х	Х	Х	Х		
12"	Х	Х	Х	Х	CllimateCraft	Inteprolated
14"	Х	Х	Х	Х	-D	CODE
16"	Х	Х	Х	Х	EOK	UUT-06

#### Note:

Table 1b - Certified Components - MiniTower Fan Structure

	Arroy	Dimensions	_	20	Overall Siz	e OSP-	-0272	Fan	Tested Tower		
	Array		10	11	12	14	16	Tower	,	UUT	
Con	figuration	[ in ]		Inte	rnally Isol	ated	LDilan	Material	Weight [ lb ]		
		Width	27	27	27	27	J 127am	J Total			
1x1	0	Depth	26	26	26	26	26		N/A	Inteprolated	
		Height	30-84	30-84	30-84	30-847	30-84	3			
		Width	27	27	27	27	27			UUT-06	
1x2	0	Depth	26	26	26	26	26		631		
	0	Height	<u><b>60</b></u> -108	60-108	60-108	60-108	60-108	Carbon			
	0	Width	27	27	27	27	27	Steel			
1x3	0	Depth	26	26	26	26	26	10V	N/A	Inteprolated	
	0	Height	84-132	84-132	84-132	84-132	84-132				
	0	Width	27	27	27	27	127				
1x4	0000	Depth	26	26	26	26	26		1363	UUT-06	
	Ŏ	Height	120-138	120-138	120-138	120-138	120- <u>138</u>				

#### Note:

<sup>1)</sup> Mini Tower consisted of: 4 - HSS 2"x2"x1/8" columns, with 11 gauge horizontal braces on three sides with internal vibration isolators.

<sup>1)</sup> All fan/motor assemblies internally isolated with VMC SW-1C Spring Isolators, as tested

Table 2a - Certified Components - Matrix (MTX) Fan Towers
Model Name: MTX Drive Type: Direct Drive

Motor HP Fan Diameter	3	5	7.5	10	15	20	25	30	Fan Tower Manufacturer	UUT
12"	Χ	Х	Х	Х	Χ	Χ	Χ	Χ		UUT-01
15"	Χ	Х	Х	Х	Х	Х	Х	Х		Inteprolated
16"	Χ	Х	Х	Χ	Χ	Χ	Χ	Х		UUT-01
18"	Χ	Х	Х	Х	Χ	Χ	X	X	CllimateCraft	Interpolated
20"	Χ	Х	Х	Х	Χ	X	$\sim$ X $\sim$	X	GilmateCraft	UUT-01
22"	X	Х	Х	Х	X	X	X	X	010	UUT-02, UUT-6
24"	Χ	Х	Х	Χ	X	X	Х	X	••••	UUT-02, UUT-6
27"	Χ	Χ	Х	X	X	Χ	Χ	Χ		UUT-02, UUT-6

#### Note:

Table 2b - Certified Components - Matrix (MTX) Fan Structure

	Array	Dimensions			MA www.	Overa	II Size				Fan	Tested Tower		
	figuration	[ in ]	12	15	16	18	102000	22	24	27	Tower	Weight [ lb ]	UUT	
Con	ilguration	[ ]		Internally Isolated								weight [ ib ]		
		Width	37	37	37	37	37	44	44	44				
1x1	0	Depth	48	48	48	48	48	48	48	48		N/A		
		Height	42 - 90	42 - 90	42 - 90	42 - 90	42 - 90	42 - 96	42 - 96	42 - 96			Interpolated	
		0	Width	37	37	137	37	37	44	44	44	Carbon	IN/A	Interpolated
1x2	0	Depth	48	48	48	<b>5</b> 48	48	48	48	48	Steel			
		Height	72 - 126	72 - 126	72 - 126	72 - 126	72 - 126	84 - 126	84 - 126	84 - 126	Steel			
	1x3	Width	37	37	37	37	37	44	44	44		UUT-01: 1886,	UUT-01,	
1x3		Depth	48	48	48	48	48	48	48	48		UUT-02: 2176,	UUT-02,	
	0	Height	114 - 144	114 - 144	114 - 144	114 - 144	114 - <b>144</b>	126 - 144	126 - 144	126 - <b>144</b>		UUT-06: 2913	UUT-06	

#### Note:

<sup>1)</sup> Matrix fan towers consisting of four HSS 3"x3"x1/8" columns, with 11 gauge horizontal braces on three sides (located at the fans), 11 gauge punched square, and 5/8" column base plates with internal vibration isolators.

<sup>1)</sup> All fan/motor assemblies internally isolated with VMC SW-1C Spring Isolators, as tested

**Table 3 - Certified Subcomponents - Fan Wheels** 

Model Family	Diameter	Туре	Weight	Wheel Material	Housing Material	Manufacturer	UUT
	10"		9				UUT-06
	11"		10		Aluminum		
MiniTower	12"	ANPA	13	Aluminum		Comerfri	Interpolated
	14"		16				
	16"		19				UUT-06
	12"		20			Greenheck	UUT-01
	15"		23				Interpolated
	16"	12	26				UUT-01
Matrix Tower	18"	Blade	29	Aluminum	Carbon		Interpolated
(MTX)	20"	QEP	33	Aluminum	Steel	Fan Corp.	UUT-01
	22"	QLI	52				UUT-02, UUT-06
	24"		67				UUT-02, UUT-06
	27"		75				UUT-02, UUT-06

Table 4 - Certified Subcomponents - Motor

Model Family	НР	Voltage <sup>1,2</sup>	Frame Size	Weight [ lb ]	Housing Material	Manufacturer	UUT
	3		182T	72	P-0272	7.	UUT-06
	5	14	7 184T	120			Interpolated
	7.5		213T	160	71 -0212	m	Interpolated
Premium	10		215T	170	U Cembran Ota al	Nidec	UUT-06
Efficient AC	15		254T	300	thy Carbon Steel	Mudec	Interpolated
	20		256T	340	07/18/2023		Interpolated
	25		284T	△ 380°		$\sim$	Interpolated
	30 <sup>3</sup>	208-230 /	286T	492			UUT-06
	3	<u>460</u>	182T	69		V	UUT-01, UUT-02
	5		184T	95			Interpolated
	7.5		213T	146			Interpolated
Premium	10		215T	158	Carbon Steel	Baldor	UUT-01, UUT-02, UUT-06
Efficient AC	15		254T	217	Carbon Steel	Daluul	UUT-06
	20		256T	286			Interpolated
	25		284T	417			Interpolated
	30		286T	380			UUT-01, UUT-02

#### Note:

- 1) The voltage is effected by the internal wiring connections only. Amp Draw (A) is dependent on the voltage.
- 2) 460V is the rated voltage of the motor. 480V power source was used during functionality testing.
- 3) This motor cannot be used in the top slot of a 1x3 Matrix (MTX) fan tower.

Table 5 - BalanceStream™

Wheel Size	Weight [lb]	Manufacturer	UUT		
18" Diamater	35		Interpolated		
20" Diamater	40		interpolated		
22" Diamater	47	ClimateCraft			
24" Diameter	54		UUT-06		
27" Diameter	63				

**Note:** This component is a spring actuated inlet cone which helps to optimize efficiency of the fans



# UNIT UNDER TEST (UUT) Summary Sheet

UUT-1

Test Report: ETL Report# 12086

Model Line	Model Number	Manufacturer
FanMatrix	12MTX3, 16MTX10, 20MTX30	ClimateCraft

#### **Product Construction Summary**

Tower consisted of: 4 - HSS 3"x3"x1/8" columns, with 11 gauge horizontal braces on three sides (located at the fans), 11 gauge seismic punched square, and 5/8" column base plates

#### **Options / Subcomponent Summary**

Fan: Greenheck Fan Corp; Motor: Baldor

IIIIT Proportios

			o i Properti	ies	70,					
Weight		Dimensions [ in ] Lowest Nat. Freq. [ H								
[lbs]	Length	Wi	dth	<u> </u>	Height /	F-B	S-S	V		
1,886	37.0	(48	39P-027	12	144.0	4.3	4.0	4.3		
	UUT H	lighest Pas	sed Seismi	c Run Inf	ormation					
Building Code	Test <mark>Criter</mark> ia	Sysim	oth Z/h	lland	A <sub>FLX-H</sub>	A <sub>RIG-H</sub>	A <sub>FLX-V</sub>	A <sub>RIG-V</sub>		
CBC 2022	ICC-ES AC156	2.00	1.0	1.5	3.20	2.51	1.74	0.70		
CBC 2022	100-E3 AC 150									

### **Test Mounting Details**

UUT-1 was rigidly mounted to the shake table using (6) 5/8" diameter Grade 8 bolts.



All units were filled with contents and maintained structural integrity and functionality after AC-156 test.



# UNIT UNDER TEST (UUT) Summary Sheet

UUT-2

Test Report: ETL Report# 12086

Model Line	Model Number	Manufacturer		
FanMatrix	22MTX3, 24MTX10, 27MTX30	ClimateCraft		

#### **Product Construction Summary**

Tower consisted of: 4 - HSS 3"x3"x1/8" columns, with 11 gauge horizontal braces on three sides (located at the fans), 11 gauge seismic punched square, and 5/8" column base plates

#### **Options / Subcomponent Summary**

Fan: Greenheck Fan Corp; Motor: Baldor

**UUT Properties** 

Weight [ lbs ]	Dimensions [ in ]				Lowest Nat. Freq. [ Hz ]			
	Length	Width	Height	F-B	S-S	V		
2,176	44.0	48.0P-0272	144.0	3.7	3.6	4.7		
UUT Highest Passed Seismic Run Information								
Building Code	Test Criteria	VSpsimoth z/h Pilan	J <sub>P</sub> A <sub>FLX-H</sub>	A <sub>RIG-H</sub>	A <sub>FLX-V</sub>	A <sub>RIG-V</sub>		

Building Code Test Criteria S<sub>DS</sub> Z/h J<sub>P</sub> A<sub>FLX-H</sub> A<sub>RIG-H</sub> A<sub>FLX-V</sub> A<sub>RIG-V</sub> A<sub>RIG-V</sub> A<sub>RIG-V</sub> CBC 2022 ICC-ES AC156 2.00 1.0 1.5 3.20 2.51 1.74 0.70

### Test Mounting Details

UUT-2 was rigidly mounted to the shake table using (6) 5/8" diameter Grade 8 bolts.



All units were filled with contents and maintained structural integrity and functionality after AC-156 test.



# UNIT UNDER TEST (UUT) Summary Sheet

UUT-6

Test Report: JID 20-00450

Model Line	Model Number	Manufacturer		
Air Handler	80177	ClimateCraft		

#### **Product Construction Summary**

MiniTower (4)16MiniTX10 consisted of: 4 - HSS 2"x2"x1/8" columns, with 11 gauge horizontal braces on three sides (located at the fans). MiniTower (2)10MiniTX3 consisted of: 4 - HSS 2"x2"x1/8" columns, with 11 gauge horizontal braces on three sides (located at the fans). FanMatrix Tower 22MTX15, 24MTX30, 27MTX30 consisted of: 4 - HSS 3"x3"x1/8" columns, with 11 gauge horizontal braces on three sides (located at the fans), 11 gauge seismic punched square, and 5/8" column base plates

#### **Options / Subcomponent Summary**

COR CODE CO.

MiniTower (4)16MiniTX10 Subcomponents - Fan: Comerfri ; Motor: Baldor & Nidec

MiniTower (2)10MiniTX3 Subcomponents - Fan: Comerfri ; Motor: Nidec

FanMatrix Tower 22MTX15, 24MTX30, 27MTX30 Subcomponents - Fan: Greenheck Fan Corp ; Motor: Baldor & Nidec ;

BalanceStream: ClimateCraft

		U	UT Propert	ies	0,			
Weight	Dimensions [ in ]				Lowest Nat. Freq. [ Hz ]			
[lbs]	Length	w	idth	H	eight	F-B	S-S	V
9,194	120.0	146,0 _ 0 2 7 2 151.0			3.2	7.8	13.4	
	UUTI	Highest Pas	sed Seism	ic Run Info	rmation			
Building Code	Test <mark>Criter</mark> ia	Sosim	oth Z/h	lland	A <sub>FLX-H</sub>	A <sub>RIG-H</sub>	A <sub>FLX-V</sub>	A <sub>RIG-V</sub>
CBC 2022	ICC-ES AC156	1.93	1.0	1.5	3.09	2.32	1.29	0.52
		DATE.	07/40/	2002	-	-	-	-

#### Test Mounting Details

UUT-6 was rigidly mounted to the shake table using (6) 7/8" diameter Grade 5 bolts.

The 4-high fan tower was attached directly to the base/floor of the UUT-6 using (6) 5/8" diameter Grade 8 bolts. The 2-high fan tower was attached directly to the base/floor of the UUT-6 using (6) 5/8" diameter Grade 8 bolts. The 3-high fan tower was attached directly to the base/floor of the UUT-6 using (6) 5/8" diameter Grade 8 bolts.



FanMatrix Tower 22MTX15, 24MTX30, 27MTX30

All units were filled with contents and maintained structural integrity and functionality after AC-156 test.