



OFFICE OF STATEWIDE HEALTH PLANNING AND DEVELOPMENT
FACILITIES DEVELOPMENT DIVISION

APPLICATION FOR OSHPD SPECIAL SEISMIC
CERTIFICATION PREAPPROVAL (OSP)

OFFICE USE ONLY

APPLICATION #: OSP – 0276 – 10

OSHPD Special Seismic Certification Preapproval (OSP)

Type: New Renewal

Manufacturer Information

Manufacturer: Alpha Industrial Power

Manufacturer's Technical Representative: Phillip Knighton

Mailing Address: 1705 Satellite BLVD NW, Suwanee, GA 30024-4625

Telephone: 678-387-4049

Email: pknighton@alpha.com

Product Information

Product Name: Spectra Battery Chargers

Product Type: Emergency Backup Power

Product Model Number: Various – See Attachments

(List all unique product identification numbers and/or part numbers)

General Description: AC powered battery charger. See attachment for complete product specification details.

Mounting Description: Rigid Floor Mount

Applicant Information

Applicant Company Name: Alpha Industrial Power

Contact Person: Ron Rice

Mailing Address: 1705 Satellite BLVD NW, Suwanee, GA 30024-4625

Telephone: 678-387-4049

Email: rrice@alpha.com

I hereby agree to reimburse the Office of Statewide Health Planning and Development review fees in accordance with the California Administrative Code, 2013.


Signature of Applicant:

Date: 5/16/2014

Title: Sales and Marketing Coordinator

Company Name: Alpha Industrial Power

"Access to Safe, Quality Healthcare Environments that Meet California's Diverse and Dvnamic Needs"



osHPd



**OFFICE OF STATEWIDE HEALTH PLANNING AND DEVELOPMENT
FACILITIES DEVELOPMENT DIVISION**

California Licensed Structural Engineer Responsible for the Engineering and Test Report(s)

Company Name: ZFA Structural Engineers
Name: David Cooper, S.E California License Number: S2768
Mailing Address: 1212 fourth street, suite Z, Santa Rosa ca 95404
Telephone: 707-526-0992 Email: davidc@zfa.com

Supports and Attachments Preapproval


- Supports and attachments are preapproved under OPM- _____
(Separate application for OSHPD Preapproval of Manufacturer's Certification (OPM) of Supports and attachments is required)
- Supports and attachments are not preapproved

Certification Method

- Testing in accordance with: ICC-ES AC156
- Other (Please Specify): _____

Testing Laboratory

Company Name: ANCO Engineers, Inc.
Contact Name: Boaz Norton
Mailing Address: 1965A 33rd St., Boulder, CO 80301
Telephone: 303-443-7580 x237 Email: boaz@ancoengineers.com





**OFFICE OF STATEWIDE HEALTH PLANNING AND DEVELOPMENT
FACILITIES DEVELOPMENT DIVISION**

Seismic Parameters

Design in accordance with ASCE 7-10 Chapter 13: Yes No

Design Basis of Equipment or Components (F_p/W_p) = 1.125

S_{DS} (Design spectral response acceleration at short period, g) = 2.5

a_p (In-structure equipment or component amplification factor) = 1.0

R_p (Equipment or component response modification factor) = 2.5

Ω_0 (System overstrength factor) = _____

I_p (Importance factor) = 1.5

z/h (Height factor ratio) = 0

Equipment or Component Natural Frequencies (Hz) = Various. See Attachments.

Overall dimensions and weight (or range thereof) = Various. See Attachments.

Equipment or Components @ grade designed in accordance with ASCE 7-10 Chapter 15: Yes No

Design Basis of Equipment or Components (V/W) = _____

S_{DS} (Design spectral response acceleration at short period, g) = _____

S_{D1} (Design spectral response acceleration at 1 second period, g) = _____

R (Response modification coefficient) = _____

Ω_0 (System overstrength factor) = _____

C_d (Deflection amplification factor) = _____

I_p (Importance factor) = 1.5

Height to Center of Gravity above base = _____

Equipment or Component Natural Frequencies (Hz) = _____

Overall dimensions and weight (or range thereof) = _____

Tank(s) designed in accordance with ASME BPVC, 2010: Yes No

List of Attachments Supporting Special Seismic Certification

Test Report(s) Drawings Calculations Manufacturer's Catalog

Other(s) (Please Specify): _____


OSHPD Approval (For Office Use Only) – Approval Expires on December 31, 2019

Signature:  Date: October 19, 2014

Print Name: Timothy J. Piland Title: SSE

Special Seismic Certification Valid Up to : S_{DS} (g) = 2.5 z/h = 0

Condition of Approval (if applicable): _____



Alpha Industrial Power Certified Product Matrix

Part Number	Dimensions (mm/in)			Weight (kg/lb)	Tested/ Interpolated
	Length	Width	Height		
Spectra Charger					
1ST02401211100000	483/19.0	425/16.8	445/17.5	34/75	Tested
1ST02401210000000	483/19.0	425/16.8	445/17.5	34/75	Interpolated ^a
1ST02401210100000	483/19.0	425/16.8	445/17.5	34/75	Interpolated ^a
1ST04800610000000	483/19.0	425/16.8	445/17.5	34/75	Interpolated ^a
1ST04800610100000	483/19.0	425/16.8	445/17.5	34/75	Interpolated ^a
1ST04800611100000	483/19.0	425/16.8	445/17.5	34/75	Interpolated ^a
1ST04800611120000	483/19.0	425/16.8	445/17.5	34/75	Interpolated ^a
1ST04800631100000	483/19.0	425/16.8	445/17.5	34/75	Interpolated ^a
1ST02402011100000	483/19.0	425/16.8	445/17.5	39/85	Tested
1ST02401811100000	483/19.0	425/16.8	445/17.5	39/85	Interpolated ^a
1ST02402010000000	483/19.0	425/16.8	445/17.5	39/85	Interpolated ^a
1ST02402010100000	483/19.0	425/16.8	445/17.5	39/85	Interpolated ^a
1ST02402011000000	483/19.0	425/16.8	445/17.5	39/85	Interpolated ^a
1ST02402031100000	483/19.0	425/16.8	445/17.5	39/85	Interpolated ^a
1ST04802511100000	483/19.0	425/16.8	445/17.5	52/115	Tested
1ST04802510000000	483/19.0	425/16.8	445/17.5	52/115	Interpolated ^a
1ST04802510100000	483/19.0	425/16.8	445/17.5	52/115	Interpolated ^a
1ST04802511000000	483/19.0	425/16.8	445/17.5	52/115	Interpolated ^a
1ST04802511100100	483/19.0	425/16.8	445/17.5	52/115	Interpolated ^a
1ST04802511120000	483/19.0	425/16.8	445/17.5	52/115	Interpolated ^a
1ST04802521100000	483/19.0	425/16.8	445/17.5	52/115	Interpolated ^a

1ST04802521100100	483/19.0	425/16.8	445/17.5	52/115	Interpolated ^a
1ST04802530000000	483/19.0	425/16.8	445/17.5	52/115	Interpolated ^a
1ST04802530100000	483/19.0	425/16.8	445/17.5	52/115	Interpolated ^a
1ST04802531000000	483/19.0	425/16.8	445/17.5	52/115	Interpolated ^a
1ST04802531100000	483/19.0	425/16.8	445/17.5	52/115	Interpolated ^a
1ST02402511120100	483/19.0	425/16.8	445/17.5	41/90	Tested
1ST02402511000000	483/19.0	425/16.8	445/17.5	41/90	Interpolated ^a
1ST02402511100000	483/19.0	425/16.8	445/17.5	41/90	Interpolated ^a
1ST02402511120100	483/19.0	425/16.8	445/17.5	41/90	Interpolated ^a
1ST02402530000000	483/19.0	425/16.8	445/17.5	41/90	Interpolated ^a
1ST04801210000000	483/19.0	425/16.8	445/17.5	41/90	Interpolated ^a
1ST04801210100000	483/19.0	425/16.8	445/17.5	41/90	Interpolated ^a
1ST04801211000000	483/19.0	425/16.8	445/17.5	41/90	Interpolated ^a
1ST04801211100000	483/19.0	425/16.8	445/17.5	41/90	Interpolated ^a
1ST04801211120000	483/19.0	425/16.8	445/17.5	41/90	Interpolated ^a
1ST04801230100000	483/19.0	425/16.8	445/17.5	41/90	Interpolated ^a
1ST04801231000000	483/19.0	425/16.8	445/17.5	41/90	Interpolated ^a
1ST04801231100000	483/19.0	425/16.8	445/17.5	41/90	Interpolated ^a

a) See Table J1 below for non-structural interpolations

Spectra Charger Part Number Convention

Tested Unit	1	ST	024	025	1	1	1	2	0	1	0	0
Generic Unit	A		B	C	D	E	F	G	H	I	J	K

Table J1: Spectra Options

If a space has no option selected, a zero must be inserted.				
Box	ST	Description	Interpolation	UUT
A	1	1 Phase	Tested	4,5,6,7
B		Nominal DC Output Voltage		
	024	24 Vdc	Tested	4,6,7
	048	48 Vdc	Tested	5
	130	130 Vdc	N/A	
C		Nominal DC Output Current		
	006	6 Adc	Wiring ¹	
	008	8 Adc	Wiring ¹	
	012	12 Adc	Tested	7
	020	20 Adc	Tested	6
	025	25 Adc	Tested	4,5
	050	50 Adc	N/A	
D		Input Voltage		
	1	120	Tested	4,5,6,7
	2	208 (not UL listed)	Wiring ¹	
	3	240	Software	
E		Filtering		
	0	Unfiltered	Software	
	1	Filtered / Eliminator	Tested	4,5,6,7
F		Relays		

	0	No Relays	Omitted	
	1	Individual Alarm Relay Contact Board	Tested	4,5,6,7
G		Remote Sensing		
	0	Not Supplied	Omitted	
	1	Remote Control Panel	N/A	
	2	Remote Temperature Compensation	Tested	4
	3	Remote DC Voltage Sensing	N/A	
	4	Lines 1 & 2	N/A	
	5	Lines 1 & 3	N/A	
	6	Lines 2 & 3	N/A	
	7	Lines 1, 2 & 3	N/A	
H		Lightning Arrester		
	0	Not Supplied	Omitted	
	1	Included	N/A	
I		Charging		
	0	Not Supplied	Omitted	
	1	Parallel Charging	Tested	4
J		Special Treatments		
	0	None	Omitted	
	1	Fungus Proofing	N/A	
	2	Conformal Seal On Electronic PC Board	N/A	
	3	Lines 1 & 2	N/A	
K		Other Options		
	0	None	Omitted	

	1	Lockable enclosure door	N/A	
	2	NEMA 4 enclosure	N/A	
	3	NEMA 12 enclosure	N/A	
	4	19" Rack flanges @ 6.0" from front	N/A	
	5	23" Rack flanges @ 6.0" from front	N/A	
	6	Lines 1 & 4	N/A	
	7	Lines 1 & 5	N/A	

- 1) These options use an identical bus to those tested, which mounts inside the cabinet using the same anchors. The weight and max dimensions are the same for all models.



1965A 33rd Street
 Boulder, CO 80301
 (303)443-7580

UUT #4

Unit Under Test (UUT) Summary Sheet

ANCO Project Number: 3324.01

Manufacturer:	Alpha Industrial Power Inc
Model Line:	AlphaRac Battery Racks and Cabinets
Model Number:	1ST02402511120100
Product Construction Summary:	Formed carbon steel sheet metal enclosure housing breakers, LCD control interface and charger module.
Options/ Subcomponent Summary:	None. Standard unit sold as tested. 24VDC, 25A, 120VAC, 1PH

UUT Properties

Weight (lb)	Dimensions (in)			Lowest Natural Frequency (Hz)		
	Depth	Width	Height	Front-Back	Side-Side	Vertical
87.5	19	16.8	17.5	>33	>33	>33

UUT Highest Passed Seismic Run Information

Building Code	Test Criteria	S _{DS}	z/h	I _p	A _{FLX-H}	A _{RIG-H}	A _{FLX-V}	A _{RIG-V}
CBC 2013	ICC-ES AC-156	2.5	0	1.5	2.5	1.0	1.68	0.68

Test Mounting Details:



Charger bolted to plate using four 3/8"-16 bolts with standard washers (one bolt in each corner)



1965A 33rd Street
 Boulder, CO 80301
 (303)443-7580

UUT #4

Unit Under Test (UUT) Summary Sheet

ANCO Project Number: 3324.01

Test Setup:	Setup #1	
UUT Function:	Emergency backup battery bank charging	
Restrictions:	Rigid Floor Mount Only (As Tested)	
Functionality	Pre-Test	Post-Test
Test Results:	Pass	Pass
Component Serial Numbers:	OSHDP1ST	

UUT Properties

Weight (lb)	CG Location (in)			Coordinate System Origin
	Depth	Width	Height	
87.5	10	6	9.5	Bottom Back Left Anchor (see drawing Below)

Additional Notes/Comments:

UUT was tested full of content
 UUT maintained structural stability after test
 UUT maintained functionality after test

Coordinate Origin (Noted by Red Dot):





1965A 33rd Street
 Boulder, CO 80301
 (303)443-7580

UUT #5

Unit Under Test (UUT) Summary Sheet

ANCO Project Number: 3324.03

Manufacturer:	Alpha Industrial Power Inc
Model Line:	AlphaRac Battery Racks and Cabinets
Model Number:	1ST04802511100000
Product Construction Summary:	Formed carbon steel sheet metal enclosure housing breakers, LCD control interface and charger module.
Options/ Subcomponent Summary:	None. Standard unit sold as tested. 48VDC, 25A, 120VAC, 1PH

UUT Properties

Weight (lb)	Dimensions (in)			Lowest Natural Frequency (Hz)		
	Depth	Width	Height	Front-Back	Side-Side	Vertical
115	19	16.8	17.5	>33	22	>33

UUT Highest Passed Seismic Run Information

Building Code	Test Criteria	S _{DS}	z/h	I _p	A _{FLX-H}	A _{RIG-H}	A _{FLX-V}	A _{RIG-V}
CBC 2013	ICC-ES AC-156	2.5	0	1.5	2.5	1.0	1.68	0.68

Test Mounting Details:



Charger bolted to plate using four 3/8"-16 bolts with standard washers (one bolt in each corner)



1965A 33rd Street
 Boulder, CO 80301
 (303)443-7580

UUT #5

Unit Under Test (UUT)

Summary Sheet

ANCO Project Number: 3324.03

Test Setup:	Setup #2	
UUT Function:	Emergency backup battery bank charging	
Restrictions:	Rigid Floor Mount Only (As Tested)	
Functionality	Pre-Test	Post-Test
Test Results:	PASS	PASS
Component Serial Numbers:	501300246	

UUT Properties

Weight (lb)	CG Location (in)			Coordinate System Origin
	Depth	Width	Height	
115	7	8.25	9.75	Bottom Back Left Anchor (see drawing Below)

Additional Notes/Comments:

UUT was tested full of content
 UUT maintained structural stability after test
 UUT maintained functionality after test

Coordinate Origin (Noted by Red Dot):





1965A 33rd Street
Boulder, CO 80301
(303)443-7580

UUT #6

Unit Under Test (UUT) Summary Sheet

ANCO Project Number: 3324.03

Manufacturer:	Alpha Industrial Power Inc
Model Line:	AlphaRac Battery Racks and Cabinets
Model Number:	1ST02402011100000
Product Construction Summary:	Formed carbon steel sheet metal enclosure housing breakers, LCD control interface and charger module.
Options/Subcomponent Summary:	None. Standard unit sold as tested. 24VDC, 20A, 120VAC, 1PH

UUT Properties

Weight (lb)	Dimensions (in)			Lowest Natural Frequency (Hz)		
	Depth	Width	Height	Front-Back	Side-Side	Vertical
85	19	16.8	17.5	32.8	20.4	>33

UUT Highest Passed Seismic Run Information

Building Code	Test Criteria	S _{DS}	z/h	I _p	A _{FLX-H}	A _{RIG-H}	A _{FLX-V}	A _{RIG-V}
CBC 2013	ICC-ES AC-156	2.5	0	1.5	2.5	1.0	1.68	0.68

Test Mounting Details:



Charger bolted to plate using four 3/8"-16 bolts with standard washers (one bolt in each corner)



1965A 33rd Street
 Boulder, CO 80301
 (303)443-7580

UUT #6

Unit Under Test (UUT) Summary Sheet

ANCO Project Number: 3324.03

Test Setup:	Setup #2	
UUT Function:	Emergency backup battery bank charging	
Restrictions:	Rigid Floor Mount Only (As Tested)	
Functionality	Pre-Test	Post-Test
Test Results:	PASS	PASS
Component Serial Numbers:	081400425	

UUT Properties

Weight (lb)	CG Location (in)			Coordinate System Origin
	Depth	Width	Height	
85	7.25	7.75	8.5	Bottom Back Left Anchor (see drawing Below)

Additional Notes/Comments:

UUT was tested full of content
 UUT maintained structural stability after test
 UUT maintained functionality after test

Coordinate Origin (Noted by Red Dot):





1965A 33rd Street
Boulder, CO 80301
(303)443-7580

UUT #7

Unit Under Test (UUT) Summary Sheet

ANCO Project Number: 3324.03

Manufacturer:	Alpha Industrial Power Inc
Model Line:	AlphaRac Battery Racks and Cabinets
Model Number:	1ST02401211100000
Product Construction Summary:	Formed carbon steel sheet metal enclosure housing breakers, LCD control interface and charger module.
Options/ Subcomponent Summary:	None. Standard unit sold as tested. 24VDC, 12A, 120VAC, 1PH

UUT Properties

Weight (lb)	Dimensions (in)			Lowest Natural Frequency (Hz)		
	Depth	Width	Height	Front-Back	Side-Side	Vertical
75	19	16.8	17.5	23.9	21.6	>33

UUT Highest Passed Seismic Run Information

Building Code	Test Criteria	S _{DS}	z/h	I _P	A _{FLX-H}	A _{RIG-H}	A _{FLX-V}	A _{RIG-V}
CBC 2013	ICC-ES AC-156	2.5	0	1.5	2.5	1.0	1.68	0.68

Test Mounting Details:



Charger bolted to plate using four 3/8"-16 bolts with standard washers (one bolt in each corner)



1965A 33rd Street
 Boulder, CO 80301
 (303)443-7580

UUT #7

Unit Under Test (UUT)

Summary Sheet

ANCO Project Number: 3324.03

Test Setup:	Setup #2	
UUT Function:	Emergency backup battery bank charging	
Restrictions:	Rigid Floor Mount Only (As Tested)	
Functionality	Pre-Test	Post-Test
Test Results:	PASS	PASS
Component Serial Numbers:	511301232	

UUT Properties

Weight (lb)	CG Location (in)			Coordinate System Origin
	Depth	Width	Height	
75	7	7.75	9.25	Bottom Back Left Anchor (see drawing Below)

Additional Notes/Comments:

UUT was tested full of content
 UUT maintained structural stability after test
 UUT maintained functionality after test

Coordinate Origin (Noted by Red Dot):

