



OFFICE OF STATEWIDE HEALTH PLANNING AND DEVELOPMENT  
FACILITIES DEVELOPMENT DIVISION

APPLICATION FOR OSHPD SPECIAL SEISMIC  
CERTIFICATION PREAPPROVAL (OSP)

OFFICE USE ONLY

APPLICATION #: OSP – 0373 – 10

OSHPD Special Seismic Certification Preapproval (OSP)

Type:  New  Renewal

Manufacturer Information

Manufacturer: BasX Solutions, LLC

Manufacturer's Technical Representative: Jorge Sanchez

Mailing Address: 3500 SW 21<sup>st</sup> Place, Redmond, OR 97756

Telephone: (503) 691-0811

Email: [info@basxsolutions.com](mailto:info@basxsolutions.com)

Product Information

Product Name: Seismically Modified Absorption Chiller

Product Type: Absorption Chiller

Product Model Number: JAS-REEV-TOB-16DNP 018L0000S

(List all unique product identification numbers and/or part numbers)

General Description: Absorption chiller manufactured by CLK Corporation (Carrier) including BasX Solutions, LLC seismic modifications. Seismic enhancements and modifications required to address anomalies observed during testing shall be incorporated into the production units. **OSP is limited to units identical to the tested unit.**

Mounting Description: Rigid floor mounted

Applicant Information

Applicant Company Name: Tobolski Watkins Engineering, Inc.

Contact Person: Derrick Watkins, PhD, SE

Mailing Address: 9246 Lightwave Ave, Suite 140, San Diego, CA 92123

Telephone: (858) 381-5843

Email: [dwatkins@tobolskiwatkins.com](mailto:dwatkins@tobolskiwatkins.com)

I hereby agree to reimburse the Office of Statewide Health Planning and Development review fees in accordance with the California Administrative Code, 2013.


Signature of Applicant:

Date: 12/03/13

Title: Executive Vice President

Company Name: Tobolski Watkins Engineering, Inc.

"Access to Safe, Quality Healthcare Environments that Meet California's Diverse and Dynamic Needs"





**OFFICE OF STATEWIDE HEALTH PLANNING AND DEVELOPMENT  
FACILITIES DEVELOPMENT DIVISION**

**California Licensed Structural Engineer Responsible for the Engineering and Test Report(s)**

Company Name: Tobolski Watkins Engineering, Inc.

Name: Derrick Watkins, PhD, SE California License Number: S 5257

Mailing Address: 9246 Lightwave Avenue, Suite 140, San Diego, CA 92123

Telephone: (858) 381-5843 Email: [dwatkins@tobolskiwatkins.com](mailto:dwatkins@tobolskiwatkins.com)

**Supports and Attachments Preapproval**

- Supports and attachments are preapproved under OPM- \_\_\_\_\_  
(Separate application for OSHPD Preapproval of Manufacturer's Certification (OPM) of Supports and attachments is required)
- Supports and attachments are not preapproved

**Certification Method**

- Testing in accordance with:  ICC-ES AC156
- Other (Please Specify): \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_


**Testing Laboratory**

Company Name: Environmental Testing Laboratory, Inc.

Contact Name: Paul E. Little

Mailing Address: 11034 Indian Trail Dallas, TX 75229

Telephone: (972) 247-9657 Email: paul@etldallas.com





**OFFICE OF STATEWIDE HEALTH PLANNING AND DEVELOPMENT  
FACILITIES DEVELOPMENT DIVISION**

**Seismic Parameters**

Design in accordance with ASCE 7-10 Chapter 13:  Yes  No

Design Basis of Equipment or Components ( $F_p/W_p$ ) = 1.15 (z/h = 0) and 1.58 (z/h = 1.0)

$S_{DS}$  (Design spectral response acceleration at short period, g) = 2.56g (z/h = 0) and 2.20g (z/h = 1.0)

$a_p$  (In-structure equipment or component amplification factor) = 1.0

$R_p$  (Equipment or component response modification factor) = 2.5

$\Omega_0$  (System overstrength factor) = 2.5

$I_p$  (Importance factor) = 1.5

z/h (Height factor ratio) = 0.0 ( $S_{DS} = 2.56g$ ) and 1.0 ( $S_{DS} = 2.20g$ )

Equipment or Component Natural Frequencies (Hz) = 5.12 Hz F-B; 4.49 Hz S-S; 19.15 Hz V

Overall dimensions and weight (or range thereof) = 145.0" x 79.5" x 82.0" – 19,731 lbs

Equipment or Components @ grade designed in accordance with ASCE 7-10 Chapter 15:  Yes  No

Design Basis of Equipment or Components (V/W) = \_\_\_\_\_

$S_{DS}$  (Design spectral response acceleration at short period, g) = \_\_\_\_\_

$S_{D1}$  (Design spectral response acceleration at 1 second period, g) = \_\_\_\_\_

R (Response modification coefficient) = \_\_\_\_\_

$\Omega_0$  (System overstrength factor) = \_\_\_\_\_

$C_d$  (Deflection amplification factor) = \_\_\_\_\_

$I_p$  (Importance factor) = 1.5

Height to Center of Gravity above base = \_\_\_\_\_

Equipment or Component Natural Frequencies (Hz) = \_\_\_\_\_

Overall dimensions and weight (or range thereof) = \_\_\_\_\_

Tank(s) designed in accordance with ASME BPVC, 2010:  Yes  No

**List of Attachments Supporting Special Seismic Certification**

Test Report(s)  Drawings  Calculations  Manufacturer's Catalog

Other(s) (Please Specify): Attachments

**OSHPD Approval (For Office Use Only) – Approval Expires on December 31, 2019**


Signature:  Date: January 17, 2014

Print Name: Timothy J. Piland Title: SSE

Special Seismic Certification Valid Up to :  $S_{DS}$  (g) = See Application z/h = See Application

Condition of Approval (if applicable): **OSP is limited to units identical to the tested unit.**

\*Access to Safe, Quality Healthcare Environments that Meet California's Diverse and Dynamic Needs\*







**UUT - 1**

## UNIT UNDER TEST (UUT) Summary Sheet

TWEI Project No.: 2012-0509-CO-002

**Manufacturer:** BasX Solutions, LLC

**Model Line:** Seismically Modified Absorption Chiller

**Model Number:** JAS-REEV-TOB-16DNP 018L0000S

**Product Construction Summary:**  
Model number uniquely identifies the unit tested. Chiller manufactured by CLK Corporation with BasX Solutions, LLC seismic modifications.

**Options/Subcomponent Summary:**  
None.

### UUT Properties

Weight (lb)	Dimensions (in)			Lowest Natural Frequency (Hz)		
	Depth	Width	Height	Front-Back	Side-Side	Vertical
19,731	145.0	79.5	82.0	5.12	4.49	19.15

### UUT Highest Passed Seismic Run Information

Building Code	Test Criteria	S <sub>ds</sub>	z/h	I <sub>p</sub>	A <sub>FLX-H</sub>	A <sub>RIG-H</sub>	A <sub>FLX-V</sub>	A <sub>RIG-V</sub>
CBC 2013	ICC-ES AC 156	2.56g	0.0	1.5	2.56g	1.92g	1.71g	0.68g
		2.20g	1.0	1.5	3.52g	2.64g	1.47g	0.59g

**Test Mounting Details:**



Unit was tested full of contents per operational condition.  
The unit is mounted to the seismic table using (16) - 3" long - 5/16" fillet welds.  
Unit maintained structural integrity and remained functional per manufacturer's requirements.

© 2010 Tobolski Watkins Engineering, Inc.