



**OFFICE OF STATEWIDE HEALTH PLANNING AND DEVELOPMENT
FACILITIES DEVELOPMENT DIVISION**

**APPLICATION FOR OSHPD SPECIAL SEISMIC
CERTIFICATION PREAPPROVAL (OSP)**

OFFICE USE ONLY

APPLICATION #: OSP – 0598 – 10

OSHPD Special Seismic Certification Preapproval (OSP)

Type: New Renewal

Manufacturer Information

Manufacturer: Honeywell Building Technologies

Manufacturer's Technical Representative: Rahul Kousik, Project Manager

Mailing Address: 22 Centerpointe Drive, Suite 100, La Palma, CA 90623

Telephone: 425-628-8401

Email: rahul.kousik@honeywell.com

Product Information

Product Name: Custom Control Panels

Product Type: Control Panels

Product Model Number: See attached

(List all unique product identification numbers and/or part numbers)

General Description: Control panels containing UPS, HMI, I/O Modules

Mounting Description: Units are rigid or flexibly wall mounted, may be wall surface mounted on any vertical surface.

Applicant Information

Applicant Company Name: The VMC Group

Contact Person: John Giuliano

Mailing Address: 113 Main Street, Bloomingdale, NJ 07403

Telephone: (973) 838-1780

Email: john.giuliano@thvmcgroup.com

I hereby agree to reimburse the Office of Statewide Health Planning and Development review fees in accordance with the California Administrative Code, 2016.


Signature of Applicant: _____

Date: 3/13/19

Title: President

Company Name: The VMC Group

"Access to Safe, Quality Healthcare Environments that Meet California's Diverse and Dynamic Needs"





**OFFICE OF STATEWIDE HEALTH PLANNING AND DEVELOPMENT
FACILITIES DEVELOPMENT DIVISION**

California Licensed Structural Engineer Responsible for the Engineering and Test Report(s)

Company Name: The VMC Group

Name: Kenneth Tarlow California License Number: SE-2851

Mailing Address: 113 Main Street, Bloomingdale, NJ 07403

Telephone: (973) 838-1780 Email: ken.tarlow@thevmcgroup.com

Supports and Attachments Preapproval

- Supports and attachments are preapproved under OPM- _____
(Separate application for OSHPD Preapproval of Manufacturer's Certification (OPM) of Supports and attachments is required)
- Supports and attachments are not preapproved

Certification Method

- Testing in accordance with: ICC-ES AC156
- Other (Please Specify): _____



Testing Laboratory

Company Name: DCL Labs

Contact Name: Josh Sailer, Laboratory Manager

Mailing Address: 1315 Greg Street, Suite 109, Sparks, NV 89431

Telephone: (775) 358-5085 Email: josh@shaketest.com





OFFICE OF STATEWIDE HEALTH PLANNING AND DEVELOPMENT
FACILITIES DEVELOPMENT DIVISION

Seismic Parameters

Design in accordance with ASCE 7-10 Chapter 13: [X] Yes [] No

Design Basis of Equipment or Components (Fp/Wp) = 1.50

Sds (Design spectral response acceleration at short period, g) = 2.00

ap (In-structure equipment or component amplification factor) = 2.5

Rp (Equipment or component response modification factor) = 6.0

Omega_0 (System overstrength factor) = 2.0

Ip (Importance factor) = 1.5

z/h (Height factor ratio) = 1

Equipment or Component Natural Frequencies (Hz) = See attachment

Overall dimensions and weight (or range thereof) = See attachment

Equipment or Components @ grade designed in accordance with ASCE 7-10 Chapter 15: [] Yes [X] No

Design Basis of Equipment or Components (V/W) =

Sds (Design spectral response acceleration at short period, g) =

Sd1 (Design spectral response acceleration at 1 second period, g) =

R (Response modification coefficient) =

Omega_0 (System overstrength factor) =

Cd (Deflection amplification factor) =

Ip (Importance factor) = 1.5

Height to Center of Gravity above base =

Equipment or Component Natural Frequencies (Hz) =

Overall dimensions and weight (or range thereof) =

Tank(s) designed in accordance with ASME BPVC, 2015: [] Yes [X] No

List of Attachments Supporting Special Seismic Certification

[X] Test Report(s) [X] Drawings [] Calculations [] Manufacturer's Catalog

[] Other(s) (Please Specify):

OSHPD Approval (For Office Use Only) - Approval Expires on December 31, 2025

Signature: [Handwritten Signature]

Date: February 7, 2020

Print Name: Timothy J. Piland

Title: SSE

Special Seismic Certification Valid Up to: Sds (g) = 2.00

z/h = 1

Condition of Approval (if applicable):




Table 1 - Certified Components

| Model Number | Manufacturer | Max. Dimensions (in) | | | Max. Weight (lb) | Mounting | Unit |
|---------------------------|--------------|----------------------|--------------|--------------|------------------|---------------------------------|--------------|
| | | Depth | Width | Height | | | |
| HWLDDCPNLxxx ¹ | Honeywell | 6.0 to 8.0 | 20.0 to 24.0 | 24.0 to 30.0 | 50 to 90 | Rigid and Isolated Wall Mounted | Extrapolated |
| HWLDDCPNL0001 | Honeywell | 8.0 | 24.0 | 30.0 | 90 | Rigid and Isolated Wall Mounted | UUT 1a,b |
| HWLDDCPNLxxx ¹ | Honeywell | 8.0 to 10.0 | 24.0 to 36.0 | 30.0 to 48.0 | 90 to 210 | Rigid and Isolated Wall Mounted | Interpolated |
| HWLDDCPNL0002 | Honeywell | 10.0 | 36.0 | 48.0 | 210 | Rigid and Isolated Wall Mounted | UUT 2a,b |

Notes:

1. "xxx" denotes Honeywell serial number, range between 0001-9999




Table 2 - Certified Subcomponents - Enclosures

| Subcomponent (Manufacturer) | Model Number | Description | Material | NEMA Rating | Approximate Weight (lb) | Unit |
|-----------------------------|--------------|--------------|--------------|-------------|-------------------------|--------------|
| Enclosures (Hoffman) | A-24N20ALPP | 24 X 20 X 6 | Carbon Steel | 1 | 30.0 | Extrapolated |
| | A-24N24ALPP | 24 X 24 X 6 | Carbon Steel | 1 | 40.0 | Extrapolated |
| | C-SD24206-P | 24 X 20 X 6 | Carbon Steel | 4 | 29.4 | Extrapolated |
| | C-SD24246-P | 24 X 24 X 6 | Carbon Steel | 4 | 36.9 | Extrapolated |
| | C-SD30248-P | 30 X 24 X 8 | Carbon Steel | 4 | 48.0 | Extrapolated |
| | A-30N24BLPP | 30 X 24 X 8 | Carbon Steel | 1 | 50.5 | UUT1a, b |
| | A-36N24BLPP | 36 X 24 X 8 | Carbon Steel | 1 | 54.2 | Interpolated |
| | C-SD36248-P | 36 X 24 X 8 | Carbon Steel | 4 | 57.0 | Interpolated |
| | A-36N30BLPP | 36 X 30 X 8 | Carbon Steel | 1 | 68.0 | Interpolated |
| | C-SD36308-P | 36 X 30 X 8 | Carbon Steel | 4 | 77.0 | Interpolated |
| | C-SD423610-P | 42 X 36 X 10 | Carbon Steel | 4 | 107.0 | Interpolated |
| | A-42N3609-P | 42 X 36 X 9 | Carbon Steel | 1 | 122.0 | Interpolated |
| | C-SD483610-P | 48 X 36 X 10 | Carbon Steel | 4 | 124.0 | UUT 2a,b |



Table 3 - Certified Subcomponents

| Subcomponent (Manufacturer) | Model Number | Description | Material | Approximate Weight (lb) | Unit |
|-----------------------------|---|---|--|-------------------------|-----------------------------------|
| Controller (Honeywell) | CPO-JACE | CPO Jace Controller | Plastic, PCB | 2.0 | UUT 2a,b |
| | CPO-CORE | BACnet Router Controller | Plastic, PCB | 2.0 | Same as UUT 1 & 2a,b ¹ |
| | XCL8010A | XL800 LON Controller | Plastic, PCB | 2.0 | Same as UUT 1 & 2a,b ¹ |
| | CP-SPC | Small point controllers | Plastic, PCB | 2.0 | Same as UUT 1 & 2a,b ¹ |
| | CP-IPC | Plant Controller | Plastic, PCB | 2.0 | Same as UUT 1 & 2a,b ¹ |
| | CPO-RL5 | Plant Controller | Plastic, PCB | 2.0 | Same as UUT 1 & 2a,b ¹ |
| | CPO-RL7U | Plant Controller | Plastic, PCB | 2.0 | Same as UUT 1 & 2a,b ¹ |
| | CPO-PC-6A | Plant Controller | Plastic, PCB | 2.0 | UUT 2a,b |
| | CPO-PC-400A | Plant Controller | Plastic, PCB | 2.0 | UUT 1a,b |
| IO Modules (Honeywell) | XF821A | Analog Input Module | Plastic, PCB | 0.4 | UUT 1a,b |
| | XFR822A | Analog Output Module w/Override | Plastic, PCB | 0.4 | UUT 1a,b |
| | XF822A | Analog Output Module | Plastic, PCB | 0.4 | UUT 1a,b |
| | XF823A | Digital Input Module | Plastic, PCB | 0.4 | UUT 1a,b |
| | XFR824A | Relay Output Module w/Override | Plastic, PCB | 0.4 | UUT 1a,b |
| | XF824A | Relay Output Module | Plastic, PCB | 0.4 | UUT 1a,b |
| | XSU821-22 | Analog I/O Module Base | Plastic, PCB | 0.4 | UUT 1a,b |
| | XSU-823 | Digital Input Module Base | Plastic, PCB | 0.4 | UUT 1a,b |
| | XSU824-25 | Digital Output Module Base | Plastic, PCB | 0.4 | UUT 1a,b |
| | CP-EXPIO | Mixed I/O Module | Plastic, PCB | 1.0 | UUT 2a,b |
| | CPO-IO830A | Mixed I/O Module | Plastic, PCB | 1.0 | UUT 2a,b |
| | CPO-DIO | Digital I/O Module | Plastic, PCB | 1.4 | UUT 2a,b |
| | NPB-8000-232 | Jace 8000 Controller - add on single port RS-232 Module | Plastic, PCB | 1.5 | UUT 2a,b |
| | NPB-8000-LON | Jace 8000 controller - add on single port LON FTT10A Module | Plastic, PCB | 1.5 | UUT 2a,b |
| | T-IO-34-485 | Remote IO Module | Plastic, PCB | 1.5 | UUT 2a,b |
| | T-IO-16-485 | Remote IO Module | Plastic, PCB | 1.5 | UUT 2a,b |
| NPB-8000-2X-485 | JACE 8000 controller - add on dual port RS-485 module | Plastic, PCB | 1.5 | UUT 2a,b | |
| UPS (Sola) | SDU500 | Uninterruptable Power Supply | LCP (Liquid Crystal Polymer) Housing, Sealed Batteries | 4.9 | UUT 1 & 2a,b |

Notes:

1. Only differs by software

Table 3 - Certified Subcomponents Continued


| Subcomponent (Manufacturer) | Model Number | Description | Material | Approximate Weight (lb) | Unit |
|--------------------------------------|-----------------------|---|-----------------|-------------------------|---------------------------|
| AC Power Supply (Functional Devices) | TR40VA001 | 40VA | Copper Winding | 2.0 | Extrapolated |
| | TR50VA001 | 50VA | Copper Winding | 2.0 | Extrapolated |
| | TR75VA001 | 75VA | Copper Winding | 3.4 | Extrapolated |
| | TR100VA001 | 100VA | Copper Winding | 3.8 | UUT 1a,b |
| | PSH75A | 75VA multi-tap, UL Class 2 | Copper Winding | 4.5 | Interpolated |
| | PSH100AB10 | 100VA,UL Class 2 | Copper Winding | 4.6 | Interpolated |
| | TR150VA001 | 150VA | Copper Winding | 5.0 | Interpolated |
| | PSH75A100AB10 | 75A and 100VA multi-tap, UL Class 2 | Copper Winding | 8.5 | Interpolated |
| | PSH100A100AB10 | (2) 100VA multitap, UL Class 2 | Copper Winding | 8.6 | UUT 2a,b |
| DC Power Supply (IDEC) | PS5R-VA24 | Switching Power Supplies - PS5R-V 7.5W | Plastic Housing | 0.3 | Extrapolated |
| | PS5R-VB24 | Switching Power Supplies - PS5R-V 15W | Plastic Housing | 0.3 | Extrapolated |
| | PS5R-VC24 | Switching Power Supplies - PS5R-V 30W | Plastic Housing | 0.3 | UUT 1a,b |
| | PS5R-VD24 | Switching Power Supplies - PS5R-V 60W | Plastic Housing | 0.6 | Interpolated |
| | PS5R-VE24 | Switching Power Supplies - PS5R-V 90W | Plastic Housing | 0.7 | Interpolated |
| | PS5R-VF24 | Switching Power Supplies - PS5R-V 120W | Plastic Housing | 1.0 | Interpolated |
| | PS5R-VG24 | Switching Power Supplies - PS5R-V 240W | Plastic Housing | 2.1 | UUT 2a,b |
| Control Point Open- HMI (Honeywell) | CPO-HMI610L | CPO Panel Mount HMI | Plastic, PCB | 2.0 | UUT 2a,b |
| | CPO-MMI | CPO MMI | Plastic, PCB | 2.0 | UUT 1a,b |
| Router (Loytec) | LIP-3ECTC (1 Port) | Loytec Router - 1 port | Plastic, PCB | 0.5 | Extrapolated |
| | LIP-33ECTC (2 Port) | Loytec Router - 2 port | Plastic, PCB | 0.5 | UUT 1a,b |
| | LIP-333ECTC (1 Port) | Loytec Router -3 port | Plastic, PCB | 0.5 | Interpolated |
| | LIP-3333ECTC (1 Port) | Loytec Router - 4 port | Plastic, PCB | 0.7 | UUT 2a,b |
| Signal Converter (ABB) | ABB-cc/e STD | Signal Converter | Plastic, PCB | 0.3 | UUT 2a,b |
| Signal Converter (Kele) | VTI-1-D | Single Output Signal Converter | Plastic, PCB | 0.3 | Extrapolated ¹ |
| | VTI-2-D | Dual Output Signal Converter | Plastic, PCB | 0.3 | UUT 1a,b |
| Panel Relay (IDEC) | RH1BULCAC24V | 24 VAC Single Pole - Double Throw | Plastic | 0.1 | Extrapolated |
| | RH2BULCAC24V | 24 VAC Double Pole - Double Throw | Plastic | 0.1 | UUT 1a,b |
| | RH3BULCAC24V | 24 VAC Three Pole - Double Throw | Plastic | 0.1 | Interpolated |
| | RH4BULCAC24V | 24 VAC Four Pole - Double Throw | Plastic | 0.2 | UUT 2a,b |
| Surge Protector (Ditek) | DTK120-HW | Surge Suppressor | Plastic | 0.6 | UUT 1 & 2a,b |
| Circuit Breakers (CBI) | QL-5 | Circuit Breaker | Plastic | 0.3 | Extrapolated |
| | QL-10 | Circuit Breaker | Plastic | 0.3 | UUT 1a,b |
| | QL-15 | Circuit Breaker | Plastic | 0.3 | Interpolated |
| | QL-20 | Circuit Breaker | Plastic | 0.3 | Interpolated |
| | QL-25 | Circuit Breaker | Plastic | 0.3 | UUT 2a,b |
| Ethernet Switch (MOXA) | Moxa EDS-205 | MOXA, DIN Rail Mounted Ethernet switch - 5 port | Plastic, PCB | 0.3 | UUT 1a,b |
| | Moxa EDS-208 | MOXA, DIN Rail Mounted Ethernet switch - 8 port | Plastic, PCB | 0.4 | UUT 2a,b |

Notes:

1. Single output is depopulated version of dual output

Table 4 - Tested Units

| Model Number | Manufacturer | Dimensions (in) | | | Weight (lb) | Mounting | Unit |
|---------------|--------------|-----------------|-------|--------|-------------|---------------|--------|
| | | Depth | Width | Height | | | |
| HWLDDCPNL0001 | Honeywell | 8.0 | 24.0 | 30.0 | 90 | Rigid Wall | UUT 1a |
| HWLDDCPNL0001 | Honeywell | 8.0 | 24.0 | 30.0 | 90 | Isolated Wall | UUT1b |
| HWLDDCPNL0002 | Honeywell | 10.0 | 36.0 | 48.0 | 210 | Rigid Wall | UUT2a |
| HWLDDCPNL0002 | Honeywell | 10.0 | 36.0 | 48.0 | 210 | Isolated Wall | UUT2b |



UUT1a

UNIT UNDER TEST (UUT) Summary Sheet

Manufacturer: Honeywell Building Technologies

Product Line: Control Panel

Model Number: HWLDDCPNL0001

Product Construction Summary: NEMA 1 Carbon Steel Panel

Options / Component Summary: Custom control panel with plant controller, UPS, HMI, and various I/O modules

Note: The UUT was operational before and after shaking and was full of operating content during the tests. The structural integrity of the component and attachment system and force-resisting systems was maintained.

UUT Properties

| Operating Weight (lb) | Dimensions (in) | | | | Lowest Natural Frequency (Hz) | | |
|-----------------------|-----------------|--------|-------|--------|-------------------------------|-----------|----------|
| | | Length | Width | Height | Front-Back | Side-Side | Vertical |
| 90 | UUT1a | 8.0 | 24.0 | 30.0 | N/A | N/A | N/A |

Seismic Test Parameters

| Building Code | Test Criteria | Sds (g) | z/h | Ip | Aflx-H (g) | Arig-H (g) | Aflx-V (g) | Arig-V (g) |
|---------------|---------------|---------|-----|-----|------------|------------|------------|------------|
| CBC 2016 | ICC-ES AC156 | 2.00 | 1.0 | 1.5 | 3.20 | 2.40 | 1.33 | 0.54 |

Unit Mounting Description:



UUT1a was rigid wall mounted to the DCL wall interface fixture with (4) 3/8" diameter, grade 5, bolts and washers into 12ga strut with a 3" x 3" x 3/16" low carbon steel plate washer between the back of the unit and the strut. Bolts were spaced at approximately 17" in width and 28" in height on center.

UUT1b

UNIT UNDER TEST (UUT) Summary Sheet

Manufacturer: Honeywell Building Technologies

Product Line: Control Panel

Model Number: HWLDDCPNL0001

Product Construction Summary: NEMA 1 Carbon Steel Panel

Options / Component Summary: Custom control panel with plant controller, UPS, HMI, and various I/O modules

Note: The UUT was operational before and after shaking and was full of operating content during the tests. The structural integrity of the component and attachment system and force-resisting systems was maintained.


UUT Properties

| Operating Weight (lb) | Dimensions (in) | | | Lowest Natural Frequency (Hz) | | | |
|-----------------------|-----------------|-------|--------|-------------------------------|-----------|----------|-----|
| | Length | Width | Height | Front-Back | Side-Side | Vertical | |
| 90 | UUT1b | 8.0 | 24.0 | 30.0 | N/A | N/A | N/A |

Seismic Test Parameters

| Building Code | Test Criteria | Sds (g) | z/h | Ip | Aflx-H (g) | Arig-H (g) | Aflx-V (g) | Arig-V (g) |
|---------------|---------------|---------|-----|-----|------------|------------|------------|------------|
| CBC 2016 | ICC-ES AC156 | 2.00 | 1.0 | 1.5 | 3.20 | 2.40 | 1.33 | 0.54 |

Unit Mounting Description:



UUT1b was isolated wall mounted to the DCL wall interface fixture with (4) 3/8" diameter, grade 5, bolts and washers into 12ga strut with a 3" x 3" x 3/16" low carbon steel plate washer between the back of the unit and the strut. Bolts were spaced at approximately 17" in width and 28" in height on center. The wall fixture was mounted on (4) VMC MSSH-1E-1400N isolators.

UUT2a

UNIT UNDER TEST (UUT) Summary Sheet

Manufacturer: Honeywell Building Technologies

Product Line: Control Panel

Model Number: HWLDDCPNL0002

Product Construction Summary: NEMA 4 Carbon Steel Panel

Options / Component Summary: Custom control panel with plant controller, UPS, HMI, and various I/O modules

Note: The UUT was operational before and after shaking and was full of operating content during the tests. The structural integrity of the component and attachment system and force-resisting systems was maintained.

UUT Properties

| Operating Weight (lb) | Dimensions (in) | | | | Lowest Natural Frequency (Hz) | | |
|-----------------------|-----------------|--------|-------|--------|-------------------------------|-----------|----------|
| | | Length | Width | Height | Front-Back | Side-Side | Vertical |
| 210 | UUT2a | 10.0 | 36.0 | 48.0 | N/A | N/A | N/A |

Seismic Test Parameters

| Building Code | Test Criteria | Sds (g) | z/h | Ip | Aflx-H (g) | Arig-H (g) | Aflx-V (g) | Arig-V (g) |
|---------------|---------------|---------|-----|-----|------------|------------|------------|------------|
| CBC 2016 | ICC-ES AC156 | 2.00 | 1.0 | 1.5 | 3.20 | 2.40 | 1.33 | 0.54 |

Unit Mounting Description:



UUT2a was rigid wall mounted to the DCL wall interface fixture with (4) 3/8" diameter, grade 5, bolts and washers into 12ga strut with a 3" x 3" x 3/16" low carbon steel plate washer between the back of the unit and the strut. Bolts were spaced at approximately 35" in width and 47" in height on center.

UUT2b

UNIT UNDER TEST (UUT) Summary Sheet

Manufacturer: Honeywell Building Technologies

Product Line: Control Panel

Model Number: HWLDDCPNL0002

Product Construction Summary: NEMA 4 Carbon Steel Panel

Options / Component Summary: Custom control panel with plant controller, UPS, HMI, and various I/O modules

Note: The UUT was operational before and after shaking and was full of operating content during the tests. The structural integrity of the component and attachment system and force-resisting systems was maintained.

UUT Properties

| Operating Weight (lb) | Dimensions (in) | | | Lowest Natural Frequency (Hz) | | | |
|-----------------------|-----------------|--------|-------|-------------------------------|------------|-----------|----------|
| | | Length | Width | Height | Front-Back | Side-Side | Vertical |
| 210 | UUT2b | 10.0 | 36.0 | 48.0 | N/A | N/A | N/A |

Seismic Test Parameters

| Building Code | Test Criteria | Sds (g) | z/h | Ip | Aflx-H (g) | Arig-H (g) | Aflx-V (g) | Arig-V (g) |
|---------------|---------------|---------|-----|-----|------------|------------|------------|------------|
| CBC 2016 | ICC-ES AC156 | 2.00 | 1.0 | 1.5 | 3.20 | 2.40 | 1.33 | 0.54 |

Unit Mounting Description:



UUT2b was isolated wall mounted to the DCL wall interface fixture with (4) 3/8" diameter, grade 5, bolts and washers into 12ga strut with a 3" x 3" x 3/16" low carbon steel plate washer between the back of the unit and the strut. Bolts were spaced at approximately 35" in width and 47" in height on center. The wall fixture was mounted on (4) VMC MSSH-1E-1400N isolators.