



# APPLICATION FOR PREAPPROVAL SPECIAL SEISMIC CERTIFICATION OF EQUIPMENT AND COMPONENTS

For Office Use Only

|   |
|---|
| <p><b>APPLICATION NO.</b></p> <p><b>OSP – 0106-10</b></p> |
|---|

Check whether application is: NEW  RENEWAL

1.0 General Electric Company Amit Patel  
*Manufacturer* *Manufacturer's Technical Representative*

41 Woodford Ave.; Plainville, CT 06062  
*Mailing Address*

860-747-7693 amit.patel2@ge.com  
*Telephone* *E-mail Address*

2.0 Limitamp MV MCC Medium Voltage Motor Control Centers  
*Product Name* *Product Type*

CR 194 (Controllers) & IC1074 (Loadbreak Switches); auxiliary units have varying product numbers  
*Product Model No. (List all unique product identification numbers and/or serial numbers)*

*General Description: Limitamp MV Motor Control Centers are floor-mounted units consisting of MCC sections, auxiliary sections, and loadbreak switch sections. They are typically installed indoor in multiple sections. Outdoor installation enclosures are not addressed.*

3.0 General Electric Company Amit Patel  
*Applicant Company Name* *Contact Person*

41 Woodford Ave.; Plainville, CT 06062  
*Mailing Address*

860-747-7693 amit.patel2@ge.com  
*Telephone* *E-mail Address*

I hereby agree to reimburse the Office of Statewide Health Planning and Development for the actual costs incurred by the department for review.

*Amit Patel*

*Signature of Applicant*

8/12/2010

*Date*

Systems Engineer

*Title*

General Electric Company

*Company Name*

1/5



Registered Design Professional Preparing the Report

4.0 \_\_\_\_\_  
**W. E. Gundy & Associates**  
 \_\_\_\_\_  
*Company Name*

\_\_\_\_\_ **William E. Gundy** \_\_\_\_\_ **CE-26539**  
 \_\_\_\_\_  
*Contact Name* *California License Number*

\_\_\_\_\_ **P.O. Box 2900; Hailey, ID 83333** \_\_\_\_\_  
 \_\_\_\_\_  
*Mailing Address*

\_\_\_\_\_ **208-788-5989** \_\_\_\_\_ **wegai@mindspring.com**  
 \_\_\_\_\_  
*Telephone* *E-mail Address*

California Licensed Structural Engineer Review and Acceptance of the Report

5.0 \_\_\_\_\_  
**Forell-Elsesser Engineers, Inc.**  
 \_\_\_\_\_  
*Company Name*

\_\_\_\_\_ **Marco Scanu, SE** \_\_\_\_\_ **S4454**  
 \_\_\_\_\_  
*Contact Name* *California License Number*

\_\_\_\_\_ **160 Pine St., 6<sup>th</sup> Flr., San Francisco, CA 94111** \_\_\_\_\_  
 \_\_\_\_\_  
*Mailing Address*

\_\_\_\_\_ **415-837-0700** \_\_\_\_\_ **m.scanu@forell.com**  
 \_\_\_\_\_  
*Telephone* *E-mail Address*

Anchorage Pre-Approval

6.0  Anchorage is pre-approved under OPA-  
 (Separate application for anchorage pre-approval is required)

Anchorage is not Pre-approved

Certification Method

7.0  Testing in accordance with:  ICC-ES AC-156  Other (Please Specify):

\_\_\_\_\_

Analysis

Experience data

Combination of Testing, Analysis, and/or Experience Data (Please Specify):

\_\_\_\_\_

Testing Laboratory (if applicable)

8.0 \_\_\_\_\_  
**Wyle Laboratories** \_\_\_\_\_ **Rod Thornberry**  
 \_\_\_\_\_  
*Company Name* *Contact Name*

\_\_\_\_\_ **7800 Hwy 20, Huntsville, AL 35806** \_\_\_\_\_  
 \_\_\_\_\_  
*Mailing Address*

\_\_\_\_\_ **(256) 837-4411** \_\_\_\_\_  
 \_\_\_\_\_  
*Telephone* *E-mail:*

216



**Approval Parameters**

9.0

Design in accordance with ASCE 7-05 Chapter 13:  Yes  No

Design Basis of Equipment or Components ( $F_p/W_p$ ) = 1.38g

$S_{DS}$  (Spectral response acceleration at short period) = 1.84g

$a_p$  (In-structure equipment or component amplification factor) = 2.5

$R_p$  (Equipment or component response modification factor) = 6.0

$I_p$  (Importance factor) = 1.5

$z/h$  (Height factor ratio) = 1.0

Equipment or Component fundamental period(s) = See attachment, "Resonant Frequency Summary"

Building period limits (if any) = n/a

Overall dimensions and weight (or range thereof) = See attachment, "Product Range Summary"

Equipment or Components @ grade designed in accordance with ASCE 7-05 Chapter 15:  Yes  No

Design Basis of Equipment or Components ( $V/W$ ) =

$S_{DS}$  (Spectral response acceleration at short period) =

$S_1$  (Spectral response acceleration at 1 second period) =

$R$  (Response modification coefficient) = 1.0

$\Omega_0$  (System overstrength factor) = 1.0

$C_d$  (Deflection amplification factor) = 1.0

$I_p$  (Importance factor) = 1.5

Height to Center of Gravity above base =

Equipment or Component fundamental period(s) = Sec

Overall dimensions and weight (or range thereof) =

Tank(s) designed in accordance with ASME BPVC, 2007:  Yes  No

**10.0 List of attachments supporting the special seismic certification of equipment or components:**

- Test Report
- Drawings
- Manufacturer's Catalog
- Calculations
- Other (Please Specify): SE Acceptance Letter, Product Range Summary, CAN2-1708A.5 & AC156 Requirements Checklist

**11.0 OSHPD Approval (For Office Use Only)**

|  |                |  |
|--|----------------|--|
| <p style="text-align: center;">Signature &amp; Date<br/><b>Chris Tokas, SHFR</b></p> <p style="text-align: center;">Name &amp; Title</p> | <p>8/12/10</p> | <p><b>December 31, 2016</b></p> <p style="text-align: center;">Approval Expiration Date</p> <p><math>S_{DS}</math> (g) = <b>1.84</b>      <math>z/h</math> = <b>1.0</b></p> <p style="text-align: center;">Special Seismic Certification Valid Up to</p> |
| <p>Condition of Approval (if any):</p>   |                |  |



OSP APPLICATION  
 GE Industrial Solutions - Limitamp MV Motor Control Centers  
 Product Range Summary

| <b>GE Industrial Solutions - Limitamp MV Motor Control Centers<br/>Product Range Summary</b>  |       |       |        |                     |             |
|---|-------|-------|--------|---------------------|-------------|
|   | Width | Depth | Height | Max. Service Weight | Notes       |
| <b>Motor Control Center - CR 194</b>  |       |       |        |                     |             |
| 400A One High   | 26 in | 30 in | 90 in  | 4,000 lbs           |             |
| 400A One High   | 34 in | 30 in | 90 in  | 4,000 lbs           | (tested)    |
| 400A One High   | 36 in | 30 in | 90 in  | 4,000 lbs           | (tested)    |
| 400A One High   | 40 in | 30 in | 90 in  | 4,000 lbs           |             |
| 800A One High   | 48 in | 30 in | 90 in  | 4,000 lbs           | UUT1        |
| 400A Two High   | 36 in | 30 in | 90 in  | 4,000 lbs           | UUT4        |
| 400A Two High   | 40 in | 30 in | 90 in  | 4,000 lbs           | (tested)    |
| <b>Auxiliary Sections</b>   |       |       |        |                     |             |
| Aux. Enclosure  | 22 in | 30 in | 90 in  | 2,700 lbs           |             |
| Aux. Enclosure  | 32 in | 30 in | 90 in  | 2,700 lbs           | UUT2, UUT1* |
| Aux. Enclosure  | 38 in | 30 in | 90 in  | 2,700 lbs           |             |
| Aux. Enclosure  | 42 in | 30 in | 90 in  | 2,700 lbs           |             |
| Aux. Enclosure  | 44 in | 30 in | 90 in  | 2,700 lbs           |             |
| <b>Loadbreak Switches - IC1704</b>  |       |       |        |                     |             |
| 600A  | 34 in | 30 in | 90 in  | 1,700 lbs           |             |
| 600A  | 38 in | 30 in | 90 in  | 1,700 lbs           |             |
| 600A  | 42 in | 30 in | 90 in  | 1,700 lbs           |             |
| 600A  | 44 in | 30 in | 90 in  | 1,700 lbs           |             |
| 1200A   | 38 in | 30 in | 90 in  | 1,700 lbs           | UUT3        |
| *Between UUT2 and one section of UUT1, there were two 32" Auxiliary Section tests (400A & 800A).  |       |       |        |                     |             |
| **All tested units had indoor enclosures.   |       |       |        |                     |             |
| <b>Anchorage</b>  |       |       |        |                     |             |
| GE Limitamp MV MCC units are rigidly anchored to the floor. Lateral forces are resisted by shear membrane action in the light gauge metal exterior sheathing. Shear is transferred to adjacent metal panels through screws into light gauge metal angle frames, then to light gauge bent metal mounting brackets then through anchorage to concrete pad/slab. |       |       |        |                     |             |

GE Industrial Solutions - Limitamp MV Motor Control Centers  
Resonant Frequency Summary

**GE Industrial Solutions - Limitamp MV Motor Control Centers  
Resonant Frequency Summary**

|            | UUT1 - MCC Starter<br>4,000 lbs |          | UUT2 - Auxiliary<br>1,300 lbs |          | UUT3 - Loadbreak<br>Switch<br>1,000 lbs |          | UUT4 - MCC 2-High<br>w/ Drawout<br>2,000 lbs |          |
|------------|---------------------------------|----------|-------------------------------|----------|---|----------|--|----------|
| Direction  | Frequency                       | Period   | Frequency                     | Period   | Frequency                               | Period   | Frequency                                    | Period   |
| Front-Back | 9.5 Hz                          | 0.11 sec | 10.5 Hz                       | 0.10 sec | 12.0 Hz                                 | 0.08 sec | 9.0 Hz                                       | 0.11 sec |
| Side-Side  | 11.0 Hz                         | 0.09 sec | 16.0 Hz                       | 0.06 sec | 14.0 Hz                                 | 0.07 sec | 8.5 Hz                                       | 0.12 sec |
| Vertical   | 15.0 Hz                         | 0.07 sec | 18.0 Hz                       | 0.06 sec | 16.0 Hz                                 | 0.06 sec | 22.5 Hz                                      | 0.04 sec |