



Garfield Medical Center

AHMC Healthcare

Re: AB 2190 Attestation
Garfield Medical Center
525 N Garfield Ave
Monterey Park, CA 961754

Dear Carl Scheuerman
Compliance Officer
Seismic Compliance Unit
Facility Development Division

Per Assembly Bill 2190 (2018) under Health & Safety Code Section 130066, we are submitting an attestation letter to certify that our board of directors are aware that our hospital have not yet met the 2030 seismic safety requirements for all of its buildings; specifically, one or more of the buildings at our facility has performance ratings less than SPC-3 "or" NPC-5, and therefore our hospital is required to meet the January 1, 2030 deadline for substantial compliance with the seismic safety regulations or standards.

Garfield Medical Center # 11658
525 N Garfield Ave
Monterey Park, CA 961754

(b) Buildings at our facility that have current performance ratings less than SPC-3 or NPC-5 identified as follows:

Building Number	Building Name	Performance Ratings	
BLD-01934	Main Hospital	SPC.2	NPC.3
BLD-01935	Nursery/Post-Partum	SPC.2	NPC.3
BLD-01936	Emergency Wing	SPC.2	NPC.3
BLD-0193	O.B. Pavilion	SPC.4	NPC.4
BLD-01937	O.B. Addition	SPC.4	NPC.4
BLD-01939	Cath Lab	SPC.4	NPC.4
BLD-03427	ER Addition	SPC.4	NPC.5
BLD-03428	Extended Service Canopy	SPC.4	NPC.3
BLD-03429	Service Canopy	SPC.4	NPC.3
BLD-06302	Medical Gas Enclosure	SPC.N/A	NPC.4

Please contact us if you have any questions. 562-818-6389
Sincerely,

A handwritten signature in black ink, consisting of several loops and a long horizontal stroke extending to the right.

CEO Patrick Petre
Chair of the Board

Cc: **Martin Rodriguez**