



2025 California Building Standards Code (CBCS 2025)							
Structural Triage Reminder List For OSHPD 1 Facilities							
Item #	Resolution			Requirement(s)	Code(s)	Section(s)	Comment(s)
	Yes	No	N/A				
<b>1.0</b>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<b>Design demand/general requirements</b>			
1.1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Construction documents	CBC	1603A	
1.2	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	General	CBC	1603A.1	
1.3	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Floor live load	CBC	1603A.1.1	
1.4	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Roof live load	CBC	1603A.1.2	
1.5	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Roof snow load	CBC	1603A.1.3	
1.6	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Wind and tornado design data	CBC	1603A.1.4	
1.7	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Earthquake design data	CBC	1603A.1.5	Aligned with ASCE 7-22
1.8	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Geotechnical information	CBC	1603A.1.6	
1.9	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Flood design data	CBC	1603A.1.7	
1.10	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Special loads	CBC	1603A.1.8	
1.11	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Roof rain load data	CBC	1603A.1.9	
1.12	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Unusual construction procedures	CBC	1603A.1.10	
1.13	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	List of equipment and components that require special seismic certification	CBC	1705A.14.3	
1.14	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Deferred submittal list	CAC	7-126	
1.15	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Alternative systems approval	CAC/ CBC	7-104 /104.2.3 & 1617A.1.1	High Priority
1.16	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Project number specified	CAC	7-113	
	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<b>Capacity requirements</b>			
<b>2.0</b>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<b>Steel</b>			
2.1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Design drawings and specification	AISC 341/AISC 360	A4	
2.2	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Connections detailed	CBC	1603A.5.1	
2.3	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Materials identified	CBC	2201A.2	
2.4	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Steel joist drawings	CBC	2207A.4	
<b>3.0</b>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<b>Concrete</b>			
3.1	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Construction documents	CBC	1901A.5	
3.2	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Construction Documents and Design Records	ACI 318	26	
3.3	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Materials identified	CBC	1903A.1	

**2025 California Building Standards Code (CBSC 2025)  
Structural Triage Reminder List For OSHPD 1 Facilities**

Item #	Resolution			Requirement(s)	Code(s)	Section(s)	Comment(s)
	Yes	No	N/A				
<b>4.0</b>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<b>Masonry</b>			
4.1	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Construction Documents and Calculations	TMS 402	1.2	
4.2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Materials identified	CBC	2103A	
<b>5.0</b>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<b>Wood</b>			
5.1	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Drawings and specifications	NDS	1.5	
5.2	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Material Standards and Quality	CBC	2303	
5.3	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Truss design drawings	CBC	2303.4	
<b>6.0</b>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<b>Structural Sealants Glazing and Thermal Barriers Mullions</b>			
6.1	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Sealand Glazing Construction Documents	CBC	2410.1.4	Test Data Required
6.2	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Thermal Barrier Mullion Systems design & tests	CBC	2411	Test Data Required
8.0	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<b>Structural calculations</b>			
8.1	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Calculations substantially complete	CBC	1603A.3	
8.2	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Index with page numbers	CBC	1603A.3	
8.3	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Overall project design basis (basis descriptions, demand parameters, materials, load combinations, etc.)	CBC	1603A.3	
8.4	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Each section (Gravity system, LFRS, foundations, enclosure, etc.) of the calculations preceded by design basis	CBC	1603A.3	
8.4	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Non-structural details and calcs. equipment, light gage framing, etc. adequate and preceded by design basis	CBC	1603A.3	
18.0	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<b>Testing, Inspection, and Observation (TIO) Program</b>			
18.1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Completed TIO form submitted	CBC	1701A.3	
20.0	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<b>Site Data</b>			
20.1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Site data report is submitted	CAC/ CBC	7-117 /1803A.7	Early Submittal
20.2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Site data report is accompanied by project description	CBC	1603A.2	

Note: Reminder list is for fixed base buildings without any unusual requirement.