



OFFICE OF STATEWIDE HEALTH PLANNING AND DEVELOPMENT
FACILITIES DEVELOPMENT DIVISION

APPLICATION FOR OSHPD PREAPPROVAL OF
MANUFACTURER'S CERTIFICATION (OPM)

OFFICE USE ONLY

APPLICATION #: OPM-0255

OSHPD Preapproval of Manufacturer's Certification (OPM)

Type: [X] New [] Renewal/Update

Manufacturer Information

Manufacturer: APC by Schneider-Electric

Manufacturer's Technical Representative: Greg Ivey

Mailing Address: 801 Corporate Centre Drive, O'Fallon, MO 63368

Telephone: (636) 300-2300 Email: greg.ivey@se.com

Product Information

Product Name: NETSHELTER SX

Product Type: Network Equipment Cabinet

Product Model Number: Netshelter SX Cabinet Series (AR3abcXXXX & AR9abcXXXX)

General Description: Data center network equipment cabinet. See OPM drawing sheet SK1a for specific models included in the OPM.

Applicant Information

Applicant Company Name: APC by Schneider-Electric

Contact Person: Greg Ivey

Mailing Address: 801 Corporate Centre Drive, O'Fallon, MO 63368

Telephone: (636) 300-2300 Email: greg.ivey@se.com

Title: Engineering Manager – Rack Systems

Access to Safe, Quality Healthcare Environments that Meet California's Diverse and Dynamic Needs

STATE OF CALIFORNIA – HEALTH AND HUMAN SERVICES AGENCY





**OFFICE OF STATEWIDE HEALTH PLANNING AND DEVELOPMENT
FACILITIES DEVELOPMENT DIVISION**

Registered Design Professional Preparing Engineering Recommendations

Company Name: RMJ STRUCTURAL ENGINEERS
Name: Jayson Haines California License Number: S4801
Mailing Address: 103 Linden Avenue, , South San Francisco, CA 94080
Telephone: (650) 871 -2282 Email: JHaines@rmjse.com

OSHPD Special Seismic Certification Preapproval (OSP)

Special Seismic Certification is preapproved under OSP OSP Number: _____

Certification Method

Testing in accordance with: ICC-ES AC156 FM 1950-16
 Other(s) (Please Specify): _____

*Use of criteria other than those adopted by the California Building Standards Code, 2019 (CBSC 2019) for component supports and attachments are not permitted. For distribution system, interior partition wall, and suspended ceiling seismic bracings, test criteria other than those adopted in the CBSC 2019 may be used when approved by OSHPD prior to testing.

- Analysis
- Experience Data
- Combination of Testing, Analysis, and/or Experience Data (Please Specify): _____

OSHPD Approval

Date: 10/29/2021
Name: Jeffrey Kikumoto Title: Senior Structural Engineer
Condition of Approval (if applicable): _____

"Access to Safe, Quality Healthcare Environments that Meet California's Diverse and Dynamic Needs"

STATE OF CALIFORNIA – HEALTH AND HUMAN SERVICES AGENCY



GENERAL NOTES

DESIGN

1. This OSHPD pre-approval of Manufacturer's Certification (OPM) based on the 2019 CBC. The demand (Design) forces for use with this OPM shall be based on the 2019 CBC.

1. This Document may only be used with the express written consent of the manufacturer listed below for the specific project site and installation location. This document is invalid without such consent.

Design Criteria:

Importance Factor1.5

Maximum Value of $S_{DS}=2.0$, $a_p=1.0$, $R_p=2.5$, $\Omega_0=2.0$ (As req'd for anchorage to concrete), $z/h=0.0$ (Concrete slab on grade), $z/h \leq 0.5$ for raised floor in lower half of building height.

Forces per ASCE 7-16 section 13.3.1, Equations 13.3-1, 13.3-2 & 13.3-3.

Note: For Site Specific S_{DS} , SEOR shall determine appropriate value to be utilized.

Dimensions: Refer to rough concrete surfaces, or top of slab, unless otherwise indicated.

Fasteners Expansion Anchors:

| Anchor Diameter | Concrete Type | Min. f'c (psi) | Anchor Type | ICC Report No. | h_{ef} Min. Embed. | Min. Spacing | Min. Edge Dist. | Min. Conc. Thickness | Torque Test | Direct Tension |
|-----------------|---------------|----------------|-------------------------|----------------|----------------------|--------------|-----------------|----------------------|-------------|----------------|
| 1/2" | Normal Weight | 3,000 | Hilti Kwik Bolt TZ-2 CS | ESR-4266 | 2" | 6" | 24" | 4" | 50 FT-LB | 1902 lb |

This pre-approval allows for up to a maximum of two adjacent concrete slab edges, 24" away minimum. See detail below for additional minimum allowable concrete edge distances. Testing of expansion anchors per 2019 CBC, 1705A.3: After a minimum of 24 hours have elapsed since installation, bolt testing shall be done in the presence of the special inspector and a report of the test results shall be submitted to SEOR and building code enforcement agency. Testing may be, direct pull tension test or torque test of at least 50% of the anchors.

DATE: 10/29/2021

Pre-Approval Conditions:

Drawing package is in accordance with the 2019 California Building Code.

The details are applicable to locations in California where $S_{DS} \leq 2.0$ and $z/h \leq 0.5$. For site specific S_{DS} , SEOR shall determine appropriate value to be utilized.

Anchorage forces shown on the drawings are factored loads that are associated with strength design.

This pre-approval only applies to the supports & attachments of the cabinet unit to the structure.



| | | |
|-----------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------|----------------------------|
| <p>Robinson Meier Juilly & Associates 241 Joaquin Avenue San Leandro CA 94577 510.991.0977</p> | <p>SCHNEIDER ELECTRIC NETSHELTER SX</p> | <p>Job No. 15262</p> |
| | <p>OSHPD CABINET SUPPORTS AND ATTACHMENTS</p> | <p>Sheet No. (SK1)</p> |
| | <p>Signed by JEH Date 10/25/2021</p> | <p>3/12</p> |

RACK MATRIX (Netshelter SX Series)

| Model # | WidthXDepth | Height | U ref. per EIA-310 | Weight | Anchor forces (lbs) | | | |
|------------------|-------------|--------|--------------------------|--------|---------------------|----------------|----------------|----------------|
| | | | | | T _U | V _U | T _U | V _U |
| AR3abc AR9abc | 600x1070 | 658 | 12 | 130 | 1220 | 440 | 625 | 660 |
| | | 924 | 18 | 159 | 1220 | 440 | 625 | 660 |
| | | 1198 | 24 | 196 | 1220 | 440 | 625 | 660 |
| | | 1991 | 42 | 275 | 1220 | 440 | 625 | 660 |
| | | 2124 | 45 | 300 | 1220 | 440 | 625 | 660 |
| | | 2258 | 48 | 327 | 1220 | 440 | 625 | 660 |
| | | 2347 | 50 | 196 | 1220 | 440 | 625 | 660 |
| | | 2436 | 52 | 367 | 1220 | 440 | 625 | 660 |
| | | 2525 | 54 | 389 | 1220 | 440 | 625 | 660 |
| | | 1198 | 24 | 212 | 1220 | 440 | 625 | 660 |
| | 1991 | 42 | 295 | 1220 | 440 | 625 | 660 | |
| | 2124 | 45 | 322 | 1220 | 440 | 625 | 660 | |
| | 2258 | 48 | 350 | 1220 | 440 | 625 | 660 | |
| | 2347 | 50 | 372 | 1220 | 440 | 625 | 660 | |
| | 2436 | 52 | 394 | 1220 | 440 | 625 | 660 | |
| | 2525 | 54 | 417 | 1220 | 440 | 625 | 660 | |
| | 1198 | 24 | 235 | 1220 | 440 | 625 | 660 | |
| | 1991 | 42 | 335 | 1220 | 440 | 625 | 660 | |
| | 2124 | 45 | 365 | 1220 | 440 | 625 | 660 | |
| | 2258 | 48 | 398 | 1220 | 440 | 625 | 660 | |
| | 2347 | 50 | 422 | 1220 | 440 | 625 | 660 | |
| | 2436 | 52 | 447 | 1220 | 440 | 625 | 660 | |
| | 2525 | 54 | 474 | 1220 | 440 | 625 | 660 | |
| | 1198 | 24 | 251 | 1220 | 440 | 625 | 660 | |
| | 1991 | 42 | 355 | 1220 | 440 | 625 | 660 | |
| | 2124 | 45 | 387 | 1220 | 440 | 625 | 660 | |
| | 2258 | 48 | 422 | 1220 | 440 | 625 | 660 | |
| | 2347 | 50 | 447 | 1220 | 440 | 625 | 660 | |
| | 2436 | 52 | 474 | 1220 | 440 | 625 | 660 | |
| | 2525 | 54 | 502 | 1220 | 440 | 625 | 660 | |
| | 1198 | 24 | 249 | 1220 | 440 | 625 | 660 | |
| | 1991 | 42 | 355 | 1220 | 440 | 625 | 660 | |
| | 2124 | 45 | 387 | 1220 | 440 | 625 | 660 | |
| | 2258 | 48 | 422 | 1220 | 440 | 625 | 660 | |
| | 2347 | 50 | 447 | 1220 | 440 | 625 | 660 | |
| | 2436 | 52 | 474 | 1220 | 440 | 625 | 660 | |
| | 2525 | 54 | 502 | 1220 | 440 | 625 | 660 | |
| | 1198 | 24 | 265 | 1220 | 440 | 625 | 660 | |
| | 1991 | 42 | 375 | 1220 | 440 | 625 | 660 | |
| | 2124 | 45 | 409 | 1220 | 440 | 625 | 660 | |
| | 2258 | 48 | 446 | 1220 | 440 | 625 | 660 | |
| | 2347 | 50 | 472 | 1220 | 440 | 625 | 660 | |
| | 2436 | 52 | 501 | 1220 | 440 | 625 | 660 | |
| | 2525 | 54 | 531 | 1220 | 440 | 625 | 660 | |
| | 600x900 | 658 | 12 | 119 | 1220 | 440 | 625 | 660 |
| | 924 | 18 | 148 | 1220 | 440 | 625 | 660 | |
| | 1198 | 24 | 185 | 1220 | 440 | 625 | 660 | |

Maximum anchor value for either a single unit or set of ganged units. 600 mm units must ganged at ground floor; Single 600mm units not allowed at ground floor.

AR3abc and AR9abc Series cabinets defined by:

a denotes depth:
 0 35.4" (900 mm) deep
 1 or 2 42.1" (1070 mm) deep
 3 47.2" (1200 mm) deep

b denotes width:
 0 or 1 23.6" (600mm) wide
 4 or 5 29.5" (750 mm) wide
 8 31.5" (800 mm) wide

c denotes height:
 0, 1 or 2 78.4" (1991 mm) high for 42U
 3 25.9" (658 mm) high for 12U
 4 47.2" (1198 mm) high for 24U
 5 83.6" (2124 mm) high for 45U
 6 36.4" (924 mm) high for 18U
 7 88.9" (2258 mm) high for 48U
 8 95.9" (2436 mm) high for 52U
 9 99.4" (2525 mm) high for 54U

Note: U designations are per EIA-310
 EIA is Electronic Industries Association

SCHNEIDER ELECTRIC CERTIFIES THIS DOCUMENT AS AN OUTLINE DRAWING.
 SIGNATURE: *Greg Ivey*
 PRINT NAME: GREG IVEY
 TITLE: ME MANAGER, RACK SYSTEMS
 DATE: 8/26/2019



U reference is depth of cabinet per Electronic Industries Alliance.

FOR PLAN REFERENCE, SEE SHEET SK4

| | | |
|---------------------------------------------------------------------------------------------------------------------------|---------------------------------------------------|---------------------------|
| <p>Robinson Meier Juilly & Associates</p> <p>241 Joaquin Avenue San Leandro CA 94577 510.991.0977</p> | <p>SCHNEIDER ELECTRIC NETSHELTER SX</p> | <p>Job No. 15262</p> |
| | <p>OSHPD CABINET SUPPORTS AND ATTACHMENTS</p> | <p>Sheet No. SK1a</p> |
| | <p>Signed by JEH Date 10/25/2021</p> | |

06/22/2022 OPM-0255: Reviewed for Code Compliance by Jeffrey Kikumoto 4/12

RESPONSIBILITY OF STRUCTURAL ENGINEER OF RECORD

1. Verify that the concrete meets the requirements of the applicable ICC ESR.
2. Verify that the anchors are at an adequate distance from any slab opening or edges.
3. Verify that all new or existing anchors are at an adequate distance from the anchors shown in this pre-approval. The SEOR shall verify that there is no adverse interaction where other anchors are within 18" or $6 h_{ef}$ from the unit's anchors.
4. Verify the adequacy of the structure to support the weight and forces shown in this pre-approval in addition to all other weights and forces that are imposed on it.
5. Provide any supplementary structure required for strength and stability.
6. Verify that the installation is in conformance with the 2019 CBC and with the notes and details shown in this pre-approval. Verify that the equipment's actual weight, center of gravity location, anchor locations, anchor details and the material and gage of the unit where attachments are made conform with the information shown in this pre-approval.
7. If content weight is less than 33 pcf, maximum live loads permitted shall be posted.

Acceptance Criteria for Expansion Anchors:

Direction Tension Test:

Anchor shall maintain and hold test load of minimum (15) seconds & shall exhibit no discernable movement during the tension test, e.g., as evidenced by loosening of the washer under the nut.


Torque Test:

The applicable torque must be achieved within the following limits: wedge type: 1/2 turn of the nut.

Acceptance Criteria for Bolts thru Concrete on Metal Deck:

- A. Bolts shall be torqued by $\frac{3}{4}$ turn of the nut, after snug tight condition is achieved. Snug tight condition is defined as the tightness required to bring the connected plies into firm contact.
- B. Thru bolt holes size shall be 1/16" larger than bolt size for concrete.
- C. Thru bolts in concrete shall receive Special Inspection and Testing (Through bolts with steel to steel connection in tension do not require tension testing) in accordance with requirements for post-installed concrete anchors.


*If any anchor fails testing, all anchors of the same type shall be tested, which are install by the same trade, not previously tested until twenty (20) consecutive anchors pass, then resume initial test frequency.




TYPICAL CONCRETE
EDGE DETAIL

- Avoid damaging existing steel reinforcing in concrete slab when installing expansion anchors.
- Provide for full thread engagement of nut & washer.



| | | |
|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------|----------------------------|
|  <p>Robinson Meier Juilly & Associates 241 Joaquin Avenue San Leandro CA 94577 510.991.0977</p> | <p>SCHNEIDER ELECTRIC NETSHELTER SX</p> | <p>Job No. 15262</p> |
| | <p>OSHPD CABINET SUPPORTS AND ATTACHMENTS</p> | <p>Sheet No. (SK2)</p> |
| | <p>Signed by JEH Date 10/25/2021</p> | <p>5/12</p> |

SEISMIC SUPPORT, ATTCHMENTS & ANCHORAGE



| | |
|-------------------------------------|-------|
| CONCRETE SLAB | |
| MAX BOLT TENSION, T_u | 1220# |
| MAX BOLT SHEAR, V_u | 440# |
| ALL LOADS INCREASED BY OMEGA FACTOR | |

| | |
|-------------------------------------------------|------|
| CONCRETE FILL OVER METAL DECK | |
| MAX BOLT TENSION, T_u | 625# |
| MAX BOLT SHEAR, V_u | 660# |
| Shear LOADS have been INCREASED BY OMEGA FACTOR | |

FRONT ELEVATION

SIDE ELEVATION

FOR DIMENSIONS "A", "B" & "C", SEE SK4

NOTES:

- DESIGN CENTER OF GRAVITY AT 1/2 THE HEIGHT OF THE UNIT. (NOTE: LOAD CABINET FROM BOTTOM FIRST)
- FORCES ARE DETERMINED PER 2019 CBC AND ITS REFERENCED STANDARDS AND ASCE 7-16 STRENGTH DESIGN. ($S_{ps} \leq 2.0$ (HIGH SEISMIC) 1.0 (LOW SEISMIC), $\alpha_p = 1.0$, $I_p = 1.5$, $R_p = 2.5$, $\Omega_0 = 2.0$, $z/h = 0$ (GROUND LEVEL) & $z/h \leq .5$ (50% OF BLDG. HT.)).
- SEE GENERAL NOTES FOR ALL OTHER CONDITIONS AND LIMITATIONS.
- NETSHELTER SX EXTERIOR CABINET UNIT COVER COMPOSED OF 14 ga COLD ROLLED STEEL 29.4 ksi.
- SIGN MUST BE POSTED INDICATING CABINET TOTAL WT. LIMITS LISTED IN THE TABLE 1.
- WEIGHTS LISTED IN "TABLE 1" APPLY TO ALL UNITS IRRESPECTIVE OF SIZE.
- ARCHITECT OR ENGINEER OF RECORD TO VERIFY THE SPECIFIC CONFIGURATION OF THE COMPONENTS WITHIN THE CABINET COMPLIES WITH C.G. PARAMETERS INDICATED BY NOTE #1.

MAXIMUM CABINET TOTAL WEIGHT (TABLE 1)

| MODEL NUMBER | MAX TOTAL WEIGHT, GROUND FLOOR, SINGLE UNIT* | MAX WEIGHT, GROUND FLOOR, GANGED UNIT* (WEIGHT PER UNIT)** | MAX TOTAL WEIGHT, UPPER FLOOR, SINGLE UNIT | MAX WEIGHT, UPPER FLOOR, GANGED UNIT* (WEIGHT PER UNIT)** |
|-----------------|----------------------------------------------|------------------------------------------------------------|--------------------------------------------|-----------------------------------------------------------|
| DIRECT ON FLOOR | 800 LBS. | 1200 LBS. | N/A | 1100 LBS. |


*MAX WEIGHT IS CABINET AND CONTENTS

**THIS WEIGHT IS PER CABINET IN GANGED CONFIGURATION; NO MAXIMUM ON # OF GANGED UNITS

| MAXIMUM CABINET WEIGHTS | |
|-------------------------|------|
| 600 mm WIDTH | 417# |
| 750 mm WIDTH | 502# |
| 800 mm WIDTH | 531# |

TABLE APPLIES TO 1070 mm AND 1200 mm CABINETS

ALLOWABLE CONTNET WEIGHT IS DIFFERENCE BETWEEN CABINET WEIGHT AND MAX WEIGHT NOTED IN TABLE




| | | |
|----------------------------------------------------------------------|---------------------------------------------------|----------------------------|
| <p>Robinson Meier Juilly & Associates 10/29/2021</p> | <p>SCHNEIDER ELECTRIC NETSHELTER SX</p> | <p>Job No. 15262</p> |
| | <p>OSHPD CABINET SUPPORTS AND ATTACHMENTS</p> | <p>Sheet No. (SK3)</p> |
| | <p>Signed by JEH Date 10/25/2021</p> | <p>6/12</p> |

NOTES:

*SEE Rack Matrix on sheet SK1a for all possible dimensions. Design based on AR3 & AR9 series rack.
 *INTERNAL and EXTERNAL BRACKETS SHALL BE INSTALLED FOR OSHPD PROJECTS.

CONDITION SCHEDULE

| | |
|------------------|------------|
| <u>CONDITION</u> | <u>SEE</u> |
| CONCRETE SLAB | (SK6) |
| | |



SCHNEIDER ELECTRIC CERTIFIES THIS DOCUMENT AS AN OUTLINE DRAWING.
 SIGNATURE: *Greg Ivey*
 PRINT NAME: GREG IVEY
 TITLE: ME MANAGER, RACK SYSTEMS
 DATE: 8/26/2019

BOLT REQUIREMENTS
 1. USE 8 EXPANSION BOLTS PER CABINET, WITH 4 EACH SIDE, THRU BRACKET

BRACKET MATERIAL (0.1181" THK, ASTM A1008-13 SHS GRADE 41) w/ M8 (ISO 898-1 CLASS 10.9) BOLTS PROVIDED BY NETSHELTER.

INTERNAL BRACKET INSTALLATION LOC'N

AR3abc and AR9abc— as follows

a denotes depth:

| | |
|--------|----------------------|
| 0 | 35.4" (900 mm) deep |
| 1 or 2 | 42.1" (1070 mm) deep |
| 3 | 47.2" (1200 mm) deep |

b denotes width:

| | |
|--------|---------------------|
| 0 or 1 | 23.6" (600 mm) wide |
| 4 or 5 | 29.5" (750 mm) wide |
| 8 | 31.5" (800 mm) wide |

c denotes height: (U designations per EIA-310) (EIA is Electronic Industries Association)

| | |
|-----------|-----------------------------------|
| 0, 1 or 2 | 78.4" (1991 mm) high for 42U rack |
| 4 | 47.2" (1198 mm) high for 24U rack |
| 5 | 83.6" (2124 mm) high for 45U rack |
| 6 | 92.4" (2347 mm) high for 50U rack |
| 7 | 88.9" (2258 mm) high for 48U rack |
| 8 | 95.9" (2436 mm) high for 52U rack |
| 9 | 99.4" (2525 mm) high for 54U rack |

AR3abc & AR9abc SERIES BOTTOM PLAN VIEW

PLAN (1) **SK4**
 N.T.S.

MAX/MIN DIMENSIONS: (TABLE 2) THESE ARE JUST THE MAX/MIN TABULATED VALUES FROM TABLE ON SHT SK1a".

| MODEL | "H" MAX (in.) | "D" MIN (in.) | MAX CABINET FRAME WEIGHT |
|--------|---------------|---------------|--------------------------|
| AR3abc | 99.4" | 11.8" | 531# |
| AR9abc | 99.4" | 11.8" | 531# |

BASED ON ARa0c and AR3a1c SERIES or AR9a1c SERIES

BASED ON AR3ab9 SERIES or AR9ab9 SERIES



| | | |
|------------------------------------------------------------------------------------------------------|-------------------------------------------|--------------------|
| Robinson Meier Juilly & Associates 241 Joaquin Avenue San Leandro CA 94577 510.991.0977 | SCHNEIDER ELECTRIC NETSHELTER SX | Job No. 15262 |
| | OSHPD CABINET SUPPORTS AND ATTACHMENTS | Sheet No. (SK4) |
| | Signed by JEH Date 10/25/2021 | 7/12 |

NOTES:

*SEE Rack Matrix on sheet SK1a for all possible dimensions. Design based on AR3 & AR9 series rack.
 *INTERNAL and EXTERNAL BRACKETS SHALL BE INSTALLED FOR OSHPD PROJECTS.


CONDITION SCHEDULE

| CONDITION | SEE |
|-------------------------------|-----|
| CONCRETE SLAB | SK6 |
| CONCRETE FILL OVER METAL DECK | SK7 |

INSTALLATION FOR THE FOLLOWING CONDITIONS:

- SEE BOLT REQUIREMENTS ON SK4 FOR ANCHORAGE REQUIREMENTS.

| | | | |
|-----------------------------------------------|-------|-------------------------------------------------|------|
| CONCRETE SLAB | | CONCRETE FILL OVER METAL DECK | |
| MAX BOLT TENSION, T_u | 1220# | MAX BOLT TENSION, T_u | 625# |
| MAX BOLT SHEAR, V_u | 440# | MAX BOLT SHEAR, V_u | 660# |
| ALL LOADS have been INCREASED BY OMEGA FACTOR | | Shear LOADS have been INCREASED BY OMEGA FACTOR | |



GANG UNIT BOTTOM PLAN VIEW (3 UNITS OR MORE GANGED TOGETHER)
 NO MAXIMUM # OF UNITS


SCHNEIDER ELECTRIC CERTIFIES THIS DOCUMENT AS AN OUTLINE DRAWING.

SIGNATURE: *Greg Ivey*
 PRINT NAME: GREG IVEY
 TITLE: ME MANAGER, RACK SYSTEMS
 DATE: 8/26/2019

PLAN

N.T.S.


1
 SK5



| | | |
|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------|--------------------------------------------------------------------|-------------------------------------------|
| <p>Robinson Meier Juilly & Associates 241 Joaquin Avenue San Leandro CA 94577 510.991.0977</p> | <p>SCHNEIDER ELECTRIC NETSHELTER SX</p> | <p>Job No. 15262</p> |
| | <p>OSHPD CABINET SUPPORTS AND ATTACHMENTS</p> | <p>Sheet No. SK5</p> |
| | <p>Signed by JEH Date 10/25/2021</p> | <p>8/12</p> |

SCHNEIDER ELECTRIC CERTIFIES THIS DOCUMENT AS AN OUTLINE DRAWING.

SIGNATURE: *Greg Ivey*
 PRINT NAME: GREG IVEY
 TITLE: ME MANAGER, RACK SYSTEMS
 DATE: 8/26/2019



**CONCRETE SLAB
 INSTALLATION
 DETAIL**

1
 SK6

3" = 1' - 0"



| | | |
|-------------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------|---------------------------------|
| <p>Robinson Meier Juilly & Associates 241 Joaquin Avenue San Leandro CA 94577 510.991.0977</p> | <p>SCHNEIDER ELECTRIC NETSHELTER SX</p> | <p>Job No. 15262</p> |
| | <p>OSHPD CABINET SUPPORTS AND ATTACHMENTS</p> | <p>Sheet No. SK6</p> |
| | <p>Signed by JEH Date 10/25/2021</p> | <p>9/12</p> |

10/29/2021


OPM-0255: Reviewed for Code Compliance by Jeffrey Kikumoto

SCHNEIDER NETSHELTER SX UNIT CABINET NOTES:

1. CABINET COVER GAGE THICKNESS SHALL NOT BE LESS THAN 16 ga.
2. BASE MATERIAL SHALL BE COLD ROLLED STEEL 29.4 ksi.
3. THE STRUT(S) AND ITS ATTACHMENTS ARE DESIGNED TO RESIST A LOAD NOT LESS THAN $V_{U \text{ STRUT}}$ IN COMBINATION WITH ALL OTHER LOADS THAT MAY BE PRESENT, WHERE $V_{U \text{ STRUT}} = 0.7V_U \times (\text{NO. OF ANCHORS ENGAGED BY STRUT}), \text{MIN.}$

SCHNEIDER ELECTRIC CERTIFIES THIS DOCUMENT AS AN OUTLINE DRAWING.

SIGNATURE: *Greg Ivey*
 PRINT NAME: GREG IVEY
 TITLE: ME MANAGER, RACK SYSTEMS
 DATE: 8/26/2019




PROVIDE HEX NUT at TOP & BOTTOM OF HORIZ. ANGLE LEG, TYP. AT CONDITIONS WHERE WHERE THE NUT CANNOT BE PROVIDED AT THE TOP OF HORIZ. LEG (WHEN BOLT GOES THRU LOWER FLUTE) PROVIDE TAPPED HOLE THRU HORIZ LEG.

CONCRETE FILL OVER METAL DECK INSTALLATION

DETAIL 1 SK7
 3" = 1'-0"



| | | |
|-------------------------------------------------------------------------------------------------------------------------------------------------------------------|----------------------------------------|------------------|
| <p>Robinson Meier Juilly & Associates 241 Joaquin Avenue San Leandro CA 94577 510.991.0977</p> | SCHNEIDER ELECTRIC NETSHELTER SX | Job No. 15262 |
| | OSHPD CABINET SUPPORTS AND ATTACHMENTS | Sheet No. SK7 |
| | Signed by JEH Date 10/25/2021 | 10/12 |




| | | |
|-----------------------------------------------------------------------------------------------------------------------|---------------------------------------------------|---------------------------|
| <p>Robinson Meier Juilly & Associates 241 Joaquin Avenue San Leandro CA 94577 510.991.0977</p> | <p>SCHNEIDER ELECTRIC NETSHELTER SX</p> | <p>Job No. 15262</p> |
| | <p>OSHPD CABINET SUPPORTS AND ATTACHMENTS</p> | <p>Sheet No. SK10</p> |
| | <p>Signed by JEH Date 10/25/2021</p> | <p>11/12</p> |

10/29/2021 OPM-0255: Reviewed for Code Compliance by Jeffrey Kikumoto

1/8" BEND RADIUS

10.23"



STIFFENER GUSSET BENT FROM VERTICAL LEG

SEISMIC BRACKET PLAN

BRACKET SUPPLIED BY SCHNEIDER ELECTRIC (4 TOTAL) (0.1181" THK PL ASTM 1008-13, SHS GRADE 41 STEEL)

0.38" MAX WIDTH HOLE for M8 BOLT



0.625"

0.5625" min DIAMETER
0.625" max DIAMETER

SCHNEIDER ELECTRIC CERTIFIES THIS DOCUMENT AS AN OUTLINE DRAWING.
SIGNATURE: [Signature]
PRINT NAME: GREG JVEY
TITLE: ME MANAGER, RACK SYSTEMS
DATE: 8/26/2019

0.25"



12.625"




SEISMIC BRACKET ELEVATION

NOTE:
BRACKET SHALL BE FABRICATED BY SCHEINDER ELECTRIC WITH METRIC DIMENSIONS, PER SCHNEIDER STANDARDS

DETAIL 1
N.T.S. SK11



PL 0.1181" ASTM 1008-13, SHS GRADE 41 STEEL



SEC. B
N.T.S. SK11

SEC. C
N.T.S. SK11

SEC. D
N.T.S. SK11

| | | |
|----------------------------------------------------------------------------------------------------------------|-----------------------------------------------|-------------------------|
| <p>Robinson Meier Juilly & Associates 241 Joaquin Avenue San Leandro CA 94577 510.991.0977</p> | <p>SCHNEIDER ELECTRIC NETSHELTER SX</p> | <p>Job No. 15262</p> |
| | <p>OSHPD CABINET SUPPORTS AND ATTACHMENTS</p> | <p>Sheet No. (SK11)</p> |
| | <p>Signed by JEH Date 10/25/2021</p> | <p>12/12</p> |