

OFFICE OF STATEWIDE HEALTH PLANNING AND DEVELOPMENT **FACILITIES DEVELOPMENT DIVISION**

| APPLICATION FOR OSHPD PREAPPROVAL | OFFICI | E USE ONLY |
|---|--|-------------------------|
| OF MANUFACTURER'S CERTIFICATION (OPM) | APPLICATION #: OF | DM 0407 42 |
| OF MARCI ACTORER O CERTIFICATION (OF MI) | APPLICATION #: OF | PM-0407-13 |
| OSUBD Programme val of Manufacturer's Cartification (OBM) | | |
| OSHPD Preapproval of Manufacturer's Certification (OPM) | | |
| Type: ☐ New ☐ Renewal ☐ Update to Pre-CBC 2013 C | PA Number: | |
| Manufacturer Information | | |
| | | |
| Manufacturer: Skytron LLC. | | |
| Manufacturer's Technical Representative: Bob Vreeland | | |
| Mailing Address: Skytron US, 5085 Corporate Exchange Blvd SE, G | rand Rapids, MI 49512 | |
| OR CODE | | |
| | nu@skytron.us | |
| Product Information | 77 | |
| Product Name: Skytron Astro | The state of the s | |
| Product Type: Surgical Lights OPM-0407-13 | C F | |
| Product Model Number: AUA3-895, AUA3-1090, AUA3-1285, AUA3 | 3-805/700 ALIA33-100 | NO/805 ALIA33-1285/1000 |
| AUA3-EA-1500, AUA3-EA-2000, AUA33-EA | | |
| AUA3- <mark>EH</mark> -895, AUA3-EH-1090, AUA3-EH-12 AUA33-EH-1285/1090, AUA3-EH-1500, AU 2000/1500, LFSAUA3, LFSAUA33, LFSLFSA 1090, AUA3-HY-1285, AUA3-HY-1500 | A3-EH-2 <mark>000, A</mark> UA33-EH | H-1500/1300, AUA33-EH- |
| General Description: Ceiling mounted surgical lights. | 10Dx | |
| Applicant Information **BUILDING** | | |
| Applicant information | | |
| Applicant Company Name: ISAT Seismic Bracing | | |
| Contact Person: William V Joerger | | |
| Mailing Address: 1020 Crews Road, Suite Q, Matthews NC 28105 | | |
| Telephone: _510-714-0216 | ger@isatsb.com | |
| I hereby agree to reimburse the Office of Statewide Health Faccordance with the California Administrative Code, 2016. | Planning and Develo | opment review fees in |
| Signature of Applicant: Wys | Date | e: 03/01/2017 |
| Title: Principal Structural Engineer Company Name: ISAT S | eismic Bracing | |
| | . Lu. | OCHDD |

"Access to Safe, Quality Healthcare Environments that Meet California's Diverse and Dynamic Needs"



USTIFU

Page 1 of 2



OFFICE OF STATEWIDE HEALTH PLANNING AND DEVELOPMENT **FACILITIES DEVELOPMENT DIVISION**

| Registered Design Professional Preparing Engineering Recommendations | | | |
|--|--|--|--|
| Company Name: ISAT Seismic Bracing | | | |
| Name: William V Joerger California License Number: SE4545 | | | |
| Mailing Address: _ 1020 Crews Rd, Matthews NC 28105 | | | |
| Telephone: _510-714-0216 | | | |
| OSHPD Special Seismic Certification Preapproval (OSP) | | | |
| □ Special Seismic Certification is preapproved under OSP- (Separate application for OSP is required) □ Special Seismic Certification is not preapproved | | | |
| Certification Method(s) | | | |
| ☐ Testing in accordance with: ☐ ICC-ES AC156 ☐ FM 1950-16 ☐ Other* (Please Specify): | | | |
| OPM-0407-13 | | | |
| *Use of criteria other than those adopted by the California Building Standards Code, 2016 (CBSC 2016) for component supports and attachments are not permitted. For distribution system, interior partition wall, and suspended ceiling seismic bracings, test criteria other than those adopted in the CBSC 2016 may be used when approved by OSHPD prior to testing. Analysis | | | |
| ☐ Combination of Testing, Analysis, and/or Experience Data (Please Specify): | | | |
| | | | |
| List of Attachments Supporting the Manufacturer's Certification ☐ Test Report ☐ Drawings ☐ Calculations ☐ Manufacturer's Catalog ☐ Other(s) (Please Specify): | | | |
| OFFICE USE ONLY – OSHPD APPROVAL VALID FOR CBC 2016 & ALL PRE-2016 CODE BASED PROJECTS | | | |
| Signature: Date: 09-05-2017 | | | |
| Print Name: William Staehlin | | | |
| Title: SSE | | | |
| Condition of Approval (if applicable): | | | |
| | | | |

"Access to Safe, Quality Healthcare Environments that Meet California's Diverse and Dynamic Needs"







A Division of Tomarco Contractor Specialties

Submittal Documents

OPM-0407-13

OSHPD OPM-0407-13

SUPPORT AND ATTACHMENT CONSTRUCTION DRAWINGS ASTRO SURGICAL LIGHTS

SKYTRON, LLC

BUILDING

ISAT 1020 Crews Road Suite Q Matthews, N.C. 28105 704-841-4080

"Empowered by Experience"

 \mathcal{O}

EXP. 06/30/2018

REV 2

OSHPD OPM-0407-13 DWG - i

FILE NO.: CLT-0217-023



OSHPD OPM-0407-13

SKYTRON ASTRO SURGICAL LIGHTS

CONSTRUCTION DRAWING INDEX

| INDEX Cover Page Index Page | OSI 7pd OPM-0407-13 | |
|---------------------------------|----------------------|------|
| Cover Page | OSI JPG | рi |
| Cover rage | OPM-0407-13 | РΙ |
| Index Page | H | рII |
| General Notes | BY: William Staehlin | p 1 |
| Attachment Notes | DATE: 09/05/2017 | p 2 |
| Metal Deck Installation Details | | р3 |
| Solid Slab Installation Details | WIA BUILDING CODS, | p 4 |
| Miscellaneous Steel 1 | WIA BUILDING CODS, | p 5 |
| Miscellaneous Steel 2 | BUILDING | p 6 |
| Mounting Plate | | p 7 |
| Mounting Plate for Extended Hub | | p 8 |
| Top Plate Details | | p 9 |
| Hub Configuration 1 | | p 10 |
| Hub Configuration 2 | | p 11 |
| Hub Configuration 3 | | p 12 |
| Forces and Moments | | p 13 |

OSHPD OPM-0407-13

MANUFACTURE: SKYTRON EQUIPMENT TYPE: SURGICAL LIGHTS

GENERAL NOTES:

- 1. THIS OSHPD PREAPPROVAL OF MANUFACTURER'S CERTIFICATION (OPM) IS BASED ON THE CBC 2016. THE DEMAND (DESIGN FORCES) FOR USE WITH THIS OPM SHALL BE BASED ON THE CBC 2016.
- 2. SEISMIC CRITERIA USED: $S_{DS} = 2.5 \quad I_P = 1.5 \quad ap = 1.0 \quad Rp = 1.5 \quad z/h \le 1.0 \quad FpH = 3.0 \; AND \; FpV = 0.50.$
- 3. SUPPORT AND ATTACHMENT FORCES ARE DETERMINED USING ASCE 7-10 CHAPTER 13 "SEISMIC DESIGN REQUIREMENTS FOR NONSTRUCTURAL COMPONENTS". AN OVERSTRENGTH FACTOR Ω_0 = 1.5 IS USED FOR CONCRETE MATERIALS PER ASCE 7-10 SUPPLEMENT 1 TABLE 13.6-1. LOADS SHOWN ARE STRENGTH DESIGN LOADS PER CBC 2016 SECTION 1909A.
- 4. THIS PREAPPROVAL COVERS ONLY THE SUPPORTS AND ATTACHMENTS OF THE EQUIPMENT TO THE STRUCTURE.
- 5. STEEL MATERIALS: ANGLES AND PLATE ASTM A36, HSS ASTM A500 GRADE B (Fy = 46 KSI), PIPE ASTM A53 GRADE B (FY = 35 KSI), WELDING ELECTROIDS E70XX, ALL THREAD ROD AND BOLTS ASTM A193-B7 (Fu = 125 KSI). BOLTS SUPPLIED BY SKYTRON ARE ASTM A193 B7.
- 6. CONCRETE SLABS:
 - a. FOR ELEVATED SOLID CONCRETE SLABS: 6" THICKNESS OF NORMAL WEIGHT CONCRETE WITH 4000 PSI MINIMUM STRENGTH.
 b. METAL DECK: 3" DEEP COMPOSITE STEEL DECK, 20 GAGE MINIMUM, 4 1/2 INCH MINIMUM BOTTOM FLUTE WIDTH AND FLUTE SPACING OF 12", WITH 3 1/4 INCH SAND LIGHT WEIGHT CONCRETE CONCRETE COVER AT 4000 PSI MINIMUM STRENGTH.
- 7. POST-INSTALLED CONCRETE ANCHORS: HILTI KWIK BOLT TZ (ESR-1917) 5/8" DIAMETER x 3 3/4" MIN. HOLE DEPTH (3 1/8" EFFECTIVE EMBEDMENT) AND 65 FT-LBS INSTALLATION TORQUE.

RESPONSIBILITIES OF THE STRUCTURAL ENGINEER OF RECORD

- 1. CONFIRM THE MATERIAL PROPERTIES AND THICKNESS OF THE CONCRETE SLAB TO WHICH THE EQUIPMENT IS ATTACHED MEETS THE REQUIREMENTS OF THIS OPM.
- 2. PROVIDE A PLAN FOR INSPECTION OF SUPPORTS AND ATTACHMENTS AND VERIFY ITS IMPLEMENTATION.
- 3. CONFIRM THE SPECIFIED MINIMUM CONCRETE EDGE DISTANCES ARE MAINTAINED BASED ON THE ACTUAL EQUIPMENT LOCATION. VERIFY THAT EXISTING OR NEW ANCHORS ARE AN ADEQUATE DISTANCE FROM THIS UNIT'S ATTACHMENT.
- 4. VERIFY THAT THE EXISITING STRUCTURE IS ADEQUATE FOR THE IMPOSED DEAD, LATERAL AND TENSION FORCES SHOWN IN ADDITION TO ALL OTHER LOADS.
- 5. VERIFY THAT THE INSTALLATION IS IN CONFORMANCE WITH CBC 2016 AND WITH THE OPM-0407-13 DETAILS INCLUDING MATERIALS AND DIMENSIONS OF THE SUPPORT WHERE THE ATTACHMENTS ARE MADE AGREE WITH THE INFORMATION SHOWN.
- 6. VERIFY THAT THE PROJECT SPECIFIC S_{DS} AND z/h VALUES RESULT IN SEISMIC FORCES (Eh AND Ev) DO NOT EXCEED THE VALUES SHOWN IN THESE DETAILS.

OPM-0407-13 SKYTRON ASTRO LIGHTS GENERAL NOTES



S 4545 EXP. 06/30/2018 *

DRAWN BY: WVJ **DATE:** 03/09/17

REVISED BY: WVJ DATE: 07/26/17

REV NO: 2

SCALE PAGE N.T.S. GEN NOTES

OSHPD OPM-0407-13

MANUFACTURE: SKYTRON **EQUIPMENT TYPE:** SURGICAL LIGHTS

ATTACHMENT NOTES:

- 1. THIS OSHPD PREAPPROVAL OF MANUFACTURER'S CERTIFICATION (OPM) IS BASED ON THE CBC 2016. THE DEMAND (DESIGN FORCES) FOR USE WITH THIS OPM SHALL BE BASED ON THE CBC 2016.
- 2. BRACE ARM INCLINATION MAY VARY FROM 30° TO 60° FROM HORIZONTAL.
- 3. PERIODIC SPECIAL INSPECTION PER CBC 2016 SECTION 1705A AND TABLE 1705A.3 INCLUDING VERIFICATION OF ANCHOR TYPE. ANCHOR DIMENSIONS, CONCRETE TYPE, CONCRETE COMPRESSIVE STRENGTH, ANCHOR SPACING, EDGE DISTANCES, CONCRETE MEMBER THICKNESS, TIGHTENING TORQUE, HOLE DIMENSIONS, ANCHOR EMBEDMENT AND ADHERENCE TO THE MANUFACTURER'S PRINTED INSTALLATION INSTRUCTIONS. IN ADDITION, FOLLOW THE PROVISIONS OF THE 2016 CALIFONIA BUILDING CODE SECTION 1910A.5 BY CONFIRMING THE INSTALLATION TORQUE SPECIFIED BY THE MANUFACTURER, TESTING IS NOT TO OCCUR UNTIL A MINIMUM OF 24 HOURS HAS ELAPSED AFTER THE INSTALLATION OF THE SUBJECT ANCHORS. TESTING SHALL BE DONE IN THE PRESENCE OF THE SPECIAL INSPECTOR. TEST 50% OF THE ANCHORS FOR EACH PIECE OF EQUIPMENT. USING A CALIBRATED TORQUE WRENCH VERIFY THE INSTALLATION TORQUE IS OBTAINED WITHIN 1/2 TURN OF THE NUT. REPORT OF TEST RESULTS ARE TO BE SUBMITTED TO THE ENFORCEMENT AGENGY. THE SEOR SHALL POVIDE REMEDIAL ANCHORAGE DETAILS IN THE EVENT THAT AN ANCHOR FAILS TO MEET THE TEST REQUIREMENTS.
- 4. WELDS ARE TO BE VISUALLY INSPECTED BY A QUALIFIED WELDING INSPECTOR.
- 5. STRENGTH DESIGN WAS USED FOR ANCHOR FORCE CALCULATIONS INCLUDING Ω PER ACI 318-14 WHERE REQUIRED FOR ATTACHMENT TO CONCRETE.
- 6. EXCERCISE DUE CARE WHEN DRILLING POST-INSTALLED ANCHORS TO AVOID DAMAGING CONCRETE REINFORCEMENT OR
- 7. PROVIDE FOR FULL THREAD ENGAGEMENT OF NUT AND WASHER.

SERIES MODELS INCLUDED IN OPM-0407-13

ASTRO STANDARD AUA3-895, AUA3-1090, AUA3-1285, AUA33-895/700, AUA33-1090/895, AUA33-1285/1090

EXTENDED ARM - SINGLE

AUA3-EA-1500, AUA3-EA-2000 Staehlin EXTENDED ARM - DUAL AUA33-EA-1500/1300, AUA33-EA-2000/1500

EXTENDED HUB AUA3-EH-895, AUA3-EH-1090, AUA3-EH-1285, AUA3-EH-895/700, AUA33-EH-1090/895, AUA33-EH-1285/1090

EXTENDED HUB/EXTENED ARM AUA3-EH-1500, AUA3-EH-2000, AUA33-EH-1500/1300, AUA33-EH-2000/1500

LFS WITH ASTRO LFSAUA3, LFSAUA33

LFSLFS WITH ASTRO LFSLFSAUA3, LFSLFSAUA33

AUA3-HY-895, AUA3-HY-1090, AUA3-HY-1285, AUA3-HY-1500

OPM-0407-13 SKYTRON ASTRO LIGHTS ATTACHMENT NOTES



International Seismic Application Technology 1020 Crews Road, Suite Q, Matthews, NC 28105 704-841-4080 www.isatsb.com




DRAWN BY: WVJ **DATE:** 03/09/17


REVISED BY: WV.J **DATE**: 07/26/17


REV NO: 2


SCALE N.T.S.


PAGE ATTACH NOTE:





























Equipment Data Seismic Design Forces at Ultimate Loads Model Number **Model Series** Hub. Bolts at Bolts at Weight at 1g Vertical Force Lateral Force Мx Mν Conf. No. Used for Design at Hub Mount. Pl. DL + FpV lbs. FpH x Wp lbs. ft.-lbs. ft.-lbs. lbs. ASTRO STANDARD AUA3-1285 2 (6) 1/2" (4) 7/8" 182 309 1,335 1,588 546 EXTENDED ARM SINGLE AUA33-1285/1090 PM- (44) 7/8" (4) 7/8" 133 226 399 1,232 1,077 EXTENDED ARM DUAL AUA33-EA-2000/1500 (4) 7/8" (4) 7/8" 231 393 693 2,030 2,018 **EXTENDED HUB** AUA33-EH-1285/1090 3 (6) 7/8" 182 309 546 1,336 3,130 EXTENDED HUB/ARM AUA33-EH-2000/1500 (6) 7/8" 229 389 687 2,042 3,786 377 Staph LFS WITH ASTRO LFSAUA33 918 (4)7/8"(4) 7/8" 306 520 2,206 2,916 LFSLFS WITH ASTRO LFSLFSAUA33 (4) 7/8" (4) 7/8" 415 706 1,245 2,896 4,075 AUA3-HY-1500 (4) 7/8" (4) 7/8" 136 231 408 985 1,127

WEIGHTS AND MOMENTS ARE FACTORED LOADS USING STRENGTH DESIGN AND INCLUDE THE FOLLOWING FACTORS: DL = 1.2, FpV = 0.5 AND FpH = 3.0. Mx ARE MOMENTS IN THE HORIZONTAL AXIS DUE TO COMPONENT WEIGHT TIMES THE MAXIMUM HORIZONTAL ECCENTRICITY.

MY ARE MOMENTS IN THE HORIZONTAL AXIS DUE TO COMPONENT LATERAL FORCE TIMES THE MAXIMUM VERTICAL ECCENTRICITY.

MODEL NUMBER TABULATED YIELDS THE WORST CASE LOADING FOR THE MODEL SERIES.

EXTENDED HUB MODELS DO NOT HAVE A UNIVERSAL MOUNTING PLATE.

SEE PAGE "ATTACH NOTES" FOR A LISTING OF THE MODEL NUMBERS INCLUDED WITHIN A GIVEN MODEL SERIES.

OPM-0407-13 SKYTRON ASTRO LIGHTS FORCES AND MOMENTS



International Seismic Application Technology
1020 Crews Road, Suite Q, Matthews, NC 28105
704-841-4080 www.isatsb.com



DRAWN BY: WVJ **DATE:** 03/09/17

REVISED BY: WVJ **DATE:** 07/26/17 **REV NO:** 2

SCALE PA

SCALE PAGE N.T.S. FORCES