



DEPARTMENT OF HEALTH CARE ACCESS AND INFORMATION
FACILITIES DEVELOPMENT DIVISION

APPLICATION FOR HCAI PREAPPROVAL OF
MANUFACTURER'S CERTIFICATION (OPM)

OFFICE USE ONLY

APPLICATION #: OPM-0453

HCAI Preapproval of Manufacturer's Certification (OPM)

Type: [] New [X] Renewal/Update

Manufacturer Information

Manufacturer: Certified Medical Sales

Manufacturer's Technical Representative: Jake Granger

Mailing Address: 41551 Date Street, Murrieta, CA 92562

Telephone: (800) 537-3090

Email: Sales@CertifiedMedicalSales.com

Product Information

Product Name: JT RACKING SYSTEMS

OPM-0453

Product Type: Rack for containing gas cylinders

Product Model Number: Various

BY: William Staehlin

General Description: Welded steel racks with chain restraints

DATE: 01/04/2023

Applicant Information

Applicant Company Name: Spire Structural Engineering Inc.

Contact Person: Jeremy Welton

Mailing Address: 26461 Rancho Parkway South, Lake Forest, CA 92630

Telephone: (949) 916-3440

Email: jwelton@spirestructures.com

Title:

"Access to Safe, Quality Healthcare Environments that Meet California's Diverse and Dynamic Needs"

STATE OF CALIFORNIA - HEALTH AND HUMAN SERVICES AGENCY





DEPARTMENT OF HEALTH CARE ACCESS AND INFORMATION
FACILITIES DEVELOPMENT DIVISION

Registered Design Professional Preparing Engineering Recommendations

Company Name: SPIRE STRUCTURAL ENGINEERING, INC.
Name: Jeremy Welton California License Number: S4614
Mailing Address: 26461 Rancho Parkway South, Lake Forest, CA 92630
Telephone: (949) 916-3440 Email: jwelton@spirestructures.com

HCAI Special Seismic Certification Preapproval (OSP)

Special Seismic Certification is preapproved under OSP OSP Number:

Certification Method

Testing in accordance with: ICC-ES AC156 FM 1950-16
Other(s) (Please Specify):

*Use of criteria other than those adopted by the California Building Standards Code, 2019 (CBSC 2019) for component supports and attachments are not permitted. For distribution system, interior partition wall, and suspended ceiling seismic bracings, test criteria other than those adopted in the CBSC 2019 may be used when approved by HCAI prior to testing.

- Analysis
Experience Data
Combination of Testing, Analysis, and/or Experience Data (Please Specify):

HCAI Approval

Date: 1/4/2023
Name: William Staehlin Title: Senior Structural Engineer
Condition of Approval (if applicable):

"Access to Safe, Quality Healthcare Environments that Meet California's Diverse and Dynamic Needs"

STATE OF CALIFORNIA - HEALTH AND HUMAN SERVICES AGENCY





26461 Rancho Parkway South tel:
 Lake Forest, CA 92630 949.916.3440
 www.spirestructures.com
 ENG: JCW

GENERAL NOTES

JT RACKING SYSTEMS

MEDICAL GAS ANCHORING SYSTEMS

SHEET:

1

OF

8

DATE:

01.04.23

DEPARTMENT OF HEALTH CARE ACCESS AND INFORMATION
 PREAPPROVAL OF MANUFACTURER'S CERTIFICATION

OPM-0453

(THIS PREAPPROVAL CONFORMS TO THE 2022 CALIFORNIA BUILDING CODE)
 THE DEMAND (DESIGN FORCES) FOR USE WITH THIS OPM SHALL BE BASED ON THE CBC 2022.

EQUIPMENT MANUFACTURER: JT RACKING SYSTEMS
 EQUIPMENT TYPE: MEDICAL COMPRESSED GAS SUPPORT AND ANCHOR SYSTEM

GENERAL NOTES

FORCES PER ASCE 7-16 SECTION 13.3.1, EQUATIONS 13.3-1, 13.3-2, AND 13.3-3, WHERE $S_{DS} \leq 1.93$, $a_p = 2.5$, $R_p = 2.5$, $\Omega_0 = 2.0$, $I_p = 1.5$ AND $z/h \leq 1.0$.

1. THIS PREAPPROVAL CONFORMS TO THE 2022 CALIFORNIA BUILDING CODE. THE DEMAND (DESIGN FORCES) FOR USE WITH THIS OPM SHALL BE BASED ON THE 2022 CBC.
2. THE DETAILS IN THIS PREAPPROVAL MAY BE USED AT ANY HEIGHT ($z/h \leq 1.0$) AND AT ANY LOCATION IN THE STATE OF CALIFORNIA WHERE $S_{DS} \leq 1.93$ BASED ON THE LIMITATIONS SHOWN IN TABLE 1.
3. EXPANSION ANCHORS [CARBON STEEL (CS) OR STAINLESS STEEL (SS)] SHALL BE HILTI KB-TZ2 (ICC ESR-4266):
 - A. ATTACHMENT IS TO BE MADE WITH ANCHORS LISTED BELOW AND INSTALLED AS DESCRIBED IN THE CORRESPONDING ICC REPORT.

ANCHOR DIAMETER	MIN f_c (psi)	NOMINAL EMBED	EFFECTIVE EMBED (h_{ef})	MIN SPACING (NOTE D)	MIN EDGE DIST	MIN CONC THICKNESS	TORQUE TEST LOADS
3/8"	2,500	3"	2 1/2"	4"	4"	6"	30 FT-LBS
5/8"	2,500	4 1/2"	4"	12"	13"	6"	40 FT-LBS (CS) 60 FT-LBS (SS)

- B. THIS PREAPPROVAL DOES NOT ALLOW CONCRETE EDGE DISTANCES LESS THAN MINIMUM.
- C. POST-INSTALLED ANCHORS INTO NORMAL WEIGHT CONCRETE SHALL SATISFY SECTION 13.4.2.1, INCLUDING THE OVERSTRENGTH FACTOR, Ω_0 PER TABLE 13.6-1 (AS LIMITED BY CBC SECTION 1617A.1.23, "ASCE 7 TABLES 13.5-1 AND 13.6-1").
- D. UNLESS NOTED OTHERWISE. SEE DETAILS FOR LOCATIONS WHERE SPACING IS LESS (THIS IS ACCEPTABLE).
4. TESTING OF EXPANSION ANCHORS PER 2022 CBC, 1910A.5.3: TESTING SHALL BE DONE IN THE PRESENCE OF THE SPECIAL INSPECTOR AND A REPORT OF THE TEST RESULTS SHALL BE SUBMITTED TO HCAI.
 - A. TORQUE TEST AT LEAST 50% OF THE ANCHORS TO THE INSTALLATION TORQUE.
 - B. ACCEPTANCE CRITERIA: THE ANCHOR SHOULD HAVE NO OBSERVABLE MOVEMENT AT THE TEST LOAD. A PRACTICAL WAY TO DETERMINE OBSERVABLE MOVEMENT IS THAT THE WASHER BECOMES LOOSE. ANCHORS TESTED WITH A CALIBRATED TORQUE WRENCH MUST ATTAIN THE SPECIFIED TORQUE WITHIN 1/2 TURN OF THE NUT.
 - C. IF ANY ANCHOR FAILS, TEST ALL ANCHORS.
5. THIS PREAPPROVAL COVERS ONLY THE SUPPORTS AND ATTACHMENTS OF THE UNIT TO THE STRUCTURE.
 6. BOLTS THROUGH CONCRETE ON STEEL DECK
 - A. BOLTS SHALL BE TORQUED BY 3/4 TURN OF THE NUTS AFTER THE SNUG-TIGHT CONDITION IS ACHIEVED (SNUG-TIGHT IS DEFINED AS THE TIGHTNESS REQUIRED TO BRING THE CONNECTED PLIES INTO FIRM CONTACT).
 - B. THROUGH BOLT HOLES IN CONCRETE SHALL BE 1/16" DIAMETER (BOLT DIAMETER + 1/16").
 - C. THROUGH-BOLTS IN CONCRETE SHALL RECEIVE SPECIAL INSPECTION AND TESTING IN ACCORDANCE WITH REQUIREMENTS FOR POST-INSTALLED ANCHORS (THROUGH BOLTS WITH STEEL-TO-STEEL CONNECTION IN TENSION DO NOT REQUIRE TENSION TESTING).



Signed 01.04.23



26461 Rancho Parkway South tel:
 Lake Forest, CA 92630 949.916.3440
 www.spirestructures.com
 ENG: JCW

GENERAL NOTES (CONTINUED)

JT RACKING SYSTEMS

MEDICAL GAS ANCHORING SYSTEMS

SHEET:
 2
 OF
 8
 DATE:
 01.04.23

RESPONSIBILITIES OF THE STRUCTURAL ENGINEER OF RECORD (SEOR)

1. VERIFY RACK CAPACITY BASED ON THE COMBINATION OF S_{DS} AND z/h AS LIMITED BY TABLE 1 OF THIS PREAPPROVAL.
2. VERIFY THAT THE CONCRETE SLAB WHERE THE EQUIPMENT IS BEING ANCHORED MEETS THE REQUIREMENTS OF THE APPLICABLE ICC REPORT.
3. VERIFY THAT THE ANCHORS ARE AN ADEQUATE DISTANCE FROM ANY SLAB EDGES OR OPENINGS.
4. PROVIDE ANY SUPPORTING STRUCTURE REQUIRED TO SUPPORT THE WEIGHTS AND FORCES SHOWN IN TABLE 2 ON SHEET 8/8 OF THIS PREAPPROVAL.
5. VERIFY THAT THE INSTALLATION IS IN CONFORMANCE WITH THE 2022 CBC AND WITH THE DETAILS SHOWN IN THIS PREAPPROVAL. VERIFY THAT THE ACTUAL EQUIPMENT WEIGHT, CENTER OF GRAVITY LOCATION, ANCHOR LOCATIONS, ANCHOR DETAILS AND THE MATERIAL AND GAGE OF THE UNIT WHERE ATTACHMENTS ARE MADE AGREE WITH THE INFORMATION SHOWN ON THE PREAPPROVAL DOCUMENTS.
6. VERIFY THAT ALL NEW OR EXISTING ANCHORS ARE AN ADEQUATE DISTANCE FROM THE ANCHORS SHOWN IN THIS PREAPPROVAL. SEOR SHALL VERIFY THAT THERE IS NO ADVERSE INTERACTION WHERE OTHER ANCHORS ARE WITHIN 18" OR $6h_{ef}$ FROM THIS UNIT'S ANCHORS.

BY: William Staehlin
 TABLE 1 - SEISMIC QUALIFICATION SUMMARY (RACK CAPACITY)

RACK	MAX S_{DS}^*	COEFF C	RACK	MAX S_{DS}^*	COEFF C
1D1W	1.93	2.48	2D2W	1.17	2.25
1D1W-L	1.93	2.42	2D2W-L	1.93	2.42
1D2W	1.93	2.54	3D1W	0.92	2.30
1D2W-L	1.93	2.10	3D1W-L	1.93	1.58
1D3W	1.93	2.61	3D2W	1.01	2.97
1D3W-L	1.93	2.22	3D2W-L	1.43	2.51
2D1W	1.40	2.51	4D2W	0.87	2.33
2D1W-L	1.93	1.76	4D2W-L	1.16	2.10

* MAX S_{DS} FOR $z/h \leq 1.0$. THE MAX S_{DS} FOR A GIVEN HEIGHT RATIO CAN BE CALCULATED BASED ON ASCE7-16 EQUATIONS 13.3-1 AND 13.3-3.

* FOR EXPANSION ANCHOR APPLICATION AT $z/h > 0$, (SEE TABLE 3, NOTE 4), FOR A GIVEN S_{DS} , MAX z/h CAN BE CALCULATED AS:
 $(z/h)_{max} = (C S_{DS} - 1)/2$

RACK SEISMIC QUALIFICATION


FOR EXAMPLE, FOR THE "2D1W" RACK:
 SEISMICALLY QUALIFIED FOR MAX $S_{DS} = 1.40g$ WHEN $z/h \leq 1.0$; $1.4*[1+(2*1.0)] = 4.20$
 IF $z/h \leq 0.5$, THEN MAX $S_{DS} * [1.0+(2*0.5)] \leq 4.2$; $S_{DS} = 4.2/2 = 2.10$

USE OF EXPANSION ANCHORS FOR $z/h > 0$ (WITH 6" MIN SLAB THICKNESS PER NOTE 3 ON SHEET 1/8)

FOR EXAMPLE, FOR THE "4D2W" RACK w/ $S_{DS} = 1.00g$:
 $C = 2.33$
 $(z/h)_{max} = (C S_{DS} - 1)/2 = (2.33*1.00 - 1)/2 = 0.67$



TYPICAL GAS RACK FRAME BY JT RACKING SYSTEMS



- NOTES:**
1. SEE SHEETS 4 & 5 FOR DIFFERENT RACK CONFIGURATIONS.
 2. ALL CHAINS ARE TO BE LOOSE AROUND TANK.

Signed 01.04.23



26461 Rancho Parkway South tel:
 Lake Forest, CA 92630 949.916.3440
 www.spirestructures.com
 ENG: JCW


RACK CONFIGURATIONS

JT RACKING SYSTEMS

MEDICAL GAS ANCHORING SYSTEMS


SHEET:
 4
 OF
 8
 DATE:
 01.04.23

1D SERIES:




MODEL: 1D1W

DESCRIPTION: 1 DEEP x 1 WIDE




MODEL: 1D1W-(L OR R)

DESCRIPTION: 1 DEEP x 1 WIDE (LEFT OR RIGHT SIDE ADD-ON, LEFT SHOWN)




MODEL: 1D2W

DESCRIPTION: 1 DEEP x 2 WIDE




MODEL: 1D2W-(L OR R)

DESCRIPTION: 1 DEEP x 2 WIDE (LEFT OR RIGHT SIDE ADD-ON, LEFT SHOWN)



MODEL: 1D3W


DESCRIPTION: 1 DEEP x 3 WIDE



MODEL: 1D3W-(L OR R)


DESCRIPTION: 1 DEEP x 3 WIDE (LEFT OR RIGHT SIDE ADD-ON, LEFT SHOWN)

2D SERIES:




MODEL: 2D1W

DESCRIPTION: 2 DEEP x 1 WIDE




MODEL: 2D1W-(L OR R)

DESCRIPTION: 2 DEEP x 1 WIDE (LEFT OR RIGHT SIDE ADD-ON, LEFT SHOWN)



MODEL: 2D2W

DESCRIPTION: 2 DEEP x 2 WIDE



MODEL: 2D2W-(L OR R)


DESCRIPTION: 2 DEEP x 2 WIDE (LEFT OR RIGHT SIDE ADD-ON, LEFT SHOWN)

NOTES:


1. ALL FRAME CONFIGURATIONS SHOWN ARE COVERED UNDER THIS OPM.
2. TYPICAL FRAMES ARE HSS2x2x1/8 (ASTM A500 GRADE B) EXCEPT 4D SERIES ARE HSS2x2x1/4.
3. 1/16" φ ANCHOR HOLES ARE PROVIDED BY MFR.
4. SEE TABLE ON SHEET 1/8 FOR MINIMUM EDGE DISTANCE CRITERIA.




3D SERIES:




MODEL: 3D1W
DESCRIPTION: 3 DEEP x 1 WIDE



MODEL: 3D1W-(L OR R)
DESCRIPTION: 3 DEEP x 1 WIDE
(LEFT OR RIGHT SIDE ADD-ON,
LEFT SHOWN)




MODEL: 3D2W
DESCRIPTION: 3 DEEP x 2 WIDE




MODEL: 3D2W-(L OR R)
DESCRIPTION: 3 DEEP x 2 WIDE
(LEFT OR RIGHT SIDE ADD-ON,
LEFT SHOWN)


4D SERIES:



MODEL: 4D2W
DESCRIPTION: 4 DEEP x 2 WIDE



MODEL: 4D2W-(L OR R)
DESCRIPTION: 4 DEEP x 2 WIDE
(LEFT OR RIGHT SIDE ADD-ON,
LEFT SHOWN)




DETAIL 'A': TYPICAL FRAME TIE

NOTES:

1. ALL FRAME CONFIGURATIONS SHOWN ARE COVERED UNDER THIS OPM.
2. TYPICAL FRAMES ARE HSS2x2x1/8 (ASTM A500 GRADE B) EXCEPT 4D SERIES ARE HSS2x2x1/4.
3. 1/16" phi ANCHOR HOLES ARE PROVIDED BY MFR.
4. SEE TABLE ON SHEET 1/8 FOR MINIMUM EDGE DISTANCE CRITERIA.





NOTES:

- SEOR SHALL PROVIDE STRUCTURE TO SUPPORT WEIGHTS AND FORCES SHOWN IN TABLES 2 & 3 IN COMBINATION w/ ALL OTHERS THAT MAY APPLY.
- 3D3W SHOWN FOR ILLUSTRATIVE PURPOSES; RACK CONFIGURATION IS NOT WITHIN THE SCOPE OF THIS OPM.
- NWC= NORMAL WEIGHT CONCRETE.
- CONCRETE SLAB MAY BE NORMAL WEIGHT OR SAND LIGHTWEIGHT UNLESS OTHERWISE NOTED (f_c= 3,000 PSI MIN). STL DECK SHALL BE 20ga MIN.
- FALLING HAZARD MUST BE ELIMINATED BY EITHER TACK WELDING NUT OR SEOR TO PROVIDE OTHER MEANS.
- PROVIDE 30 FT-LBS TORQUE FOR TOP & BOT NUTS.
- SEE TABLE ON SHEET 1/8 FOR MINIMUM EDGE DISTANCE CRITERIA.

REGISTERED PROFESSIONAL ENGINEER
JEREMY C. WELTON
S4614
Jeremy C. Welton
STRUCTURAL ENGINEER
STATE OF CALIFORNIA
Signed 01.04.23



26461 Rancho Parkway South tel:
Lake Forest, CA 92630 949.916.3440

www.spirestructures.com
ENG: JCW

DETAILS

JT RACKING SYSTEMS

MEDICAL GAS ANCHORING SYSTEMS

SHEET:

7


OF

8


DATE:

01.04.23

TYPICAL FRAME WELDS FOR ALL CONFIGURATIONS



PLAN



ELEVATION A-A

ELEVATION B-B

NOTES:

1. ALL FILLET WELDS FOR 1/8" TUBE SHALL BE 1/8".
2. ALL FILLET WELDS FOR 1/4" TUBE SHALL BE 3/16".



Signed 01.04.23



26461 Rancho Parkway South tel:
 Lake Forest, CA 92630 949.916.3440
 www.spirestructures.com
 ENG: JCW

EXPANSION ANCHOR FORCES

JT RACKING SYSTEMS

MEDICAL GAS ANCHORING SYSTEMS

SHEET: 8
 OF 8
 DATE: 01.04.23

TABLE 2 - MAXIMUM EXPANSION ANCHOR FORCES (LBS, z/h=0)

			WIDTH SERIES					
			1W	1W-(L or R)	2W	2W-(L or R)	3W	3W-(L or R)
DEPTH SERIES	1D	$\Omega_0 P_u$	2,592	2,645	2,503	3,053	2,455	2,894
		$\Omega_0 V_u$	585	386	583	660	586	467
	2D	$\Omega_0 P_u$	2,546	3,633	2,856	2,643	N.A.	
		$\Omega_0 V_u$	595	579	1,127	788		
	3D	$\Omega_0 P_u$	2,792	4,029	2,159	2,556		
		$\Omega_0 V_u$	670	657	751	739		
	4D	$\Omega_0 P_u$	N.A.		2,762	3,066		
		$\Omega_0 V_u$	N.A.		968	687		

EXPANSION ANCHOR DESIGN (INCLUDING SEISMIC REDUCTION) IS PER ACI 318, CHAPTER 17, 2022 CBC, CHAPTER 19A AND IN ACCORDANCE WITH THE ICC REPORT.

BY: William Staehlin

NOTES:

- FORCES SHOWN IN SCHEDULE ARE BASED ON ORTHOGONAL LOAD COMBINATIONS WITH 100% OF FORCE IN ONE DIRECTION AND 30% OF FORCE IN THE PERPENDICULAR DIRECTION.
- "L" & "R" INDICATE LEFT AND RIGHT SIDE FRAMES.
- AREA MARKED WITH N.A. INDICATES FRAMES OF THIS DIMENSION DO NOT EXIST.
- EXPANSION ANCHORS SHALL BE $\frac{5}{8}$ " ϕ HILTI KB-TZ2 (ICC-4266) WITH $4\frac{1}{2}$ " NOMINAL EMBEDMENT & 4" EFFECTIVE EMBEDMENT.
- MAXIMUM $S_{DS} = 1.93g$ PER TABLE 1 ON SHEET 2/8.
- SEOR TO CHECK STRUCTURE FOR THE LOADS SHOWN DIVIDED BY 2 (TO REMOVE THE OVERSTRENGTH FACTOR).

TABLE 3 - MAXIMUM THRU-BOLT ANCHOR FORCES (LBS, z/h \leq 1)

			WIDTH SERIES 1/04/2023					
			1W	1W (L or R)	2W	2W (L or R)	3W	3W (L or R)
DEPTH SERIES	1D	P_u	3,888	3,968	3,754	4,580	3,683	4,341
		$\Omega_0 V_u$	1,754	1,158	1,750	1,980	1,758	701
	2D	P_u	3,819	5,449	4,284	3,965	N.A.	
		$\Omega_0 V_u$	1,784	1,736	3,380	2,366		
	3D	P_u	4,188	6,043	3,239	3,834		
		$\Omega_0 V_u$	2,010	1,972	2,254	2,218		
	4D	P_u	N.A.		4,144	4,599		
		$\Omega_0 V_u$	N.A.		2,904	2,060		

NOTES:

- SEE NOTES ON TABLE 2 FOR ADDITIONAL INFORMATION.
- ANCHORS SHALL BE $\frac{5}{8}$ " ϕ A36 RODS (SEE DETAILS AND GENERAL NOTES FOR ADDITIONAL INFORMATION).
- MAXIMUM $S_{DS} = 1.93g$ PER TABLE 1 ON SHEET 2/8.
- ALTERNATE DESIGN FOR EXPANSION ANCHORS (WHEN S_{DS} IS SMALLER & WHEN ADEQUATE SLABS ARE PRESENT: SEE TABLE 1 FOR COEFFICIENTS & EXAMPLE CALCULATION FOR MAXIMUM (z/h) FOR APPLICABILITY.
- SEOR TO CHECK STRUCTURE FOR THE LOADS SHOWN WITH $\Omega_0 V_u$ DIVIDED BY 2 (TO REMOVE OVERSTRENGTH FACTOR).

