



**OFFICE OF STATEWIDE HEALTH PLANNING AND DEVELOPMENT  
FACILITIES DEVELOPMENT DIVISION**

**APPLICATION FOR OSHPD PREAPPROVAL OF  
MANUFACTURER'S CERTIFICATION (OPM)**

OFFICE USE ONLY

**APPLICATION #: OPM-0454**

**OSHPD Preapproval of Manufacturer's Certification (OPM)**

Type:  New  Renewal/Update

**Manufacturer Information**

Manufacturer: Omniceil, Inc.

Manufacturer's Technical Representative: Todd Kijowski

Mailing Address: 51 Pennwood Place, Suite 400, Warrendale, PA 15086

Telephone: (724) 741-7777 Email: Todd.Kijowski@omnicell.com

**Product Information**

Product Name: OMNICELL VBM 200

Product Type: Automated Pharmacy

Product Model Number: VBM 200F, VBM 200DS

General Description: Automated medication dispensing unit

**Applicant Information**


Applicant Company Name: Omincell, Inc

Contact Person: Todd Kijowski

Mailing Address: 51 Pennwood Place, Suite 400, Warrendale, PA 15086

Telephone: (724) 741-7777 Email: todd.Kkjowski@omnicell.com

Title: Engineer V Mechanical Design



\*Access to Safe, Quality Healthcare Environments that Meet California's Diverse and Dynamic Needs\*

STATE OF CALIFORNIA – HEALTH AND HUMAN SERVICES AGENCY





**OFFICE OF STATEWIDE HEALTH PLANNING AND DEVELOPMENT  
FACILITIES DEVELOPMENT DIVISION**

**Registered Design Professional Preparing Engineering Recommendations**

Company Name: DEGENKOLB ENGINEERS

Name: Chad Closs

California License Number: S5946

Mailing Address: 225 Broadway, Suite 1325, San Diego, CA 92101

Telephone: (858) 699-5412

Email: ccloss@degenkolb.com

**OSHPD Special Seismic Certification Preapproval (OSP)**

Special Seismic Certification is preapproved under OSP

OSP Number: \_\_\_\_\_

**Certification Method**

Testing in accordance with:  ICC-ES AC156  FM 1950-16

Other(s) (Please Specify): \_\_\_\_\_

\*Use of criteria other than those adopted by the California Building Standards Code, 2019 (CBSC 2019) for component supports and attachments are not permitted. For distribution system, interior partition wall, and suspended ceiling seismic bracings, test criteria other than those adopted in the CBSC 2019 may be used when approved by OSHPD prior to testing.

Analysis

Experience Data

Combination of Testing, Analysis, and/or Experience Data (Please Specify): \_\_\_\_\_

**OSHPD Approval**

Date: 9/14/2021

Name: Kamalpreet Kalsi

Title: Senior Structural Engineer

Condition of Approval (if applicable): \_\_\_\_\_





**OSHPD PRE-APPROVAL OF MANUFACTURER'S CERTIFICATION**

**OPM-0454-19**  
**OMNICELL VBM 200**

DEGENKOLB ENGINEERS  
 225 Broadway, Suite 1325  
 San Diego, CA 92101  
 619.515.0299 PHONE  
 619.515.0298 FAX



**CABINET MODELS**

**OMNICELL VBM 200F, VBM 200DS**

GENERAL NOTES:

1. THIS OSHPD PREAPPROVAL OF MANUFACTURER'S CERTIFICATION (OPM) IS BASED ON THE 2019 CALIFORNIA BUILDING CODE (CBC). THE DEMAND (DESIGN FORCES) FOR USE WITH THIS OPM SHALL BE BASED ON THE CBC 2019.
2. PRE-APPROVED DESIGN AND MATERIALS CONFORM WITH THE 2019 EDITION OF THE CALIFORNIA BUILDING CODE. DETAILS WITHIN THIS PRE-APPROVAL MAY BE USED ANYWHERE IN THE STATE OF CALIFORNIA WHERE  $S_{Ds} \leq 2.00$  FOR SUPPORTS & ATTACHEMENT TO S.O.G AND THRU BOLT OPTIONS (CASES 1 & 2).
3. SEISMIC FORCES ON EQUIPMENT DETERMINED PER THE 2019 CBC & ASCE 7-16 SECTION 13.3. ALL LOADS IN THIS PRE-APPROVAL ARE AT STRENGTH LEVEL AND SHALL BE USED FOR STRENGTH DESIGN.

CASE 1 (EQUIPMENT ABOVE GRADE TO ROOF, THRU-BOLT OPTION):

$S_{Ds} \leq 2.00$ ,  $a_p=1.0$ ,  
 $R_p=1.5$ ,  $I_p=1.5$ ,  $\Omega_o=1.5$ ,  $z/h \leq 1.0$   
 i.  $F_p=2.40W_p$ ,  $F_v=0.40W_p$

CASE 2 (EQUIPMENT AT OR BELOW GRADE, EXPANSION ANCHOR OPTION):

$S_{Ds} \leq 2.00$ ,  $a_p=1.0$ ,  
 $R_p=1.5$ ,  $I_p=1.5$ ,  $z/h = 0.0$ ,  $\Omega_o=1.5$   
 i.  $F_p=0.80W_p$ ,  $F_v=0.40W_p$

4. THE STRUCTURAL ENGINEER-OF-RECORD (S.E.O.R.) IS RESPONSIBLE FOR THE FOLLOWING:
  - a. VERIFY THAT THE ANCHORS ARE AN ADEQUATE DISTANCE FROM ANY SLAB OPENINGS OR EDGES.
  - b. VERIFY THAT THE ANCHORS ARE AN ADEQUATE DISTANCE FROM ANY NEW OR EXISTING ANCHORS.
  - c. DESIGN ANY SUPPLEMENTARY MEMBERS AND THEIR ATTACHMENTS WHICH THE UNIT IS ANCHORED TO. VERIFY THE ADEQUACY OF ANY EXISTING MEMBERS AND THEIR ATTACHMENTS WHICH THE UNIT IS ANCHORED TO FOR THE FORCES EXERTED ON THEM BY THE UNIT IN ADDITION TO ALL OTHER LOADS AND FORCES.
  - d. VERIFY THAT THE INSTALLATION IS IN CONFORMANCE WITH THE 2019 CBC AND WITH THE DETAILS SHOWN IN THIS PRE-APPROVAL. VERIFY THAT THE EQUIPMENT'S ACTUAL WEIGHT, CG LOCATION, ANCHOR LOCATIONS, ANCHOR DETAILS AND THE MATERIAL AND GAGE OF THE UNIT WHERE ATTACHMENTS ARE MADE AGREE WITH THE INFORMATION SHOWN IN THIS PRE-APPROVAL.
5. THE MANUFACTURER SUPPLIED BASE BRACKETS HAVE BEEN EVALUATED FOR THE WORST CASE LOADING PER THE 2019 CBC. STRUCTURAL ENGINEER-OF-RECORD (S.E.O.R.) SHALL EVALUATE BRACKET ANCHORAGE FOR CONDITIONS THAT VARY FROM THIS PRE-APPROVAL.

6. CONTRACTOR/INSPECTOR OF RECORD MUST VERIFY ANCHOR SPACING TO EXISTING ADJACENT ANCHORS IS TO BE GREATER THAN 8".
7. THIS OPM COVERS ONLY THE SUPPORTS AND ATTACHMENTS OF THE UNIT TO THE STRUCTURE.
8. IF ANY ANCHOR FAILS DURING TESTING, UNIT MUST BE MOVED SO THAT NO ANCHOR IS WITHIN 8" OF AN ABANDONED ANCHOR.
9. EXPANSION OR WEDGE ANCHORS INTO CONCRETE: HILTI HSL-3 (ICC ESR-1545) AND HILTI KB-TZ2 (ICC ESR-4266). INSTALL ANCHORS IN ACCORDANCE WITH THE ICC REPORT AND MANUFACTURER'S RECOMMENDATIONS. TEST AT LEAST 50% OF ANCHORS NO SOONER THAN 24 HOURS AFTER INSTALLATIONS. TESTS SHALL BE CONDUCTED IN THE PRESENCE OF THE INSPECTOR OF RECORD (IOR) AND A REPORT OF THE TEST RESULTS SHALL BE SUBMITTED TO OSHPD.

TEST PER ONE OF THE FOLLOWING METHODS:

- A. DIRECT PULL TENSION TEST. ANCHOR IS ACCEPTABLE IF NO MOVEMENT IS OBSERVED AT THE TEST LOAD GIVEN IN TABLE BELOW. MOVEMENT MAY BE DETERMINED WHEN THE WASHER UNDER THE NUT BECOMES LOOSE.
- B. TORQUE WRENCH TEST: TEST ANCHORS TO THE REQUIRED TORQUE LOAD GIVEN IN TABLE BELOW WITHIN THE LIMIT OF ONE-HALF TURN OF THE NUT.



10. FOR BOLTS THROUGH CONCRETE FILL ON METAL DECK:
  - A. BOLTS SHALL BE TORQUED BY 3/4 TURN OF THE NUTS AFTER THE SNUG TIGHT CONDITION (SNUG TIGHT CONDITION IS DEFINED AS THE TIGHTNESS REQUIRED TO BRING THE CONNECTED PLIES INTO FIRM CONTACT) IS ACHIEVED.
  - B. THRU-BOLTS IN CONCRETE SHALL RECEIVE SPECIAL INSPECTION IN ACCORDANCE WITH REQUIREMENTS FOR POST-INSTALLED ANCHORS.
11. INSTALLATION PROCEDURE:
  - A. MOUNT BASE BRACKETS TO EXISTING STRUCTURE WITH THROUGH BOLTS OR EXPANSION ANCHORS AS SPECIFIED FOR CASE 1 OR 2.
  - B. ROLL UNIT OVER BASE BRACKETS AND ATTACH UNIT TO BASE BRACKETS WITH SPECIFIED BOLT, PLATE WASHER AND SPACER.

ANCHOR TEST LOAD VALUES									
ANCHOR TYPE	ANCHOR DIAMETER	EMBED hef	TENSION LOAD (LBS)	TORQUE LOAD (FT-LBS)	f <sub>c</sub> MIN (PSI)	MINIMUM EDGE DIST REQ.	MINIMUM SPACING REQ.	CONCRETE TYPE	MIN CONC. THICKNESS
HILTI HSL-3	M10	2-3/4"	2,640	50	3,000	36"	5"	NORMAL WEIGHT	5"
HILTI KB-TZ2	1/2"	2"	2,010	50	3,000	-	6 3/4"	SAND LIGHT WEIGHT	2 1/2"

CABINET MODELS

OMNICELL VBM 200F, VBM 200DS

CASE 1 - CABINETS ABOVE GRADE



MODEL	Wp (LBS)	FORCES				CABINET PROPERTIES		
		Rult1 (LBS/BOLT)	Rult2 (LBS/BOLT)	$\Omega_0$ Vult (LBS/BOLT GROUP)	Tult (LBS/BOLT)	L (in)	W (in)	H (in)
200F, 200DS	2247	4904	1752	3140	4737	62	36	90

MAX. DRILLED HOLE SIZE = BOLT DIAM. PLUS 1/16"

FRONT ELEVATION

SEE "MINIMUM STEEL DECK REQUIREMENTS" DETAIL FOR SLAB PROPERTIES ON PAGE 3


SIDE ELEVATION

L7x4x3/8 LLH, TYP. ASTM A36

NOTES:

1. THE DESIGN OF SUPPORTS AND ATTACHMENTS CONFORMS TO THE 2019 CALIFORNIA BUILDING CODE.
2. Rults, Vult AND Tult GIVEN ARE FACTORED LOADS AT STRENGTH LEVEL. FINAL DEMAND FORCES FOR BEARING ON CONCRETE AND BREAK OUT OF CONCRETE SHALL INCLUDE OVERSTRENGTH FACTOR  $\Omega_0$  AS DEFINED BY ASCE 7-16.
3. SEE GENERAL NOTES SECTION ON PAGE 1.
4. FOR THE SUPPORT AND ATTACHMENT DESIGN, THE MOST CRITICAL LOAD COMBINATION IS  $(0.9 - 0.2S_{DS}) \times DL$
5. SEE PAGE 5 FOR LOCATION OF APPLIED FORCES IN BASE BRACKET.
6. S.E.O.R. MAY RECALCULATE MAX ANCHOR FORCES Rult, Vult AND Tult AT THEIR DISCRETION, BASED ON PROJECT SPECIFIC SEISMIC DEMANDS SUBJECT TO OSHPD REVIEW/APPROVAL
7. TOTAL WEIGHT (Wp) IS A MAXIMUM. THIS PREAPPROVAL ENCOMPASSES ALL WEIGHTS UP TO THE MAXIMUM SHOWN.
8. EQUIPMENT MANUFACTURER MUST DESIGN UNIT TO MAKE Hcg EQUAL OR LESS THAN THE HEIGHT DIMENSION SHOWN.
9. SEE "MINIMUM STEEL DECK REQUIREMENTS" DETAIL FOR SLAB PROPERTIES ON PAGE 3 OF 5

1/2"Ø A325 THRU-BOLT IN STANDARD SIZE HOLE AT BASE BRACKET AND ANGLE BELOW SLAB, (2) TOTAL PER BRACKET




PLAN SECTION C-C

CABINET MODELS


OMNICELL VBM 200F, VBM 200DS

**MINIMUM STEEL DECK REQUIREMENTS**



**NOTES:**

1. PROVIDE 1/2" Ø HILTI KB-TZ2 W/ 2" EMBED EXPANSION ANCHORS TO SUPPORT ANGLE. INSTALL ON THE SLAB RIB INDEPENDENT FROM THROUGH BOLTS. EXTEND ANGLE AS REQUIRED. DO NOT INSTALL EXPANSION ANCHORS IN SLAB RIBS WHERE THROUGH BOLTS ARE PRESENT.
2. W-STEEL DECK TO BE 20 GAGE MIN.







CABINET MODELS

OMNICELL VBM 200F, VBM 200DS

CASE 2 - CABINETS AT GRADE OR BELOW



MODEL	Wp (LBS)	FORCES				CABINET PROPERTIES		
		Rult1 (LBS/BOLT)	Rult2 (LBS/BOLT)	$\Omega_o$ Vult (LBS/BOLT)	$\Omega_o$ Tult (LBS/BOLT)	L (in)	W (in)	H (in)
200F, 200DS	2247	1659	657	578	2277	62	36	90


$F_p = 0.90 W_p [S_{DS} \leq 2.00, I_p = 1.5, R_p = 1.5, a_p = 1.0, \Omega_o = 1.5, z/h = 0]$   
 $F_v = 0.40 W_p$   
 Rult1 = MAXIMUM BOLT UPLIFT FORCE AT STRENGTH LEVEL AT UNDERSIDE OF UNIT  
 Rult2 = MAXIMUM BOLT SHEAR FORCE AT STRENGTH LEVEL AT UNDERSIDE OF UNIT  
 Vult = MAXIMUM SHEAR PER EXPANSION ANCHOR AT STRENGTH LEVEL  
 Tult = MAXIMUM ANCHOR TENSION FORCE AT STRENGTH LEVEL  
 Wp = TOTAL WEIGHT; SEE PG 5 OF 5 FOR FORCE VECTORS

NOTES:

1. THE DESIGN OF SUPPORTS AND ATTACHMENTS CONFORMS TO THE 2019 CALIFORNIA BUILDING CODE.
2. Rults, Vults AND Tult GIVEN ARE FACTORED LOADS AT STRENGTH LEVEL. FINAL DEMAND FORCES FOR BEARING ON CONCRETE AND BREAK OUT OF CONCRETE INCLUDE OVERSTRENGTH FACTOR  $\Omega_o$  AS DEFINED BY ASCE 7-16.
3. SEE GENERAL NOTES SECTION ON PAGE 1.
4. FOR THE SUPPORT AND ATTACHMENT DESIGN, THE MOST CRITICAL LOAD COMBINATION IS  $(0.9 - 0.2S_{DS}) \times DL$
5. SEE PAGE 5 FOR LOCATION OF APPLIED FORCES IN BASE BRACKET.
6. S.E.O.R. MAY RECALCULATE MAX. ANCHOR FORCES Rult, Vult AND Tult, AT THEIR DISCRETION, BASED ON PROJECT SPECIFIC SEISMIC DEMANDS SUBJECT TO OSHPD REVIEW/APPROVAL.
7. TOTAL WEIGHT (Wp) IS A MAXIMUM. THIS PREAPPROVAL ENCOMPASSES ALL WEIGHTS UP TO THE MAXIMUM SHOWN.
8. EQUIPMENT MANUFACTURER MUST DESIGN UNIT TO MAKE Hcg EQUAL OR LESS THAN THE HEIGHT DIMENSION SHOWN.
9. SEE "MINIMUM STEEL DECK REQUIREMENTS" DETAIL FOR SLAB PROPERTIES ON PAGE 3.

HILTI HSL-3 M10 EXPANSION ANCHORS W/ A MIN. HOLE DEPTH INTO CONC. OF 3-1/2" TO PROVIDE AN EFFECTIVE EMBEDMENT OF 2-3/4". INSTALL IN STANDARD SIZE HOLE AT BASE BRACKET, (2) EXPANSION ANCHORS TOTAL PER BRACKET




MANUF. PROVIDE BASE BRACKET SEE PAGE 5 FOR PROPERTIES AND ATTACHMENT TO UNIT



PLAN SECTION C-C


CABINET MODELS

OMNICELL VBM 200F, VBM 200DS



FORCE DISTRIBUTION IN BASE BRACKET

EXPANSION ANCHOR OR THRU-BOLT PER PAGE 4 OR 2, RESPECTIVELY, SHOWN IS EXPANSION ANCHOR



- NOTE:**
1. AS DEFINED BY AISC 360-16, THE DIAMETER OF A STANDARD SIZE HOLES EQUALS THE BOLT DIAMETER + 1/16"
  2. SEE PAGES 2 AND 4 FOR BRACKET FORCES.