

OFFICE OF STATEWIDE HEALTH PLANNING AND DEVELOPMENT FACILITIES DEVELOPMENT DIVISION

APPLICATION FOR OSHPD PREAPPROVAL
OF MANUFACTURER'S CERTIFICATION (OPM) APPLICATION #: OPM-0541-19
OF MANUFACTURER'S CERTIFICATION (OPM) APPLICATION #: OPM-0541-19
OSHPD Preapproval of Manufacturer's Certification (OPM)
Type: ☐ New ☐ Renewal ☐ Update to Pre-CBC 2013 OPA Number:
Manufacturer Information
Manufacturer: Humanscale
Manufacturer's Technical Representative: Aaron Klein
Mailing Address 41114 Avenue of the American 15th Floor New York NV 10026
Mailing Address: 1114 Avenue of the Americas, 15 th Floor, New York, NY. 10036
Telephone: On File Email: DOn File
Product Information
Product Name: VFlex and V6 Work Stations w/47" Wall Track and Horizontal Support Rails
Product Type: Computer OPM-0541-19
TIME STATE OF THE
Product Model Number: Vflex, V6 BY: Jeffrey Kikumoto
General Description: Wall Mounted Computer Work Stations
G
DATE: 04/21/2020
Applicant Information
Applicant Company Name: EASE Co. BUILDING
Contact Person: Jonathan Roberson, S.E.
Mailing Address: 5877 Pine Ave. Suite 210, Chino Hills, CA. 91709
Telephone: (909) 606-7622 Email: J.Roberson@EASECo.com
I hereby agree to reimburse the Office of Statewide Health Planning and Development review fees in
accordance with the California Administrative Code, 2019.

Signature of Applicant:

Principal Engineer

Title:

EASE Co.

Company Name:

Date: 6/28/19



OFFICE OF STATEWIDE HEALTH PLANNING AND DEVELOPMENT FACILITIES DEVELOPMENT DIVISION

Registered Design Professional Preparing Engineering Recommendations
Company Name: EASE Co.
Name: Jonathan Roberson, S.E. California License Number: S4197
Mailing Address: 5877 Pine Ave. Suite 210, Chino Hills, CA. 91709
Telephone: 909-606-7622 Email: J.Roberson@EASECo.com
OSHPD Special Seismic Certification Preapproval (OSP)
 □ Special Seismic Certification is preapproved under OSP- (Separate application for OSP is required) □ Special Seismic Certification is not preapproved
Certification Method(s)
 ☐ Testing in accordance with: ☐ Other* (Please Specify): ☐ Testing in accordance with: ☐ ICC-ES AC156 ☐ FM 1950-16 ☐ FM 1950-16
*Use of criteria other than those adopted by the California Building Standards Code, 2017 (CBSC 2017) for component supports and attachments are not permitted. For distribution system, interior partition wall, and suspended ceiling seismic bracings, test criteria other than those adopted in the CBSC 2017 may be used when approved by OSHPD prior to testing. Analysis Experience Data Combination of Testing, Analysis, and/or Experience Data (Please Specify):
List of Attachments Supporting the Manufacturer's Certification
 ☐ Test Report ☐ Other(s) (Please Specify): Calculations ☐ Manufacturer's Catalog
OFFICE USE ONLY – OSHPD APPROVAL VALID FOR CBC 2017 & ALL PRE-2017 CODE BASED PROJECTS
Signature: Date:
Print Name:
Condition of Approval (if applicable):



5877 Pine Ave, Ste. 210 Chino Hills, CA. 91709 Phn: (909) 606-7622

Office of Statewide Health Planning and Development

PREAPPROVAL OF MANUFACTURER'S CERTIFICATION OPM-0541-19

THIS PREAPPROVAL CONFORMS TO THE 2019 CALIFORNIA BUILDING CODE

MANUFACTURER: EQUIPMENT NAME:

HUMANSCALE HEALTHCARE

VFLEX AND V6 WORK STATIONS W/ 47" WALL TRACK AND HORIZ SUPPORT RAILS

Sheet: 1 of 6

Date: 4/17/20

GENERAL NOTES

- 1. THIS OSHPD PREAPPROVAL OF MANUFACTURER'S CERTIFICATION (OPM) IS BASED ON THE 2019 CBC. THE DEMANDS (DESIGN FORCES) FOR USE WITH THIS OPM SHALL BE BASED ON THE 2019 CBC
- 2. THIS DOCUMENT MAY ONLY BE USED WITH THE EXPRESS WRITTEN CONSENT OF THE MANUFACTURER LISTED ABOVE FOR THE SPECIFIC PROJECT SITE AND INSTALLATION LOCATION. THIS DOCUMENT IS INVALID WITHOUT SUCH CONSENT.
- 3. THIS PREAPPROVAL CONFORMS TO THE 2019 CALIFORNIA BUILDING CODE.
- 4. FORCES PER ASCE 7-16 SECTION 13.3-1, EQUATIONS 13.3-1, 13.3-2 & 13.3-3, WHERE SDS = 1.70 & 2.00, $A_p = 2.5$, $A_p = 2.$
- 5. THE DETAILS IN THIS PREAPPROVAL MAY BE USED AT ANY LOCATION IN THE STATE OF CALIFORNIA, WHERE SDS IS NOT GREATER THAN 2.20.
- 6. ALL DESIGN FORCES SHOWN ON THE DRAWINGS ARE FACTORED LOADS THAT SHALL BE USED FOR STRENGTH DESIGN.
- 7. SHEET METAL SCREWS SHALL BE TEKS SCREWS BY ITW BUILDEX (ICC ESR-1976).
- 8. THIS PREAPPROVAL COVERS ONLY THE SUPPORTS AND ATTACHMENTS OF THE EQUIPMENT TO THE STRUCTURE.
- 9. RESPONSIBILITIES OF THE STRUCTURAL ENGINEER OF RECORD OF THE BUILDING
 - A. PROVIDE SUPPORTING STRUCTURE REQUIRED TO SUPPORT WEIGHTS AND FORCES SHOWN, IN ADDITION TO ALL OTHER LOADS.
 - B. VERIFY THAT THE INSTALLATION IS IN CONFORMANCE WITH THE 2019 CBC AND WITH THE DETAILS SHOWN IN THIS PREAPPROVAL. VERIFY THAT THE ACTUAL EQUIPMENT'S WEIGHT, CG LOCATION, ANCHOR LOCATIONS, ANCHOR DETAILS AND THE MATERIAL AND GAGE OF THE UNIT WHERE ATTACHMENTS ARE MADE AGREE WITH THE INFORMATION SHOWN ON THE PREAPPROVAL DOCUMENTS.
 - C. VERIFY THAT THE COMBINATION OF SDS & z/h RESULT IN SEISMIC FORCES (Eh , Ev) THAT ARE NOT GREATER THAN THE VALUES ON THE DETAILS.
 - D. DESIGN BACKING BARS, STUDS, ETC. WHICH THE UNITS ARE ATTACHED TO AS NOTED ON THE DRAWINGS.

www.EquipmentAnchorage.com

HUMANSCALE HEALTHCARE

DES. J. ROBERSON

11-1904


SHEET

WFLEX AND V6 WORK STATIONS
W/ 47" WALL TRACK AND HORIZ SUPPORT RAILS

DATE 4/17/20

JOB NO.

of 6 SHEETS



1. FORCES ARE DETERMINED PER 2019 CALIFORNIA BUILDING CODE AND ASCE 7-16. STRENGTH DESIGN IS USED. (SDs = 2.00, a_p = 2.5, I_p = 1.5, R_p = 2.5, $z/h \le 1$)

HORIZONTAL FORCE (Eh) = 3.60 Wp VERTICAL FORCE (Ev) = 0.40 Wp

- 2. CENTER OF GRAVITY (C.G.) AND WEIGHT ARE THE GOVERNING PARAMETERS FOR DESIGN. THIS PREAPPROVAL ENCOMPASSES ALL WEIGHTS UP TO THE MAXIMUM WEIGHT SHOWN.
- 3. STRUCTURAL ENGINEER OF RECORD FOR THE BUILDING SHALL PROVIDE SUPPORT STRUCTURE DESIGNED TO SUPPORT WEIGHTS AND FORCES SHOWN, IN COMBINATION WITH ALL OTHER LOADS THAT MAY BE PRESENT.
- 4. SEE GENERAL NOTES: SHEETS 1

EQUIPMENT ANCHORAGE & SEISMIC ENGINEERING www.EquipmentAnchorage.com

HUMANSCALE HEALTHCARE

DES. J. ROBERSON

_

JOB NO. 11-1904


3

SHEET

WFLEX AND V6 WORK STATIONS W/ 47" WALL TRACK AND HORIZ SUPPORT RAILS

DATE 4/17/20

of 6 SHEETS





www.EquipmentAnchorage.com

HUMANSCALE HEALTHCARE

DE8. J. ROBERSON

11-1904


4

WFLEX AND V6 WORK STATIONS
W/ 47" WALL TRACK AND HORIZ SUPPORT RAILS

DATE 4/17/20

JOB NO.

of 6 SHEETS



1. FORCES ARE DETERMINED PER 2019 CALIFORNIA BUILDING CODE AND ASCE 7-16. STRENGTH DESIGN IS USED. (SDs = 1.70, α_p = 2.5, I_p = 1.5, R_p = 2.5, $z/h \le 1$)

HORIZONTAL FORCE (En) = 3.06 Wp VERTICAL FORCE (Ev) = 0.34 Wp

- 2. CENTER OF GRAVITY (C.G.) AND WEIGHT ARE THE GOVERNING PARAMETERS FOR DESIGN. THIS PREAPPROVAL ENCOMPASSES ALL WEIGHTS UP TO THE MAXIMUM WEIGHT SHOWN.
- 3. STRUCTURAL ENGINEER OF RECORD FOR THE BUILDING SHALL PROVIDE SUPPORT STRUCTURE DESIGNED TO SUPPORT WEIGHTS AND FORCES SHOWN, IN COMBINATION WITH ALL OTHER LOADS THAT MAY BE PRESENT.
- 4. SEE GENERAL NOTES: SHEETS 1.

www.EquipmentAnchorage.com

OF

HUMANSCALE HEALTHCARE

DES. J. ROBERSON

4/17/20

5


SHEET


WFLEX AND V6 WORK STATIONS W/ 47" WALL TRACK AND HORIZ SUPPORT RAILS

ЈОВ NO. 11-1904

DATE

6 SHEETS





www.EquipmentAnchorage.com

HUMANSCALE HEALTHCARE

DES. J. ROBERSON

4/17/20

VFLEX AND V6 WORK STATIONS W/ 47" WALL TRACK AND HORIZ SUPPORT RAILS DATE

11-1904 JOB NO.

SHEET

SHEETS

OF MAX Sps ≤ 2.00 SEISMIC SUPPORTS & ATTACHMENTS **WALL MOUNTED** _0.71" 2.08" 26" ALUMINUM RAILS TYP (6105-T5, Fy=35 KSI MIN) (3 TOTAL) 00 C.G. WT. = E 80 LB (MAX) $(\overline{Z} = 28")$ 38.36" USE (2)- M6 (CL 8.8) BOLTS W/ T-NUT (BY HUMANSCALE) B (3 LOCATIONS, 6 TOTAL) ELEVATION AT 47" WALL TRACK (CONNECTION OF VERT TRACK TO HORIZ RAILS) BUILDING

