

APPLICATION FOR OSHPD SPECIAL SEISMIC	OFFICE USE ONLY			
CERTIFICATION PREAPPROVAL (OSP)	APPLICATION #:	OSP – 0012		
OSHPD Special Seismic Certification Preapproval (OSP)				
Type: 🗌 New 🛛 Renewal				
Manufacturer Information				
Manufacturer: Eaton				
Manufacturer's Technical Representative: Art Jur				
Mailing Address: 3990 Old Tasso Road NE, Cleveland, TN 37312				
Telephone: 423-478-0201	@eaton.com			
Product Information	MD,			
Product Name: HD Safety Switches OSHPD	TT I			
Product Type: Low Voltage Switching Devices OSP-0012	Î			
Product Model Number: See Product Range Summary (List all unique product identification numbers and/or part numbers) Options of the second	nd ver distribution system 1200A, 2-6 poles, 120	ns per UL 98 and KS-1. D-600 Vac/Vdc. NEMA 1, 3R		
Mounting Description: <u>Rigid wall mounted</u> .	010			
Applicant Information	ODE			
Applicant Company Name: Eaton				
Contact Person: Eddie Wilkie				
Mailing Address: 175 Vista Blvd, Arden, NC 28704				
Telephone: 828-651-0707 Email: eddiew	ilkie@eaton.com			
I hereby agree to reimburse the Office of Statewide Health F accordance with the California Administrative Code, 2016.	Planning and Dev	elopment review fees in		
Signature of Applicant: _ Eddie Wilkie	D.	ate: <u>11/21/19</u>		
Title: Director of Engineering Company Name: Eaton				
"Access to Safe, Quality Healthcare Environments that Meet California's Diverse and Dynamic Needs"	. IL AM AAAA	OSHPD		
STATE OF CALIFORNIA – HEALTH AND HUMAN SERVICES AGENCY OSH-FD-759 (REV 09/05/19)	AND MANA	Page 1 of 3		

OFFICE OF STATEWIDE HEALTH PLANNING AND DEVELOPMENT FACILITIES DEVELOPMENT DIVISION

California Licensed Structural Engineer Responsible for the Engineering and Test Report(s)											
Company Name: ISAT											
Name: William V. Joerger California License Number: SE 4545											
Mailing Address: 1020 Crews Road, Quite Q, Matthews, NC 28105											
Telephone: 510-714-0216 Email: wvjoerger@isatsb.com											
Supports and Attachments Preapproval											
Supports and attachments are preapproved under OPM- (Separate application for OSHPD Preapproval of Manufacturer's Certification (OPM) of Supports and attachments is required)											
Supports and attachments are not preapproved											
Certification Method											
 Testing in accordance with: Other (Please Specify): 											
SP-0012											
Testing Laboratory											
Company Name: NTS Laboratories DATE: 06/22/2020											
Contact Name: Tom Boonarkat											
Mailing Address: P.O. Box 77777, Huntsville, AL 35807											
Telephone: 256-716-4291 Email: Tom.Boonarkat@nts.com											

OFFICE OF STATEWIDE HEALTH PLANNING AND DEVELOPMENT FACILITIES DEVELOPMENT DIVISION

Seismic Parameters
Design in accordance with ASCE 7-10 Chapter 13: 🖂 Yes 🔲 No
Design Basis of Equipment or Components (Fp/Wp) = <u>2.06</u>
S_{DS} (Design spectral response acceleration at short period, g) = 2.74
a _p (In-structure equipment or component amplification factor) = <u>2.5</u>
R _p (Equipment or component response modification factor) = <u>6.0</u>
Ω_0 (System overstrength factor) = _2.0
I _p (Importance factor) = 1.5
z/h (Height factor ratio) = _1
Equipment or Component Natural Frequencies (Hz) = <u>N/A, wall mounted.</u>
Overall dimensions and weight (or range thereof) = See Product Range Summary
Equipment or Components @ grade designed in accordance with ASCE 7-10 Chapter 15: 🗌 Yes 🛛 No
Design Basis of Equipment or Components (V/W) =
S _{DS} (Design spectral response acceleration at short period, g) =
S _{D1} (Design spectral response acceleration at 1 second period, g) =
R (Response modification coefficient) =
Ω₀ (System overstrength factor) =
C₄ (Deflection amplificati <mark>on fa</mark> ctor) =
I_P (Importance factor) = 1.5 DATE: 06/22/2020
Height to Center of Gravity above base =
Equipment or Component Natural Frequencies (Hz) =
Overall dimensions and weight (or range thereof) =
Tank(s) designed in accordance with ASME BPVC, 2015: 🗌 Yes 🖾 No
List of Attachments Supporting Special Seismic Certification
🖂 Test Report(s) 🛛 Drawings 🔲 Calculations 🔲 Manufacturer's Catalog
Other(s) (Please Specify):
OSHPD Approval (For Office Use Only) – Approval Expires on December 31, 2025
1.1.1.00
Signature: Date: Date: June 22, 2020
Print Name: Timothy J. Piland Title: SSE
Special Seismic Certification Valid Up to: $S_{DS}(g) = 2.74$ $z/h = 1$
Condition of Approval (if applicable):
"Access to Safe. Quality Healthcare Environments that Meet California's Diverse and Dynamic Needs"
STATE OF CALIFORNIA – HEALTH AND HUMAN SERVICES AGENCY

STATE OF CALIFORNIA - HEALTH AND HUMAN SERVICES AGENCY OSH-FD-759 (REV 09/05/19)

Page 3 of 3



Heavy Duty Safety Switches⁴ Seismic Certification **Certified Product Range Summary**

Product	Product		Enc	losure Dimen	sions				
Numbering System	Current Rating (Amperes	Primary Voltage Class (Max)	Width (in.)	Depth ³ (in.)	Height (in.)	Weight (Ibs.)	Anchorage Type	Notes	Comments
DHXX1XXK							0.0.0.		Extrapolated
DTXX1XXK	30	600VAC/1000VDC	8-13	5-6	14-20	16-20	RCWallF	1,2	Extrapolated
DCXXXX1XXM						L FU			Extrapolated
DHXX2XXK								190	Extrapolated
DTXX2XXK	60	600VAC/1000VDC	8-13	5-6	14-20	16-20	Wall	1,2	Extrapolated
DCXXXX2XXM							CLDF		Extrapolated
DHXX3XXK							J111 L		Extrapolated
DTXX3XXK	100	600VAC/1000VDC	11-16	5-6	22-40	23-50	Wall	1,2	Extrapolated
DCXXXX3XXM					$\langle \cdot \rangle$	0			Extrapolated
DHXXX4XXK			16-24	6-7	24-56	38-100	13P-0012	1,2	Extrapolated
DTXX4XXK	200	600	10-24	0-7	24-30	38-100	Wall		Extrapolated
DT364FRK			20.75	11.25	51.75	92		NEMA 3R CS Enclosure	UUT 15
DHXX5XXK	400	600	23-27	7-9	45-78 B	115-230	othwall Pi	and 1,2	Interpolated
DTXX5XXK	400	000	23-27	7-9	43-78 D	110-250			Interpolated
DHXX6XXK	600	600	25-29	8-9	52-87	148-320	Wall	1,2	Interpolated
DTXX6XXK	000	000	23-29	6-9	32-87	146-320	Wall	1,2	Interpolated
DHXX7XXK	800	600	26-31	8-21	56-89 D	175-315	6/2 _{wall} 202	U _{1,2}	Interpolated
DTXX7XXK	800	000	20-31	0-21	30-89	175-515-	vvali	1,2	Interpolated
DHXX8XXK			41-44	12-21	71-81	465-528		1,2	Interpolated
DTXX8XXK	1200	600	41-44	12-21	/1-81	403-328	Wall	1,2	Interpolated
DT368NRK			44	25.5	81	528		NEMA 3R CS Enclosure	UUT 16
2 - Carbon Steel (3R, 12 enclosure CS) sheet metal con rension only. Does	nstruction not include handle of	perator.		CO.	NIA	BUILDING	CODE	

4 - Manufactured by Eaton.



Certified Major Component Summary Enclosures³

	Dimensions			Manufacturar	
Width (in.)	Height (in.)	Depth ¹ (in.)	Ratings ²	Manufacturer	UUT
8-13	14-20	5-6	1, 3R, 12	Eaton	Extrapolated
8-13	14-20	5-6	1, 3R, 12	Eaton	Extrapolated
11-16	22-40	5-6	1, 3R, 12	Eaton	Extrapolated
20.75	51.75	11.25	3R CS	Eaton	15
23-27	45-78	7-9	1, 3R, 12	Eaton	Interpolated
25-29	52-87	8-9	1, 3R, 12	Eaton	Interpolated
26-31	56-89	8-21	1, 3R, 12	Eaton	Interpolated
44	81	25.5	3R CS	Eaton	16

1 - Enclosure dimension only. Does not include handle operator.

2 - NEMA 3R includes rain shield and gasket material for door. NEMA 12 includes gasket material for seams.

3 - Carbon Steel (CS) sheet metal construction.

Operating Mechanisms OSP-0012								
Current Rating	Mechanism Part	Material	UUT	Manufacturer				
(Amperes)	Number	BY:TI	mothy J P	land				
30	95-927		Extrapolated	Eaton				
60	95-927		Extrapolated	Eaton				
100	95-927	DATE	Extrapolated	Eaton				
200	26-2261	Mild Carbon	15	Eaton 🚫				
400	26-2261	Steel	Interpolated	Eaton				
600	26-2261		Interpolated	Eaton				
800	26-2261	PAL	Interpolated	Eaton				
1200	26-2521	· V	BUILDIN	Eaton				



Safety Switches Resonant Frequency Summary

Report	UUT	Front to Back (Hz)	Side to Side (Hz)	Vertical (Hz)
70282R12	15	N/A*	N/A*	N/A*
70282R12	16	N/A*	N/A*	N/A*

* - UUT secured to wall fixture.



UUT 15 (Unit Under Test) Summary Sheet

Manufacturer: Eaton Corporation

Product Line: Safety Switches Model Number: DT364FRK

Product Construction Summary:

Cabinet is constructed of electro-coated carbon steel, NEMA 3R rating.

Options/Component Summary: Operating Mechanism (26-2261)

UUT Properties (As Tested)									
Weight (lbs.)		Dimensions (inches)			Lowest Natural Frequency (Hz)				
weign	t (ibs.)	Width	Depth	Height	Front-Back		Side-Side		Vertical
9	2	20.75	11.25	51.75	N,	/A	N/A		N/A
	Seismic Test Parameters								
Building Code	Test Criteria	C.G Height (in.)	S _{DS} (g)	z/h		Aflx-H	Arig-H	Aflx-V	Arig-V
CBC 2019	ICC-ES AC156	N/A	3.10	1	1.5	4.96	3.72	2.08	0.84

UUT maintained structural integrity and functionality as observed in post test inspection and operation checks.



UUT 15 (center) was mounted to a rigid wall frame using (4) 1/2" bolts. The steel frame was welded to the shake table.

UUT 16 (Unit Under Test) Summary Sheet

Manufacturer: Eaton Corporation

Product Line: Safety Switches Model Number: DT368NRK

Product Construction Summary:

Cabinet is constructed of electro-coated carbon steel, NEMA 3R rating.

Options/Component Summary: Operating Mechanism (26-2521)

UUT Properties (As Tested)									
Weight (lbs.)		Dimensions (inches)			Lowest Natural Frequency (Hz)				
weigh	t (IDS.)	Width	Depth	Height	Front-Back		Side-Side		Vertical
52	28	44	25.5	81	N,	/A	N/A		N/A
	Seismic Test Parameters								
Building Code	Test Criteria	C.G Height (in.)	S _{DS} (g)	z/h		Aflx-H	Arig-H	Aflx-V	Arig-V
CBC 2019	ICC-ES AC156	N/A	2.74	1	1.5	4.38	3.29	1.84	0.74

UUT maintained structural integrity and functionality as observed in post test inspection and operation checks.



UUT 16 (left) was mounted to a rigid wall frame using (4) 1/2 bolts. The steel frame was welded to the shake table.

Eaton Safety Switch Product Numbering System

Safety Switch

