



# APPLICATION FOR PREAPPROVAL SPECIAL SEISMIC CERTIFICATION OF EQUIPMENT AND COMPONENTS

For Office Use Only

<b>APPLICATION NO.</b>
<b>OSP -0017-10</b>

Check whether application is: NEW  RENEWAL

<b>1.0</b>	<b>Eaton Corporation</b>	<b>Eddie Wilkie</b>
	<i>Manufacturer</i>	<i>Manufacturer's Technical Representative</i>
	1000 Cherrington Parkway, Moon Township, PA 15108	175 Vista Blvd, Arden, NC 28704
	<i>Mailing Address</i>	

	828-651-0707	<a href="mailto:eddiwilkie@eaton.com">eddiwilkie@eaton.com</a>
	<i>Telephone</i>	<i>E-mail Address</i>

<b>2.0</b>	<b>Unitized Power Centers</b>	<b>Integrated Primary Switch, Transformer and LV Distribution Switchboard Substation</b>
	<i>Product Name</i>	<i>Product Type</i>

*Custom Product, order specific numbers*

*Product model No (List all unique product identification numbers and/or serial numbers)*

*General Description: Integrated Unit Substation for electrical distribution systems per applicable UL listings; Floor Mounted – Free Standing; Rear or Front Access only; Three-Phase 3 or 4 Wire; 112 through 1000-kVA; Primary 2.4 to 15-kV; Secondary 208Y/120 to 575Y/380-Volt; 50-60Hz; Multiple Sections; NEMA Type 1 ; Silver plated copper bus; Fully Rated up to 65-kAIC.*

<b>3.0</b>	<b>Eaton Corporation</b>	<b>Eddie Wilkie</b>
	<i>Applicant Company Name</i>	<i>Contact Person</i>
	1000 Cherrington Parkway, Moon Township, PA 15108	175 Vista Blvd, Arden, NC 28704
	<i>Mailing Address</i>	

	828-651-0707	<a href="mailto:eddiwilkie@eaton.com">eddiwilkie@eaton.com</a>
	<i>Telephone</i>	<i>E-mail Address</i>

I hereby agree to reimburse the Office of Statewide Health Planning and Development for the actual costs incurred by the department for review.

	3/4/11
<i>Signature of Applicant</i>	<i>Date</i>

Division Engineering Manager	Eaton Corporation
<i>Title</i>	<i>Company Name</i>

1/7



**Registered Design Professional Preparing the Report**

4.0 Westinghouse Electric Co., LLC  
*Company Name*

Nathan Glenn M35222  
*Contact Name* *California License Number*

1000 Westinghouse Drive, New Stanton, PA 15672  
*Mailing Address*

724-722-5737 glennnm@westinghouse.com  
*Telephone* *E-mail Address*

**California Licensed Structural Engineer Review and Acceptance of the Report**

5.0 William Merkel Associates  
*Company Name*

William Merkel SE1993  
*Contact Name* *California License Number*

2804 Fulton Avenue, Sacramento, CA 95821  
*Mailing Address*

916-481-1962 wmase@pacbell.net  
*Telephone* *E-mail Address*

**Anchorage Pre-Approval**

6.0  Anchorage is pre-approved under OPA-  
 (Separate application for anchorage pre-approval is required)

Anchorage is not Pre-approved

**Certification Method**

7.0  Testing in accordance with:  ICC-ES AC-156  Other (Please Specify):  
 Eaton Test Protocol, Publication SA12501SE. Test results are compared to ICC-ES AC 156 requirements to prove equivalence.

Analysis

Experience data

Combination of Testing, Analysis, and/or Experience Data (Please Specify):

**Testing Laboratory (if applicable)**

8.0 Wyle Laboratories/Clark Dynamic Testing Lab Don Smith / John Antenucci  
*Company Name* *Contact Name*

7800 Hwy 20 West / 1801 Route 51  
Huntsville, AL 35806 / Jefferson Hills, PA 15025  
*Mailing Address*

256-716-4445/412-382-7173 Don.smith@wyle.com / jantenucci@clarktesting.com  
*Telephone* *E-mail:*

2/7



**Approval Parameters**

9.0

Design in accordance with ASCE 7-05 Chapter 13:  Yes  No

Design Basis of Equipment or Components ( $F_p/W_p$ ) = 1.04g

$S_{DS}$  (Spectral response acceleration at short period) = 1.38g

$a_p$  (In-structure equipment or component amplification factor) = 2.5

$R_p$  (Equipment or component response modification factor) = 6.0

$I_p$  (Importance factor) = 1.5

$z/h$  (Height factor ratio) = 1.0

Equipment or Component fundamental period(s) = See Attachments

Building period limits (if any) = n./a

Overall dimensions and weight (or range thereof) = See Attachments

Equipment or Components @ grade designed in accordance with ASCE 7-05 Chapter 15:  Yes  No

Design Basis of Equipment or Components (VW) =

$S_{DS}$  (Spectral response acceleration at short period) =

$S_1$  (Spectral response acceleration at 1 second period) =

$R$  (Response modification coefficient) = 1.0

$\Omega_0$  (System overstrength factor) = 1.0

$C_d$  (Deflection amplification factor) = 1.0

$I_p$  (Importance factor) = 1.5

Height to Center of Gravity above base =

Equipment or Component fundamental period(s) = Sec

Overall dimensions and weight (or range thereof) =

Tank(s) designed in accordance with ASME BPVC, 2007:  Yes  No

**10.0 List of attachments supporting the special seismic certification of equipment or components:**

- Test Report  Drawings  Manufacturer's Catalog  
 Calculations  Others (Please Specify): On file under existing OSP's (LV Panelboards – OSP-0009-10, LV Switchboards – OSP-0010-10, MV Switch – OSP-0019-10)

**11.0 OSHPD Approval (For Office Use Only)**

*Chris Tokas*  
Signature & Date

4/8/2011

December 31, 2016

Chris Tokas, SHFR

Approval Expiration Date

$S_{DS}$  (g) = 1.38  $z/h$  = 1.0

Name & Title

Special Seismic Certification Valid Up to

Condition of Approval (if any): Expiration dates and limitations in OSP's referred in Section 10.0 of this application shall apply to this approval, where any component within the unit depends on certification of the OSP's referred.



**Attachment #4**  
**Unit Under Test (UUT)**  
**Summary Sheet**

Manufacturer: Eaton Corporation  
 Product Family: Unitized Power Centers  
 Model Number: GWDMVS0P06  
 Product Construction Summary:

NEMA 1 Enclosure, painted carbon steel. Open core-coil transformer (112kVA), copper windings. Assembly is attached to the foundation via (8) 1/2-13 Grade 5 bolts.

Major components include: Medium Voltage Switch, Transformer, LV panelboard with MCCB's.

UUT Properties						
Weight (lbs.)	Dimensions			Lowest Natural Frequency (Hz)		
	Depth (in.)	Width (in.)	Height (in.)	Front-Back (Hz)	Side-Side (Hz)	Vertical (Hz)
3675	36	48	80	11.4	14.6	>33

UUT Highest Passed Seismic Run Information								
Building Code	Test Criteria	S <sub>DS</sub>	z/h	I <sub>p</sub>	A <sub>FLX-H</sub>	A <sub>RIG-H</sub>	A <sub>FLX-V</sub>	A <sub>RIG-V</sub>
IBC 2009	ICC-ES AC 156	1.38	1	1.5	2.21	1.66	0.92	0.37





**Attachment #5**  
**Unit Under Test (UUT)**  
**Summary Sheet**

Manufacturer: Eaton Corporation  
 Product Family: Unitized Power Centers  
 Model Number:

**Product Construction Summary:**

NEMA 1 Enclosure, painted carbon steel. Open core-coil transformer (1000kVA), copper windings.  
 Assembly is attached to the foundation via (10) 1/2-13 Grade 5 bolts.  
 Major components include: Medium Voltage Switch, Transformer

UUT Properties						
Weight (lbs.)	Dimensions			Lowest Natural Frequency (Hz)		
	Depth (in.)	Width (in.)	Height (in.)	Front-Back (Hz)	Side-Side (Hz)	Vertical (Hz)
9010	36	96	80	6	6	30

UUT Highest Passed Seismic Run Information								
Building Code	Test Criteria	$S_{DS}$	$z/h$	$I_p$	$A_{FLX-H}$	$A_{RIG-H}$	$A_{FLX-V}$	$A_{RIG-V}$
IBC 2009	ICC-ES AC 156	1.92	1	1.5	3.06	2.3	1.28	0.52

**Page No. SS-15**  
**Test Report No. 55906R08-11A**



**TEST SETUP**  
**EUT 14**



**Attachment #3  
Seismic Certification  
Product Matrix**

Product	Product Numbering	Transformer Size (kVA)	Primary Voltage Class	Dimensions			Weight (lbs.)	Mounting Hardware	Notes	Comments
				Width (in.)	Depth (in.)	Height (in.)				
United Power Center (UPC)	Product configured per order	112	5	84	37.92	100	3675	8	1,2,3,4,5,6,8,9	Tested (EL9401), EUT #1
		112	15	84	37.92	100	4097	8	1,2,3,4,5,6,8,9	Interpolated
		150	5	84	37.92	100	4317	8	1,2,3,4,5,6,8,9	Interpolated
		150	15	84	37.92	100	4317	8	1,2,3,4,5,6,8,9	Interpolated
		225	5	84	37.92	100	4744	8	1,2,3,4,5,6,8,9	Interpolated
		225	15	84	37.92	100	4744	8	1,2,3,4,5,6,8,9	Interpolated
		300	5	84	37.92	100	5247	8	1,2,3,4,5,6,8,9	Interpolated
		300	15	84	37.92	100	5247	8	1,2,3,4,5,6,8,9	Interpolated
		500	5	84	37.92	100	5659	10	1,2,3,4,5,6,8,9	Interpolated
		500	15	84	37.92	100	5659	10	1,2,3,4,5,6,8,9	Interpolated
		750	5	84	37.92	100	6721	10	1,2,3,4,5,6,8,9	Interpolated
		750	15	84	37.92	100	6721	10	1,2,3,4,5,6,8,9	Interpolated
		1000	5	96	37.92	100	9010	10	1,2,3,4,6,7,8,9	Interpolated
		1000	15	96	37.92	100	9010	10	1,2,3,4,6,7,8,9	Tested 55906R08-11A, EUT #14

- 1 NEMA Type 1 enclosure
- 2 Mild steel sheet metal construction
- 3 Rigid floor anchored, 1/2-13 Grade 5 bolts per manufacturers floor-plan
- 4 Dimensions and weights include optional cooling fans, and ventilation packages
- 5 Single Fused Primary Switch, LV distribution in front of the transformer
- 6 Open core and coil construction, Copper and Aluminum Windings, ~~Optional~~
- 7 Single Fused Primary Switch, Separate LV switchboard close coupled to transformer, with weight and seismic performance characteristics established by separate OSP
- 8 Major Components & Vendors - Transformer/Hammond & Eaton, Enclosure/Eaton, HV Switch/Eaton, LV Panelboard (Eaton), Fuses (Eaton)
- 9-1/2-13, Grade 5 Mounting Hardware



*Powering Business Worldwide*

**Attachment #6  
Major Component Data**

Transformer Enclosure Dimensions						
Size (kVA)	Width (in.)	Depth (in.)	Height (in.)	Weight (lbs)	Transformer Vendor 1	Transformer Vendor 2
112	48	36	85	3697	Hammond	Eaton
150	48	36	85	3917	Hammond	Eaton
225	48	36	85	4074	Hammond	Eaton
300	48	36	85	4847	Hammond	Eaton
500	60	36	85	6321	Hammond	Eaton
750	60	36	85	5259	Hammond	Eaton
1000	60	36	85	8610	Hammond	Eaton

HV Switch					
Size (Amperes)	Dimensions			Weight (lbs.)	Vendor
	Width (in.)	Depth (in.)	Height (in.)		
600	36	36	80	400	Eaton