OFFICE USE ONLY APPLICATION FOR OSHPD SPECIAL SEISMIC **CERTIFICATION PREAPPROVAL (OSP)** OSP - 0025 - 10 **APPLICATION #: OSHPD Special Seismic Certification Preapproval (OSP) Manufacturer Information** ABB Inc. Manufacturer: Manufacturer's Technical Representative: Brian Akers Mailing Address: P.O. Box 38, 171 Industry Drive, Bland, VA 24315 Telephone: (276) 688-1673 Email: brian.akers@us.abb.com **Product Information** Product Name: Copper Wiring and Aluminum Wiring Coil Transformers Product Type: 112-3,000 kVA Single & 3-Phase Dry Type Transformers Product Model Number: See Certified Product Table attached (List all unique product identification numbers and/or part numbers) General Description: ABB copper wiring and aluminum wiring transformers are built with either copper or aluminum coils and are optionally braced within their enclosures with L-frames (Level 2) or A-frames (Level 3). Seismic enhancements made to the test units and modifications required to address the anomalies observed during the tests shall be incorporated into the production units Mounting Description: Rigid floor mounted **Applicant Information** Applicant Company Name: ABB Inc. Contact Person: Brian Akers Mailing Address: P.O. Box 38, 171 Industry Drive, Bland, VA 24315 Telephone: (276) 688-1673 Email: brian.akers@us.abb.com I hereby agree to reimburse the Office of Statewide Health Planning and Development review fees in accordance with the California Administrative Code, 2016. Signature of Applicant: Title: ABB Engineer Company Name: ABB Inc.

"Access to Safe, Quality Healthcare Environments that Meet California's Diverse and Dynamic Needs'





Page 1 of 3

California Licensed Structural Engineer Responsible for the Engineering and Test Report(s)
Company Name: Forell/Elsesser Engineers, Inc.
Name: Marco Scanu, SE California License Number: S4454
Mailing Address: 160 Pine St., 6th Flr., San Francisco, CA 94111
Telephone: (415) 837-0700 Email: m.scanu@forell.com
Supports and Attachments Preapproval
Supports and attachments are preapproved under OPM- (Separate application for OSHPD Preapproval of Manufacturer's Certification (OPM) of Supports and attachments is required)
Supports and attachments are not preapproved
Certification Method
☐ Testing in accordance with:☐ Other (Please Specify):
Testing Laboratory
Company Name: Wyle Laboratories
Contact Name: Rod Thornberry
Mailing Address: 7800 Hwy 20, Huntsville, AL 35806
Telephone: (256) 837-4411 Email:
Telephone: (256) 837-4411 Email:



Page 2 of 10



OFFICE OF STATEWIDE HEALTH PLANNING AND DEVELOPMENT FACILITIES DEVELOPMENT DIVISION

Seismic Parameters
Design in accordance with ASCE 7-10 Chapter 13: ⊠ Yes □ No
Design Basis of Equipment or Components (F _p /W _p) = See Certified Products Table
S _{DS} (Design spectral response acceleration at short period, g) = See Certified Products Table
a _p (In-structure equipment or component amplification factor) = 1.0
R _p (Equipment or component response modification factor) =2.5
Ω_0 (System overstrength factor) =2.0
I _p (Importance factor) = 1.5
z/h (Height factor ratio) = 1.0
Equipment or Component Natural Frequencies (Hz) = See attachment, UUT Summary Sheets
Overall dimensions and weight (or range thereof) = See attachment, Certified Products Table
Equipment or Components @ grade designed in accordance with ASCE 7-10 Chapter 15: Yes No
Design Basis of Equipment or Components (V/W) =
S _{DS} (Design spectral response acceleration at short period, g) =
S _{D1} (Design spectral response acceleration at 1 second period, g) =
R (Response modification coefficient) =
Ω_0 (System overstrength factor) =
C _d (Deflection amplification factor) =
I _P (Importance factor) = 1.5
Height to Center of Gravity above base =
Equipment or Component Natural Frequencies (Hz) =
Overall dimensions and weight (or range thereof) =
Tank(s) designed in accordance with ASME BPVC, 2015: ☐ Yes ☐ No
List of Attachments Supporting Special Seismic Certification
□ Test Report(s) □ Drawings □ Calculations □ Manufacturer's Catalog
Other(s) (Please Specify): Certified Products Table, Certified Subcomponents Table, UUT Summary Sheets
OSHPD Approval (For Office Use Only) – Approval Expires on December 31, 2022
11/1 00 Date: October 42, 2047
Signature: Date: October 12, 2017
Print Name: Timothy J. Piland Title: SSE
Special Seismic Certification Valid Up to: S _{DS} (g) = See Above z/h = 1
Condition of Approval (if applicable):

"Access to Safe, Quality Healthcare Environments that Meet California's Diverse and Dynamic Needs"





Page 3 of 3

OSP APPLICATION ABB Dry Type Transformers Product Range Summary

ABB Dry Type Transformers Product Range Summary

					Bracing (Bracing Configuration (max. S _{DS} per type)				Bracing Co	nfiguration		
Type	Max. Service Wt.	Height	Width	Depth	Α	В	С	D	Α	В	С	D	Testing Status
					S _{DS}	S _{DS}	S _{DS}	S _{DS}	F _p /W _p				
Copper Windings													
112 kVA Dry Type Transformer	2,400 lbs	60"	38"	36"									Test Report PR055313-TR-16 UUT1A, UUT1C, UUT1D
Dry Type Transformer	2,400 lbs - 21,000 lbs	60" - 120"	38" - 138"	36" - 72"	0.29	N/A	0.98	1.11	0.21	N/A	0.71	0.80	Interpolated
3000 kVA Dry Type Transformer	21,000 lbs	120"	138"	72"									Test Report T55796-1 - UUT2 UUT2C, UUT2D
Aluminum Winding	S							•					
112 kVA Dry Type Transformer	1,956 lbs	60"	48"	36"	0.37	1.35	N/A	3.00	0.27	0.97	N/A	2.16	Test Report 57467R10-1 - UUT3A, UUT3B, UUT3D

Bracing Types

Configuration A - two feet with core clamps and cross channel brackets

Configuration B - two feet with core clamps and cross channel brackets, L-frame supports and gussets

Configuration C - three feet with core clamps and cross channel brackets, L-frame supports and gussets

Configuration D - three feet structural core clamps, core clamp and cross channel brackets, and diagonal A-frame braces.

Nameplate

ABB transformers are delivered to the project site with ABB, Eaton, Cutler Hammer, Square D, Siemens, or GE nameplates. In all cases the units are designated as 0-30 MVA 3-Phase Dry Type Transformers.

Test Report PR055313-TR-16 - UUT1A, UUT1C, UUT1D

112kVA Dry Type Copper Wiring Transformer 60"H x 38"W x 36"D, 2,400 lbs 11 ga. Cold Formed Carbon Steel Floor Mounted by welding

UUT1A - Configuration A: two feet with core clamps and cross channel brackets.

UUT1C - Configuration C: three feet with core clamps and cross channel brackets, L-frame supports and gussets

UUT1D - Configuration D: three feet structural core clamps, core clamp and cross channel brackets, and diagonal A-frame braces.



UUT1A - Configuration A:



Building	Test	S _{DS}	z/h		Horizontal		Vert	ical		
Code	Criteria	(g)	2/11	I _p	A _{FLX-H} (g)	A _{RIG-H} (g)	A _{FLX-V} (g)	A _{RIG-V} (g)		
CBC 2016	ICC-ES AC 156	0.44	1.0	1.5	0.70	0.53	0.29	0.12		
Natur	al Frequencie	es (Hz)			Test Results					
F-B	S-S	٧	The UUT maintained structural integrity and functionality after							
7.9	13	N/A		the AC156 test. UUT full of contents during testing.						

UUT1C – Configuration C:



Building	Test	S _{DS}	z/h		Horiz	Horizontal		ical	
Code	Criteria	(g)	2/11	Iр	A _{FLX-H} (g)	A _{RIG-H} (g)	A _{FLX-V} (g)	A _{RIG-V} (g)	
CBC 2016	ICC-ES AC 156	1.60	1.0	1.5	2.56	1.92	1.07	0.43	
Natur	al Frequencie	es (Hz)		Test Results					
F-B	S-S	٧	The UUT maintained structural integrity and functionality after						
15	15	N/A	the AC156 test. UUT full of contents during testing.						

UUT1D – Configuration D:



Building	Test	S _{DS}	- /h					7/b	Horiz	Horizontal		ical
Code	Criteria	(g)	z/h	Ιp	A _{FLX-H} (g)	A _{RIG-H} (g)	A _{FLX-V} (g)	A _{RIG-V} (g)				
CBC 2016	ICC-ES	3.16	1.0	1.5	5.06	3.79	2.12	0.84				
CBC 2010	AC 156	3.10	1.0	1.5	5.00	3.73	2.12	0.04				
Natur	al Frequencie	es (Hz)		Test Results								
F-B	S-S	٧	The UUT maintained structural integrity and functionality after									
8.8	10.2	N/A	the AC156 test. UUT full of contents during testing.									

Test Report T55796-1 – UUT2A, UUT2C, UUT2D

3000 kVa Copper Wiring Transformer & Enclosure (Largest)
120"H x 138"W x 72"D, 21,000 lbs
14 ga. Cold Formed Carbon Steel
Floor Mounted by welding

UUT2A - Configuration A: two feet with core clamps and cross channel brackets.

UUT2C - Configuration C: three feet with core clamps and cross channel brackets, L-frame supports and gussets

UUT2D - Configuration D: three feet


structural core clamps, core clamp and cross channel brackets, and diagonal A-frame braces.



UUT2A - Configuration A:








Building	Test	S _{DS}	z/h			1	Horizo		ontal	Vert	ical
Code	Criteria	(g)	2/11	Iр	A _{FLX-H} (g)	A _{RIG-H} (g)	A _{FLX-V} (g)	A _{RIG-V} (g)			
CBC 2016	ICC-ES AC 156	0.29	1.0	1.5	0.46	0.35	0.19	0.08			
Natur	al Frequencie	es (Hz)			Test	Results					
F-B	S-S	V	The UUT maintained structural integrity and functionality after								
1.7	6.6	20.0	the AC156 test. UUT full of contents during testing.								

UUT2C – Configuration C:






Building	Test	S _{DS}	z/h		Horiz	Horizontal		ical		
Code	Criteria	(g)	2/11	Iр	A _{FLX-H} (g)	A _{RIG-H} (g)	A _{FLX-V} (g)	A _{RIG-V} (g)		
CBC 2016	ICC-ES AC 156	0.98	1.0	1.5	1.57	1.18	0.66	0.26		
Natur	al Frequencie	es (Hz)			Test Results					
F-B	S-S	٧	The UUT maintained structural integrity and functionality after							
5.5	4.4	N/A		the AC156 test. UUT full of contents during testing.						

UUT2D – Configuration D:







Building	Test	S _{DS}	- /b		Horizontal		Vertical		
Code	Criteria	(g)	z/h	Iр	A _{FLX-H} (g)	A _{RIG-H} (g)	A _{FLX-V} (g)	A _{RIG-V} (g)	
CBC 2016	ICC-ES AC 156	1.11	1.0	1.5	1.78	1.33	0.74	0.30	
Natur	al Frequencie	es (Hz)			Test	Results			
F-B	S-S	٧	The UUT maintained structural integrity and functionality after						
4.6	5.7	N/A	the AC156 test. UUT full of contents during testing.						

Test Report 57467R10-1 – UUT3A, UUT3B, UUT3D

112 kVA Aluminum Wiring Transformer & Enclosure 60"H x 48"W x 36"D, 1,956 lbs
11 ga. Cold Formed Carbon Steel
Floor Mounted by welding


UUT3A - Configuration A: two feet with core clamps and cross channel brackets.

UUT3B - Configuration B: two feet with core clamps and cross channel brackets, L-frame supports and gussets

UUT3D - Configuration D: three feet structural core clamps, core clamp and cross channel brackets, and diagonal A-frame braces.




UUT3A - Configuration A:




Building	Test	S _{DS}	- /h	, ,			7/h	Horizo	ontal	Vertical	
Code	Criteria	(g)	z/h	Ip	A _{FLX-H} (g)	A _{RIG-H} (g)	A _{FLX-V} (g)	A _{RIG-V} (g)			
CBC 2016	ICC-ES AC 156	0.37	1.0	1.5	0.59	0.44	0.25	0.10			
Natur	al Frequencie	es (Hz)		Test Results							
F-B	S-S	٧	The UUT maintained structural integrity and functionality after								
9.1	16.0	32.0	the AC156 test. UUT full of contents during testing.								

UUT3B – Configuration B:



Building	Test	S _{DS}	-/h			z/h I _n	Horizo	Horizontal		ical
Code	Criteria	(g)	2/11	Iр	A _{FLX-H} (g)	A _{RIG-H} (g)	A _{FLX-V} (g)	A _{RIG-V} (g)		
CBC 2016	ICC-ES	1.35	1.0	1.5	2.16	1.62	0.90	0.36		
CBC 2010	AC 156	1.55	1.0	1.5	2.10	1.02	0.50	0.30		
Natur	al Frequencie	es (Hz)			Test	Results				
F-B	S-S	٧	The UUT maintained structural integrity and functionality after							
16.0	17.0	27.0		the AC156 test. UUT full of contents during testing.						

UUT3D - Configuration D:



Building	Test	S _{DS}	_ /b	z/h I _p	Horizontal		Vert	ical		
Code	Criteria	(g)	2/11	Iр	A _{FLX-H} (g)	A _{RIG-H} (g)	A _{FLX-V} (g)	A _{RIG-V} (g)		
CBC 2016	ICC-ES AC 156	3.00	1.0	1.5	4.80	3.60	2.01	0.80		
Natur	al Frequencie	es (Hz)			Test	Results				
F-B	S-S	٧	The UUT maintained structural integrity and functionality after							
8.6	27.0	32.0]	the AC156 test. UUT full of contents during testing.						