



**DEPARTMENT OF HEALTH CARE ACCESS AND INFORMATION
FACILITIES DEVELOPMENT DIVISION**

**APPLICATION FOR HCAI SPECIAL SEISMIC
CERTIFICATION PREAPPROVAL (OSP)**

OFFICE USE ONLY

APPLICATION #: OSP-0044

HCAI Special Seismic Certification Preapproval (OSP)

Type: New Renewal

Manufacturer Information

Manufacturer: ABB, Inc.

Manufacturer's Technical Representative: Elwood Combs

Mailing Address: 6801 Industrial Drive, Mebane, NC 27302

Telephone: (919) 563-7624

Email: elwood.combs@us.abb.com

Product Information

Product Name: Switchgear/Switchboards

Product Type: Switchboards

Product Model Number: See Certified Product Table attached

General Description: Class 1, Class 2, and ISB Switchboards. 800 to 6000A Evolution, Spectra, Jiffy, GenTower, Integrated, Reliagear, Commercial Metering, PowerBreak II, and AV-3 Stack Switchboards include disconnects and distribution units in indoor and outdoor enclosures.

Mounting Description: Rigid, Floor Mounted

Tested Seismic Enhancements: Seismic enhancements made to the test units and/or modifications required to address anomalies during the tests shall be incorporated into the production units.

Applicant Information

Applicant Company Name: WE Gundy & Associates, Inc

Contact Person: Travis Soppe

Mailing Address: PO Box 9121, Boise, ID 83707

Telephone: (208) 342-5989

Email: tsoppe@wegai.com

Title: President





DEPARTMENT OF HEALTH CARE ACCESS AND INFORMATION
FACILITIES DEVELOPMENT DIVISION

California Licensed Structural Engineer Responsible for the Engineering and Test Report(s)

Company Name: W.E. GUNDY & ASSOCIATES INC.
Name: Travis Soppe California License Number: S6115
Mailing Address: P.O. Box 9121, Boise, ID 83707
Telephone: (208) 342-5989 Email: tsoppe@wegai.com



Certification Method

GR-63-Core [X] ICC-ES AC156 [] IEEE 344 [] IEEE 693 [] NEBS 3
Other (Please Specify):

Testing Laboratory

Company Name: Clark Dynamics Test Laboratory
Contact Person: Robert Francis
Mailing Address: 1801 Route 51, Jefferson Hills PA 75229-3513
Telephone: (972) 247-9657 Email: rfrancis@clarktesting.com

Company Name: ENVIRONMENTAL TESTING LABORATORIES, INC. (ETL)
Contact Person: Jeremy Lange
Mailing Address: 11034 Indian Trail, Dallas TX 75229-3513
Telephone: (972) 247-9657 Email: Jeremy@etldallas.com





**DEPARTMENT OF HEALTH CARE ACCESS AND INFORMATION
FACILITIES DEVELOPMENT DIVISION**

Seismic Parameters

Design Basis of Equipment or Components (F_p/W_p) = Multiple, see attachments

SDS (Design spectral response acceleration at short period, g) = Multiple, see attachments

a_p (Amplification factor) = 2.5

R_p (Response modification factor) = 6.0

Ω_0 (System overstrength factor) = 2.0

I_p (Importance factor) = 1.5

z/h (Height ratio factor) = 1 and 0

Natural frequencies (Hz) = See Attachment

Overall dimensions and weight = See Attachment

HCAI Approval (For Office Use Only) - Approval Expires on 10/25/2028

Date: 10/25/2022

Name: Mohammad Karim Title: Supervisor, Health Facilities

Special Seismic Certification Valid Up to: SDS (g) = See Above z/h = See Above

Condition of Approval (if applicable): DATE: 10/25/2022




Table 1

**ABB, INC. CLASS 1 SWITCHBOARD
CERTIFIED PRODUCT LINE MATRICES**



Seismic Certification Limits: $S_{DS} = 2.0g$ at $z/h = 1 \rightarrow F_p = 1.50g$ and $S_{DS} = 2.5$ at $z/h = 0 \rightarrow F_p = 1.13g$

ID/Catalog Number ¹	Max Current Rating (A)	NEMA Enclosure	Equipment Dimensions (in)				Weight (lbs)	Representative UUT ²
			Width	Depth	Height	Max CG		
EV-CL1-SB	800	1	30	25	90	45	510	UUT _w -5
[EV/SP/JF/GT/INT/RG/CM]-CL1-SB	800-4000	1, 3R	30	25-30	93	46.5	500-700	Interpolated
[EV/SP/JF/GT/INT/RG/CM]-CL1-SB	800-4000	1, 3R	30	25-30	90	45	500-800	Interpolated
RG-CL1-SB ³	800	1	30	25	90	45	809	UUT _s -7
EV-CL1-SB	4000	1	45	25	90	45	870	UUT _v -6
CM-CL1-SB	NA	3R	35	40	93	46.5	1020	UUT _t -2
EV-CL1-SB	4000	1	45	25	90	45	1026	UUT _v -3
RG-CL1-SB	1200	1	30	30	90	50.1	1226	UUT _r -3
[EV/SP/JF/GT/INT/RG/CM]-CL1-SB	800-6000	1, 3R	30-45	30-45	90-93	46.5	500-1000	Interpolated
[EV/SP/JF/GT/INT/RG/CM]-CL1-SB	800-6000	1, 3R	35-45	35-45	90-93	46.5	500-1400	Interpolated
[EV/SP/JF/GT/INT/RG/CM]-CL1-SB	800-6000	1, 3R	40-45	40-45	90-93	46.5	500-1750	Interpolated
RG-CL1-SB ³	4000	1	50	50	90	45	1625	UUT _s -8
EV-CL1-SB	4000	1	40	35	90	45	1176	UUT _w -4
GT-CL1-SB	4000	3R	40	50	93	46.5	1852	UUT _t -1
[EV/SP/JF/GT/INT/RG/CM]-CL1-SB	800-6000	1, 3R	45-60	45-60	90-93	46.5	500-1950	Interpolated
[EV/SP/JF/GT/INT/RG/CM]-CL1-SB	800-6000	1, 3R	50-60	50-60	90-93	46.5	500-2200	Interpolated
[EV/SP/JF/GT/INT/RG/CM]-CL1-SB	800-6000	1, 3R	55-60	55-60	90-93	46.5	500-2400	Interpolated
[EV/SP/JF/GT/INT/RG/CM]-CL1-SB	800-6000	1, 3R	60	60	93	46.5	500-2600	Interpolated
[EV/SP/JF/GT/INT/RG/CM]-CL1-SB	800-6000	1, 3R	60	60	90	45	500-2700	Interpolated
RG-CL1-SB ³	4000	1	60	60	90	45	2711	UUT _s -9
RG-CL1-SB	5000	1	50	45	90	50.2	2884	UUT _r -2
RG-CL1-SB	6000	1	50	50	90	47.2	2975	UUT _r -1

Table 1

**ABB, INC. CLASS 1 SWITCHBOARD
CERTIFIED PRODUCT LINE MATRICES**



Seismic Certification Limits: $S_{DS} = 2.0g$ at $z/h = 1 \rightarrow F_p = 1.50g$ and $S_{DS} = 2.5$ at $z/h = 0 \rightarrow F_p = 1.13g$

ID/Catalog Number ¹	Max Current Rating (A)	NEMA Enclosure	Equipment Dimensions (in)				Weight (lbs)	Representative UUT ²
			Width	Depth	Height	Max CG		

General Notes:

¹ ABB's switchboard product line utilizes the same typical construction across the varied switchboard product offerings for a wide variety of industrial applications. The following naming conventions are utilized by ABB to identify the varied switchboard product offerings. The initials are utilized within this seismic certification document to identify the switchboard product offerings.

EV = Evolution / SP = Spectra / JF = Jiffy / GT = GenTower / INT = Integrated / RG = Reliagear / CM = Commercial Metering

The switchboard configuration is made of a typical enclosure that houses a wide variety of internal electrical components. Seismic certification levels vary for the different internal electrical components. Therefore ABB utilizes a classification system (Class 1, Class 2, and ISB) to define the seismic ratings for the varied configurations based on the internal components housed within a switchboard section. This classification and seismic rating is detailed on the seismic certification label applied to each switchboard section within a lineup.

² The units were tested at different times and the subscripts on the UUT's reference the following lab test reports:

r - 16188 / s - 15605 / t - 2346A / u - 10164 / v - 10155 / w - 10154 / x - 8101 / y - 8055 / z - 8480

³ Reliagear has both copper and aluminum bus. UUT_s-7/9 are copper and UUT_s-8 is aluminum.

⁴ See Table 4 for listing of certified subcomponents of the Class 1 Switchboard product line.




Table 2

**ABB, INC. CLASS 2 SWITCHBOARD
CERTIFIED PRODUCT LINE MATRICES**



Seismic Certification Limits: $S_{DS} = 1.56g$ at $z/h = 1 \rightarrow F_p = 1.17g$ and $S_{DS} = 2.50g$ at $z/h = 0 \rightarrow F_p = 1.13g$

ID/Catalog Number ¹	Max Current Rating (A)	NEMA Enclosure	Equipment Dimensions (in)				Weight (lbs)	Representative UUT ²
			Width	Depth	Height	Max CG		
INT-CL2-SB	4000	1	25	15	90	45	380	UUT _x -5
INT-CL2-SB	4000	1	20	30	90	45	405	UUT _x -3
INT-CL2-SB	4000	1	40	15	90	45	435	UUT _x -1
EV-CL2-SB	800	1	30	25	90	45	510	UUT _w -5
[EV/SP/JF/GT/INT/RG/CM/PB/AV]-CL2-SB	800-6000	1, 3R	15-20	15-20	90	45	150-250	Interpolated
			20-30	20-30	90-93	46.5	150-525	
			25-30	25-30	90-93	46.5	300-900	
			30	30	90-93	46.5	500-1450	
RG-CL2-SB ³	800	1	30	25	90	45	809	UUT _s -7
EV-CL2-SB	4000	1	45	25	90	45	870	UUT _v -6
CM-CL2-SB	NA	3R	35	40	93	46.5	1020	UUT _t -2
EV-CL2-SB	4000	1	45	25	90	45	1026	UUT _v -3
AV-CL2-SB	6000	3R	15	50	92	46	1050	UUT _y -1a
RG-CL2-SB	1200	1	30	30	90	50.1	1226	UUT _r -3
RG-CL2-SB ³	4000	1	50	50	90	45	1625	UUT _s -8
[EV/SP/JF/GT/INT/RG/CM/PB/AV]-CL2-SB	800-6000	1, 3R	30-45	30-45	90-93	46.5	500-1400	Interpolated
			35-45	35-45	90-93	46.5	500-2000	
			40-45	40-45	90-93	46.5	500-2400	
			45	45	90-93	46.5	500-2400	
EV-CL2-SB	4000	1	40	35	90	45	1176	UUT _w -4
EV-CL2-SB	2000	1	35	35	90	45	1435	UUT _v -2a
GT-CL2-SB	4000	3R	40	50	93	46.5	1852	UUT _t -1
PB-CL2-SB	6000	3R	22	50	92	46	2129	UUT _y -1b
RG-CL2-SB ³	4000	1	60	60	90	45	2711	UUT _s -9

Table 2

**ABB, INC. CLASS 2 SWITCHBOARD
CERTIFIED PRODUCT LINE MATRICES**



Seismic Certification Limits: $S_{DS} = 1.56g$ at $z/h = 1 \rightarrow F_p = 1.17g$ and $S_{DS} = 2.50g$ at $z/h = 0 \rightarrow F_p = 1.13g$

ID/Catalog Number ¹	Max Current Rating (A)	NEMA Enclosure	Equipment Dimensions (in)				Weight (lbs)	Representative UUT ²
			Width	Depth	Height	Max CG		
[EV/SP/JF/GT/INT/RG/CM/PB/AV]-CL2-SB	800-6000	1, 3R	45-60	45-60	90-93	46.5	1000-3000	Interpolated
			50-60	50-60	90-93	46.5	1000-3400	
			55-60	55-60	90-93	46.5	1000-3900	
			60	60	90	45	1000-4300	
			60	60	90	45	1000-4450	
RG-CL2-SB	5000	1	50	45	90	50.2	2884	UUT _r -2
RG-CL2-SB	6000	1	50	50	90	47.2	2975	UUT _r -1
EV-CL2-SB	6000	1	60	60	90	45	4463	UUT _u -1

General Notes:

¹ ABB's switchboard product line utilizes the same typical construction across the varied switchboard product offerings for a wide variety of industrial applications. The following naming conventions are utilized by ABB to identify the varied switchboard product offerings. The initials are utilized within this seismic certification documentation to identify the switchboard product offerings.

EV = Evolution / SP = Spectra / JF = Jiffy / GT = GenTower / INT = Integrated / RG = Reliagear / CM = Commercial Metering
PB = Power Break II / AV = AV-3 Stack

The switchboard configuration is made of a typical enclosure that houses a wide variety of internal electrical components. Seismic certification levels vary for the different internal electrical components. Therefore ABB utilizes a classification system (Class 1, Class 2, and ISB) to define the seismic ratings for the varied configurations based on the internal components housed within a switchboard section. This classification and seismic rating is detailed on the seismic certification label applied to each switchboard section within a lineup.

² The units were tested at different times and the subscripts on the UUT's reference the following lab test reports:

r - 16188 / s - 15605 / t - 2346A / u - 10164 / v - 10155 / w - 10154 / x - 8101 / y - 8055 / z - 8480

³ Reliagear has both copper and aluminum bus. UUT_s-7/9 are copper and UUT_s-8 is aluminum.

⁴ See Table 5 for listing of certified subcomponents of the Class 2 Switchboard product line.

Table 3

**ABB, INC. ISB SWITCHBOARD
CERTIFIED PRODUCT LINE MATRICES**



Seismic Certification Limits: $S_{DS} = 1.10g$ at $z/h = 1 \rightarrow F_p = 0.83g$ and $S_{DS} = 1.76g$ at $z/h = 0 \rightarrow F_p = 0.79g$

ID/Catalog Number ¹	Max Current Rating (A)	NEMA Enclosure	Equipment Dimensions (in)				Weight (lbs)	Representative UUT ²
			Width	Depth	Height	Max CG		
INT-ISB-SB	4000	1	25	15	90	45	380	UUT _x -5
INT-ISB-SB	4000	1	20	30	90	45	405	UUT _x -3
INT-ISB-SB	4000	1	40	15	90	45	435	UUT _x -1
EV-ISB-SB	800	1	30	25	90	45	510	UUT _w -5
RG-ISB-SB ³	800	1	30	25	90	45	809	UUT _s -7
[EV/SP/JF/GT/INT/RG/CM/PB/AV]-ISB-SB	800-6000	1, 3R	15-20	15-20	90	45	150-250	Interpolated
			20-30	20-30	90-93	46.5	150-525	Interpolated
			25-30	25-30	90-93	46.5	300-975	Interpolated
			30	30	90-93	46.5	500-1450	Interpolated
EV-ISB-SB	4000	1	45	25	90	45	870	UUT _v -6
CM-ISB-SB	NA	3R	35	40	93	46.5	1020	UUT _t -2
EV-ISB-SB	4000	1	45	25	90	45	1026	UUT _v -3
AV-ISP-PB	6000	3R	15	50	92	46	1050	UUT _y -1a
EV-ISB-SB	4000	1	40	35	90	45	1176	UUT _w -4
RG-ISB-SB	1200	1	30	30	90		1226	UUT _r -3
EV-ISB-SB	2000	1	35	35	90	45	1435	UUT _v -2a
[EV/SP/JF/GT/INT/RG/CM/PB/AV]-ISB-SB	800-6000	1, 3R	30-45	30-45	90-93	46.5	500-1500	Interpolated
			35-45	35-45	90-93	46.5	500-2100	Interpolated
			40-45	40-45	90-93	46.5	500-2400	Interpolated
			45	45	90-93	46.5	500-2400	Interpolated
RG-ISB-SB ³	4000	1	50	50	90	45	1625	UUT _s -8
GT-ISB-SB	4000	3R	40	50	93	46.5	1852	UUT _t -1
INT-ISB-SB	4000	1	40	35	90	45	2125	UUT _z -1
PB-ISB-SB	6000	3R	22	50	92	46	2129	UUT _y -1b
INT-ISB-SB	4000	1	40	35	90	45	2410	UUT _z -2

Table 3

**ABB, INC. ISB SWITCHBOARD
CERTIFIED PRODUCT LINE MATRICES**



Seismic Certification Limits: $S_{DS} = 1.10g$ at $z/h = 1 \rightarrow F_p = 0.83g$ and $S_{DS} = 1.76g$ at $z/h = 0 \rightarrow F_p = 0.79g$

ID/Catalog Number ¹	Max Current Rating (A)	NEMA Enclosure	Equipment Dimensions (in)				Weight (lbs)	Representative UUT ²
			Width	Depth	Height	Max CG		
RG-ISB-SB ³	4000	1	60	60	90	45	2711	UUT _s -9
[EV/SP/JF/GT/INT/RG/CM/PB/AV]-ISB-SB	800-6000	1, 3R	45-60	45-60	90-93	46.5	1000-3200	Interpolated
			50-60	50-60	90-93	46.5	1000-3600	Interpolated
			55-60	55-60	90-93	46.5	1000-3900	Interpolated
			60	60	93	46.5	1000-4300	Interpolated
			60	60	90	45	1000-4450	Interpolated
RG-ISB-SB	5000	1	50	45	90	50.2	2884	UUT _r -2
RG-ISB-SB	6000	1	50	50	90	47.2	2975	UUT _r -1
EV-ISB-SB	6000	1	60	60	90	45	4463	UUT _u -1

General Notes:

¹ ABB's switchboard product line utilizes the same typical construction across the varied switchboard product offerings for a wide variety of industrial applications. The following naming conventions are utilized by ABB to identify the varied switchboard product offerings. The initials are utilized within this seismic certification document to identify the switchboard product offerings.

EV = Evolution / SP = Spectra / JF = Jiffy / GT = GenTower / INT = Integrated / RG = Reliagear / CM = Commercial Metering
PB = Power Break II / AV = AV-3 Stack

The switchboard configuration is made of a typical enclosure that houses a wide variety of internal electrical components. Seismic certification levels vary for the different internal electrical components. Therefore ABB utilizes a classification system (Class 1, Class 2, and ISB) to define the seismic ratings for the varied configurations based on the internal components housed within a switchboard section. This classification and seismic rating is detailed on the seismic certification label applied to each switchboard section within a lineup.

² The units were tested at different times and the subscripts on the UUT's reference the following lab test reports:

r - 16188 / s - 15605 / t - 2346A / u - 10164 / v - 10155 / w - 10154 / x - 8101 / y - 8055 / z - 8480

³ Reliagear has both copper and aluminum bus. UUT_s-7/9 are copper and UUT_s-8 is aluminum.

⁴ See Table 6 for listing of certified subcomponents of the ISB Switchboard product line.

Table 4	ABB, INC. CLASS 1 SWITCHBOARD CERTIFIED SUBCOMPONENT MATRICES			 WEGAI <small>W. E. GUNDY & ASSOCIATES, INC. STRUCTURAL & EARTHQUAKE ENGINEERING</small>	
Seismic Certification Limits: $S_{DS} = 2.0g$ at $z/h = 1 \rightarrow F_p = 1.50g$ and $S_{DS} = 2.5$ at $z/h = 0 \rightarrow F_p = 1.13g$					
Identification Number	Manufacturer	Description	Approximate Weights (lbs)	Representative UUT ¹	
Fusible Switches					
ADS36030HS	GE	30A	18.7	UUT _v -6	
ADS*	GE	30-1200A	18.7-75	Interpolated	
ADS36120LB	GE	1200A	75	UUT _v -6	
Fuses					
ATDR1/2	Mersen	0.5A	0.9	UUT _w -4	
AJT1-1/2	Mersen	1.5A	0.25	UUT _v -2a	
A4J6	Mersen	6.0A	0.12	UUT _v -2a	
AJT, A4J6, A4BY, ATDR	Mersen	0.5A-4000A	0.9-25.5	Interpolated	
A4BY800	Mersen	800A	3.9	UUT _w -5	
A4BY1200	Mersen	1200A	4.5	UUT _v -6	
A4BY4000	Mersen	4000A	25.5	UUT _w -4	
Record Plus Circuit Breakers					
NEFBV	ABB	15A	3	UUT _s -7	
NEFBV	ABB	30A	3	Interpolated	
NEFB	ABB	15A - 100A	3-5	Interpolated	
NEFBV	ABB	50A	4	Interpolated	
NEFBV	ABB	100A	5	UUT _s -7	
FBL36TE030R	GE	F-type, 30A	5	UUT _v -3	
FBH36TE035R2	GE	F-type, 35A	4	UUT _v -3	
F*	GE	F-type, 30A-600A	1-22	Interpolated	
FGP36AA066R1	GE	F-type, 600A	22	UUT _v -3	
Spectra RMS Circuit Breakers					
SEHA36AT0030	GE	S-type, 30A	5	UUT _v -3	
S*	GE	S-type, 30A-1200A	5 - 42.8	Interpolated	
SKHA36AT1200	GE	S-type, 1200A	42.8	UUT _v -3	
Thermal Mag, Q-Line, Molded Case Switches					
TEYF1015	GE	T-type, 15A	2	UUT _v -3	
TEYF2015	GE	T-type, 15A	2	UUT _v -3	
TEYF3015	GE	T-type, 15A	2	UUT _v -3	
T*	GE	T-type, 15A-1200A	2-37	Interpolated	
TKM3F	GE	T-type, 1200A	37	UUT _v -6	
XT Molded Case Switches					
XT1	ABB	160A	4	UUT _s -7	
XT4	ABB	250A	7	UUT _s -7, UUT _s -8	
XT5	ABB	600A	15	UUT _s -8, UUT _s -9, UUT _r -2	
XT7	ABB	1200A	43	UUT _s -8, UUT _s -9, UUT _r -3	
General Notes:					
¹ The units were tested at different times and the subscripts on the UUT's reference the following lab test reports: r - 16188 / s - 15605 / t - 2346A / u - 10164 / v - 10155 / w - 10154 / x - 8101 / y - 8055 / z - 84800					
* Is used to indicated the series of identification numbers (range of subcomponents) beyond the primary identification number for the specified subcomponent product line.					

Seismic Certification Limits: $S_{DS} = 2.0g$ at $z/h = 1 \rightarrow F_p = 1.50g$ and $S_{DS} = 2.5$ at $z/h = 0 \rightarrow F_p = 1.13g$

Identification Number	Manufacturer	Description	Approximate Weights (lbs)	Representative UUT ¹
Emax Breakers - Fixed				
Emax 1.2	ABB	1200A Fixed 3P/4P	31-35	Extrapolated
Emax 1.2	ABB	1200A Fixed 3P	31	UUT _r -3
Emax 2.2	ABB	2000A Fixed 3P/4P	115-148	Interpolated
Emax 4.2	ABB	3000A Fixed 3P/4P	201-256	Interpolated
Emax 6.2 - 5kA	ABB	5000A Fixed 3P/4P	314-406	Interpolated
Emax 6.2 - 5kA	ABB	5000A Fixed 4P	406	UUT _r -2
Emax Breakers - Drawout				
Emax 1.2	ABB	1200A Drawout 3P/4P	90.4-102.5	Extrapolated
Emax 1.2	ABB	1200A Drawout 4P	102.5	UUT _r -3
Emax 2.2	ABB	2000A Drawout 3P/4P	135-239	Interpolated
Emax 4.2	ABB	3000A Drawout 3P/4P	300-377	Interpolated
Emax 6.2 - 5kA	ABB	5000A Drawout 3P/4P	486-620	Interpolated
Emax 6.2 - 6kA	ABB	6000A Drawout Only 3P	818	UUT _r -1
Spectra Power Panels				
APNB3812	GE	Spectra 1200A	150	UUT _v -6
APN*	GE	Spectra 1200A-2000A	150-175	Interpolated
APNB3820	GE	Spectra 2000A	175	UUT _v -3
Religear Power Panels Bus Stack				
IN1604TX3H1	ABB	400A, Aluminum	53	UUT _s -7
IN1604CC3H2	ABB	400A, Copper	62	UUT _s -7
Inxx(04-40)xx(1,3,4)(Hx,Bx)	ABB	400A-4000A, CU & AL	53-510	Interpolated
IN4030CC3H1	ABB	3000A, Aluminum	280	UUT _s -8
IN5640CC4B3	ABB	4000A, Copper	510	UUT _s -9
Surge Protection Device (SPD)				
TPHE*, THE*, ATHE*, TPME*	GE	25-100kA/130-200kA	0-25	Extrapolated
TPHE480D12PP	GE	125kA/250kA	25	UUT _v -3
TPHE*, THE*, ATHE*, TPME*	GE	125-300kA/250-600kA	25	Interpolated
TPHE480D30PP	GE	300kA/600kA	25	UUT _v -6
SP120Y	ABB	120Wye, SPD, Disconnect	50	UUT _s -8
SP277Y	ABB	480/277Y, SPD, Disconnect	50	Interpolated
SP347Y	ABB	600/347Y, SPD, Disconnect	50	Interpolated
SP480D	ABB	480D, SPD, Disconnect	50	UUT _s -8

General Notes:

¹ The units were tested at different times and the subscripts on the UUT's reference the following lab test reports:
r - 16188 / s - 15605 / t - 2346A / u - 10164 / v - 10155 / w - 10154 / x - 8101 / y - 8055 / z - 8480

* Is used to indicated the series of identification numbers (range of subcomponents) beyond the primary identification number for the specified subcomponent product line.

Table 4	ABB, INC. CLASS 1 SWITCHBOARD CERTIFIED SUBCOMPONENT MATRICES	
----------------	--	--

Seismic Certification Limits: $S_{DS} = 2.0g$ at $z/h = 1 \rightarrow F_p = 1.50g$ and $S_{DS} = 2.5$ at $z/h = 0 \rightarrow F_p = 1.13g$

Identification Number	Manufacturer	Description	Approximate Weights (lbs)	Representative UUT ¹
Meter Socket				
CM100A35K480V	GE	480V	8.4	UUT _t -2
CM200A65K480V	GE	480V	8.4	UUT _t -2
CM100, CM200	GE	240V-600V	6.7-10.2	Interpolated
CM200MSJF240V	GE	240V	6.7	UUT _t -2
CM200MSJF600V	GE	600V	10.2	UUT _t -2
MT04AP	ABB	Pulse, Carbon Steel	16	UUT _s -7
MT04AM(AD)	ABB	ModBus, Carbon Steel	16	Interpolated
MT04AB	ABB	BacNe, Carbon Steel	16	UUT _s -8
Generator Connectors				
HBLFRSBN	Hubbell		0.1	UUT _t -1
HBL	Hubbell		0.1 - 1.54	Interpolated
HBLFRGN	Hubbell		1.54	UUT _t -1
Transfer Switches				
OXA30U2X2QB	ABB	30A 2 Pole ATS	25	UUT _s -8
OX*	ABB	TruONE ATS	25-125	Interpolated
OXB1200U3S2QT	ABB	1200A 4 pole ATS	125	UUT _s -8
Control Power Transformer				
9T58K2808	GE	0.3 kVA 240/480	7	UUT _v -2a
9T58K28(08-15)	GE	0.05kVA-3kVA 240/480	7-54	Interpolated
9T58K2815	GE	3.0kVA 240/480	54	UUT _s -7

General Notes:

¹ The units were tested at different times and the subscripts on the UUT's reference the following lab test reports:
r - 16188 / s - 15605 / t - 2346A / u - 10164 / v - 10155 / w - 10154 / x - 8101 / y - 8055 / z - 8480

* Is used to indicated the series of identification numbers (range of subcomponents) beyond the primary identification number for the specified subcomponent product line.

Table 5	ABB, INC. CLASS 2 SWITCHBOARD CERTIFIED SUBCOMPONENT MATRICES			 WEGAI <small>W.E. GUNDY & ASSOCIATES, INC. STRUCTURAL & EARTHQUAKE ENGINEERING</small>	
Seismic Certification Limits: $S_{DS} = 1.56g$ at $z/h = 1 \rightarrow F_p = 1.17g$ and $S_{DS} = 2.50g$ at $z/h = 0 \rightarrow F_p = 1.13g$					
Identification Number	Manufacturer	Description	Approximate Weights (lbs)	Representative UUT ¹	
High Pressure Contact Switch (HPC)					
THPR3608GA3	GE	HPC, 800A	115	UUT _w -5	
THPR*, THPC*	GE	HPC, 800A-4000A	115-540	Interpolated	
THPC3640G3T	GE	HPC, 4000	540	UUT _w -4	
Fusible Switches					
ADS36030HS	GE	30A	18.7	UUT _v -6	
ADS*	GE	30-1200A	18.7-75	Interpolated	
ADS36120LB	GE	1200A	75	UUT _v -6	
Fuses					
ATDR1/2	Mersen	0.5A	0.9	UUT _w -4	
AJT1-1/2	Mersen	1.5A	0.25	UUT _v -2a	
A4J6	Mersen	6.0A	0.12	UUT _v -2a	
AJT, A4J6, A4BY, ATDR	Mersen	0.5A-4000A	0.9-25.5	Interpolated	
A4BY800	Mersen	800A	3.9	UUT _w -5	
A4BY1200	Mersen	1200A	4.5	UUT _v -6	
A4BY4000	Mersen	4000A	25.5	UUT _w -4	
Record Plus Circuit Breakers					
NEFBV	ABB	15A	3	UUT _s -7	
NEFBV	ABB	30A	3	Interpolated	
NEFB	ABB	15A - 100A	3-5	Interpolated	
NEFBV	ABB	50A	4	Interpolated	
NEFBV	ABB	100A	5	UUT _s -7	
FBL36TE030R	GE	F-type, 30A	2.7	UUT _v -3	
FBH36TE035R2	GE	F-type, 35A	4	UUT _v -3	
F*	GE	F-type, 30A-600A	2.7-22	Interpolated	
FGP36AA066R1	GE	F-type, 600A	22	UUT _v -3	
Spectra RMS Circuit Breakers					
SEHA36AT0030	GE	S*-type, 30A	5	UUT _v -3	
SELA36AT0150	GE	S*-type, 150A	5	UUT _y -1a	
SFLA36AT0250	GE	S*-type, 250A	9	UUT _y -1a	
S*	GE	S*-type, 30A-1200A	5-42.8	Interpolated	
SGLA36AT0600	GE	S*-type, 600A	13	UUT _y -1a	
SKPA36AT1200	GE	S*-type, 1200A	40	UUT _y -1a	
SKHA36AT1200	GE	S*-type, 1200A	42.8	UUT _v -3	
General Notes:					
¹ The units were tested at different times and the subscripts on the UUT's reference the following lab test reports: r - 16188 / s - 15605 / t - 2346A / u - 10164 / v - 10155 / w - 10154 / x - 8101 / y - 8055 / z - 8480 * Is used to indicated the series of identification numbers (range of subcomponents) beyond the primary identification number for the specified subcomponent product line.					

Table 5

ABB, INC. CLASS 2 SWITCHBOARD CERTIFIED SUBCOMPONENT MATRICES



Seismic Certification Limits: $S_{DS} = 1.56g$ at $z/h = 1 \rightarrow F_p = 1.17g$ and $S_{DS} = 2.50g$ at $z/h = 0 \rightarrow F_p = 1.13g$

Identification Number	Manufacturer	Description	Approximate Weights (lbs)	Representative UUT ¹
Thermal Mag, Q-Line, Molded Case Switches				
TEYF1015	GE	T-type, 15A	2	UUT _v -3
TEYF2015	GE	T-type, 15A	2	UUT _v -3
TEYF3015	GE	T-type, 15A	2	UUT _v -3
T*	GE	T-type, 15A-1200A	2-37	Interpolated
TKM3F	GE	T-type, 1200A	37	UUT _v -6
XT Molded Case Switches				
XT1	ABB	160A	4	UUT _s -7
XT4	ABB	250A	7	UUT _s -7, UUT _s -8
XT5	ABB	600A	15	UUT _s -8, UUT _s -9, UUT _r -2
XT7	ABB	1200A	43	UUT _s -8, UUT _s -9, UUT _r -3
Emax Breakers - Fixed				
Emax 1.2	ABB	1200A Fixed 3P/4P	31-35	Extrapolated
Emax 1.2	ABB	1200A Fixed 3P	31	UUT _r -3
Emax 2.2	ABB	2000A Fixed 3P/4P	115-148	Interpolated
Emax 4.2	ABB	3000A Fixed 3P/4P	201-256	Interpolated
Emax 6.2 - 5kA	ABB	5000A Fixed 3P/4P	314-406	Interpolated
Emax 6.2 - 5kA	ABB	5000A Fixed 4P	406	UUT _r -2
Emax Breakers - Drawout				
Emax 1.2	ABB	1200A Drawout 3P/4P	90.4-102.5	Extrapolated
Emax 1.2	ABB	1200A Drawout 4P	102.5	UUT _r -3
Emax 2.2	ABB	2000A Drawout 3P/4P	135-239	Interpolated
Emax 4.2	ABB	3000A Drawout 3P/4P	300-377	Interpolated
Emax 6.2 - 5kA	ABB	5000A Drawout 3P/4P	486-620	Interpolated
Emax 6.2 - 6kA	ABB	6000A Drawout Only 3P	818	UUT _r -1
EntelliGuard G (800A-4000A)				
G*	GE	800A-2000A	136.7-176.4	Extrapolated
GA20M2X	GE	2000A	176.4	UUT _v -2a
G*	GE	2500A-6000A	253.5-463.0	Interpolated
GA60M2X	GE	6000A	463	UUT _u -1
PowerBreak II (800A-4000A)				
SSD30D30H	GE	3000A	353	UUT _y -1b
SSD	GE	800A-3000A	166-353	Interpolated
SSD20D20H	GE	2000A	202	UUT _y -1b
SSD08D08H	GE	800A	166	UUT _y -1b

General Notes:

¹ The units were tested at different times and the subscripts on the UUT's reference the following lab test reports:

r - 16188 / s - 15605 / t - 2346A / u - 10164 / v - 10155 / w - 10154 / x - 8101 / y - 8055 / z - 8480

* Is used to indicated the series of identification numbers (range of subcomponents) beyond the primary identification number for the specified subcomponent product line.

Table 5	ABB, INC. CLASS 2 SWITCHBOARD CERTIFIED SUBCOMPONENT MATRICES			 WEGAI <small>W.E. GUNDY & ASSOCIATES, INC. STRUCTURAL & EARTHQUAKE ENGINEERING</small>
	Seismic Certification Limits: $S_{DS} = 1.56g$ at $z/h = 1 \rightarrow F_p = 1.17g$ and $S_{DS} = 2.50g$ at $z/h = 0 \rightarrow F_p = 1.13g$			

Identification Number	Manufacturer	Description	Approximate Weights (lbs)	Representative UUT ¹
Power Panels				
APNB3812	GE	Spectra 1200A	150	UUT _v -6
APN*	GE	Spectra 1200A-2000A	150-170	Interpolated
APNB3820	GE	Spectra 2000A	170	UUT _v -3
ALM3424MTX	GE	A Series 225A	33	UUT _x -1
AL*, AD*	GE	A Series 225-600A	33-75	Interpolated
ADM3366MTX	GE	A Series 600A	75	UUT _x -5
Reliagear Power Panels Bus Stack				
IN1604TX3H1	ABB	400A, Aluminum	53	UUT _s -7
IN1604CC3H2	ABB	400A, Copper	62	UUT _s -7
Inxx(04-40)xx(1,3,4)(Hx,Bx)	ABB	400A-4000A, CU & AL	53-510	Interpolated
IN4030CC3H1	ABB	3000A, Aluminum	280	UUT _s -8
IN5640CC4B3	ABB	4000A, Copper	510	UUT _s -9
Surge Protection Device (SPD)				
TPHE*, THE*, ATHE*, TPME*	GE	25-100kA/130-200kA	0-25	Extrapolated
TPHE480D12PP	GE	125kA/250kA	25	UUT _v -3
TPHE*, THE*, ATHE*, TPME*	GE	125-300kA/250-600kA	25	Interpolated
TPHE480D30PP	GE	300kA/600kA	25	UUT _v -6
SP120Y	ABB	120Wye, SPD, Disconnect	50	UUT _s -8
SP277Y	ABB	480/277Y, SPD, Disconnect	50	Interpolated
SP347Y	ABB	600/347Y, SPD, Disconnect	50	Interpolated
SP480D	ABB	480D, SPD, Disconnect	50	UUT _s -8
Strip Heaters				
CRX# OT-1225	Chromalox	Heater	3	UUT _v -2a
Transfer Switches				
ZTG000A00020E	GE	Zenith Transfer Switch	60	UUT _x -3
ZTG*	GE	Zenith Transfer Switch	60-69	Interpolated
ZTGD00A0U020E	GE	Zenith Transfer Switch	69	UUT _x -3
OXA30U2X2QB	ABB	30A 2 Pole ATS	25	UUT _s -8
OX*	ABB	TruONE ATS	25-125	Interpolated
OXB1200U3S2QT	ABB	1200A 4 pole ATS	125	UUT _s -8
Meter Socket				
CM100A35K480V	GE	480V	8.4	UUT _t -2
CM200A65K480V	GE	480V	8.4	UUT _t -2

General Notes:

¹ The units were tested at different times and the subscripts on the UUT's reference the following lab test reports:
r - 16188 / s - 15605 / t - 2346A / u - 10164 / v - 10155 / w - 10154 / x - 8101 / y - 8055 / z - 8480

* Is used to indicated the series of identification numbers (range of subcomponents) beyond the primary identification number for the specified subcomponent product line.

Table 5

**ABB, INC. CLASS 2 SWITCHBOARD
CERTIFIED SUBCOMPONENT MATRICES**




Seismic Certification Limits: $S_{DS} = 1.56g$ at $z/h = 1 \rightarrow F_p = 1.17g$ and $S_{DS} = 2.50g$ at $z/h = 0 \rightarrow F_p = 1.13g$

Identification Number	Manufacturer	Description	Approximate Weights (lbs)	Representative UUT ¹
Meter Socket - cont'd				
CM100, CM200	GE	240V-600V	6.7-10.2	Interpolated
CM200MSJF240V	GE	240V	6.7	UUT _t -2
CM200MSJF600V	GE	600V	10	UUT _t -2
MT04AP	ABB	Pulse, Carbon Steel	16	UUT _s -7
MT04AM(AD)	ABB	ModBus, Carbon Steel	16	Interpolated
MT04AB	ABB	BacNe, Carbon Steel	16	UUT _s -8
Generator Connectors				
HBLFRSBN	Hubbell		0.1	UUT _t -1
HBL	Hubbell		0.1-1.54	Interpolated
HBLFRGN	Hubbell		1.54	UUT _t -1
Control Power Transformer				
9T58K2808	GE	0.3 kVA 240/480	7	UUT _v -2a
9T58K28(08-15)	GE	0.05kVA-3kVA 240/480	7-54	Interpolated
9T58K2815	GE	3.0kVA 240/480	54	UUT _s -7

General Notes:

¹ The units were tested at different times and the subscripts on the UUT's reference the following lab test reports:
r - 16188 / s - 15605 / t - 2346A / u - 10164 / v - 10155 / w - 10154 / x - 8101 / y - 8055 / z - 8480

* Is used to indicated the series of identification numbers (range of subcomponents) beyond the primary identification number for the specified subcomponent product line.



Seismic Certification Limits: $S_{DS} = 1.10g$ at $z/h = 1 \rightarrow F_p = 0.83g$ and $S_{DS} = 1.76g$ at $z/h = 0 \rightarrow F_p = 0.79g$

Identification Number	Manufacturer	Description	Approximate Weights (lbs)	Representative UUT ¹
High Pressure Contact Switch (HPC)				
THPR3608GA3	GE	HPC, 800A	115	UUT _w -5
THPR*, THPC*	GE	HPC, 800A-4000A	115-540	Interpolated
THPC3640G3T	GE	HPC, 4000	540	UUT _w -4
Fusible Switches				
ADS36030HS	GE	30A	18.7	UUT _v -6
ADS*	GE	30-1200A	18.7-75	Interpolated
ADS36120LB	GE	1200A	75	UUT _v -6
Fuses				
ATDR1/2	Mersen	0.5A	<10	UUT _w -4
AJT1-1/2	Mersen	1.5A	<10	UUT _v -2a
A4J6	Mersen	6.0A	<10	UUT _v -2a
AJT, A4J6, A4BY, ATDR	Mersen	0.5A-4000A	<10-25	Interpolated
A4BY800	Mersen	800A	<10	UUT _w -5
A4BY1200	Mersen	1200A	<10	UUT _v -6
A4BY4000	Mersen	4000A	25	UUT _w -4
Record Plus Circuit Breakers				
NEFBV	ABB	15A	3	UUT _s -7
NEFBV	ABB	30A	3	Interpolated
NEFB	ABB	15A - 100A	3-5	Interpolated
NEFBV	ABB	50A	4	Interpolated
NEFBV	ABB	100A	5	UUT _s -7
FBL36TE030R	GE	F-type, 30A	5	UUT _v -3
FBH36TE035R2	GE	F-type, 35A	4	UUT _v -3
F*	GE	F-type, 30A-600A	3.3-22	Interpolated
FGP36AA066R1	GE	F-type, 600A	22	UUT _v -3
Spectra RMS Circuit Breakers				
SEHA36AT0030	GE	S*-type, 30A	5	UUT _v -3
SELA36AT0150	GE	S*-type, 150A	5	UUT _y -1a
SFLA36AT0250	GE	S*-type, 250A	9	UUT _y -1a
S*	GE	S*-type, 30A-1200A	5-42.8	Interpolated
SGLA36AT0600	GE	S*-type, 600A	13	UUT _y -1a
SKPA36AT1200	GE	S*-type, 1200A	40	UUT _y -1a
SKHA36AT1200	GE	S*-type, 1200A	42.8	UUT _v -3

General Notes:

¹ The units were tested at different times and the subscripts on the UUT's reference the following lab test reports:
 r - 16188 / s - 15605 / t - 2346A / u - 10164 / v - 10155 / w - 10154 / x - 8101 / y - 8055 / z - 8480


* Is used to indicated the series of identification numbers (range of subcomponents) beyond the primary identification number for the specified subcomponent product line.

Seismic Certification Limits: $S_{DS} = 1.10g$ at $z/h = 1 \rightarrow F_p = 0.83g$ and $S_{DS} = 1.76g$ at $z/h = 0 \rightarrow F_p = 0.79g$

Identification Number	Manufacturer	Description	Approximate Weights (lbs)	Representative UUT ¹
Thermal Mag, Q-Line, Molded Case Switches				
TEYF1015	GE	T-type, 15A	2	UUT _v -3
TEYF2015	GE	T-type, 15A	2	UUT _v -3
TEYF3015	GE	T-type, 15A	2	UUT _v -3
T*	GE	T-type, 15A-1200A	2-36	Interpolated
TKM3F	GE	T-type, 1200A	36	UUT _v -6
XT Molded Case Switches				
XT1	ABB	160A	4	UUT _s -7
XT4	ABB	250A	7	UUT _s -7, UUT _s -8
XT5	ABB	600A	15	UUT _s -8, UUT _s -9, UUT _r -2
XT7	ABB	1200A	43	UUT _s -8, UUT _s -9, UUT _r -3
Emax Breakers - Fixed				
Emax 1.2	ABB	1200A Fixed 3P/4P	31-35	Extrapolated
Emax 1.2	ABB	1200A Fixed 3P	31	UUT _r -3
Emax 2.2	ABB	2000A Fixed 3P/4P	115-148	Interpolated
Emax 4.2	ABB	3000A Fixed 3P/4P	201-256	Interpolated
Emax 6.2 - 5kA	ABB	5000A Fixed 3P/4P	314-406	Interpolated
Emax 6.2 - 5kA	ABB	5000A Fixed 4P	406	UUT _r -2
Emax Breakers - Drawout				
Emax 1.2	ABB	1200A Drawout 3P/4P	90.4-102.5	Extrapolated
Emax 1.2	ABB	1200A Drawout 4P	102.5	UUT _r -3
Emax 2.2	ABB	2000A Drawout 3P/4P	135-239	Interpolated
Emax 4.2	ABB	3000A Drawout 3P/4P	300-377	Interpolated
Emax 6.2 - 5kA	ABB	5000A Drawout 3P/4P	486-620	Interpolated
Emax 6.2 - 6kA	ABB	6000A Drawout Only 3P	818	UUT _r -1
EntelliGuard G				
G*	GE	800A-2000A	136.7-176.4	Extrapolated
GA20M2X	GE	2000A	176.4	UUT _v -2a
G*	GE	2500A-6000A	253.5-463.0	Interpolated
GA60M2X	GE	6000A	463	UUT _u -1
PowerBreak II (800A-4000A)				
SSD30D30H	GE	3000A	353	UUT _y -1b
SSD	GE	800A-3000A	166-353	Interpolated
SSD20D20H	GE	2000A	202	UUT _y -1b
SSD08D08H	GE	800A	166	UUT _y -1b

General Notes:
 1 The units were tested at different times and the subscripts on the UUT's reference the following lab test reports:
 r - 16188 / s - 15605 / t - 2346A / u - 10164 / v - 10155 / w - 10154 / x - 8101 / y - 8055 / z - 8480
 * Is used to indicated the series of identification numbers (range of subcomponents) beyond the primary identification number for the specified subcomponent product line.

Table 6	ABB, INC. ISB SWITCHBOARD CERTIFIED SUBCOMPONENT MATRICES			 WEGAI <small>W.E. GUNDY & ASSOCIATES, INC. STRUCTURAL & EARTHQUAKE ENGINEERING</small>	
Seismic Certification Limits: $S_{DS} = 1.10g$ at $z/h = 1 \rightarrow F_p = 0.83g$ and $S_{DS} = 1.76g$ at $z/h = 0 \rightarrow F_p = 0.79g$					
Identification Number	Manufacturer	Description	Approximate Weights (lbs)	Representative UUT ¹	
Dry Type Transformer					
9T84C9474G03	GE	75kVA	833	UUT _z -1	
9T84C9474G03	GE	112.5kVA	833	UUT _z -1	
9T45J0006	GE	150kVA	851	UUT _z -2	
9T*	GE	75kVA-225kVA	833-851	Interpolated	
9T45J0007	GE	225kVA	851	UUT _z -2	
Power Panels					
APNB3812	GE	Spectra 1200A	150	UUT _v -6	
APN*	GE	Spectra 1200A-2000A	150-170	Interpolated	
APNB3820	GE	Spectra 2000A	170	UUT _v -3	
ALM3424MTX	GE	A Series 225A	33	UUT _x -1	
AL*, AD*	GE	A Series 225-600A	33-75	Interpolated	
ADM3366MTX	GE	A Series 600A	75	UUT _x -5	
Reliagar Power Panels Bus Stack					
IN1604TX3H1	ABB	400A, Aluminum	53	UUT _s -7	
IN1604CC3H2	ABB	400A, Copper	62	UUT _s -7	
Inxx(04-40)xx(1,3,4)(Hx,Bx)	ABB	400A-4000A, CU & AL	53-510	Interpolated	
IN4030CC3H1	ABB	3000A, Aluminum	280	UUT _s -8	
IN5640CC4B3	ABB	4000A, Copper	510	UUT _s -9	
Surge Protection Device (SPD)					
TPHE*, THE*, ATHE*, TPME*	GE	25-100kA/130-200kA	0-25	Extrapolated	
TPHE480D12PP	GE	125kA/250kA	25	UUT _v -3	
TPHE*, THE*, ATHE*, TPME*	GE	125-300kA/250-600kA	25	Interpolated	
TPHE480D30PP	GE	300kA/600kA	25	UUT _v -6	
SP120Y	ABB	120Wye, SPD, Disconnect	50	UUT _s -8	
SP277Y	ABB	480/277Y, SPD, Disconnect	50	Interpolated	
SP347Y	ABB	600/347Y, SPD, Disconnect	50	Interpolated	
SP480D	ABB	480D, SPD, Disconnect	50	UUT _s -8	
Strip Heaters					
CRX# OT-1225	Chromalox	Heater	3	UUT _v -2a	
Transfer Switches					
ZTG000A00020E	GE	Zenith Transfer Switch	60	UUT _x -3	
ZTG*	GE	Zenith Transfer Switch	60-69	Interpolated	
ZTGD00A0U020E	GE	Zenith Transfer Switch	69	UUT _x -3	
General Notes:					
1 The units were tested at different times and the subscripts on the UUT's reference the following lab test reports:					
r - 16188 / s - 15605 / t - 2346A / u - 10164 / v - 10155 / w - 10154 / x - 8101 / y - 8055 / z - 8480					
* Is used to indicated the series of identification numbers (range of subcomponents) beyond the primary identification number for the specified subcomponent product line.					

Table 6	ABB, INC. ISB SWITCHBOARD CERTIFIED SUBCOMPONENT MATRICES			 WEGAI <small>W.E. GUNDY & ASSOCIATES, INC. STRUCTURAL & EARTHQUAKE ENGINEERING</small>	
Seismic Certification Limits: $S_{DS} = 1.10g$ at $z/h = 1 \rightarrow F_p = 0.83g$ and $S_{DS} = 1.76g$ at $z/h = 0 \rightarrow F_p = 0.79g$					
Identification Number	Manufacturer	Description	Approximate Weights (lbs)	Representative UUT ¹	
Transfer Switches - cont'd					
OXA30U2X2QB	ABB	30A 2 Pole ATS	25	UUT _s -8	
OX*	ABB	TruONE ATS	25-125	Interpolated	
OXB1200U3S2QT	ABB	1200A 4 pole ATS	125	UUT _s -8	
Meter Socket					
CM100A35K480V	GE	480V	8.4	UUT _t -2	
CM200A65K480V	GE	480V	8.4	UUT _t -2	
CM100, CM200	GE	240V-600V	6.7 - 10.2	Interpolated	
CM200MSJF240V	GE	240V	6.7	UUT _t -2	
CM200MSJF600V	GE	600V	10.2	UUT _t -2	
MT04AP	ABB	Pulse, Carbon Steel	16	UUT _s -7	
MT04AM(AD)	ABB	ModBus, Carbon Steel	16	Interpolated	
MT04AB	ABB	BacNe, Carbon Steel	16	UUT _s -8	
Generator Connectors					
HBLFRSBN	Hubbell		0.1	UUT _t -1	
HBL	Hubbell		0.1-1.54	Interpolated	
HBLFRGN	Hubbell		1.54	UUT _t -1	
Control Power Transformer					
9T58K2808	GE	0.3 kVA 240/480	7	UUT _v -2a	
9T58K28(08-15)	GE	0.05kVA-3kVA 240/480	7-54	Interpolated	
9T58K2815	GE	3.0kVA 240/480	54	UUT _s -7	
<p>General Notes:</p> <p>¹ The units were tested at different times and the subscripts on the UUT's reference the following lab test reports: r - 16188 / s - 15605 / t - 2346A / u - 10164 / v - 10155 / w - 10154 / x - 8101 / y - 8055 / z - 8480</p> <p>* Is used to indicated the series of identification numbers (range of subcomponents) beyond the primary identification number for the specified subcomponent product line.</p>					

UUT_r-1

**UNIT UNDER TEST (UUT)
SUMMARY SHEET**



Mounting Details: Floor mounted with (4) 1/2" diameter grade 5 bolts.



Manufacturer: ABB, Inc.	Test Location: ETL
Product Line: Class1, Class 2, ISB Switchboard	Report Number: 16188, Rev 1
Model Number: RG-(CL1/CL2/ISB)-SB	UUT No. in Test Report: UUT-1
UUT Function: Synchronization of multiple power sources to main bus for distribution of electricity.	
UUT Description: The unit is comprised of a standalone floor mounted NEMA type 1 enclosure with Emax 6.2 - 6kA circuit breaker.	
UUT Components: NEMA 1 12ga Carbon Steel Enclosure with 6000A copper bus with (1) Emax 6.2 - 6kA drawout circuit breaker.	

UUT PROPERTIES

Weight (lb)	Dimensions (inches)			Natural Fequency (Hz)		
	Enclosure Width	Enclosure Depth	Enclosure Height	FB	SS	V
2,975	50.0"	50.0"	90.0"	5.9	5.6	15.5

SEISMIC TEST PARAMETERS

Test Criteria	S _{DS} (g)	z / h	I _p	A _{FLX-H}	A _{RIG-H}	A _{FLX-V}	A _{RIG-V}
CBC 2019 / ICC-ES-AC156	2.00	1.00	1.50	3.20g	2.40g	-	-
	2.50	0.00	1.50	-	-	1.68g	0.68g

Note: The unit was full of contents during testing and remained functional before and after the ICC-ES AC156 test. The unit maintained structural integrity during and after the ICC-ES AC156 Test.

UUT_r-2

**UNIT UNDER TEST (UUT)
SUMMARY SHEET**



Mounting Details: Floor mounted with (4) 1/2" diameter grade 5 bolts.



Manufacturer: ABB, Inc. **Test Location:** ETL

Product Line: Class1, Class 2, ISB Switchboard **Report Number:** 16188, Rev 1

Model Number: RG-(CL1/CL2/ISB)-SB **UUT No. in Test Report:** UUT-2

UUT Function: Synchronization of multiple power sources to main bus for distribution of electricity.

UUT Description: The unit is comprised of a standalone floor mounted NEMA type 1 enclosure with Emax 6.2 - 5kA and XT5 circuit breakers.

UUT Components: NEMA 1 12ga Carbon Steel Enclosure with 5000A copper bus with (1) Emax 6.2 - 5kA fixed circuit breaker and (1) XT5 600A circuit breaker.

UUT PROPERTIES

Weight (lb)	Dimensions (inches)			Natural Frequency (Hz)		
	Enclosure Width	Enclosure Depth	Enclosure Height	FB	SS	V
2,884	50"	45.0"	90.0"	5.9	5.4	14.7

SEISMIC TEST PARAMETERS

Test Criteria	S _{DS} (g)	z / h	I _p	A _{FLX-H}	A _{RIG-H}	A _{FLX-V}	A _{RIG-V}
CBC 2019 / ICC-ES-AC156	2.00	1.00	1.50	3.20g	2.40g	-	-
	2.50	0.00	1.50	-	-	1.68g	0.68g

Note: The unit was full of contents during testing and remained functional before and after the ICC-ES AC156 test. The unit maintained structural integrity during and after the ICC-ES AC156 Test.

UUT_r-3

**UNIT UNDER TEST (UUT)
SUMMARY SHEET**



Mounting Details: Floor mounted with (4) 1/2" diameter grade 5 bolts.



Manufacturer: ABB, Inc.	Test Location: ETL
Product Line: Class1, Class 2, ISB Switchboard	Report Number: 16188, Rev 1
Model Number: RG-(CL1/CL2/ISB)-SB	UUT No. in Test Report: UUT-3
UUT Function: Synchronization of multiple power sources to main bus for distribution of electricity.	
UUT Description: The unit is comprised of a standalone floor mounted NEMA type 1 enclosure with Emax 1.2 and XT7 circuit breakers.	
UUT Components: NEMA 1 12ga Carbon Steel Enclosure with 1200A copper bus with (1) Emax 1.2 - fixed breaker, (1) Emax 1.2 - drawout breaker and (1) XT7 1200A circuit breaker.	

UUT PROPERTIES

Weight (lb)	Dimensions (inches)			Natural Fequency (Hz)		
	Enclosure Width	Enclosure Depth	Enclosure Height	FB	SS	V
1,226	30.0"	30.0"	90.0"	8.3	10.4	20.8

SEISMIC TEST PARAMETERS

Test Criteria	S _{DS} (g)	z / h	I _p	A _{FLX-H}	A _{RIG-H}	A _{FLX-V}	A _{RIG-V}
CBC 2019 / ICC-ES-AC156	2.00	1.00	1.50	3.20g	2.40g	-	-
	2.50	0.00	1.50	-	-	1.68g	0.68g

Note: The unit was full of contents during testing and remained functional before and after the ICC-ES AC156 test. The unit maintained structural integrity during and after the ICC-ES AC156 Test.

UUT_s-7

**UNIT UNDER TEST (UUT)
SUMMARY SHEET**



Mounting Details: Floor mounted with (4) 1/2" diameter grade 8 bolts.



Manufacturer: ABB, Inc. **Test Location:** ETL

Product Line: Class1, Class 2, ISB Switchboard **Report Number:** 15605, Rev 1

Model #: RG-[CL1/CL2/ISB]-SB **UUT No. in Test Report:** UUT-7

UUT Function: Synchronization of multiple power sources to main bus for distribution of electricity.

UUT Description: The unit is comprised of a standalone floor mounted NEMA type 1 enclosure with (2) Reliagear panelboards.

UUT Components: NEMA 1 12ga Carbon Steel Enclosure with a 400A aluminum Reliagear power panel bus stack (IN1604TX3H1), 400A copper Reliagear power panel bus stack (IN1604CC3H2), Record plus breakers (NEFBV-15A, NEFBV-100A), XT molded case switches (2x XT1, 2x XT4), CPT (9T58K2815) and metering socket (MT04AP).

UUT PROPERTIES

Weight (lb)	Dimensions (inches)			Natural Fequency (Hz)		
	Enclosure Width	Enclosure Depth	Enclosure Height	FB	SS	V
809	30.0"	25.0"	90.0"	6.9	9.7	24.0

SEISMIC TEST PARAMETERS

Test Criteria	S _{DS} (g)	z / h	I _p	A _{FLX-H}	A _{RIG-H}	A _{FLX-V}	A _{RIG-V}
CBC 2019 / ICC-ES-AC156	2.00	1.00	1.50	3.20g	2.40g	-	-
CBC 2019 / ICC-ES-AC156	2.50	0.00	1.50	-	-	1.68g	0.68g

Note: The unit was full of contents during testing and remained functional before and after the ICC-ES AC156 test. The unit maintained structural integrity during and after the ICC-ES AC156 Test.

UUT_s-8

**UNIT UNDER TEST (UUT)
SUMMARY SHEET**



Mounting Details: Floor mounted with (4) 1/2" diameter grade 8 bolts.



Manufacturer: ABB, Inc.	Test Location: ETL
Product Line: Class1, Class 2, ISB Switchboard	Report Number: 15605, Rev 1
Model #: RG-[CL1/CL2/ISB]-SB	UUT No. in Test Report: UUT-8C
UUT Function: Synchronization of multiple power sources to main bus for distribution of electricity.	
UUT Description: The unit is comprised of a standalone floor mounted NEMA type 1 enclosure with (1) Reliagear panelboard.	
UUT Components: NEMA 1 12ga Carbon Steel Enclosure with a 3000A aluminum Reliagear power panel bus stack (IN4030CC3H1), XT molded case switches (2x XT4, 3x XT5, 2x XT7), surge protection devices (SP120Y, SP480D), ATS (OXA30U2X2QB, OXB1200U3S2QT), and metering socket (MT04AB).	

UUT PROPERTIES

Weight (lb)	Dimensions (inches)			Natural Frequency (Hz)		
	Enclosure Width	Enclosure Depth	Enclosure Height	FB	SS	V
1,625	50.0"	50.0"	90.0"	4.8	6.9	12.5

SEISMIC TEST PARAMETERS

Test Criteria	S _{DS} (g)	z / h	I _p	A _{FLX-H}	A _{RIG-H}	A _{FLX-V}	A _{RIG-V}
CBC 2019 / ICC-ES-AC156	2.00	1.00	1.50	3.20g	2.40g	-	-
CBC 2019 / ICC-ES-AC156	2.50	0.00	1.50	-	-	1.68g	0.68g

Note: The unit was full of contents during testing and remained functional before and after the ICC-ES AC156 test. The unit maintained structural integrity during and after the ICC-ES AC156 Test.

UUT_s-9

**UNIT UNDER TEST (UUT)
SUMMARY SHEET**



Mounting Details: Floor mounted with (4) 1/2" diameter grade 8 bolts.



Manufacturer: ABB, Inc.	Test Location: ETL
Product Line: Class1, Class 2, ISB Switchboard	Report Number: 15605, Rev 1
Model #: RG-[CL1/CL2/ISB]-SB	UUT No. in Test Report: UUT-9B
UUT Function: Synchronization of multiple power sources to main bus for distribution of electricity.	
UUT Description: The unit is comprised of a standalone floor mounted NEMA type 1 enclosure with (1) Reliagear panelboard.	
UUT Components: NEMA 1 12ga Carbon Steel Enclosure with a 4000A copper Reliagear power panel bus stack (IN5640CC4B3), and XT molded case switches (11x XT5, 7x XT7).	

UUT PROPERTIES

Weight (lb)	Dimensions (inches)			Natural Frequency (Hz)		
	Enclosure Width	Enclosure Depth	Enclosure Height	FB	SS	V
2,711	60.0"	60.0"	90.0"	4.8	3.5	9.9

SEISMIC TEST PARAMETERS

Test Criteria	S _{DS} (g)	z / h	I _p	A _{FLX-H}	A _{RIG-H}	A _{FLX-V}	A _{RIG-V}
CBC 2019 / ICC-ES-AC156	2.00	1.00	1.50	3.20g	2.40g	-	-
CBC 2019 / ICC-ES-AC156	2.50	0.00	1.50	-	-	1.68g	0.68g

Note: The unit was full of contents during testing and remained functional before and after the ICC-ES AC156 test. The unit maintained structural integrity during and after the ICC-ES AC156 Test.

UUT_t-1

**UNIT UNDER TEST (UUT)
SUMMARY SHEET**



Mounting Details: Floor mounted with (4) 1/2" diameter grade 5 bolts.

Required Modification: Door hinge bolts replaced with 1/4-20 bolts.



UUT-1 on the right

BY: Mohammad Karim

DATE: 10/25/2022

Manufacturer: ABB, Inc.	Test Location: Clark Test Laboratory
Product Line: Class 1, Class 2, ISB Switchboard	Report Number: 2346A-R Rev.1
Model #: GT-[CL1/CL2/ISB]-SB	UUT No. in Test Report: UUT1
UUT Function: Synchronization of multiple power sources to main bus for distribution of electricity.	
UUT Description: The unit is comprised of a standalone floor mounted NEMA type 3R enclosure with (2) Generator Connection Receptacle Studs.	
UUT Components: NEMA 3R 12ga Carbon Steel Enclosure with (2) Generator Connection Receptacles Studs (HBLFRSBN, HBLFRGN)	

UUT PROPERTIES

Weight (lb)	Dimensions (inches)			Natural Frequency (Hz)		
	Enclosure Width	Enclosure Depth	Enclosure Height	FB	SS	V
1,852	40.0"	50.0"	93.0"	11.5	7.57	32.8

SEISMIC TEST PARAMETERS

Test Criteria	S _{DS} (g)	z / h	I _p	A _{FLX-H}	A _{RIG-H}	A _{FLX-V}	A _{RIG-V}
CBC 2019 / ICC-ES-AC156	2.00	1.00	1.50	3.20g	2.40g	-	-
CBC 2019 / ICC-ES-AC156	2.50	0.00	1.50	-	-	1.68g	0.68g

Note: The unit was full of contents during testing and remained functional before and after the ICC-ES AC156 test. The unit maintained structural integrity during and after the ICC-ES AC156 Test.

UUT_t-2

**UNIT UNDER TEST (UUT)
SUMMARY SHEET**



Mounting Details: Floor mounted with (4) 1/2" diameter grade 5 bolts.



UUT-2 on the left

DATE: 10/25/2022

Manufacturer: ABB, Inc.	Test Location: Clark Test Laboratory
Product Line: Class1, Class 2, ISB Switchboard	Report Number: 2346A-R Rev.1
Model #: CM-[CL1/CL2/ISB]-SB	UUT No. in Test Report: UUT2
UUT Function: Synchronization of multiple power sources to main bus for distribution of electricity.	
UUT Description: The unit is comprised of a standalone floor mounted NEMA type 3R enclosure with (4) meter sockets.	
UUT Components: NEMA 3R 12ga Carbon Steel Enclosure with (4) meter sockets ((2) CM100A35K480V, (2) CM200A65K600V) and (2) FD1 meter sockets(CM200MSJF600V, CM200MSJF240V)	

UUT PROPERTIES

Weight (lb)	Dimensions (inches)			Natural Frequency (Hz)		
	Enclosure Width	Enclosure Depth	Enclosure Height	FB	SS	V
1,020	35.0"	40.0"	93.0"	17.2	11.5	32.0

SEISMIC TEST PARAMETERS

Test Criteria	S _{DS} (g)	z / h	I _p	A _{FLX-H}	A _{RIG-H}	A _{FLX-V}	A _{RIG-V}
CBC 2019 / ICC-ES-AC156	2.00	1.00	1.50	3.20g	2.40g	-	-
CBC 2019 / ICC-ES-AC156	2.50	0.00	1.50	-	-	1.68g	0.68g

Note: The unit was full of contents during testing and remained functional before and after the ICC-ES AC156 test. The unit maintained structural integrity during and after the ICC-ES AC156 Test.

UUT_v-3

**UNIT UNDER TEST (UUT)
SUMMARY SHEET**



Mounting Details: Floor mounted with (4) 1/2" diameter grade 5 bolts.

Required Modifications: (6) 1/4"-20 bolts added to front frame.



Manufacturer: ABB, Inc.	Test Location: Clark Test Laboratory
Product Line: Class1, Class 2, ISB Switchboard	Report Number: 10155
Model #: EV-[CL1/CL2/ISB]-SB / Switchboard NPI-2	UUT No. in Test Report: UUT3
UUT Function: Synchronization of multiple power sources to main bus for distribution of electricity.	
UUT Description: The unit comprised of a standalon floor mounted NEMA 1 enclosure with 4000A busway and multiple circuit breakers.	
UUT Components: NEMA 1 12ga carbon steel enclosure with 4000A copper bus, 2000 spectra series panelboard (APNB3820), TVSS Surge Protection device (TPHE480D12PP), record plus circuit breakers (FBL36TE030R, FBH36TE035R2, FGP36AA066R1), spectra circuit breakers (SEHA36AT0030, SKHA36AT1200), thermal mag molded case breakers (TEYF1015, TEYF2015, TEYF3015).	

UUT PROPERTIES

Weight (lb)	Dimensions (inches)			Natural Fequency (Hz)		
	Enclosure Width	Enclosure Depth	Enclosure Height	FB	SS	V
1,026	45.0"	25.0"	90.0"	8.95	10	>33

SEISMIC TEST PARAMETERS

Test Criteria	S _{DS} (g)	z / h	I _p	A _{FLX-H}	A _{RIG-H}	A _{FLX-V}	A _{RIG-V}
CBC 2019 / ICC-ES-AC156	2.00	1.00	1.50	3.20g	2.40g	-	-
CBC 2019 / ICC-ES-AC156	2.50	0.00	1.50	-	-	1.68g	0.68g

Note: The unit was full of contents during testing and remained functional before and after the ICC-ES AC156 test. The unit maintained structural integrity during and after the ICC-ES AC156 Test.

UUT_v-6

**UNIT UNDER TEST (UUT)
SUMMARY SHEET**



Mounting Details: Floor mounted with (4) 1/2" diameter grade 5 bolts.

Required Modifications: (6) 1/4"-20 bolts added to front frame



Manufacturer: ABB, Inc.	Test Location: Clark Test Laboratory
Product Line: Class1, Class 2, ISB Switchboard	Report Number: 10155
Model #: EV-[CL1/CL2/ISB]-SB / Switchboard NPI-2	UUT No. in Test Report: UUT6
UUT Function: Synchronization of multiple power sources to main bus for distribution of electricity.	
UUT Description: The unit is comprised of a standalone floor mounted NEMA type 1 enclosure with 4000A busway and multiple circuit breakers.	
UUT Components: NEMA 1 12ga carbon steel enclosure with 4000A aluminum bus, 1200A (TKM3F), fusible switches (ADS36030HS, ADS36120LB), surge protection device (TPHE480D30PP), and 1200A fuse (AFBY1200)	

UUT PROPERTIES

Weight (lb)	Dimensions (inches)			Natural Frequency (Hz)		
	Enclosure Width	Enclosure Depth	Enclosure Height	FB	SS	V
870	45.0	25.0	91.0	9.48	11.4	13.0

SEISMIC TEST PARAMETERS

Test Criteria	S _{DS} (g)	z / h	I _p	A _{FLX-H}	A _{RIG-H}	A _{FLX-V}	A _{RIG-V}
CBC 2019 / ICC-ES-AC156	2.00	1.00	1.50	3.20g	2.40g	-	-
CBC 2019 / ICC-ES-AC156	2.50	0.00	1.50	-	-	1.68g	0.68g

Note: The unit was full of contents during testing and remained functional before and after the ICC-ES AC156 test. The unit maintained structural integrity during and after the ICC-ES AC156 Test.

UUT_w-4

**UNIT UNDER TEST (UUT)
SUMMARY SHEET**



Mounting Details: Floor mounted with (4) 1/2" diameter grade 5 bolts.

Required Modifications: (6) 1/4-20 screws to the front door.



Manufacturer: ABB, Inc.	Test Location: Clark Test Laboratory
Product Line: Class1, Class 2, ISB Switchboard	Report Number: 10154
Model #: EV-[CL1/CL2/ISB]-SB / Switchboard NPI-2	UUT No. in Test Report: UUT4
UUT Function: Synchronization of multiple power sources to main bus for distribution of electricity.	
UUT Description: The unit is comprised of a standalone floor mounted NEMA type 1 enclosure with a 4000A busway and high pressure contact switch (HPC).	
UUT Components: NEMA 1 12ga carbon steel enclosure with 4000A aluminum bus, 4000A HPC (THPC3640G3T), 4000A fuse (A4BY4000), ground fault transformer (BGFL254-1200), EPM power meter (PL74501AB0A000).	

UUT PROPERTIES

Weight (lb)	Dimensions (inches)			Natural Frequency (Hz)		
	Enclosure Width	Enclosure Depth	Enclosure Height	FB	SS	V
1,176	40.0"	35.0"	90.0"	8.77	7.43	>33

SEISMIC TEST PARAMETERS

Test Criteria	S _{DS} (g)	z / h	I _p	A _{FLX-H}	A _{RIG-H}	A _{FLX-V}	A _{RIG-V}
CBC 2019 / ICC-ES-AC156	2.00	1.00	1.50	3.20g	2.40g	-	-
CBC 2019 / ICC-ES-AC156	2.50	0.00	1.50	-	-	1.68g	0.68g

Note: The unit was full of contents during testing and remained functional before and after the ICC-ES AC156 test. The unit maintained structural integrity during and after the ICC-ES AC156 Test.

UUT_w-5

**UNIT UNDER TEST (UUT)
SUMMARY SHEET**



Mounting Details: Floor mounted with (4) 1/2" diameter grade 5 bolts.

Required Modifications: (4) 1/4-20 screws to the front door.



Manufacturer: ABB, Inc.	Test Location: Clark Test Laboratory
Product Line: Class1, Class 2, ISB Switchboard	Report Number: 10154
Model #: EV-[CL1/CL2/ISB]-SB / Switchboard NPI-2	UUT No. in Test Report: UUT5
UUT Function: Synchronization of multiple power sources to main bus for distribution of electricity.	
UUT Description: The unit is comprised of a standalone floor mounted NEMA type 1 enclosure with 800A busway and 800A high pressure contract (HPC) switch.	
UUT Components: NEMA 1 12ga carbon steel enclosure with 800A aluminum bus, 800A HPC switch (THPR3608GA3), 800A fuses (A4BY800), ammeter (250440LSVE7JBNU), voltmeter (250444SJS7JGSU) and 2 selector switches (A11A00721E, A11A048-723E)	

UUT PROPERTIES

Weight (lb)	Dimensions (inches)			Natural Frequency (Hz)		
	Enclosure Width	Enclosure Depth	Enclosure Height	FB	SS	V
510	30.0"	25.0"	90.0"	12.3	10.9	12.7

SEISMIC TEST PARAMETERS

Test Criteria	S _{DS} (g)	z / h	I _p	A _{FLX-H}	A _{RIG-H}	A _{FLX-V}	A _{RIG-V}
CBC 2019 / ICC-ES-AC156	2.00	1.00	1.50	3.20g	2.40g	-	-
CBC 2019 / ICC-ES-AC156	2.50	0.00	1.50	-	-	1.68g	0.68g


Note: The unit was full of contents during testing and remained functional before and after the ICC-ES AC156 test. The unit maintained structural integrity during and after the ICC-ES AC156 Test.

UUT_v-2a

**UNIT UNDER TEST (UUT)
SUMMARY SHEET**



Mounting Details: Floor mounted with (4) 1/2" diameter grade 5 bolts in both sections.



REVIEWED FOR CODE COMPLIANCE
HCAi
OSP-0044
BY: Mohammad Karim
DATE: 10/25/2022

Manufacturer: ABB, Inc.	Test Location: Clark Test Laboratory
Product Line: Class 2, ISB Switchboard	Report Number: 10155
Model #: EV-[CL2/ISB]-SB / Switchboard NPI 2	UUT No. in Test Report: UUT2
UUT Function: Synchronization of multiple power sources to main bus for distribution of electricity.	
UUT Description: The unit is comprised of a two mated, floor mounted NEMA type 1 enclosure with 2000A busway with Entelliguard circuit breaker.	
UUT Components: NEMA 1 12ga carbon steel enclosure with 2000 copper bus, 1 Entelliguard circuit breaker (GA20M2X), heater (CRX# OT-1225), fuse (A4J6, AJT1-1/2, TR3R), relay (SPVRB 480), 0.3kVA Control Power Transformer (9T58K2808), and 123" top feeder stack.	

UUT PROPERTIES

Weight (lb)	Dimensions (inches)			Natural Frequency (Hz)		
	Enclosure Width	Enclosure Depth	Enclosure Height	FB	SS	V
1,435	35.0"	35.0"	90.0"	8.2	16.8	31.0

SEISMIC TEST PARAMETERS

Test Criteria	S _{DS} (g)	z / h	I _p	A _{FLX-H}	A _{RIG-H}	A _{FLX-V}	A _{RIG-V}
CBC 2019 / ICC-ES-AC156	2.00	1.00	1.50	3.20g	2.40g	-	-
CBC 2019 / ICC-ES-AC156	2.50	0.00	1.50	-	-	1.68g	0.68g

Note: The unit was full of contents during testing and remained functional before and after the ICC-ES AC156 test. The unit maintained structural integrity during and after the ICC-ES AC156 Test.

UUT_u-1

**UNIT UNDER TEST (UUT)
SUMMARY SHEET**



Mounting Details: Floor mounted with (4) 1/2" diameter grade 5 bolts.

Required Modification: (24) 1/4-20 screws added to front panels.



DATE: 10/25/2022

Manufacturer: ABB, Inc. **Test Location:** Clark Test Laboratory

Product Line: Class 2, ISB Switchboard **Report Number:** 10164

Model #: EV-[CL2/ISB]-SB / Switchboard NPI-2 **UUT No. in Test Report:** UUT1

UUT Function: Synchronization of multiple power sources to main bus for distribution of electricity.

UUT Description: The unit is comprised of a floor mounted NEMA type 1 enclosure consisting of a 6000A copper busway and a 6000A Entelguard Breaker.

UUT Components: NEMA1 12ga Carbon Steel Enclosure; 6000A Entelguard G Circuit Breaker (GA60M2X), 6000A Copper silver-plated bus, PQM Meter (PQM II), Fuse (AJT2), Fuse Block (15149-3), Voltage Conditioner Plate (SVCA480Y), Power Supply Plate (SPSA480).

UUT PROPERTIES

Weight (lb)	Dimensions (inches)			Natural Frequency (Hz)		
	Enclosure Width	Enclosure Depth	Enclosure Height	FB	SS	V
4,463	60.0"	60.0"	90.0"	3.5	2.4	10.6

SEISMIC TEST PARAMETERS

Test Criteria	S _{DS} (g)	z / h	I _p	A _{FLX-H}	A _{RIG-H}	A _{FLX-V}	A _{RIG-V}
CBC 2019 / ICC-ES-AC156	1.56	1.00	1.50	2.50g	1.87g	-	-
CBC 2019 / ICC-ES-AC156	2.50	0.00	1.50	-	-	1.68g	0.68g

Note: The unit was full of contents during testing and remained functional before and after the ICC-ES AC156 test. The unit maintained structural integrity during and after the ICC-ES AC156 Test.

UUT_x-1

**UNIT UNDER TEST (UUT)
SUMMARY SHEET**



Mounting Details: Floor mounted with (4) 1/2" diameter grade 5 bolts.



BY: Mohammad Karim

UUT-1

DATE: 10/25/2022

Manufacturer: ABB, Inc.	Test Location: Clark Test Laboratory
Product Line: Class 2, ISB Switchboard	Report Number: 8101
Model #: INT-[CL2/ISB]-SB / Distribution	UUT No. in Test Report: Switchboard#1
UUT Function: Synchronization of multiple power sources to main bus for distribution of electricity.	
UUT Description: The unit is comprised of a standalone floor mounted NEMA type 1 enclosure with a 250A Circuit Breaker and (2) A Series Panelboards.	
UUT Components: NEMA1 12ga Carbon Steel Enclosure with a 250A Spectra F Circuit Breaker (SFLA36AT0250), (2) A Series Panel Board (AQM3424MTX, ALM342MTX)	

UUT PROPERTIES

Weight (lb)	Dimensions (inches)			Natural Frequency (Hz)		
	Enclosure Width	Enclosure Depth	Enclosure Height	FB	SS	V
435	40.0"	15.0"	90.0"	19.50	12.5	>33

SEISMIC TEST PARAMETERS

Test Criteria	S _{DS} (g)	z / h	I _p	A _{FLX-H}	A _{RIG-H}	A _{FLX-V}	A _{RIG-V}
CBC 2019 / ICC-ES-AC156	1.56	1.00	1.50	2.50g	1.87g	-	-
CBC 2019 / ICC-ES-AC156	2.50	0.00	1.50	-	-	1.68g	0.68g


Note: The unit was full of contents during testing and remained functional before and after the ICC-ES AC156 test. The unit maintained structural integrity during and after the ICC-ES AC156 Test.

UUT_x-3

**UNIT UNDER TEST (UUT)
SUMMARY SHEET**



Mounting Details: Floor mounted with (4) 1/2" diameter grade 5 bolts.



Manufacturer: ABB, Inc.	Test Location: Clark Test Laboratory
Product Line: Class 2, ISB Switchboard	Report Number: 8101
Model #: INT-[CL2/ISB]-SB	UUT No. in Test Report: Switchboard #3
UUT Function: Synchronization of multiple power sources to main bus for distribution of electricity.	
UUT Description: The unit is comprised of a standalone floor mounted NEMA type 1 enclosure with ATS Switches.	
UUT Components: NEMA1 12ga Carbon Steel Enclosure; (2) 200A Automatic Transfer Switches (ZTG000A00020E, ZTG00A0U020E)	

UUT PROPERTIES

Weight (lb)	Dimensions (inches)			Natural Frequency (Hz)		
	Enclosure Width	Enclosure Depth	Enclosure Height	FB	SS	V
405	20.0"	30.0"	90.0"	18.70	14.8	>33

SEISMIC TEST PARAMETERS

Test Criteria	S _{DS} (g)	z / h	I _p	A _{FLX-H}	A _{RIG-H}	A _{FLX-V}	A _{RIG-V}
CBC 2019 / ICC-ES-AC156	1.67	1.00	1.50	2.67g	2.0g	-	-
CBC 2019 / ICC-ES-AC156	2.50	0.00	1.50	-	-	1.68g	0.68g


Note: The unit was full of contents during testing and remained functional before and after the ICC-ES AC156 test. The unit maintained structural integrity during and after the ICC-ES AC156 Test.

UUT_x-5

**UNIT UNDER TEST (UUT)
SUMMARY SHEET**



Mounting Details: Floor mounted with (4) 1/2" diameter grade 5 bolts.



UUT-5

DATE: 10/25/2022

Manufacturer: ABB, Inc.	Test Location: Clark Test Laboratory
Product Line: Class 2, ISB Switchboard	Report Number: 8101
Model #: INT-[CL2/ISB]-SB	UUT No. in Test Report: Switchboard #5
UUT Function: Synchronization of multiple power sources to main bus for distribution of electricity.	
UUT Description: The unit is comprised of a standalone floor mounted NEMA type 1 enclosure with A Series Panel Board 600A	
UUT Components: NEMA1 12ga Carbon Steel Enclosure; A Series Panel Board 600A (ADM3366MTX), and TVSS (TPHE480D30PP).	

UUT PROPERTIES

Weight (lb)	Dimensions (inches)			Natural Frequency (Hz)		
	Enclosure Width	Enclosure Depth	Enclosure Height	FB	SS	V
380	25.0"	15.0"	90.0"	5.5	12.5	>33

SEISMIC TEST PARAMETERS

Test Criteria	S _{DS} (g)	z / h	I _p	A _{FLX-H}	A _{RIG-H}	A _{FLX-V}	A _{RIG-V}
CBC 2019 / ICC-ES-AC156	1.67	1.00	1.50	2.67g	2.00g	-	-
CBC 2019 / ICC-ES-AC156	2.50	0.00	1.50	-	-	1.68g	0.68g



Note: The unit was full of contents during testing and remained functional before and after the ICC-ES AC156 test. The unit maintained structural integrity during and after the ICC-ES AC156 Test.

UUT_y-1a

**UNIT UNDER TEST (UUT)
SUMMARY SHEET**



Mounting Details: Floor mounted with (4) 1/2" diameter grade 5 bolts.



REVIEWED FOR CODE COMPLIANCE
 BY: Mohammad Karim
 UUT-1A
 DATE: 10/25/2022
 CSP-0044

Manufacturer: ABB, Inc.	Test Location: Clark Test Laboratory
Product Line: Class 2, ISB Switchboard	Report Number: 8055
Model #: AV-[CL2/ISB]-SB	UUT No. in Test Report: UUT1A
UUT Function: Synchronization of multiple power sources to main bus for distribution of electricity.	
UUT Description: The unit is comprised of a floor mounted NEMA type 3R enclosure consisting of a drip roof, circuit breakers and a relay.	
UUT Components: NEMA3R 12ga Carbon Steel Enclosure with Relay (BE3-27-1A1N2), Spectra Circuit Breaker (SKPA36AT1200, SGLA36AT0600, SFLA36AT0250, SELA36AT0150).	

UUT PROPERTIES

Weight (lb)	Dimensions (inches)			Natural Frequency (Hz)		
	Enclosure Width	Enclosure Depth	Enclosure Height	FB	SS	V
1,050	15.0"	50.0"	104.0"	12.4	7.8	>33

SEISMIC TEST PARAMETERS

Test Criteria	S _{DS} (g)	z / h	I _p	A _{FLX-H}	A _{RIG-H}	A _{FLX-V}	A _{RIG-V}
CBC 2019 / ICC-ES-AC156	1.67	1.00	1.50	2.67g	2.00g	-	-
CBC 2019 / ICC-ES-AC156	2.50	0.00	1.50	-	-	1.68g	0.68g

Note: The unit was full of contents during testing and remained functional before and after the ICC-ES AC156 test. The unit maintained structural integrity during and after the ICC-ES AC156 Test.

UUT_y-1b


**UNIT UNDER TEST (UUT)
SUMMARY SHEET**



Mounting Details: Floor mounted with (4) 1/2" diameter grade 5 bolts.



UUT-1B



Manufacturer: ABB, Inc.	Test Location: Clark Test Laboratory
Product Line: Class 2, ISB Switchboard	Report Number: 8055
Model #: PB-[CL2/ISB]-SB	UUT No. in Test Report: UUT1B
UUT Function: Synchronization of multiple power sources to main bus for distribution of electricity.	
UUT Description: The unit is comprised of a floor mounted NEMA type 3R enclosure consisting of a drip roof, circuit breakers.	
UUT Components: NEMA3R 12ga Carbon Steel Enclosure with Powerbreak II Circuit Breaker (SSD30D30H, SSD20B20H, SSD08B08H).	

UUT PROPERTIES

Weight (lb)	Dimensions (inches)			Natural Frequency (Hz)		
	Enclosure Width	Enclosure Depth	Enclosure Height	FB	SS	V
2,129	22.0"	50.0"	104.0"	12.4	7.8	>33

SEISMIC TEST PARAMETERS

Test Criteria	S _{DS} (g)	z / h	I _p	A _{FLX-H}	A _{RIG-H}	A _{FLX-V}	A _{RIG-V}
CBC 2019 / ICC-ES-AC156	1.67	1.00	1.50	2.67g	2.00g	-	-
CBC 2019 / ICC-ES-AC156	2.50	0.00	1.50	-	-	1.68g	0.68g

Note: The unit was full of contents during testing and remained functional before and after the ICC-ES AC156 test. The unit maintained structural integrity during and after the ICC-ES AC156 Test.

UUT_z-1

**UNIT UNDER TEST (UUT)
SUMMARY SHEET**



Mounting Details: Floor mounted with (4) 1/2" diameter grade 5 bolts.



Manufacturer: ABB, Inc.	Test Location: Clark Test Laboratory
Product Line: ISB Switchboard	Report Number: 8480
Model #: INT-[ISB]-SB	UUT No. in Test Report: UUT1
UUT Function: Synchronization of multiple power sources to main bus for distribution of electricity.	
UUT Description: The unit is comprised of a standalone floor mounted NEMA type 1 enclosure with (2) dry type transformers.	
UUT Components: NEMA1 12ga Carbon Steel Enclosure with 75kVA Transformer (9T84C9474G03), 112.5kVA Transformer (9T84C9475G03).	

UUT PROPERTIES

Weight (lb)	Dimensions (inches)			Natural Frequency (Hz)		
	Enclosure Width	Enclosure Depth	Enclosure Height	FB	SS	V
2,125	40.0"	35.0"	90.0"	7.8	32.0	>33

SEISMIC TEST PARAMETERS

Test Criteria	S _{DS} (g)	z / h	I _p	A _{FLX-H}	A _{RIG-H}	A _{FLX-V}	A _{RIG-V}
CBC 2019 / ICC-ES-AC156	1.10	1.00	1.50	1.52g	1.14g	-	-
CBC 2019 / ICC-ES-AC156	1.76	0.00	1.50	-	-	1.02g	0.41g

Note: The unit was full of contents during testing and remained functional before and after the ICC-ES AC156 test. The unit maintained structural integrity during and after the ICC-ES AC156 Test.

UUT_z-2

**UNIT UNDER TEST (UUT)
SUMMARY SHEET**



Mounting Details: Floor mounted with (4) 1/2" diameter grade 5 bolts.



Manufacturer: ABB, Inc.	Test Location: Clark Test Laboratory
Product Line: ISB Switchboard	Report Number: 8480
Model #: INT-[ISB]-SB	UUT No. in Test Report: UUT2
UUT Function: Synchronization of multiple power sources to main bus for distribution of electricity.	
UUT Description: The unit is comprised of a standalone floor mounted NEMA type 1 enclosure with a 150kVA Transformer and 225kVA Transformer	
UUT Components: NEMA1 12ga Carbon Steel Enclosure; 150kVA Transformer (copper windings), 225kVA Transformer (copper windings)	

UUT PROPERTIES

Weight (lb)	Dimensions (inches)			Natural Frequency (Hz)		
	Enclosure Width	Enclosure Depth	Enclosure Height	FB	SS	V
2,410	40.0"	35.0"	90.0"	15.6	15.5	>33

SEISMIC TEST PARAMETERS

Test Criteria	S _{DS} (g)	z / h	I _p	A _{FLX-H}	A _{RIG-H}	A _{FLX-V}	A _{RIG-V}
CBC 2019 / ICC-ES-AC156	1.10	1.00	1.50	1.52g	1.14g	-	-
CBC 2019 / ICC-ES-AC156	1.76	0.00	1.50	-	-	1.02g	0.41g

Note: The unit was full of contents during testing and remained functional before and after the ICC-ES AC156 test. The unit maintained structural integrity during and after the ICC-ES AC156 Test.