

Title: Seismic Test Engineer

# **DEPARTMENT OF HEALTH CARE ACCESS AND INFORMATION** OFFICE OF STATEWIDE HOSPITAL PLANNING AND DEVELOPMENT

APPLICATION FOR HCAI SPECIAL SEISM	OFFICE USE ONLY
CERTIFICATION PREAPPROVAL (OSP)	APPLICATION #: OSP-0054
HCAI Special Seismic Certification Preapproval (OSP	')
Type: New X Renewal	
Manufacturer Information	
Manufacturer: Electronic Systems Support	
Manufacturer's Technical Representative: Ruben Narvaez	
Mailing Address: 3233 W Kingsley Rd. Suite 200, Garland, TX	75041
Telephone: (972) 272-2468 Email: rub	pen.narvaez@ess.to
Product Information	
Product Name: Battery Cabinets	100
Product Model Number(s): See Attachment	
Product Category: UPS and Batteries	
Product Sub-Category: Batteries	U54 (F)
	ame elements along al <mark>l edg</mark> es. The units are welded and s. The cabinets contain batteries and breakers.
Mounting Description: Base Mounted Rigid	
	ade to the test units and/or modifications required to address shall be incorporated into the production units.
Applicant Information	
Applicant Company Name: Dynamic Certification Laboratories	
Contact Person: Rachel Wolfe	
Mailing Address: 1315 Greg Street, Sparks, NV 89431	DING
Telephone: (775) 358-5085 Email: rac	chel.wolfe@shaketest.com





STATE OF CALIFORNIA - HEALTH AND HUMAN SERVICES AGENCY



# DEPARTMENT OF HEALTH CARE ACCESS AND INFORMATION OFFICE OF STATEWIDE HOSPITAL PLANNING AND DEVELOPMENT

California Licensed Structural Engineer Responsible for the Engineering and Test Report(s)
Company Name: THE VMC GROUP
Name: Kenneth Tarlow California License Number: S2851
Mailing Address: 980 9th Street, 16th Floor, Sacramento, CA 95814
Telephone: (832) 627-2214 Email: ken.tarlow@thevmcgroup.com
Contification Mathed
Certification Method
GR-63-Core X ICC-ES AC156 IEEE 344 IEEE 693 NEBS 3
Other (Please Specify):
Testing Laboratory
Company Name: DYNAMIC CERTIFICATION LABORATORY (DCL)
Contact Person: Josh Sailer
Mailing Address: 1315 Greg St., Ste 109, Sparks NV 89431
Telephone: (775) 358-5085 Email:
Company Name: ENVIRONMENTAL TESTING LABORATORIES, INC. (ETL)
Contact Person: Brady Richard BY: Hmothy J. Plland
Mailing Address: 11034 Indian Trail, Dallas TX 75229
Telephone: (972) 247-9657 Email: info@etldallas.com
BUILDING CODE:

All the



STATE OF CALIFORNIA - HEALTH AND HUMAN SERVICES AGENCY



# DEPARTMENT OF HEALTH CARE ACCESS AND INFORMATION OFFICE OF STATEWIDE HOSPITAL PLANNING AND DEVELOPMENT

# **Seismic Parameters**

Certified Response Spectral Acceleration Factors:(Fp/Wp)

Horizontal (A Flx-H), g= 2.40 (A Rig-H), g= 1.80

Vertical (A Flx-V), g= 1.00 (A Rig-V), g= 0.40

SDS (Design spectral response acceleration at short period, g) = 1.50

Hf (Force amplification height factor) = 3.5 at z/h=1; 1.0 at z/h=0

Ru (Structure ductility redution factor) = 1.3 at z/h=1; 1.0 at z/h=0

Ip (Importance factor) = 1.5

z/h (Height ratio factor) = 0 and 1

# HCAI Approval (For Office Use Only) - Approval Expires on 10/08/2031

Date: 10/8/2025

Name: Timothy Piland Title: Senior Structural Engineer

Condition of Approval (if applicable): OSP-0054

BY: Timothy J. Piland

DATE: 10/08/2025





STATE OF CALIFORNIA – HEALTH AND HUMAN SERVICES AGENCY

### Table 1 - Certified Components - 16V Battery Cabinets



DCL Project Number: 49106-2501

Manufacturer: Electronic Systems Support

Product Line: Battery Cabinets

Certified Construction: Powder-coated carbon steel frame

NEMA Rating: 1

Certified Options: Enclosures, batteries and breakers
Certified Mounting Description: Rigid base mounted
Certified Seismic Levels: Sds = 1.5g at z/h = 1.0 and z/h = 0

Factors for Force Amplification and Structure Ductility Reduction:  $H_f = 3.5$  at z/h=1.0; 1.0 at z/h=0 and  $R_{\mu} = 1.3$  at z/h=1.0; 1.0 at z/h=0

Model Number	Horizontally-Arrayed	Vertically Stacked	Unit Battery Size	<b>Battery Size</b>	N	/lax. Dimensions (i	in)	Max. Weight	Unit
woder Number	Batteries <sup>1</sup>	Batteries	Onit Battery Size	Tested	Width <sup>1</sup>	Depth	Height	(lb)	Onit
Sx33800144BLxxxx	3	3	800	N/A	25.0	31.5	72.0	2,420	Extrapolated <sup>3</sup>
ST35xxx144BL250D	3	3	925	800, 925	25.0	31.5	84.0 <sup>2</sup>	2,600	UUT4 <sup>4</sup>
Sx34800192BLxxxx	3	4	800	N/A	25.0	31.5	72.0	3,290	Interpolated
Sx34925192BLxxxx	3	4	925	N/A	25.0	31.5	72.0	3,350	Interpolated
Sx35800240BLxxxx	3	5	800	N/A	25.0	31.5	84.0	4,030	Interpolated
ST35925240BLA00A	3	5	925	925	25.0	31.5	84.0 <sup>2</sup>	4,092	UUT2
Sx64550384BLxxxx	6	4	550	N/A	32.0	31.5	72.0	4,400	Interpolated
ST65550288BL250C	6	3	550	550	32.0	31.5	84.0 <sup>2</sup>	3,300	UUT3
ST65550480BLA00B	6	5	550	550	32.0	31.5	84.0 <sup>2</sup>	5,185	UUT1
Sx63800288BLxxxx	6 (3,3)	3	800	N/A	50.0	31.5	72.0	4,820	Extrapolated <sup>5</sup>
Sx63925288BLxxxx	6 (3,3)	3	925	N/A	50.0	31.5	72.0	5,180	Extrapolated <sup>5</sup>
Sx64800384BLxxxx	6 (3,3)	4	800	N/A	50.0	31.5	72.0	6,200	Extrapolated <sup>5</sup>
Sx64925384BLxxxx	6 (3,3)	4	925	N/A	50.0	31.5	72.0	6,680	Extrapolated <sup>5</sup>
Sx65800480BLxxxx	6 (3,3)	5	800	N/A	50.0	31.5	84.0	7,580	Extrapolated <sup>5</sup>
Sx65925480BLxxxx	6 (3,3)	5	925	N/A	50.0	31.5	84.0	8,180	Extrapolated <sup>5</sup>

#### Notes:

1. For systems containing 800 or 925 batteries, a 6-battery horizontal array is two structurally-independent cabinets installed side-by-side, each containing a 3-battery horizontal array.

2. Tested unit used a full height enclosure (84"). However, a 3- and 4- vertically stacked units use a 72" tall enclosure.

3. Unit is extrapolated based on UUT4 Test. The units are similar in construction to UUT4.

4. Multiple batteries were used in the UUTs to cover the battery types offered in the full product line. A distinct model number cannot be associated with the actual tested units since they utilize multiple battery types.

5. Unit is extrapolated based on UUT2 and UUT4 test (extrapolated unit is two structurally-independent 25-inch wide enclosures installed side-by-side, as tested in UUT2 and UUT4).

DATE: 10/08/2025

Nomenclature Notes:

Options (designated as "x" in certified model numbers):

Digit 2: Cabinet color (T, A, C, E)

Digit 13-15: Breaker size in Amps (250 - A00 for 250Amp - 1000Amp breakers); reference certified breakers subcomponent table

Digit 16: Breaker option (A, B, C, D, E, F, G, H, K); reference breaker option subcomponent table

BUILDING

10/08/2025 OSP-0054 Page 4 of 19

# Table 2 - Nomenclature Chart - 16V Battery Cabinet Nomenclature Chart



DCL Project Number: 45798-1901

Manufacturer: Electronic Systems Support
Product Line: Battery Cabinets

		Sa	mple Part Number: STWHCDBFG	SU .		
Character	Category	Digit	Allowable Value	Description	Unit	
S	System	1	S	Battery Cabinets	UUT1, UUT2, UUT3, UUT	
			Т	Top Breaker, Gray	UUT1, UUT2, UUT3, UUT	
<del>-</del>	~ 1: <del>.</del>		A	Top Breaker , Black	Same as	
Т	Cabinet Type	2	С	Top Breaker , White	Same as	
			E	Top Breaker, Liebert Black	Same as	
w	Number of Blocs Wide	3	3 <sup>1</sup>	Three Blocs Wide	UUT2, UUT4	
vv	Number of Blocs Wide	3	6	Six Blocs Wide	UUT1, UUT3	
			3	Three Blocs High	Extrapolated	
Н	Number of Blocs High	4	4	Four Blocs High	Extrapolated	
			5	Five Blocs High	UUT1, UUT2, UUT3, UU	
			550	16HX550F	UUT1, UUT3	
С	Type of Cell	5 - 7	800	16HX800F	UUT4	
			925	16HX925F	UUT2, UUT4	
			144	144 Volts	UUT4	
		COK	192	192 Volts	Interpolated	
D	Contain Valtage	8 - 10	240	240 Volts	UUT2	
Ь	System Voltage	9-10	288	288 Volts	UUT3	
			384	384 Volts	Interpolated	
	//		480	480 Volts	UUT1	
В	Breaker	11	В	Breaker	UUT1, UUT2, UUT3, UI	
F	Options	12		Locked	UUT1, UUT2, UUT3, UI	
	141	1 OCI	250	280 Amps	UUT3, UUT4	
			300	300 Amps	Interpolated	
G	Breaker Size (in Amps)	13 - 15	400	400 Amps	Interpolated	
G	Breaker Size (III Amps)	13-15	600	600 Amps	Interpolated	
		RV. Time	othy 800 Pilano	800 Amps	Interpolated	
		יוייוי , וט	A00	1000 Amps	UUT1, UUT2	
			A	24 VDC Shunt Trip/Aux. Contact	UUT2	
	Š		В	48 VDC Shunt Trip/Aux. Contact	UUT1	
			0/08:2025	24 UVR/Aux. Contact	UUT3	
		DAIL.	D	48 UVR/Aux. Contact	UUT4	
U	Breaker Options	16	H	120 VDC Shunt Trip/Aux. Contact	Extrapolated <sup>2</sup>	
			E	250 VDC Shunt Trip/Aux. Contact	Extrapolated <sup>2</sup>	
			G	250 UVR/Aux. Contact	Extrapolated <sup>2</sup>	
		0	K SHAMA	120 UVR/Aux. Contact	Extrapolated <sup>2</sup>	
		TO.		Aux. Contact (only)	UUT1, UUT2, UUT3, UL	

Note:

10/08/2025 OSP-0054 Page 5 of 19

<sup>1.</sup> Only available for 800/925 with a system voltage up to 240.

<sup>2.</sup> Extrapolated breaker options are bookended by options tested in UUT5 and UUT6.

### Table 3 - Certified Components - 12V Battery Cabinets



DCL Project Number: 49106-2501

Manufacturer: Electronic Systems Support

Product Line: Battery Cabinets

Certified Construction: Powder-coated carbon steel frame

NEMA Rating: 1

Certified Options: Enclosures, batteries and breakers Certified Mounting Description: Rigid base mounted Certified Seismic Levels: Sds = 1.5g at z/h = 1.0 and z/h = 0

Factors for Force Amplification and Structure Ductility Reduction:  $H_f = 3.5$  at z/h = 1.0; 1.0 at z/h = 0 and  $R_{\mu} = 1.3$  at z/h = 1.0; 1.0 at z/h = 0 and z/h = 0 an

Model Number	Battery Quantity	Battery Manufacturer	Breaker	Amps	M	ax. Dimensions (i	n)	Max. Weight	Unit
Wodel Number	Battery Quantity	Battery Manufacturer	breaker	Amps	Width	Depth	Height	(lb)	Onit
ETC40xx04xxxxxxxx	4			100-600	40.0	29.5	76.8 - 78.7	820	Extrapolated
ETC40xx05xxxxxxxx	5			100-600	40.0	29.5	70.8 - 78.7	820	Extrapolated
ETC40AE06xxxxxB16F	6			100	40.0	29.5	78.7	820	UUT6
ETC40xx04xxxxxxxx	4								Interpolated
ETC40xx05xxxxxxxx	5								Interpolated
ETC40xx06xxxxxxxx	6								Interpolated
ETC40xx08xxxxxxxx	8								Interpolated
ETC40xx10xxxxxxxx	10		20						Interpolated
ETC40xx12xxxxxxxx	12	5 000 5 10	JK C	UDE					Interpolated
ETC40xx15xxxxxxxx	15	Enersys, C&D, East Penn, CSB, GNB, Fiamm	Square D	Wii Wii Weiner	$-O_A$ .				Interpolated
ETC40xx18xxxxxxxx	18	CSD, GIVD, Flamini		100-600	40.0	29.5	76.8 - 78.7	820 - 4,710	Interpolated
ETC40xx20xxxxxxxx	20				11111				Interpolated
ETC40xx24xxxxxxxx	24				1111111				Interpolated
ETC40xx27xxxxxxxx	27				1111111	7			Interpolated
ETC40xx29xxxxxxxx	29	\ \ \ \ \ \ \ \ \ \ \ \ \ \ \ \ \ \ \	Stall Shin	estilus Hillistoles	101111111	17/			Interpolated
ETC40xx30xxxxxxxx	30		CD	0054		20			Interpolated
ETC40xx32xxxxxxxx	32		JOP-	0034					Interpolated
ETC40xx40xxxxxxxx	40			77/44	HHILLHILL				Interpolated
ETC40AE40xxxxxH04E	40			600	40.0	29.5	78.7	4,710	UUT5

Notes:

Notes:

1. Multiple batteries were used in the UUTs to cover all the battery types offered in the full product line. A distinct model number cannot be associated with the actual tested units since they utilize multiple battery types.

DATF: 10/08/2025

Nomenclature Notes:

Options (designated as "x" in certified model numbers):

Digit 6: Cabinet color (A, B, C, D, E, F, G, H, I)

Digit 7: Cabinet height, 76.8" to 78.7" (C, D, E, F, G, H, J)

Digit 10-14: Battery model per manufacturer; reference certified batteries subcomponent table

Digit 15: B or H, for breaker or breaker with handle; reference certified breakers subcomponent table

Digit 16-17: 02 to 16 for 100 to 600 Amp breaker; reference certified breakers subcomponent table

Digit 18: Breaker option (A, B, C, D, E, F, G, H, J, K); reference breaker option subcomponent table for explanation of designation in certified component nomenclature

10/08/2025 OSP-0054 Page 6 of 19

# Table 4 - Nomenclature Chart - 12V Battery Cabinet Nomenclature Chart



DCL Project Number: 45798-1901

Manufacturer: Electronic Systems Support

			Sample Part Number: ABCDEFG	HJKL	
Character	Category	Digit	Allowable Value	Description	Unit
Α	System	1	E	ESS	UUT5, UUT6
В	Type of Battery	2	T	Top Terminal	UUT5, UUT6
С	Type of Cabinet	3	С	Cabinet	UUT5, UUT6
D	Cabinet Model	4 and 5	40	Width	UUT5, UUT6
			А	Black	UUT5, UUT6
			В	Beige	Same as tested
			С	Liebert Gray	Same as tested
			D	Mitsubishi Beige	Same as tested
E	Cabinet Color	6	E	MGE White	Same as tested
			F	Toshiba Black	Same as tested
			G	GE White	Same as tested
			Н	Liebert Black	Same as tested
				Eaton Black	Same as tested
				80	Extrapolated <sup>1</sup>
			( CODE O	79	Extrapolated <sup>1</sup>
		ko.	angidudidudid Educara	78.7	UUT5, UUT6
F	Height (inches)	7	F	78.4	Same as tested
			G	78	Same as tested
			Y CONTACTOR	77.3	Extrapolated <sup>1</sup>
			A CHILDREN HE	76.8	Extrapolated <sup>1</sup>
		7		4 Batteries	Interpolated <sup>2</sup>
			0051	5 Batteries	Interpolated <sup>2</sup>
			<del>10004</del>	6 Batteries	UUT6
			8	8 Batteries	Interpolated
			10	10 Batteries	Interpolated
		RV. Tir	nothy12 Pila	12 Batteries	Interpolated
			15	15 Batteries	Interpolated
G	Battery Quantity	8 and 9	18	18 Batteries	Interpolated
			20	20 Batteries	Interpolated
		DATE	10/(247/202	24 Batteries	Interpolated
		DVIL	27	27 Batteries	Interpolated
			29	29 Batteries	Interpolated
			30	30 Batteries	Interpolated
			32	32 Batteries	Interpolated
			40	40 Batteries	UUT5

1. 84 inch heigh cabinet were tested in UUT1, UUT2, UUT3 and UUT4.

Note:

2. Cabinets with four and five batteries can weigh more than, same as or less then the tested six battery configuration.

10/08/2025 OSP-0054 Page 7 of 19

# Table 5 - Nomenclature Chart - 12V Battery Cabinet Nomenclature Chart (continued)



DCL Project Number: 45798-1901

Manufacturer: Electronic Systems Support

Product Line: Battery Cabinets Sample Part Number: ABCDEFGHJKL Character Category Digit Manufacturer Allowable Value **Model Number** Unit HX205 12HX205 UUT6 HX300 12HX300 Interpolated HX330 12HX330 Interpolated XE760 12XE760 Interpolated HX400 12HX400 Interpolated EnerSvs HX800 6HX800 Interpolated XE040 12XE1040 Interpolated HX560 12HX560 Interpolated XH505 12HX505 Interpolated XH540 12HX540 UUT5 210MR UPS12-210MR UUT6 UPS12-300MR 300MR Interpolated 305PL UPS12-305PLP Interpolated 305PM UPS12-305PLM Interpolated 350MR UPS12-350MR Interpolated 355PL UPS12-355PLP Interpolated UPS12-355PLM 355PM Interpolated 620MR UPS6-620MR Interpolated 400MR UPS12-400MR Interpolated UPS12-405PLP 405PL Interpolated 405PM UPS12-405PLM Interpolated 490ML UPS12-490MRLP Interpolated 490MR UPS12-490MR Interpolated UPS12-495PLP Interpolated 545PI UPS12-545PLP Interpolated UPS12-495PLM 495PM Interpolated 545PM UPS12-545PLM Interpolated Battery Model Per 10 - 14 Н Manufacturer 540MF UPS12-540MR UUT5 HR200 45HR2000 UUT6 HR300 24HR3000 Interpolated HR350 27HR3500 Interpolated HR400 31HR4000 Interpolated HRC95 HRC950 Interpolated HR500 31HR5000 Interpolated HR550 31HR5500 XPL22 XPL2200 Extrapolated HL200 HRL12200W UUT6 XPL27 XPL2700 Interpolated XL250 XHRL12250W Interpolated Interpolated XPL35 XPL3500 HL280 HRL12280W Interpolated XL36W XHRL12360WG Interpolated XPL42 Interpolated XPL4200 XL360 XHRL12360W Interpolated CSB HL33W HRL12330WG Interpolated HL330 HRL12330W Interpolated XPL47 XPL4700 Interpolated Interpolated XHRL12410WG XL41G XL410 XHRL12410W Interpolated HL390 HRL12390W Interpolated XPL57 XPL5700 Interpolated XL475 XHRL12475W Interpolated Interpolated XHRL12500W HRL12540W UUT5 HL540

Continued on next page

# Table 6 - Nomenclature Chart - 12V Battery Cabinet Nomenclature Chart (continued)



DCL Project Number: 45798-1901

Manufacturer: Electronic Systems Support

				Sample Part Number: ABCDEFO	GHJKL	
haracter	Category	Digit	Manufacturer	Allowable Value	Model Number	Unit
				SV120	S12V120	Extrapolated
				SV170	S12V170	Extrapolated
				SV285	S12V285	UUT6
			GNB	SV300	S12V300	Interpolated
				SV370	S12V370	Interpolated
				SV500	S12V500	Interpolated
	Battery Model Per	10.11		SV550	S12V550	UUT5
Н	Manufacturer	10 - 14		FL200	12FLX200	UUT6
				FL250	12FLX250	Interpolated
				FL300	12FLX300	Interpolated
			Fiamm	FL350	12FLX350	Interpolated
				FL400	12FLX400	Interpolated
				FL500	12FLX500	Interpolated
				FL540	12FLX540	UUT5
aracter	Category		igit	Allowable Value	Description	Unit
				личнични В предуст	Breaker	UUT6
J	Breaker		15	н	Breaker With Handle Option	UUT5
				04	600 Amps	UUT5
				05	500 Amps	Interpolated
				06	450 Amps	Interpolated
		17		07	400 Amps	Interpolated
				0.08 5 4	350 Amps	Interpolated
				<del>00 04 09 04 0</del>	300 Amps	Interpolated
K	Amps	16	- 17	10	250 Amps	Interpolated
				11	225 Amps	Interpolated
			DV. Ti	mothy 12   Dila	200 Amps	Interpolated
			DY, III	13	175 Amps	Interpolated
				14	150 Amps	Interpolated
				15	125 Amps	Interpolated
			DATE	10/06/202	100 Amps	UUT6
			DATE	A	24 VDC Shunt Trip/Aux. Contact	Extrapolated <sup>1</sup>
				В	48 VDC Shunt Trip/Aux. Contact	Extrapolated <sup>1</sup>
		171		c	24 UVR/Aux. Contact	Extrapolated <sup>1</sup>
					48 UVR/Aux. Contact	Extrapolated <sup>1</sup>
			).		120 VDC Shunt Trip/Aux. Contact	UUT5
L	Breaker Option		18 VIA B		250 VDC Shunt Trip/Aux. Contact	UUT6
			1/17	G	120 UVR/Aux. Contact	Extrapolated <sup>2</sup>
			MAR		250 UVR/Aux. Contact	Extrapolated <sup>2</sup>
			6	PATRITICE IT	Aux. Contact (Only)	UUT5, UUT6
	1			9111911	24 VDC UVR with Bell Alarm/Aux. Contact	Extrapolated <sup>2</sup>

#### Notes

<sup>1.</sup> Extrapolated breaker options are bookended by options tested in UUT1, UUT2, UUT3 and UUT4.

<sup>2.</sup> Under voltage release (UVR) option features a coil that requires power to allow a breaker to turn on. The shunt option features the same coil, that when energized pushes a lever to trip a breaker and turn it off.

# Table 7 - Certified Subcomponents for 12V and 16V Battery Cabinets



DCL Project Number: 49106-2501

**Product Line:** Battery Cabinets

Certified Seismic Level: Sds = 1.5g at z/h = 1.0 and z/h = 0

			Enclosu	ires					
Cabinet Type	Manufacturer	Construction	Material -		Dimensions (in	)	NEMA Rating	Weight (lb)	Unit
Cabillet Type	Wallaracturer	Construction		Width	Depth	Height	NEIWA Rating	weight (ib)	
			Powder-Coated Carbon Steel	25.0	31.5	72.0	1	360	Extrapolated <sup>1</sup>
				25.0	31.5	84.0	1	422	UUT2, UUT4
16V Battery	ESS Welded	Wolded		32.0	31.5	72.0	1	490	Interpolated
Cabinets	233	weided		32.0	31.5	84.0	1	550	UUT1, UUT3
			Fowder-Coated Carbon Steel	50.0	31.5	72.0	1	640	Extrapolated <sup>2</sup>
				50.0	31.5	84.0	1	750	Extrapolated <sup>3</sup>
12V Battery	ESS	Welded		40.0	29.5	76.8 - 78.4	1	538 - 543	Extrapolated <sup>4</sup>
Cabinets	L33	vvelueu		40.0	29.5	78.7	1	545	UUT5, UUT6

			Ba	atteries: 16V Ba	ttery Cabinets					
Model Number	Designation in Certified Component Nomenclature	Manufacturer	Case Material	Type	Voltage	Аррг	rox. Dimension	s (in)	Approx. Weight	Unit
Woder Hamber	(Digits 5-7)	- Walland Co	case Material	Турс	Voltage	Width	Depth	Height	(lb)	O.I.I.
16HX550F-FR	550		Third, Mr. He al			4.6	27.2	12.3	151	UUT1, UUT3
16HX800F-FR	800	Enersys	Thick-Walled Plastic	Lead-Acid	16	7.0	27.2	12.3	232	UUT4
16HX925F-FR	925		Tigstic	musium in the inter-		7.0	27.2	12.3	248	UUT2, UUT4

#### Notes:

- 1. Extrapolated cabinet is based on the testing of UUT2 and UUT4. These cabinets are the same footprint as UUT2 and UUT4, but 12 inches shorter and house one horizontal tier less (up to four horizontal tiers instead of five).
- 2. Extrapolated cabinet is two structurally-independent 25"-wide cabinets, installed side-by-side. Cabinets were tested in UUT2 and UUT4. These cabinets are the same footprint as the tested units, but 12 inches shorter and house one horizontal tier less (up to four horizontal tiers instead of five).
- 3. Extrapolated cabinet is two structurally-independent 25"-wide cabinets, installed side-by-side. Cabinets were tested in UUT2 and UUT4.
- 4. Extrapolated cabinet is based on the UUT5 and UUT6 testing. No additional batteries are added and the batteries stay in the same location.

BY: Timothy J. Piland

DATE: 10/08/2025

10/08/2025 OSP-0054 Page 10 of 19

# Table 8 - Certified Subcomponents for 12V and 16V Battery Cabinets (continued)



DCL Project Number: 49106-2501
Product Line: Battery Cabinets

			Dut	teries: 12V Bat	tery casinets					
Model Number	Designation in Certified Component Nomenclature	Manufacturer	Case Material	Tuno	Voltage	Арр	rox. Dimension	s (in)	Approx. Weight	Unit
woder Number	(Digits 10-14)	Manufacturer	Case Material	Туре	voitage	Width	Depth	Height	(lb)	Onit
12HX205	HX205					5.5	8.9	8.1	43	UUT6
12HX300	HX300					6.9	10.2	8.2	60	Interpolate
12HX330	HX330					6.8	11.8	8.4	71	Interpolate
12XE760	XE760					6.8	13.0	8.6	77	Interpolate
12HX400	HX400	_				6.8	13.3	8.3	80	Interpolate
6HX800	HX800	Enersys	Thick-Walled Plastic	Lead-Acid	12	6.8	13.4	8.3	80	Interpolate
12XE1040	XE040					6.8	13.3	10.8	97	Interpolate
12HX560	HX560					6.8	13.3	10.7	99	Interpolate
12HX505	XH505					6.8	13.3	10.7	103	Interpolate
12HX540	XH540					6.8	13.3	10.7	106	UUT5
UPS12-210MR	210MR					5.5	9.0	8.1	40	UUT6
UPS12-300MR	300MR					6.8	10.3	8.0	58	Interpolate
UPS12-305PLP	305PL		OR (			6.8	10.3	7.9	58	Interpolate
			COL		- (0	6.8		7.9	+	
JPS12-305PLM UPS12-350MR	305PM 350MR		og Hill Hilling		QHI D	6.8	10.3 12.0	7.9 8.1	58 67	Interpolate
UPS12-350IVIK					HILLAND	-/-			+	Interpolate
	355PL	/ N			1197/17	6.8	12.0	7.9	67	Interpolate
UPS12-355PLM	355PM			A V	# ##	6.8	12.0	7.9	67	Interpolate
UPS6-620MR	620MR				4 17-17	7.0	12.6	8.9	72	Interpolate
UPS12-400MR	400MR	C&D	Polypropylene	Lead-Acid	12	6.8	13.4	8.5	76	Interpolate
UPS12-405PLP	405PL	Li 🔯	OSP	_005	1	6.8	13.4	8.4	76	Interpolate
UPS12-405PLM	405PM	<i>&gt;                                    </i>	001	-000	T	6.8	13.4	8.4	76	Interpolate
JPS12-490MRLP	490ML				HHTT447	6.8	13.4	8.5	83	Interpolate
UPS12-490MR	490MR			7.7.4Hm	HITILILIHT I LE	6.8	13.6	10.9	100	Interpolate
UPS12-495PLP	495PL	R	V. Timo	hv.I	Pilano	6.8	13.6	10.8	100	Interpolate
UPS12-545PLP	545PL		1. 11110	illy 0.	Harre	6.8	13.6	10.8	100	Interpolate
UPS12-495PLM	495PM				HHHUUUH+++7ZZ+	6.8	13.6	10.8	100	Interpolate
UPS12-545PLM	545PM				HHMIIIIILLEFT / /	6.8	13.6	10.8	100	Interpolate
UPS12-540MR	540MR		<b>ATE: 1</b>	<b>1/08/</b>	2025	6.8	13.6	10.9	100	UUT5
45HR2000	HR200		AIL. '	010011	-020	5.5	9.0	8.3	40	UUT6
24HR3000	HR300				HIIIIIIIIIIIIIIIIIIIIIIIIIIIIIIIIIIIII	6.6	10.2	8.2	56	Interpolate
27HR3500	HR350			7 1	3444476	6.6	12.0	8.2	66	Interpolate
31HR4000	HR400	East Penn	Polypropylene	Lead-Acid	12	6.7	12.9	8.7	74	Interpolate
HRC950	HRC95					6.8	13.5	11.0	93	Interpolate
31HR5000	HR500	90.				6.8	13.5	11.2	98	Interpolate
31HR5500	HR550		/>			6.8	13.5	11.2	98	UUT5
XPL2200	XPL22		(A)		. (	5.5	9.0	8.1	36	Extrapolate
HRL12200W	HL200		31 BI 11	IDI	10	5.5	9.0	8.2	38	UUT6
XPL2700	XPL27		201	LDI		5.5	9.0	8.1	40	Interpolate
XHRL12250W	XL250					5.5	9.0	8.1	41	Interpolate
XPL3500	XPL35					6.6	10.3	8.4	57	Interpolate
HRL12280W	HL280					6.6	10.3	8.4	57	Interpolate
	= =									Interpolate
XHRL12360WG	XL36W					6.6	10.9	8.4	62	
XPL4200	XPL42					6.6	10.3	8.4	62	Interpolat
XHRL12360W	XL360	CCB	Rolumbonulana Fel	Load Asid	12	6.6	10.3	8.4	62	Interpolat
HRL12330WG	HL33W	CSB	Polyphenylene Ether	Lead-Acid	12	6.6	12.8	8.4	65	Interpolate
HRL12330W	HL330					6.7	12.2	8.4	65	Interpolate
XPL4700	XPL47					6.6	12.2	8.4	71	Interpolate
XHRL12410WG	XL41G					6.7	12.8	8.4	72	Interpolate
XHRL12410W	XL410					6.7	12.2	8.4	72	Interpolate
HRL12390W	HL390					6.7	13.5	8.6	73	Interpolate
XPL5700	XPL57					6.6	13.5	8.5	80	Interpolate
XHRL12475W	XL475					6.7	13.5	8.5	80	Interpolate
XHRL12500W	XL500					6.7	13.5	8.5	81	Interpolate
HRL12540W	HL540				1	6.7	13.5	10.8	97	UUT5

# Table 9 - Certified Subcomponents for 12V and 16V Battery Cabinets (continued)



Product Line: Battery Cabinets

Certified Seismic I	Level: Sds = 1.5g	at $z/h = 1.0$ and $z_i$	/h = 0										
				Batte	eries: 12V Batte	ry Cabinets	continued)						
		n in Certified			_		Appro	ox. Dimensio	ns (in)				
Model Number		Nomenclature s 10-14)	Manufacturer	Case Material	Туре	Voltage	Width	Depth	Height	Approx. Weight (lb)	Unit		
S12V120	SV	120					6.5	6.8	5.9	27	Extrapolated		
S12V170	SV	170					6.6	7.8	7.0	36	Extrapolated		
S12V285	SV	285		Reinforced			6.9	10.3	8.8	61	UUT6		
S12V300	SV	300	GNB	polypropylene container and	Lead-Acid	12	6.9	10.3	8.8	63	Interpolated		
S12V370	SV	370		cover			6.9	12.1	8.8	74	Interpolated		
S12V500	SV	500					6.8	13.6	10.9	106	Interpolated		
S12V550	SV	550					6.8	13.6	10.9	106	UUT5		
12FLX200	FL	200					5.4	9.0	8.4	41	UUT6		
12FLX250	FL	250					6.5	10.7	7.7	52	Interpolated		
12FLX300	FL	300					6.9	10.3	8.6	60	Interpolated		
12FLX350	FL	350	Fiamm	Thick-wall ABS case	Lead-Acid	12	6.9	11.9	8.6	68	Interpolated		
12FLX400	FL	400		case			6.9	13.3	8.5	76	Interpolated		
12FLX500	FL	500		OD	COI	)E ~	6.9	13.3	10.9	102	Interpolated		
12FLX540	FL	540		C()D		7 (	6.9	13.3	10.9	106	UUT5		
	<u>'</u>		•		Bre	eakers							
0.0 - 1 - 1 0 1 -		B. G. at a wind	App	rox. Dimensions	(in)	Weight	Number of	Ampere	Contract MDC	Hamilla Outlan	11-14		
Model No.	Manufacturer	iviateriai	Width	Depth	Height	(lb.)	Poles	Rating	System VDC	Handle Option	Unit		
PowerPact J			4.1	3.4	7.5	5.3	2, 3	100-250		Handle Extension	UUT6		
PowerPact J		Material  Thermal- magnetic, molded case								No Handle Extension	UUT3, UUT4		
LH-DC			Thermal-		6.0	3.9	11.0	16	2, 3	300-400		Handle Extension	Interpolated
LH-DC								,			No Handle Extension	Interpolated	
LG3-DC	Square D		5.5	4.5	13.5	17	3	300-600	500	Handle Extension	Interpolated		
LG3-DC		molded case								No Handle Extension	Interpolated		
LG4-DC			7.3	4.5	13.5	26	4	700-1000		Handle Extension	Interpolated		
LG4-DC										No Handle Extension	Interpolated		
MH-DC			9.0	4.5	14.0	38	3	450-1000		No Handle Extension	Extrapolated <sup>1</sup>		
MH-DC										Handle Extension	UUT1, UUT2, UUT5		
						r Options							
	Opti	ons		Digit 16, 16V B Nomen			2V Battery omenclature	Manuf	facturer	Material	Unit		
24	4 VDC Shunt Trip ,	Auxiliary Contac	t				A	7,0			UUT2		
48	3 VDC Shunt Trip	Auxiliary Contac	t				В				UUT1		
24 Un	ider Voltage Relea	ase / Auxiliary Cor	ntact		アルじ		C	1 /			UUT3		
48 Un	ider Voltage Relea	ase / Auxiliary Cor	ntact				D	\\\\\			UUT4		
12	0 VDC Shunt Trip	/ Auxiliary Contac	ct		· Market		E				UUT5		
25	0 VDC Shunt Trip	/ Auxiliary Contac	ct	//			F ( )	San	are D	Thermal-magnetic,	UUT6		
120 VDC	Under Voltage R	elease / Auxiliary	Contact	7 RI	(III D	1//	G	]		molded case	Extrapolated <sup>2</sup>		
250 VDC	Under Voltage R	elease/ Auxiliary	Contact		JILU	114	Н				Extrapolated <sup>2</sup>		
24 VDC Under	Voltage Release /	Bell Alarm / Aux	iliary Contact	N,	/A		J				Extrapolated <sup>2</sup>		
	Auxiliary Co	ntact (Only)		ı	F		K				UUT1, UUT2, UUT3,		
Note:				<u> </u>				<u> </u>			UUT4, UUT5, UUT6		

#### Note:

10/08/2025 OSP-0054 Page 12 of 19

<sup>1.</sup> Breaker is a depopulated version of what was tested in UUT5.

<sup>2.</sup> Under voltage release option features a coil that requires power to allow a breaker to turn on. The shunt option features the same coil, that when energized pushes a lever to trip a breaker and turn it off. Extrapolated units are similar in construction to options tested in UUT5 and UUT6.

# Table 10 - Tested Components



DCL Project Number: 49106-2501

Manufacturer: Electronic Systems Support

Product Line: Battery Cabinets

Certified Options: Enclosures, batteries and breakers
Certified Mounting Description: Rigid base mounted
Certified Seismic Levels: Sds = 1.5g at z/h = 1.0 and z/h = 0

Factors for Force Amplification and Structure Ductility Reduction:  $H_1 = 3.5$  at z/h = 1.0; 1.0 at z/h = 0 and  $R_{ii} = 1.3$  at z/h = 1.0; 1.0 at z/h = 0

Model Number <sup>1</sup>	Construction Material	NEMA Rating		Dimensions (in)		Weight (lb)	Unit	
Model Number	Construction Waterial	NEIVIA Kating	Width	Depth	Height	weight (ib)	Ollic	
ST65550480BLA00B	Powder-Coated Carbon Steel	1	32.0	31.5	84.0	5,185	UUT1	
ST35925240BLA00A	Powder-Coated Carbon Steel	1	25.0	31.5	84.0	4,092	UUT2	
ST65550288BL250C	Powder-Coated Carbon Steel	1	32.0	31.5	84.0	3,300	UUT3	
ST35xxx144BL250D	Powder-Coated Carbon Steel	1	25.0	31.5	84.0	2,600	UUT4	
ETC40AE40xxxxxH04E	Powder-Coated Carbon Steel		40.0	29.5	78.7	4,710	UUT5	
ETC40AE06xxxxxB16F	Powder-Coated Carbon Steel		40.0	29.5	78.7	820	UUT6	

Note

1. UUT4 shows "xxxx" because the tested unit included 2 different types of batteries. UUT5 and UUT6 show "xxxxx" because each unit contained multiple types of batteries.

OSP-0054

BY: Timothy J. Piland

DATE: 10/08/2025



### UUT1

Repot Number: MakeltRight 90220-0901 Test Report

Manufacturer: ESS

**Product Line:** Battery Cabinets Model Number: ST65550480BLA00B

Product Construction Summary: Powder-Coated Carbon Steel, NEMA 1.

#### **Options / Component Summary:**

Rigid base mounted. Enersys 16HX550F-FR lead acid batteries, Square D 450-1000 Amp breaker with handle extension and 48 VDC shunt trip / auxiliary contact.

Note: The UUT was operational before and after shaking and was full of operating content during the tests. The structural integrity of the component attachment system and force-resisting systems was maintained after the AC 156 test.

				UUT P	roperties								
Operating Weight (lb)		Dimensions (inches)			Lowest Natural Frequency (Hz)								
Operating	weight (ib)	Depth	Width	Height	Front	:-Back	Side	Side-Side Vertical					
5,2	5,185		31.5	84.0	4.8		5.8		>33.3				
	Seismic Test Parameters												
<b>Building Code</b>	Test Criteria	Sds (g)	z/h	H <sub>f</sub>	Rμ	lp	Aflx-H (g)	Arig-H (g)	Aflx-V (g)	Arig-V (g)			
CBC 2025	ICC-ES AC156	1.5	1.0	3.5	1.3	1.5	2.40	1.80	N/A	N/A			
CBC 2023		1.5	0.0	1.0	1.0		N/A	N/A	1.00	0.40			
Unit Mounting [	Description:	<b>Y</b>	05	DP-00	54								

#### **Unit Mounting Description:**

The unit was rigid base-mounted to the shake table interface plate using (6) 1/2-inch diameter Grade 5 bolts and flat washers. The bolts were spaced 11 inches on center length-wise and 29 inches on center width-wise.



Overall view of UUT1



### UUT2

Repot Number: MakeltRight 90220-0901 Test Report

Manufacturer: ESS

**Product Line:** Battery Cabinets Model Number: ST35925240BLA00A

Product Construction Summary: Powder-Coated Carbon Steel, NEMA 1.

#### **Options / Component Summary:**

Rigid base mounted. Enersys 16HX925F-FR lead acid batteries, Square D 450-1000 Amp breaker with handle extension and 24 VDC shunt trip / auxiliary contact.

Note: The UUT was operational before and after shaking and was full of operating content during the tests. The structural integrity of the component attachment system and force-resisting systems was maintained after the AC 156 test.

				UUT F	Properties								
Operating Weight (lb)		Dimensions (inches)			Lowest Natural Frequency (Hz)								
Operating	weight (ib)	Depth	Width	Height	Front	-Back	Side	Side-Side Vertical			Side-Side Vertica		tical
4,0	092	25.0	31.5	84.0	6.6		3.6		17.7				
			V	Seismic Te	st Parameter	5/0							
<b>Building Code</b>	Test Criteria	Sds (g)	z/h	H <sub>f</sub>	Rμ	lp	Aflx-H (g)	Arig-H (g)	Aflx-V (g)	Arig-V (g)			
CBC 2025	ICC-ES AC156	1.5	1.0	3.5	1.3	1.5	2.40	1.80	N/A	N/A			
CBC 2023		1.5	0.0	1.0	1.0	1.5	N/A	N/A	1.00	0.40			
Unit Mounting D	Description:	Y	U.S	5P-00	54	4		-					

#### **Unit Mounting Description:**

The unit was rigid base-mounted to the shake table interface plate using (6) 1/2-inch diameter Grade 5 bolts and flat washers. The bolts were spaced 11 inches on center length-wise and 23 inches on center width-wise.



Overall view of UUT2

### UUT3



Repot Number: DCL 42217-1401\_Test Report

Manufacturer: ESS

**Product Line:** Battery Cabinets Model Number: ST65550288BL250C

Product Construction Summary: Powder-Coated Carbon Steel, NEMA 1.

#### Options / Component Summary:

Rigid base mounted. Enersys 16HX550F-FR lead acid batteries, Square D 100-250 Amp breaker with no handle extension and 24V under voltage release / auxiliary contact.

Note: The UUT was operational before and after shaking and was full of operating content during the tests. The structural integrity of the component attachment system and force-resisting systems was maintained after the AC 156 test.

				UUT P	roperties							
Operating Weight (lb)		Dimensions (inches)			Lowest Natural Frequency (Hz)							
Operating	weight (ib)	Depth	Width	Height	Front	t-Back	Side-Side Vertical			tical		
3,3	300	32.0	31.5	84.0	10.8		13	3.8	>33.3			
				Seismic Tes	t Parameter	s Vo						
<b>Building Code</b>	Test Criteria	Sds (g)	z/h	H <sub>f</sub>	Rμ	lp	Aflx-H (g)	Arig-H (g)	Aflx-V (g)	Arig-V (g)		
CBC 2025	ICC-ES AC156	2.0	1.0	3.5	1.3	1.5	3.20	2.40	N/A	N/A		
CBC 2023		2.0	0.0	1.0	1.0		N/A	N/A	1.33	0.53		
Unit Mounting D	Description:	<b>Y</b>	0;	5P-00	54	7		<u> </u>				

### Unit Mounting Description:

The unit was rigid base-mounted to the shake table interface plate using (6) 1/2-inch diameter Grade 5 bolts and flat washers. The bolts were spaced 11 inches on center length-wise and 29 inches on center width-wise.



Overall view of UUT3

# UUT4



Repot Number: DCL 42217-1401\_Test Report

Manufacturer: ESS

**Product Line:** Battery Cabinets Model Number: ST35xxx144BL250D

Product Construction Summary: Powder-Coated Carbon Steel, NEMA 1.

#### **Options / Component Summary:**

Rigid base mounted. Enersys 16HX800F-FR and 16HX925F-FR lead acid batteries, Square D 100-250 Amp breaker with no handle extension and 48V under voltage release / auxiliary contact.

Note: The UUT was operational before and after shaking and was full of operating content during the tests. The structural integrity of the component attachment system and force-resisting systems was maintained after the AC 156 test.

				UUT P	roperties						
Operating Weight (lb)		Dimensions (inches)			Lowest Natural Frequency (Hz)						
Operating	weight (ib)	Depth	Width	Height	Front	t-Back	Side-Side Ver		Side-Side Vertical		
2,6	2,600		31.5	84.0	10.8		8.0		19.0		
			V 3	Seismic Te	st Parameter	s Vo					
<b>Building Code</b>	Test Criteria	Sds (g)	z/h	H <sub>f</sub>	Rμ	lp	Aflx-H (g)	Arig-H (g)	Aflx-V (g)	Arig-V (g)	
CBC 2025	ICC-ES AC156	2.0	1.0	3.5	1.3	1.5	3.20	2.40	N/A	N/A	
CBC 2023		2.0	0.0	1.0	1.0		N/A	N/A	1.33	0.53	
Unit Mounting [	Description:	7	0;	5P-00	54	7					

### Unit Mounting Description:

The unit was rigid base-mounted to the shake table interface plate using (6) 1/2-inch diameter Grade 5 bolts and flat washers. The bolts were spaced 11 inches on center length-wise and 23 inches on center width-wise.



Overall view of UUT4

### **UUT5**



Repot Number: DCL 42217-1401\_Test Report

Manufacturer: ESS

**Product Line:** Battery Cabinets

Model Number: ETC40AE40xxxxxH04E

Product Construction Summary: Powder-Coated Carbon Steel, NEMA 1.

#### Options / Component Summary:

Rigid base mounted. Enersys 12HX540, C&D UPS12-540MR, East Penn 31HR5500, CSB HRL12540W, GNB S12V550 and Fiamm 12FLX540 lead acid batteries, Square D 450-1000 Amp breaker with handle extension and 120VDC shunt trip / auxiliary contact.

Note: The UUT was operational before and after shaking and was full of operating content during the tests. The structural integrity of the component attachment system and force-resisting systems was maintained after the AC 156 test.

				UUT P	roperties						
Operating Weight (lb)		Dimensions (inches)			Lowest Natural Frequency (Hz)						
Operating	weight (ib)	Depth	Width	Height	Front	:-Back	Side-Side Vertion		tical		
4,7	710	40.0	29.5	78.7	7.8		8.3		19.8		
			V 3	Seismic Tes	t Parameter	s //O					
<b>Building Code</b>	Test Criteria	Sds (g)	z/h	H <sub>f</sub>	Rμ	lp	Aflx-H (g)	Arig-H (g)	Aflx-V (g)	Arig-V (g)	
CBC 2025	ICC-ES AC156	2.0	1.0	3.5	1.3	1.5	3.20	2.40	N/A	N/A	
CDC 2023		2.0	0.0	1.0	1.0		N/A	N/A	1.33	0.53	

#### **Unit Mounting Description:**

The unit was rigid base-mounted to the shake table interface plate using (6) 5/8-inch diameter Grade 5 bolts and flat washers. The bolts were spaced 24 inches on center length-wise and 18 inches on center width-wise.



Overall view of UUT5

### **UUT6**



Repot Number: DCL 42217-1401\_Test Report

Manufacturer: ESS

**Product Line:** Battery Cabinets

Model Number: ETC40AE06xxxxxB16F

Product Construction Summary: Powder-Coated Carbon Steel, NEMA 1.

#### Options / Component Summary:

Rigid base mounted. Enersys 12HX205, C&D UPS12-210MR, East Penn 45HR2000, CSB HRL12200W, GNB S12V285 and Fiamm 12FLX200 lead acid batteries, Square D 100-250 Amp breaker with handle extension and 240VDC shunt trip / auxiliary contact.

Note: The UUT was operational before and after shaking and was full of operating content during the tests. The structural integrity of the component attachment system and force-resisting systems was maintained after the AC 156 test.

				UUT P	roperties						
Operating Weight (lb)		Dimensions (inches)			Lowest Natural Frequency (Hz)						
Operating	weight (ib)	Depth	Width	Height	Front	:-Back	Side	-Side	Ver	tical	
8:	820		29.5	78.7	13.8		18.8		30.5		
			V 3	Seismic Tes	st Parameter	s //O					
<b>Building Code</b>	Test Criteria	Sds (g)	z/h	H <sub>f</sub>	Rμ	lp	Aflx-H (g)	Arig-H (g)	Aflx-V (g)	Arig-V (g)	
CBC 2025	ICC-ES AC156	2.0	1.0	3.5	1.3	1.5	3.20	2.40	N/A	N/A	
CBC 2023		2.0	0.0	1.0	1.0	1.5	N/A	N/A	1.33	0.53	
Unit Mounting D	Description:	Y	U.	5P-00	54	7		<u> </u>			

#### Unit Mounting Description:

The unit was rigid base-mounted to the shake table interface plate using (6) 5/8-inch diameter Grade 5 bolts and flat washers. The bolts were spaced 24 inches on center length-wise and 18 inches on center width-wise.



Overall view of UUT6