

APPLICATION FOR OSHPD SPECIAL SEISMIC	OFFICE	USE ONLY
CERTIFICATION PREAPPROVAL (OSP)	APPLICATION #:	OSP – 0055 – 10
OSHPD Special Seismic Certification Preapproval (OSP)		
Type: 🗌 New 🛛 Renewal		
Manufacturer Information		
Manufacturer: Climatec		
Manufacturer's Technical Representative: Clark Freeman, PE		_
Mailing Address:18002 Cowan, Irvine, CA 92614		
Telephone: 949.214.8652 Email: clarkf@	Oclimatec.com	
Product Information		
Product Name: Alerton Custom Control panels		
Product Type: Control Panel		
Product Model Number: See Attachment		
(List all unique product identification numbers and/or part numbers) General Description: Configurable control panels for HVAC applicat	ions.	
· · · · · · · · · · · · · · · · · · ·		
Mounting Description: Rigidly mounted to wall.		
Applicant Information		
Applicant Company Name:TRU Compliance, LLC		
Contact Person: Matthew Tobolski, PhD, SE		
Mailing Address: _ 960 SW Disk Dr., Suite 104, Bend, OR 97702		
Telephone: 844.878.0200 Email: mtobo	lski@trucompliance.com	1
I hereby agree to reimburse the Office of Statewide Health I accordance with the California Administrative Code, 2016.	Planning and Develo	opment review fees in
Signature of Applicant:	Date	: 12/05/2016
Title: President and CEO Company Name: TRU C	Compliance, LLC	
"Access to Safe, Quality Healthcare Environments that Meet California's Diverse and Dynamic Needs"	AM AMAAAA	OSHPD

IMMA

1

# OFFICE OF STATEWIDE HEALTH PLANNING AND DEVELOPMENT FACILITIES DEVELOPMENT DIVISION

California Licensed Structural Engineer Responsible for the Engineering and Test Report(s)
Company Name: TRU Compliance, LLC
Name:       Matthew Tobolski, PhD, SE       California License Number:       S5648
Mailing Address: _960 SW Disk Dr., Suite 104, Bend, OR 97702
Telephone:       844.878.0200       Email: mtobolski@trucompliance.com
Supports and Attachments Preapproval
<ul> <li>Supports and attachments are preapproved under OPM- (Separate application for OSHPD Preapproval of Manufacturer's Certification (OPM) of Supports and attachments is required)</li> <li>Supports and attachments are not preapproved</li> </ul>
Certification Method
<ul> <li>Testing in accordance with: ICC-ES AC156</li> <li>Other (Please Specify):</li> </ul>
Testing Laboratory
Company Name: Clark Dynamic Testing Laboratory, Inc.
Contact Name: Robert Francis
Mailing Address: 1801 Route 51, Jefferson Hills, PA, 15025
Telephone: 412.387.1001 Email: rfrancis@clarktesting.com



OFFICE OF STATEWIDE HEALTH PLANNING AND DEVELOPMENT FACILITIES DEVELOPMENT DIVISION


Seismic Parameters
Design in accordance with ASCE 7-10 Chapter 13: 🖂 Yes 🔲 No
Design Basis of Equipment or Components (Fp/Wp) = <u>1.45</u>
$S_{DS}$ (Design spectral response acceleration at short period, g) = <u>1.93</u>
a <sub>p</sub> (In-structure equipment or component amplification factor) = <u>2.5</u>
$R_p$ (Equipment or component response modification factor) = <u>6.0</u>
$\Omega_0$ (System overstrength factor) = _2.0
$I_p$ (Importance factor) = 1.5
z/h (Height factor ratio) = 1.0
Equipment or Component Natural Frequencies (Hz) = <u>See attached</u>
Overall dimensions and weight (or range thereof) = See attached
Equipment or Components @ grade designed in accordance with ASCE 7-10 Chapter 15: 🔲 Yes 🛛 🛛 No
Design Basis of Equipment or Components (V/W) =
S <sub>DS</sub> (Design spectral response acceleration at short period, g) =
S <sub>D1</sub> (Design spectral response acceleration at 1 second period, g) =
R (Response modification coefficient ) =
$\Omega_0$ (System overstrength factor) =
C <sub>d</sub> (Deflection amplification factor) =
$I_p$ (Importance factor) = 1.5
Height to Center of Gravity above base =
Equipment or Component Natural Frequencies (Hz) =
Overall dimensions and weight (or range thereof) =
Tank(s) designed in accordance with ASME BPVC, 2015: 🛛 Yes 🖾 No
List of Attachments Supporting Special Seismic Certification
Test Report(s)     Drawings     Calculations     Manufacturer's Catalog     Other(s) (Please Specify): <u>Attachment</u>
OSHPD Approval (For Office Use Only) – Approval Expires on December 31, 2022
La com -
Signature: Date: _1/10/17
Print Name: M. R. Karim Title: SHFR
Special Seismic Certification Valid Up to : $S_{DS}(g) = 1.93$ $z/h = 1.0$
Condition of Approval (if applicable):
"Access to Safe, Quality Healthcare Environments that Meet California's Diverse and Dynamic Needs"

### **TRU PROJECT NO. 16027**



#### Manufacturer: Climatec **TABLE 1** Model Line: **Alerton Custom Control Panels Certified Product Construction Summary:** Carbon steel enclosure. **Certified Options Summary:** NEMA 1 or NEMA 4/12 rating. See Tables 2 - 8 for certified subcomponents. Mounting Configuration: Wall mounted - rigid Note: Installed mounting configuration must be of similar configuration and equivalent strength and stiffness to those tested. $I_{P} = 1.5$ Building Code: CBC 2016 Seismic Certification Limits: $S_{DS} = 1.93 g z/h=1.0$ **Model Line Dimensions (in)** Weight Model UUT Notes (Manufacturer) (lb) Depth Width Height 51 UUT: A24H20ALP-NEMA 4/12 2 6.0 20.0 24.0 interp. ... 3 6.6 24.0 24.0 51 UUT: A24N24ALP-NEMA 1 Alerton Custom **Custom Control Panel** interp. . . . **Control Panels** 9.0 36.0 42.0 170 UUT: A42N36o9-NEMA 1 1 (Climatec) interp. 8.0 36.0 48.0 180 *UUT: A48H36BLP-NEMA 4/12* 4 PSH500A UUT: NEMA 1 6 12.1 12.1 29 5


### **TRU PROJECT NO. 16027**



TRU Compliance, LLC - A Tobolski Watkins Affiliate 844.TRU.0200 | info@trucompliance.com

TRU

COMPLIANCE






### **TRU PROJECT NO. 16027**

Manufacturer:

**Component Type** 

Controller

Model Line:



**DIN-Z =** Mounted with zip-tie around rail and component **BP =** Attached directly to back plate

BACtalk VAV; BP

BACtalk VLX; BP

VAV-SD2A

VLX

3

4






Manufacturer: Model Line:	Climatec Alerton Custom Control	Panels		TABLE 3	
Building Code: CBC	2016	Seismic Certifica	ation Limits: \$ <sub>DS</sub> = 1.93 g z/h = 1.0	$I_{P} = 1.5$	
Component Type	Manufacturer	Model	Description	Notes	UUT
	1	VLX-PLATINUM	BACtalk VLX; BP	Similar to VLX	Interp.
		EXP-1048	BACtalk EXP; BP		4
	Alerton	EXP-10120	BACtalk EXP; BP	Similar to EXP-1048	Interp
		EXP-2200	BACtalk EXP; BP	Similar to EXP-1048	Interp
		FLG-MODBUS	BACtalk FLG; BP	Similar to EXP-1048	Interp
		J-200	JACE-200; BP		1
		J-200e	JACE-200e; BP	Similar to J-200	Interp
Controller		J-600	JACE-600; BP		1
		J-600e	JACE-600e; BP	Similar to J-600	Interp
Controller		J-700	JACE-700; BP	Similar to J-600	Interp
		J-700e	JACE-700e; BP	Similar to J-600	Interp
	Tridium	J-8000	JACE-8000; BP	Similar to J-600	Interp
		NPB-8000-2X-485	RS-485 Comm Card	Similar to J-600	Interp
		NPB-8000-232	RS-232 Comm Card	Similar to J-600	Interp
		I/O-16	Vykon JACE; BP		1
		I/O-34	Vykon JACE; BP		1
		NWR-PWR-UN	Vykon JACE; BP	Similar to JACE NWR-PW	R Interp
		JACE NWR-PWR	Vykon JACE; BP		1
			Attached directly to back plate		



Manufacturer: Model Line:	Climatec Alerton Custom Control F		TABLE 4		
Building Code: CBC			tion Limits: S <sub>DS</sub> = 1.93 g z/h = 1.0	1 <sub>P</sub> = 1.5	
Component Type	Manufacturer	Model	Description	Note	es UUT
		PS 247.5	Product line - PS; BP		1
		PS 2415	Product line - PS; BP		Interp.
	Veris	PS 2430	Product line - PS; BP		Interp.
		PS 2450	Product line - PS; BP		Interp
Power Supply		PS 2460	Product line - PS; BP		4
		PSH75AB10	Product line - PSH; BP	Similar to PSH100AB1	.0 Extrap
		PSH75A75AB10	Product line - PSH; BP	Similar to PSH100A10	0AB10 Extrap
	Functional Devices	PSH100AB10	Product line - PSH; BP		4
		PSH100A100AB10	Product line - PSH; BP		1
			Mounted directly to back plane		



<i>Manufacturer: Model Line:</i>	Climatec Alerton Custom Contro	l Panels	Table Description:       Control Transformers       TABLE 5         nels       TABLE 5					
Building Code: CBC 2	2016	Seismic Certifi	cation Limits: S <sub>DS</sub> = 1.93 g z/h = 1.0	<i>I<sub>P</sub></i> = 1.5				
Component Type	Manufacturer	Model	Description	Note	es UUT			
Control Transformer	Veris	X100CBB X050CBB	100VA X-Series; BP 50VA X-Series; BP		1 - 5 1 - 5			
		DD -	Attached directly to back plane					





### **TRU PROJECT NO. 16027**



	Climatec	TABLE 7					
<i>Model Line: Building Code: CBC 2</i>	Alerton Custom Contro 016		nels Seismic Certification Limits: S <sub>DS</sub> = 1.93 g z/h = 1.0 I <sub>P</sub> = 1.5				
Component Type	Manufacturer	Model	Description	n N	lotes UUT		
		EIR102-MC	EIR; BP	Similar to EIR208	Extrap.		
		EIR208	EIR; BP		1		
Ethernet Switches	B&B Electronics	EIR418	EIR; BP		4		
		SFP-100FX-M-2KM-T	EIR; BP		4		
		BP = A	ttached directly to back plane				

TRU Compliance, LLC - A Tobolski Watkins Affiliate 844.TRU.0200 | info@trucompliance.com



Manufacturer:	Climatec			TABLE 8				
Model Line:	Iel Line:     Alerton Custom Control Panels							
Building Code: CBC	2016	Seismic Certific	Seismic Certification Limits: S <sub>DS</sub> = 1.93 g z/h = 1.0 I <sub>P</sub> = 1.5					
Component Type	Manufacturer	Model	Description	Notes	UUT			
Panel Light	IDEC -	APW299D-R-24	Red panel light; Door mount		1 - 5			
Parlet Light	IDEC	APW299D-G-24	Green panel light; Door mount		1 - 4			
Curital		ASW2K10	2 Position Switch; Door mount		1 - 5			
Switch	IDEC -	ASW3K20	3 Position Switch; Door mount		1-5			
LCD Display	Kele	LPI-1C	LPI; Door mount		2			
LIDC	SOLA-HD	SDU 500	SDU; BP		1			
UPS	SOLA-HD	SDU-PMBRK	SDU; BP		1			

### **TRU PROJECT NO. 16027**

Manufacturer:ClimatecModel Line:Custom Control Panels

Model Number: BV-741412

Serial Number: N/A

#### Product Construction Summary:


NEMA 1, carbon steel enclosure.

#### Options/Subcomponent Summary:

Controllers, power supply, control transformer, relays, ethernet switches, panel light and uninterruptible power supply. See Tables 2 - 8 for a specific listing of subcomponents installed in the panel.

			UUT Pro	operties						
Weight	Dimension (in)				Lowest Natural Frequency (Hz)					
(lb)	Depth	Width	Height		Front-Back		Side-Side		Vertical	
170	9	36	4	42 N			/A N		N/A N/A	
		UUT Highest I	Passed Se	eismic Rul	n Informa	ation				
Building Code		Test Criteria S <sub>DS</sub> (g)		z/h	I <sub>P</sub>	A <sub>FLX-H</sub> (g)	A <sub>RIG-H</sub> (g)	A <sub>FLX-V</sub> (g)	A <sub>RIG-V</sub> (g)	
СВС	2016	ICC-ES AC156		1.93	1.0 1.5		3.09	2.32	1.29	0.51

#### Test Mounting Details:





Rigid wall mounted to wall fixture with (4) 5/16" cap screws. Unit maintained structural integrity and remained functional per manufacturer requirement after shake table test. Contents were included in testing per operating conditions.



**UUT 1** 



### **TRU PROJECT NO. 16027**

Manufacturer:ClimatecModel Line:Custom Control Panels

*Model Number:* BV-741410

Product Construction Summary:

NEMA 4/12, carbon steel enclosure.

#### *Options/Subcomponent Summary:*

Controller, power supply, control transformer, relays, panel light and LCD panel display. See Tables 2 - 8 for a specific listing of subcomponents installed in the panel.

			UUT Pro	operties						
Weight	Dimension (in)				Lowest Natural Frequency (Hz)					
(lb)	Depth	Width	Height		Front-Back		Side-Side		Vertical	
51	6	20	2	4	N/A		N/A		N/A	
		UUT Highest I	Passed Se	eismic Rul	n Informa	ation				
Buildi	ing Code	Test Criter	ia	S <sub>DS</sub> (g)	z/h	I <sub>P</sub>	A <sub>FLX-H</sub> (g)	A <sub>RIG-H</sub> (g)	A <sub>FLX-V</sub> (g)	A <sub>RIG-V</sub> (g)
CBO	C 2016	ICC-ES AC156		1.93	1.0 1.5		3.09	2.32	1.29	0.51

#### Test Mounting Details:





Rigid wall mounted to wall fixture with (4) 3/8" cap screws. Unit maintained structural integrity and remained functional per manufacturer requirement after shake table test. Contents were included in testing per operating conditions.



**UUT 2** 



### **TRU PROJECT NO. 16027**

Manufacturer:ClimatecModel Line:Custom Control Panels

Model Number: BV-741413

Product Construction Summary:

NEMA 1, carbon steel enclosure.

#### Options/Subcomponent Summary:

Controllers, control transformer, relays, ethernet switches and panel light. See Tables 2 - 8 for a specific listing of subcomponents installed in the panel.

			UUT Pro	operties						
Weight	Dimension (in)				Lowest Natural Frequency (Hz)					
(lb)	Depth	Width	Height		Front-Back		Side-Side		Vertical	
51	6.6	24	2	.4	N/A		N/A		N/A	
		UUT Highest F	Passed Se	eismic Rui	n Informa	ation				
Buildi	ilding Code Test Criteri		ia	S <sub>DS</sub> (g)	z/h	I <sub>P</sub>	A <sub>FLX-H</sub> (g)	A <sub>RIG-H</sub> (g)	A <sub>FLX-V</sub> (g)	A <sub>RIG-V</sub> (g)
CBC 2016 ICC-ES AC156		56	1.93	1.0	1.5	3.09	2.32	1.29	0.51	

#### Test Mounting Details:



	CHOC HORPYTAL BEIEMIC PANEL #3
	A7 - F8
	A8- 55
	A9-Y
22 (0)111	

Rigid wall mounted to wall fixture with (4) 5/16" cap screws.

Unit maintained structural integrity and remained functional per manufacturer requirement after shake table test. Contents were included in testing per operating conditions.



**UUT 3** 

Serial Number: N/A

### **TRU PROJECT NO. 16027**

Manufacturer:ClimatecModel Line:Custom Control Panels

Model Number: BV-741411

Product Construction Summary:

NEMA 4/12, carbon steel enclosure.

#### Options/Subcomponent Summary:

Controllers, power supplies, control transformer, relays, ethernet switches and panel light. See Tables 2 - 8 for a specific listing of subcomponents installed in the panel.

			UUT Pro	operties							
Weight	Dimension (in)				Lowest Natural Frequency (Hz)						
(lb)	Depth	Width	Height		Front-Back		Side-Side		Vertical		
180	8	36	۷	18	N/A		N/A		N/A		
		UUT Highest I	Passed Se	eismic Rul	n Informa	ation					
Building Code		Test Criteria		S <sub>DS</sub> (g)	z/h	I <sub>P</sub>	A <sub>FLX-H</sub> (g)	A <sub>RIG-H</sub> (g)	A <sub>FLX-V</sub> (g)	A <sub>RIG-V</sub> (g)	
CBC 2016		ICC-ES AC156		1.93	1.0	1.5	3.09	2.32	1.29	0.51	

#### Test Mounting Details:





Rigid wall mounted to wall fixture with (4) 5/16" cap screws. Unit maintained structural integrity and remained functional per manufacturer requirement. Contents were included in testing per operating conditions.



**UUT 4** 

#### Serial Number: N/A

### **TRU PROJECT NO. 16027**

Manufacturer:ClimatecModel Line:Custom Control Panels

Model Number: PSH500A

Seriali

#### Product Construction Summary:

NEMA 1, carbon steel enclosure.

#### Options/Subcomponent Summary:

Power supply and control transformer. See Tables 2 - 8 for a specific listing of subcomponents installed in the panel.

			UUT Pro	operties							
Weight	Dimension (in)				Lowest Natural Frequency (Hz)						
(lb)	Depth	Width	Height		Front-Back		Side-Side		Vertical		
29	6	12.1	12	2.1	N/A		N/A		N/A		
		UUT Highest I	Passed Se	eismic Rul	n Informa	ation					
Building Code		Test Criteria		S <sub>DS</sub> (g)	z/h	I <sub>P</sub>	A <sub>FLX-H</sub> (g)	A <sub>RIG-H</sub> (g)	A <sub>FLX-V</sub> (g)	A <sub>RIG-V</sub> (g)	
CBC 2016		ICC-ES AC156		1.93	1.0	1.5	3.09	2.32	1.29	0.51	

#### Test Mounting Details:





Rigid wall mounted to wall fixture with (4) 5/16" cap screws. Unit maintained structural integrity and remained functional per manufacturer requirement after shake table test. Contents were included in testing per operating conditions.



**UUT 5** 

