

DEPARTMENT OF HEALTH CARE ACCESS AND INFORMATION FACILITIES DEVELOPMENT DIVISION

OFFICE USE ONLY APPLICATION FOR HCAI SPECIAL SEISMIC **CERTIFICATION PREAPPROVAL (OSP)** APPLICATION #: OSP-0056 **HCAI Special Seismic Certification Preapproval (OSP)** Renewal Type: New **Manufacturer Information** Manufacturer: MGM Transformers Manufacturer's Technical Representative: Mike Iman Mailing Address: 5701 Smithway Street, City of Commerce, CA 90040 Telephone: (323) 726-0888 Email: miman@mgmtransfomer.com **Product Information Product Name: Transformers** Product Type: Transformers – Dry Type Product Model Number: General Purpose & Unit Substation Transformers General Description: Dry-Type General Purpose & Unit Substation Transformers Mounting Description: Rigid, Floor Mounted None Tested Seismic Enhancements: **Applicant Information** Applicant Company Name: TRU Compliance, by Structural Integrity Associates, Inc. Contact Person: Galen Reid Mailing Address: 5215 Hellyer Ave. Suite 210, San Jose, CA 95138

Email: greid@structint.com





Telephone: (541) 604-7225

Title: Director, TRU Compliance

04/27/2022

OSP-0056 Page 1 of 14



DEPARTMENT OF HEALTH CARE ACCESS AND INFORMATION FACILITIES DEVELOPMENT DIVISION

California Licensed Structural Engineer Responsible for the Engineering and Test Report(s)
Company Name: STRUCTURAL INTEGRITY ASSOCIATES, INC.
Name: Andrew Coughlin California License Number: S6082
Mailing Address: 5215 Hellyer Ave, Suite 101, San Jose, CA 95138-1025
elephone: (415) 635-8461 Email: acoughlin@structint.com
Certification Method
GR-63-Core X ICC-ES AC156 IEEE 344 IEEE 693 NEBS 3
Other (Please Specify):
FOR CODE CO
Testing Laboratory
Company Name: Pacific Earthquake Engineering Research Center (PEER)
Contact Person: Amarnath Kasalanati
Mailing Address: 1301 South 46th St., Bldg. 420, Richmond CA 94804
Telephone: (510) 642-3437 Email: Amarnath1@berkeley.edu
Company Name: CLARK TESTING LABORATORY, INC.
Contact Person: Q DATE: 04/27/2022
Mailing Address: 1801 Route 51, Jefferson Hills PA 15025
Telephone: () - Email:
Company Name: UNIVERSITY OF CALIFORNIA, BERKELEY (PEER)
Contact Person: Amarnath Kasalanati
Mailing Address: 1301 South 46th St., Bldg. 420, Richmond CA 94804
Folianhana: (F10) 642 6475 Email: near contar@harkelay.adu







z/h (Height ratio factor) =

DEPARTMENT OF HEALTH CARE ACCESS AND INFORMATION FACILITIES DEVELOPMENT DIVISION

Seismic Parameters								
Design Basis of Equipment or Components (Fp/Wp) = 1.44 (z/h = 1); 0.90 (z/h = 0)								
SDS (Design spectral response accele	eration at short period, g) = 2.0							
ap (Amplification factor) =	1.0							
R _P (Response modification factor) =	2.5							
Ω_0 (System overstrength factor) =	2.0							
Ip (Importance factor) =	1.5							

Natural frequencies (Hz) = See Attachment

Overall dimensions and weight = See Attachment

1 and 0

HCAI A	pproval (For Office Use Only) - Approval Expires on 04/27/2028	8 7	
Date:	4/27/2022 SP-0056	12	
Name:	Mohammad Karim	Title:	Supervisor, Health Facilities
Special	Seismic Certification Valid Up to: Sps (g) = 2.00	z/h =	See Above
Conditio	n of Approval (if applicable):		





04/27/2022 OSP-0056 Page 3 of 14

SPECIAL SEISMIC CERTIFICATION CERTIFIED COMPONENT MATRIX

2200378-CR-001-R0



Manufacturer: MGM Transformer Company

Model Line: General Purpose & Unit Substation Transformers

TABLE 1

Certified Product Construction Summary:

Carbon steel enclosure. Open wound coil construction.

Certified Options Summary:

NEMA 1 or 3R construction. See Table 3 for possible product configurations and the significance of "X".

MGM Transformers can be rebranded as GE Energy Industrial Solutions, Eaton, Square D Company/Schneider Electric, Siemens Energy & Automation, or OnLine Power.

Mounting Configuration:

Base mounted - rigid

Note: Installed mounting configuration must be of similar configuration and equivalent strength and stiffness to those tested.

Building Code: CBC 2019

Seismic Certification Limits:

 $S_{DS} = 2.0 g$ z/h=1.0 $S_{DS} = 2.0 g$ z/h=0.0

I_P= 1.5

Madalita.	44	Ρiι	mensions	(in); 6	Weight	N.1	
Model Line	Model	Depth	Width	Height	(lb) ²	Notes	UUT
Unit Substation	AD2XX-XX <mark>XXX/HS</mark> XXXX2	50	56	90	1,970		Extrap.
Transformers		D Y IVIO	namma	id Karin	1 (1000		Extrap.
(Al - single phase)	AD2XX-XXXXX/HSXXXX2	50	64	90	2,250		Extrap.
	AC2XX-XXX <mark>XX/HSX</mark> XXX1)A50 E :	056/27	729022	1,970	0	Extrap.
							Extrap.
Unit Substation	AC2XX-XXXXX/HSXXXX1	50	90	100	3,165		Extrap.
Transformers (Cu - single phase)	AC2XX-XXXXX/HSXXXX1	60	90	90	3,800		Extrap.
(Cu - siligle pilase)		17	1.11.11		04//		Extrap.
	AC2XX-XXXXX/HSXXXX1	60 8	1108	100	20,502		Extrap.
	AD3XX-XXXXX/HTXXXX2	50	56	90	1,970		Extrap.
							Extrap.
	AD374-Q0224	50	64	90	2,500		3
Unit Substation							Interp.
Transformers	AD3XX-XXXXX/HTXXXX2	50	90	100	3,516		Interp.
(Al - three phase)	AD3XX-XXXXX/HTXXXX2	60	90	90	4,219		Interp.
							Interp.
	AD3XX-XXXXX/HTXXXX2	60	108	108	20,502		Interp.
	AE381-Z0107	60	108	108	20,502	UUT6: Hybrid Cu/Al	6
11 2 6 1 1 12	AC3XX-XXXXX/HTXXXX1	60	56	90	2,625		Interp.
Unit Substation Transformers							Interp.
(Cu - three phase	AC3XX-XXXXX/HTXXXX1	60	108	108	20,502		Interp.
(Cu - tillee pilase	AE381-Z0107	60	108	108	20,502	UUT6: Hybrid Cu/Al	6

¹"H" model numbering applies up to 600V class only and has identical construction to "A" models.

² Maximum operating weight and maximum allowed per enclosure depth dimensions.

SPECIAL SEISMIC CERTIFICATION CERTIFIED COMPONENT MATRIX

2200378-CR-001-R0



Manufacturer: MGM Transformer Company

Model Line: General Purpose & Unit Substation Transformers

TABLE 2

Certified Product Construction Summary:

Carbon steel enclosure. Open wound coil construction.

Certified Options Summary:

NEMA 1 or 3R construction. See Table 3 for possible product configurations and the significance of "X".

MGM Transformers can be rebranded as GE Energy Industrial Solutions, Eaton, Square D Company/Schneider Electric, Siemens Energy & Automation, or OnLine Power

Mounting Configuration:

Base mounted - rigid

Note: Installed mounting configuration must be of similar configuration and equivalent strength and stiffness to those tested.

Building Code: CBC 2019

Seismic Certification Limits:

s= 2.0 g z/h=1

I_P= 1.5

		<u>NYAAANYXX</u>	Next Marchall	<u> </u>	S DS	2.0 g z/h=0.0	
Model Line	Model	Dir	mensions	(in) ₆	Weight	Notes	UUT
Model Lille	Model	Depth	Width	Height	(lb) ²	Mores	
General Purpose	AD2XX-XXXXX/HSXXXX2	14.0	21.0	28.0	295		Extrap.
Transformers	I.O (()	DYIVIO	папппа	id Kalli	1		Extrap.
(Al - single phase)	AD2XX-XXXXX/HSXXXX2	32.0	50.5	66.0	3,560		Extrap.
General Purpose	AC2XX-XXXXX/HSXXXX1	14.0	21.027	//228.02	295	0	Extrap.
Transformers							Extrap.
(Cu - single phase)	AC2XX-XXXXX/HSXXXX1	32.0	50.5	66.0	3,560		Extrap.
	AD3XX-XXXXX/HTXXXX2	14.0	21.0	28.0	325		Extrap.
		17.			0		Extrap.
General Purpose Transformers	AE374-N0227	21.0	36.5	40.5	1,086	UUT 4: Hybrid Cu/Al	4
(Al - three phase)					•••		Interp.
(All times pridate)	AD3XX-XXXXX/HTXXXX2	32.0	50.5	66.0	3,957		Interp.
	AE378-U0376	32.0	50.5	66.0	3,957	UUT 5: Hybrid Cu/Al	5
	AC3XX-XXXXX/HTXXXX1	14.0	21.0	28.0	325		Extrap.
Caraval D.		•••	•••	•••	•••		Extrap.
General Purpose Transformers	AE374-N0227	21.0	36.5	40.5	1,086	UUT 4: Hybrid Cu/Al	4
(Cu - three phase)				•••	•••		Interp.
(ca timee phase)	AC3XX-XXXXX/HTXXXX1	32.0	50.5	66.0	3,957		Interp.
	AE378-U0376	32.0	50.5	66.0	3,957	UUT 5: Hybrid Cu/Al	5

 $^{^{1}}$ "H" model numbering applies up to 600V class only and has identical construction to "A" models.

² Maximum operating weight and maximum allowed per enclosure depth dimensions.

SPECIAL SEISMIC CERTIFICATION MODEL LINE NUMBERING - REFERENCE ONLY

TRU

2200378-CR-001-R0

Manufacturer: Model Line:	MGM Transformer Cor General Purpose & Un	npany it Substation Transformers	TABLE 3
Column	Description	Key	
Column 1	Prefix	A = This column is always letter "A"	
Column 2	Winding Material	C = Copper D = Aluminum E = Aluminum / Copper Hyprid	
Column 3	Phase	2 - Single Phase 3 - Three Phase	
Column 4 & 5	Voltage Class	70 = 600V Class 72 = 2.5kV Class 74 = 5kV Class 76 8.7kV Class 78 = 15lV Class 79 = 25kV Class 81 = 35kV Class	
Column 6	Max kVA Rating	A = 9 - 14 B = 15 - 19 C = 20 - 24 D = 25 - 29 E = 30 - 36 F = 37 - 44 G = 45 - 49 H = 50 - 74 J = 75 - 99 K = 100 - 111 L = 112.5 - 124 M = 125 - 149 N = 150 - 199 P = 200 - 224 Q = 225 - 249 R = 250 - 299 S = 300 - 399 T = 400 - 499 U = 500 - 749 V = 750 - 999 W = 1,000 - 1,499 X = 1,500 - 1,999 Y = 2,000 - 2,499 Z = 2,500 and up	
Columns 7-10	Unit Specific Digits	Details specific primary and secondary voltage / tem	nn rise. No mechanical change

SPECIAL SEISMIC CERTIFICATION ALTERNATE NUMBERING - REFERENCE ONLY

2200378-CR-001-R0



Manufacturer:	MGM Transformer Con	npany		TABLE 4
Model Line:	General Purpose & Uni	it Substation Transf	ormers	I ADLE 4
Column	Description		Key	
Column 1	Prefix	H = 220° C Insulation	on system	
Column 2	Phase	T = Three phase		
Columniz	Filase	S = Single phase		
Column 3	kVA Rating	9 to 1500		
		Letter	3-Phase Voltage	1-Phase Voltage
		A	480 Delta	480
		В	208Y/120	120/240
		CFORCO	240 Delta	240/480
	REVIEW	D	480Y/277	240
		E	120 Delta	120
		F	600 Delta	600
	4	G OSP-C	208 Delta	208
		H	230 Delta	230/460
		J. Mohamm	460 Delta	460
		K . Wollailii	240/120 CT	
		TANABESES SES	240Y/139	
	CP	MATE: 04/2	380 Delta	
		N	575 Delta	
		P	230Y/133	230/115
	\O _k	Q	400Y/231	
Column 4 & 6	Primary Voltage or	R	380Y/220	
	Secondary Voltage	BUILD	240Y/139	
		U	440D	
		V	220D	110/220
		W	500D	230
		X	440Y/254	
		AZ	450D	450
		BZ	440Y/254	440
		CZ	415D	
		DZ	240 X 480	
		EZ	220Y/127	
		FZ	416Y/240	
		GZ	560Y/266	
		HZ	115D	115
		JZ	550D	
		KZ	280D	
		LZ	360D	
		MZ	160Y/93	Structural Integrity Associates, Inc

TRU Compliance, by Structural Integrity Associates, Inc. 844-TRU-0200 | info@trucompliance.com

SPECIAL SEISMIC CERTIFICATION ALTERNATE NUMBERING - REFERENCE ONLY

TRU

2200378-CR-001-R0

anufacturer: odel Line:	MGM Transformer Con General Purpose & Un		ransformers	TABLE 4
Column	Description		Key	
		NZ	130Y/75	
	5	PZ	240Y X 208Y	
Column 4 & 6	Primary Voltage or	RZ	208D X 230D	
	Secondary Voltage	SZ	277Y/160	
		TZ	490D	
Column 5	Taps	1 through 8	<u> </u>	
Column 7	Conductor Material	1 = Cu 2 = Al 3 = Al/Cu	ODE COMP	
	W W W W W W W W W W W W W W W W W W W	OS	P-0056	
		BY: Moha	04/27/2022 6	
		VIA BUI	LDING CO	

SPECIAL SEISMIC CERTIFICATION CERTIFIED SUBCOMPONENT MATRIX

2200378-CR-001-R0



Manufacturer: MGM Transformer Company Table Description: Enclosures **TABLE 5 Model Line:** General Purpose & Unit Substation Transformers

 $S_{DS} = 2.0 g z/h = 1.0$ Puilding Codo, CPC 2010 Saismis Cartification Limits

Model Line		Di	mension ((in)	Weight	$S_{DS} = 2.0 g z/h = 0.0$			
(Manufacturer)	Model	Depth Width		Height	(lb)	Material	Notes	UUT	
	GPA	14	21	28	60	Carbon steel		4	
	GPB	17	26.5	32	90	Carbon steel		Interp	
Conoral Durnoso	GPB+	20	28.5	38.5	115	Carbon steel		Interp	
General Purpose (MGM)	GPC	21.8	31.5	40.5)S25-(Carbon steel		Interp	
(MOM)	GPC+	21.8	36.5	40.5	135	Carbon steel		Interp	
	GPD	26.5	4 0.5	B51.5 _M	oh 345 m	Carbon steel		Interp.	
	GPE	32	50.5	66	535	Carbon steel		5	
	US56	50	56	90	1100	Carbon steel		Interp.	
	US64	50	-64	90	1200	Carbon steel		3	
	US72	50	72	90	1300	Carbon steel		Interp.	
	US80	50	80	90	1460	Carbon steel		Interp.	
	US90	50	90	90	1630	Carbon steel		Interp	
Unit Substation	US90L	60	90	100	1780	Carbon steel		Interp	
(MGM)	US90K	60	90	90	1640	Carbon steel		Interp	
	US90M	50	90	100	1710	Carbon steel		Interp	
	US100	60	100	100	2070	Carbon steel		Interp	
	US108	60	108	108	2330	Carbon steel		6	
	US100M	60	100	108	2150	Carbon steel	1" Max difference in C.G. from US108	Extrap	
	US108L	60	108	108	2330	Carbon steel	1" Max difference in C.G. from US108	Extrap	





UUT	Unit Description	Report Number	Testing Lab	Year Tested	ISO 17025 Accredited?	S _{DS}	z/h	Ι _Ρ
3	Unit Substation 225kVA Al, Three Phase	T5138	Clark Testing	2010	Yes	2.0 2.0	1.0 0.0	1.5
4	General Purpose Transformer 15kVA Al/Cu, Single Phase	1700707-TR-001 R3	Pacific Earthquale Engineering Research Center (PEER)	2018	Yes	2.12 2.75	1.0 0.0	1.5
5	General Purpose Transformer 500kVA Al/Cu, Three Phase	1700707-TR-001 R3	Pacific Earthquale Engineering Research Center (PEER)	2018	Yes	2.12 2.75	1.0 0.0	1.5
6	Unit Substation 3000kVA Al/Cu, Three Phase	1700707-TR-001 R3	Pacific Earthquale Engineering Research Center (PEER)	2018	Yes	2.12 2.75	1.0 0.0	1.5
		4	OSP-0056		A			
		BY: M	ohammad Ka	rim	0			
	\	DATI	: 04/27/202	2	6			
				HARAF.	0			
		Commission						
		VIA	BUILDING					
lotes:								

2200378-CR-001-R0



UUT 3

Manufacturer: MGM Transformer Company

Model Line: General Purpose & Unit Substation Transformers

Model Number: AD374-Q0224 Serial Number: N/A

Product Construction Summary:

NEMA 3R.

Carbon Steel Enclosure.

Open Wound Coil Construction.

Options/Subcomponent Summary:

225 kVA. 5kV class. Aluminum windings. 3 phase. US64 Enclosure.

			UUT P	roperties		7					
Weight		Dimension (in	Mark Mark March	###XXX		Lowest Natural Frequency (Hz)					
(lb)	Depth	OSH	OS Height 56		Front-Back		Side-Side		Vertical		
2,500	50.0	64.0	9	90.0		12.7		14.2		19.1	
		UUT Highes	st Passed S	eismic Run	Informa	tion			,		
Buildi	ng Code	Test Crit	eria	S _{DS} (g)	z/h	I _P	A _{FLX-H} (g)	A _{RIG-H} (g)	A _{FLX-V} (g)	A _{RIG-V} (g)	
СВС	2019	ICC-ES AC	156 04	272.0	2 1.0 0.0	1.5	3.20	2.40	1.33	0.53	

Test Mounting Details:



Unit was rigid floor mounted using four (4) 5/8" Grade 5 bolts with washers and lock washers.
Unit maintained structural integrity and remained functional per manufacturer requirement after shake table test.
Contents were included in testing per operating conditions.

2200378-CR-001-R0



UUT 4

Manufacturer: MGM Transformer Company

Model Line: General Purpose & Unit Substation Transformers

Model Number: AE374-N0227 Serial Number: N/A

Product Construction Summary:

NEMA 3R.

Carbon Steel Enclosure.

Open Wound Coil Construction.

Options/Subcomponent Summary:

150 kVA. 5kV class. Aluminum and Copper windings. 3 phase. GPA Enclosure.

		141	UUT PI	operties		7					
Weight		t Natural	t Natural Frequency (Hz)								
(lb)	Depth	Width	OS Height 56		Front-Back		Side-Side		Vertical		
1,086	21.0	36.5	4	40.5		10.85		5.31		10.96	
		UUT Highes	t Passed S	eismic Run	Informa	tion					
Buildi	ng Code	Test Crite	eria	S _{DS} (g)	z/h	I _P	A _{FLX-H} (g)	A _{RIG-H} (g)	A _{FLX-V} (g)	A _{RIG-V} (g)	
СВС	2019	ICC-ES AC	156 04/	2.75 2.75	2 1.0 0.0	1.5	3.39	2.54	1.83	0.73	

Test Mounting Details:





Base mounted-rigid using four (4) 1/2" -13 SAE Grade 8 bolts with lock washers and flat washers. Unit maintained structural integrity and remained functional per manufacturer requirement after shake table test. Contents were included in testing per operating conditions.

2200378-CR-001-R0



UUT5

Manufacturer: MGM Transformer Company

Model Line: General Purpose & Unit Substation Transformers

Model Number: AE378-U0376 Serial Number: N/A

Product Construction Summary:

NEMA 3R.

Carbon Steel Enclosure.

Open Wound Coil Construction.

Options/Subcomponent Summary:

500 kVA. 5kV class. Aluminum and Copper windings. 3 phase. GPE Enclosure.

				MAA WAA JAAA	AXX								
			UUT Pr	operties		7							
Weight	Dimension (in)				Lowest Natural Frequency (Hz)								
(lb)	Depth	Width	OS Height 56		Front-Back		Side-Side		Vertical				
3,957	32.0	50.5	66.0		8.25		6.85		16.42				
	UUT Highest Passed Seismic Run Information												
Building Code		Test Criteria		S _{DS} (g)	z/h	I _P	A _{FLX-H} (g)	A _{RIG-H} (g)	A _{FLX-V} (g)	A _{RIG-V} (g)			
CBC 2019		ICC-ES AC	156 04/	2.75	2 1.0 0.0	1.5	3.39	2.54	1.83	0.73			

Test Mounting Details:





Base mounted-rigid using four (4) 1/2" -13 SAE Grade 8 bolts with lock washers and flat washers. Unit maintained structural integrity and remained functional per manufacturer requirement after shake table test. Contents were included in testing per operating conditions.

2200378-CR-001-R0



UUT 6

Manufacturer: MGM Transformer Company

Model Line: General Purpose & Unit Substation Transformers

Model Number: AE381-Z0107 Serial Number: N/A

Product Construction Summary:

NEMA 3R.

Carbon Steel Enclosure.

Open Wound Coil Construction.


Options/Subcomponent Summary:

3000 kVA. 35kV class. Aluminum and Copper windings. 3 phase. US108 Enclosure.

			UUT PI	roperties		7					
Weight	Dimension (in)				Lowest Natural Frequency (Hz)						
(lb)	Depth	Width	OS Height 56		Front-Back		Side-Side		Vertical		
20,502	60.0	108.0	108.0		15.78		20.00		15.14		
		UUT Highe:	st Passed S	eismic Run	Informa	tion					
Building Code		Test Criteria		S _{DS} (g)	z/h	I _P	A _{FLX-H} (g)	A _{RIG-H} (g)	A _{FLX-V} (g)	A _{RIG-V} (g)	
CBC 2019		ICC-ESAC156 04/2		2.75	2 1.0 0.0	1.5	3.39	2.54	1.83	0.73	

Test Mounting Details:





Base mounted-rigid using four (4) 3/4" -10 SAE Grade 8 bolts with lock washer and flat washer internally at units corners and four (4) 3/4"-10 SAE Grade 8 bolts with lock washer and flat washer on the exterior of the unit through the down-turned manufacturer provided lifting lugs.

Unit maintained structural integrity and remained functional per manufacturer requirement after shake table test. Contents were included in testing per operating conditions.