DEPARTMENT OF HEALTH CARE ACCESS AND INFORMATION
OFFICE OF STATEWIDE HOSPITAL PLANNING AND DEVELOPMENT

APPLICATION FOR HCAI SPECIAL SEISMIC CERTIFICATION PREAPPROVAL (OSP)

OFFICE USE ONLY

APPLICATION #: OSP-0064

HCAI Special Seismic Certification Preapproval (OSP)

Type: ☐ New ☒ Renewal

Manufacturer Information

Manufacturer: Square D by Schneider Electric

Manufacturer's Technical Representative: Scott Littler

Mailing Address: 6700 Tower Circle, Suite 700, Franklin, TN 37067

Telephone: (615) 267-9407 Email: scott.littler@se.com

Product Information

Product Name: Enclosed Circuit Breakers - Low Voltage (600V and below)

Product Model Number(s): Varies (see attachment)

Product Category: Panelboards

Product Sub-Category: Panelboards

General Description: Enclosed Circuit Breaker Units from 15A to 1200A ratings consisting of molded case circuit breakers packaged in carbon or stainless-steel sheet metal framed enclosures (NEMA Type 1, 3, 3R, 4, 4X, 5, and 12)

Mounting Description: Wall Mounted Rigid

Tested Seismic Enhancements: None

Applicant Information

Applicant Company Name: Pre Compliance

Contact Person: Galen Reid

Mailing Address: 324 NW Hill St., Bend, OR 97703

Telephone: (541) 241-2310 Email: galen@go-pre.com

Title: Principal and Program Manager

REVIEWED FOR CODE COMPLIANCE
HCAi
OSP-0064
BY: Mohammad Karim
DATE: 11/09/2026
CALIFORNIA BUILDING CODE, 2025

California Licensed Structural Engineer Responsible for the Engineering and Test Report(s)

Company Name: PRE COMPLIANCE

Name: Andrew Coughlin California License Number: S6082

Mailing Address: 324 NW Hill St, Bend, OR 97703

Telephone: (415) 635-8461 Email: Andy@go-pre.com

Certification Method

☐ GR-63-Core ☒ ICC-ES AC156 ☐ IEEE 344 ☐ IEEE 693 ☐ NEBS 3

☐ Other (Please Specify):

Testing Laboratory

Company Name: NATIONAL TECHNICAL SYSTEMS (NTS)

Contact Person: Greg Mason

Mailing Address: 7800 Highway 20 West, Huntsville AL 35806

Telephone: (256) 837-4411 Email: greg.mason@nts.com

REVIEWED FOR CODE COMPLIANCE
HCAi
OSP-0064
BY: Mohammad Karim
DATE: 11/09/2026
CALIFORNIA BUILDING CODE, 2025

Seismic Parameters

Certified Response Spectral Acceleration Factors:(F_p/W_p)

Horizontal	(A Flx-H), g=	3.80	(A Rig-H), g=	2.56
Vertical	(A Flx-V), g=	2.05	(A Rig-V), g=	0.82

S_{DS} (Design spectral response acceleration at short period, g) = 2.38 (z/h=1.0), 3.06 (z/h=0.0)

Hf (Force amplification height factor) = 1 @ z/h = 0; 3.5 @ z/h = 1

Ru (Structure ductility redution factor) = 1 @ z/h = 0; 1.3 @ z/h = 1

I_p (Importance factor) = 1.5

z/h (Height ratio factor) = 0 and 1

HCAI Approval (For Office Use Only) - **Approval Expires on 11/09/2032**

Date: 11/9/2026

Name: Mohammad Karim Title: Supervisor, Health Facilities

Condition of Approval (if applicable):

REVIEWED FOR CODE COMPLIANCE
HCAi
OSP-0064
BY: Mohammad Karim
DATE: 11/09/2026
CALIFORNIA BUILDING CODE, 2025

SPECIAL SEISMIC CERTIFICATION CERTIFIED COMPONENTS

Pre No. 251824-01-R0

Manufacturer: Schneider Electric
Product Type: Enclosed Circuit Breakers
Model Line: 15-1200A Enclosed Circuit Breakers

Seismic Parameters		Building Codes
S_{DS} = 2.38g for z/h=1,R_μ=1.3,H_f=3.5	I_p=1.5	CBC 2025
S_{DS} = 3.06g for z/h=0,R_μ=1.0,H_f=1.0		

TABLE 1

Mounting Configuration: Wall Mounted - Rigid

Construction Summary

Enclosures constructed of carbon steel (CS) or stainless steel (SS) as noted in Table below.

Options Summary

Models with suffix "A", "AWK", "DS", or "SS" provide a mechanism to operate the enclosed circuit breaker. These are NEMA type 12, 4, 4X, or 5. Models without suffix "A", "AWK", "DS", or "SS" provide no operating mechanism. These are NEMA types 1 or 3R.

Model Line	Model	Max Ampacity	Max. Dimensions (in)			Wt. (lb)	Material	NEMA Type	UUT
			D	W	H				
With Operating Mechanism	FA100A	100	4.88	9.13	19.5	13	CS	12	22
	F*100***		4.88	9.13	19.5	13	CS	12	Interp.
			4.88	9.13	19.5	16	SS	4,4X,5	Interp.
	H*100*		4.75	7.9	17	16	CS	1	Interp.
	B125***	125	4.88	9.13	19.5	16	CS	1,3R	Interp.
	H150*	150	6.28	15.4	32.26	24	CS	1,3R	Interp.
	J250AWK	250	7.94	9.72	32.26	24	CS	12	25
	J250***		7.94	9.72	32.26	24	CS	12	Interp.
	J250DS		7.94	9.72	32.26	28	SS	4,4X,5	3
	J250***		7.94	9.72	32.26	28	SS	4,4X,5	Interp.
	LA400AWK	400	7.25	13.75	42.25	52	CS	12	27
	L*400***		7.25	13.75	42.25	52	CS	12	Interp.
	L*600***	600	8.2	20.42	59.63	110	CS	12	Interp.
	M800***	800	9.5	20.75	40.88	86	CS	12	Interp.
	L1200*	1200	7.75	20.25	51.88	107	CS	1	Interp.
	P1200***		9.5	20.75	53	104.7	CS	12	Interp.
Without Operating Mechanism	F*100** H*100*	100	4.75	7.9	17	11	CS	1	Interp.
			4.88	8.88	18	16	CS	3R	Interp.
			4.13	8.63	18.13	14	CS	1	Interp.
			4.13	9.88	19.5	14	CS	1	Interp.
	B125***	125	4.88	9.13	19.5	16	CS	1,3R	Interp.
	H150*	150	6.28	15.4	32.26	24	CS	1,3R	Interp.
	Q**200***	200	4.25	7.63	23.13	11.84	CS	1	Interp.
			4.75	7.63	23.13	15.28	CS	3R	Interp.
	Q**225***	225	4.75	9.88	26.25	18	CS	1	Interp.
	Q23225NRB		5.5	9.88	26.25	23	CS	3R	23
	Q**225***		5.5	9.88	26.25	23	CS	3R	Interp.

REVIEWED FOR CODE COMPLIANCE OSP-0064 BY: Mohammad Karim DATE: 11/09/2026 CALIFORNIA BUILDING CODE, 2025

SPECIAL SEISMIC CERTIFICATION CERTIFIED COMPONENTS

Manufacturer: Schneider Electric
Product Type: Enclosed Circuit Breakers
Model Line: 15-1200A Enclosed Circuit Breakers

Seismic Parameters		Building Codes
S_{DS} = 2.38g for z/h=1,R_μ=1.3,H_f=3.5 S_{DS} = 3.06g for z/h=0,R_μ=1.0,H_f=1.0	I_p=1.5	CBC 2025

TABLE 1

Mounting Configuration: Wall Mounted - Rigid

Construction Summary

Enclosures constructed of carbon steel (CS) or stainless steel (SS) as noted in Table below.

Options Summary

Models with suffix "A", "AWK", "DS", or "SS" provide a mechanism to operate the enclosed circuit breaker. These are NEMA type 12, 4, 4X, or 5. Models without suffix "A", "AWK", "DS", or "SS" provide no operating mechanism. These are NEMA types 1 or 3R.

Model Line	Model	Max Ampacity	Max. Dimensions (in) D	W	H	Wt. (lb)	Material	NEMA Type	UUT
Without Operating Mechanism	J250** J*250**	250	5.5	8.9	26.4	17.37	CS	1	Interp.
			5.63	19	20	19	CS	1	Interp.
			7.12	19	20.25	27	CS	3R	Interp.
	J250R		6.28	14.47	31.05	34	CS	3R	24
	J250** J*250**		6.28	14.47	31.05	34	CS	3R	Interp.
			6	14.36	31.36	33	CS	1	Interp.
			6	15.4	32.4	33	CS	1	Interp.
	L*400***	400	6.63	15.4	27.4	36	CS	1	Interp.
			7.88	15.38	44	60	CS	3R	Interp.
			6.5	15.38	44.5	46	CS	1	Interp.
			6.5	16.5	45.63	46	CS	1	Interp.
	M800*	800	9.75	21	40.38	98	CS	1,3R	Interp.
	M*1200** P1200* L1200*	1200	7.75	20.25	51.8	107	CS	1	Interp.
	P1200R		9.75	21	52.13	160	CS	3R	4
	M*1200** P1200*		9.75	21	52.13	160	CS	1,3R	Interp.

REVIEWED FOR CODE COMPLIANCE
OSP-0064
BY: Mohammad Karim
DATE: 11/09/2026
CALIFORNIA BUILDING CODE 2025

SPECIAL SEISMIC CERTIFICATION CERTIFIED COMPONENTS

Manufacturer: Schneider Electric
Product Type: Enclosed Circuit Breakers
Model Line: 15-1200A Enclosed Circuit Breakers

Seismic Parameters		Building Codes
S_{DS} = 2.38g for z/h=1,R_μ=1.3,H_f=3.5	I_p=1.5	CBC 2025
S_{DS} = 3.06g for z/h=0,R_μ=1.0,H_f=1.0		

Circuit Breaker Enclosures - Model Number Nomenclature

Circuit Breaker			Enclosure		
Catalog No. Prefix	Rating	Poles	NEMA 1 Flush	NEMA 1 Surface	NEMA 3R
FAL, FHL, FCL	15-100 A	1,2,3	FA100F	FA100S	FA10RB
BDL, BGL, BJL	15-125 A	2,3	B125F	B125S	B125RB
BKL	15-30 A	2			
HDL	15-100 A	3	-	HD100S	-
HDL, JDL	125-250 A	3	-	JD250S	-
HDL, HGL	15-150 A	2	H150F	H150S	H150R
HJL, HLL	15-100 A	2	J250F	J250S	H150R
HDL, HGL, HJL, HLL	15-150 A	3			
JDL, JGL, JJL, JLL	150-250 A	2,3			
QBL, QDL, QGL, QJL	70-225 A	2	-	Q22200NS	Q22200NRB
QBL, QDL, QGL, QJL	70-225 A	2,3	Q23225NF	Q23225NS	Q23225NRB
LAL, LHL, Q4L	125-400 A	2,3	LA400F	LA400S	LA400R
LAL	125-400 A	3	-	LA400LS	-
MGL, MJL, PGL, PJL, PKL, PLL	300-800 A	2,3	-	M800S	M800R
PGL, PJL, PKL, PLL	250-1200 A	2,3	-	P1200S	M1200R

Circuit Breaker			NEMA 4,4X,5, 304 Stainless Steel	NEMA 12 w/Knockouts	NEMA 12 w/out Knockouts
FAL, FHL, FCL	15-100A	1,2,3	FA100DS	FA100A	FA100AWK
BDL, BGL, BJL	15-100A	2,3	B125S	B125A	B125AWK
BDL, BGL, BJL	110-125 A	2,3			
BKL	15-30 A	2			

Circuit Breaker			NEMA 4,4X,5, 304 Stainless Steel	NEMA 4,4X,5, 316 Stainless Steel	NEMA 12/3R w/out Knockouts
FAL, FHL, FCL	15-100 A	1,2,3	FA100DS	-	FA100AWK
HDL, HGL, HJL, HLL	15-150 A	2,3	J250DS	J250SS	J250AWK
JDL, JGL, JJL, JLL	150-250 A	2,3			
LAL, LHL, Q4L	125-400 A	2,3	LA400DS	-	LA400AWK
LDL, LGL, LJL, LLL, LRL	250-600 A	3	-	-	L600AWK
LGL, LLL, LRL	250-600 A	3	-	-	L600AWKMC
MGL, MJL, PGL, PJL, PKL, PLL	300-800 A	2,3	M800DS	M800SS	M800AWK
PGL, PJL, PKL, PLL	250-1200 A	2,3	-	-	P1200AWK

DC Circuit Breaker Enclosures for LG and LL DC-Rated Circuit Breakers

Circuit Breaker			NEMA 1 Surface
LGL, LLL	300-600 A	3	L1200S
LGL, LLL	700-1200 A	4	

REVIEWED FOR CODE COMPLIANCE
HCAi
OSP-0064
BY: Mohammad Karim
DATE: 11/09/2026
CALIFORNIA BUILDING CODE, 2025
FOR REFERENCE ONLY

SPECIAL SEISMIC CERTIFICATION
CERTIFIED SUBCOMPONENTS

Manufacturer: Schneider Electric
Product Type: Enclosed Circuit Breakers
Model Line: 15-1200A Enclosed Circuit Breakers

Seismic Parameters		Building Codes
S_{DS} = 2.38g for z/h=1,R_μ=1.3,H_f=3.5	I_p=1.5	CBC 2025
S_{DS} = 3.06g for z/h=0,R_μ=1.0,H_f=1.0		

TABLE 2

Table Description: Molded Case Circuit Breakers

Component	Manufacturer	Model	Description	UUT
Molded Case Circuit Breakers (2, 3, and 4 Pole)	Square D	F*	15-100A, 208-600V, 6 lbs.	Interp.
		FAL34100	100A, 480V, 6 lbs.	22
		B*	15-125A, 208-600V, 4 lbs.	Interp.
		H*	15-250A, 208-600V, 5 lbs.	Interp.
		Q*	70-250A, 208-600V, 5 lbs.	Interp.
		QJL32250	250A, 600V, 5 lbs.	23
		J*	150-250A, 208-600V, 5 lbs.	Interp.
		JDL36250	250A, 600V, 5 lbs.	3
		JGL36250	250A, 600V, 5 lbs.	24,25
		K*	110-250A, 208-600V, 10 lbs.	Interp.
		L*	250-600A, 208-600V, 14 lbs.	Interp.
		LAL36400	400A, 600V, 14 lbs.	27
		M*	300-800A, 208-600V, 24 lbs.	Interp.
		L*	250-1200A, 208-600V, 24 lbs.	Interp.
		P*	600-1200A, 208-600V, 36 lbs.	Interp.
		PLL34000S12	1200A, 600V. 36 lbs.	4

*The sub–components listed here include part numbers which provided identify configuration, manufacturer, and materials. Tested sub–components and interpolated/extrapolated items have the same manufacturer and materials and have similar configuration and construction as the tested units.

REVIEWED FOR CODE COMPLIANCE
HCAI
OSP-0064
BY: Mohammad Karim
DATE: 11/09/2026
CALIFORNIA BUILDING CODE, 2025

SPECIAL SEISMIC CERTIFICATION TESTING SUMMARY

UUT	Model	Test Report	Test Date	Test Laboratory	S_{DS}	z/h	R_μ	H_f	I_p
3	J250DS	58773R11	8/23/2011	NTS Huntsville	2.38 3.06	1 0	1.3 1.0	3.5 1.0	1.5
4	P1200R	58773R11	8/23/2011	NTS Huntsville	2.38 3.06	1 0	1.3 1.0	3.5 1.0	1.5
22	FA100A	53276-4	3/2/2006	NTS Huntsville	2.70 3.16	1 0	1.3 1.0	3.5 1.0	1.5
23	Q23225NRB	53276-6	3/3/2006	NTS Huntsville	2.46 3.10	1 0	1.3 1.0	3.5 1.0	1.5
24	J250R	53276-4	3/2/2006	NTS Huntsville	2.70 3.16	1 0	1.3 1.0	3.5 1.0	1.5
25	J250AWK	53276-2	3/2/2006	NTS Huntsville	2.51 3.10	1 0	1.3 1.0	3.5 1.0	1.5
27	LA400AWK	53276-5	3/3/2006	NTS Huntsville	2.50 3.17	1 0	1.3 1.0	3.5 1.0	1.5

REVIEWED FOR CODE COMPLIANCE
HCAi
OSP-0064
BY: Mohammad Karim
DATE: 11/09/2026
CALIFORNIA BUILDING CODE, 2025

Notes:

SPECIAL SEISMIC CERTIFICATION UUT SUMMARY

UUT 3 Test Report# 58773R11

Manufacturer: Schneider Electric
Model Line: 15-1200A Enclosed Circuit Breakers
Model Number: J250DS
Serial Number: N/A

Highest Passed Test Level

S_{DS} (g)	z/h	R_μ	H_f	I_p	A_{flx-h} (g)	A_{rig-h} (g)	A_{flx-v} (g)	A_{rig-v} (g)
2.38	1.0	1.3	3.5	1.5	3.80	2.56	2.05	0.82
3.06	0.0	1.0	1.0					

Dimensions/Weights

Depth (in)	Width (in)	Height (in)	Weight (lbs.)
7.94	9.72	32.26	28

Lowest Natural Frequency (Hz)

Front-Back	Side-Side	Vertical
N/A	N/A	N/A

Building Codes

CBC 2025

Test Criteria

ICC-ES AC156-24

Construction/Option Summary

Stainless steel enclosure

UUT Mounting Details:



UUT was rigid wall mounted using (3) 1/4" grade 5 bolts and flat washers torqued to 7 ft-lbs.
Unit maintained structural integrity and remained operational per manufacturer requirement following shake table test. All contents were included in the unit per operating conditions.

List of Included Subcomponents

Description (Manufacturer)	Model #	Wt. (lbs.)
250A Molded Case Circuit Breaker (Square D)	JDL36250	5

HCAi
REVIEWED FOR CODE COMPLIANCE
OSP-0064
BY: Mohammad Kaim
DATE: 11/09/2026
CALIFORNIA BUILDING CODE, 2025

SPECIAL SEISMIC CERTIFICATION UUT SUMMARY

UUT 4 Test Report# 58773R11

Manufacturer: Schneider Electric
Model Line: 15-1200A Enclosed Circuit Breakers
Model Number: P1200R
Serial Number: N/A

Highest Passed Test Level

S_{DS} (g)	z/h	R_μ	H_f	I_p	A_{flx-h} (g)	A_{rig-h} (g)	A_{flx-v} (g)	A_{rig-v} (g)
2.38	1.0	1.3	3.5	1.5	3.80	2.56	2.05	0.82
3.06	0.0	1.0	1.0					

Dimensions/Weights

Depth (in)	Width (in)	Height (in)	Weight (lbs.)
9.75	21	52.13	160

Lowest Natural Frequency (Hz)

Front-Back	Side-Side	Vertical
N/A	N/A	N/A

Building Codes

CBC 2025

Test Criteria

ICC-ES AC156-24

Construction/Option Summary

Carbon steel enclosure

UUT Mounting Details:



UUT was rigid wall mounted using (4) 1/4" grade 5 bolts and flat washers torqued to 7 ft-lbs.
Unit maintained structural integrity and remained operational per manufacturer requirement following shake table test. All contents were included in the unit per operating conditions.

List of Included Subcomponents

Description (Manufacturer)	Model #	Wt. (lbs.)
1200A Molded Case Circuit Breaker (Square D)	PLL34000S12	36

REVIEWED FOR CODE COMPLIANCE
HCAi
OSP-0064
BY: Monammad Kaim
DATE: 11/09/2026
CALIFORNIA BUILDING CODE, 2025

SPECIAL SEISMIC CERTIFICATION UUT SUMMARY

UUT 22 Test Report# 53276-4

Manufacturer: Schneider Electric
Model Line: 15-1200A Enclosed Circuit Breakers
Model Number: FA100A
Serial Number: N/A

Highest Passed Test Level

S_{DS} (g)	z/h	R_μ	H_f	I_p	A_{flx-h} (g)	A_{rig-h} (g)	A_{flx-v} (g)	A_{rig-v} (g)
2.70	1.0	1.3	3.5	1.5	4.32	2.9	2.11	0.85
3.16	0.0	1.0	1.0					

Dimensions/Weights

Depth (in)	Width (in)	Height (in)	Weight (lbs.)
4.88	9.13	19.5	13

Lowest Natural Frequency (Hz)

Front-Back	Side-Side	Vertical
N/A	N/A	N/A

Building Codes

CBC 2025

Test Criteria

ICC-ES AC156-24

Construction/Option Summary

Carbon steel enclosure

UUT Mounting Details:



UUT was rigid wall mounted using (3) 1/4" grade 5 bolts and flat washers torqued to 7 ft-lbs.
Unit maintained structural integrity and remained operational per manufacturer requirement following shake table test. All contents were included in the unit per operating conditions.

List of Included Subcomponents

Description (Manufacturer)	Model #	Wt. (lbs.)
100A Molded Case Circuit Breaker (Square D)	FAL34100	6

REVIEWED FOR CODE COMPLIANCE
HCAi
OSP-0064
BY: Mohammad Kaim
DATE: 11/09/2026
CALIFORNIA BUILDING CODE, 2025

SPECIAL SEISMIC CERTIFICATION UUT SUMMARY

UUT 23 Test Report# 53276-6

Manufacturer: Schneider Electric
Model Line: 15-1200A Enclosed Circuit Breakers
Model Number: Q23225NRB
Serial Number: N/A

Highest Passed Test Level

S_{DS} (g)	z/h	R_μ	H_f	I_p	A_{flx-h} (g)	A_{rig-h} (g)	A_{flx-v} (g)	A_{rig-v} (g)
2.46	1.0	1.3	3.5	1.5	3.93	2.64	2.07	0.83
3.10	0.0	1.0	1.0					

Dimensions/Weights

Depth (in)	Width (in)	Height (in)	Weight (lbs.)
5.5	9.88	26.25	23

Lowest Natural Frequency (Hz)

Front-Back	Side-Side	Vertical
N/A	N/A	N/A

Building Codes

CBC 2025

Test Criteria

ICC-ES AC156-24

Construction/Option Summary

Carbon steel enclosure

UUT Mounting Details:



UUT was rigid wall mounted using (3) 1/4" grade 5 bolts and flat washers torqued to 7 ft-lbs.
Unit maintained structural integrity and remained operational per manufacturer requirement following shake table test. All contents were included in the unit per operating conditions.

List of Included Subcomponents

Description (Manufacturer)	Model #	Wt. (lbs.)
225A Molded Case Circuit Breaker (Square D)	QBL32225	5

REVIEWED FOR CODE COMPLIANCE
HCAi
OSP-0064
BY: Mohammad Kaim
DATE: 11/09/2026
CALIFORNIA BUILDING CODE, 2025

SPECIAL SEISMIC CERTIFICATION UUT SUMMARY

UUT 24 Test Report# 53276-4

Manufacturer: Schneider Electric
Model Line: 15-1200A Enclosed Circuit Breakers
Model Number: J250R
Serial Number: N/A

Highest Passed Test Level

S_{DS} (g)	z/h	R_μ	H_f	I_p	A_{flx-h} (g)	A_{rig-h} (g)	A_{flx-v} (g)	A_{rig-v} (g)
2.70	1.0	1.3	3.5	1.5	4.32	2.9	2.11	0.85
3.16	0.0	1.0	1.0					

Dimensions/Weights

Depth (in)	Width (in)	Height (in)	Weight (lbs.)
6.28	14.47	31.05	34

Lowest Natural Frequency (Hz)

Front-Back	Side-Side	Vertical
N/A	N/A	N/A

Building Codes

CBC 2025

Test Criteria

ICC-ES AC156-24

Construction/Option Summary

Carbon steel enclosure

UUT Mounting Details:



UUT was rigid wall mounted using (4) 1/4" grade 5 bolts and flat washers torqued to 7 ft-lbs.
Unit maintained structural integrity and remained operational per manufacturer requirement following shake table test. All contents were included in the unit per operating conditions.

List of Included Subcomponents

Description (Manufacturer)	Model #	Wt. (lbs.)
250A Molded Case Circuit Breaker (Square D)	JGL36250	5

REVIEWED FOR CODE COMPLIANCE
HCAi
OSP-0064
BY: Mohammad Kaim
DATE: 11/09/2026
CALIFORNIA BUILDING CODE, 2025

SPECIAL SEISMIC CERTIFICATION UUT SUMMARY

UUT 25 Test Report# 53276-2

Manufacturer: Schneider Electric
Model Line: 15-1200A Enclosed Circuit Breakers
Model Number: J250AWK
Serial Number: N/A

Highest Passed Test Level

S_{DS} (g)	z/h	R_μ	H_f	I_p	A_{flx-h} (g)	A_{rig-h} (g)	A_{flx-v} (g)	A_{rig-v} (g)
2.51	1.0	1.3	3.5	1.5	4.01	2.7	2.07	0.83
3.10	0.0	1.0	1.0					

Dimensions/Weights

Depth (in)	Width (in)	Height (in)	Weight (lbs.)
7.94	9.72	32.26	24

Lowest Natural Frequency (Hz)

Front-Back	Side-Side	Vertical
N/A	N/A	N/A

Building Codes

CBC 2025

Test Criteria

ICC-ES AC156-24

Construction/Option Summary

Carbon steel enclosure

UUT Mounting Details:



UUT was rigid wall mounted using (3) 1/4" grade 5 bolts and flat washers torqued to 7 ft-lbs.
Unit maintained structural integrity and remained operational per manufacturer requirement following shake table test. All contents were included in the unit per operating conditions.

List of Included Subcomponents

Description (Manufacturer)	Model #	Wt. (lbs.)
250A Molded Case Circuit Breaker (Square D)	JGL36250	5

HCAi
OSP-0064
BY: Mohammad Kaim
DATE: 11/09/2026
REVIEWED FOR CODE COMPLIANCE
CALIFORNIA BUILDING CODE, 2025

SPECIAL SEISMIC CERTIFICATION UUT SUMMARY

UUT 27 Test Report# 53276-5

Manufacturer: Schneider Electric
Model Line: 15-1200A Enclosed Circuit Breakers
Model Number: LA400AWK
Serial Number: N/A

Highest Passed Test Level

S_{DS} (g)	z/h	R_μ	H_f	I_p	A_{flx-h} (g)	A_{rig-h} (g)	A_{flx-v} (g)	A_{rig-v} (g)
2.50	1.0	1.3	3.5	1.5	4.00	2.69	2.12	0.85
3.17	0.0	1.0	1.0					

Dimensions/Weights

Depth (in)	Width (in)	Height (in)	Weight (lbs.)
7.25	13.75	42.25	52

Lowest Natural Frequency (Hz)

Front-Back	Side-Side	Vertical
N/A	N/A	N/A

Building Codes

CBC 2025

Test Criteria

ICC-ES AC156-24

Construction/Option Summary

Carbon steel enclosure

UUT Mounting Details:



UUT was rigid wall mounted using (3) 1/4" grade 5 bolts and flat washers torqued to 7 ft-lbs.
Unit maintained structural integrity and remained operational per manufacturer requirement following shake table test. All contents were included in the unit per operating conditions.

List of Included Subcomponents

Description (Manufacturer)	Model #	Wt. (lbs.)
400A Molded Case Circuit Breaker (Square D)	LAL36400	14

HCAi
REVIEWED FOR CODE COMPLIANCE
OSP-0064
BY: Mohammad Kaim
DATE: 11/09/2026
CALIFORNIA BUILDING CODE, 2025