



**DEPARTMENT OF HEALTH CARE ACCESS AND INFORMATION  
OFFICE OF STATEWIDE HOSPITAL PLANNING AND DEVELOPMENT**

**APPLICATION FOR HCAI SPECIAL SEISMIC  
CERTIFICATION PREAPPROVAL (OSP)**

OFFICE USE ONLY

**APPLICATION #: OSP-0115**

**HCAI Special Seismic Certification Preapproval (OSP)**

Type:  New  Renewal

**Manufacturer Information**

Manufacturer: Hitachi Energy USA Inc. (formerly ABB)

Manufacturer's Technical Representative: Oscar Saenz

Mailing Address: 500 W. Highway 94, Jefferson City, MO 65101

Telephone: (573) 659-6325 Email: oscar.a.saenz@hitachienergy.com

**Product Information**

Product Name: Transformer Product Family

Product Model Number(s): Varies (see attachment)

Product Category: Transformers

Product Sub-Category: Transformers – Liquid Filled

General Description: One and three phase, liquid filled distribution transformers including padmount, horizontal, and unit substation product families.

Mounting Description: Base Mounted Rigid -

Tested Seismic Enhancements: None

**Applicant Information**

Applicant Company Name: TRU Compliance, by Structural Integrity Associates

Contact Person: Daniel Zentner

Mailing Address: 233 SW Wilson Ave, Suite 101, Bend, OR 97702

Telephone: (541) 292-5839 Email: dzentner@structint.com

Title: Program Manager





**DEPARTMENT OF HEALTH CARE ACCESS AND INFORMATION  
OFFICE OF STATEWIDE HOSPITAL PLANNING AND DEVELOPMENT**

**California Licensed Structural Engineer Responsible for the Engineering and Test Report(s)**

Company Name: STRUCTURAL INTEGRITY ASSOCIATES, INC.  
 Name: LACHEZAR HANDZHIYSKI California License Number: S6515  
 Mailing Address: 5215 Hellyer Avenue, Suite 210, San Jose, CA 95138  
 Telephone: (669) 437-0200 Email: Lhandzhiyski@StructInt.com

**Certification Method**

GR-63-Core       ICC-ES AC156       IEEE 344       IEEE 693       NEBS 3  
 Other (Please Specify): \_\_\_\_\_

**Testing Laboratory**

Company Name: U.S. ARMY ENGINEER RESEARCH AND DEVELOPMENT CENTER, CONSTRUCTION ENGINEERING RESEARCH LABORATORY (CERL)  
 Contact Person: James Wilcoski  
 Mailing Address: 2902 Newmark Dr., Champaign IL 61822-1076  
 Telephone: (217) 373-1026 Email: ERDCinfo@usace.army.mil

Company Name: CLARK TESTING LABORATORY, INC.  
 Contact Person: Devon Lohr  
 Mailing Address: 1801 Route 51, Jefferson Hills PA 15025  
 Telephone: (412) 387-1001 Email: smazon@clarktesting.com

Company Name: ENVIRONMENTAL TESTING LABORATORIES, INC. (ETL)  
 Contact Person: Jeremy Lange  
 Mailing Address: 11034 Indian Trail, Dallas TX 75229-3513  
 Telephone: (972) 247-9657 Email: info@etldallas.com





**DEPARTMENT OF HEALTH CARE ACCESS AND INFORMATION  
OFFICE OF STATEWIDE HOSPITAL PLANNING AND DEVELOPMENT**

**Seismic Parameters**

Design Basis of Equipment or Components ( $F_p/W_p$ ) = 1.01

SDS (Design spectral response acceleration at short period, g) = 2.25

$a_p$  (Amplification factor) = 1.0

$R_p$  (Response modification factor) = 2.5

$\Omega_0$  (System overstrength factor) = 2.0

$I_p$  (Importance factor) = 1.5

$z/h$  (Height ratio factor) = 0

Natural frequencies (Hz) = See Attachment

Overall dimensions and weight = See Attachment



**HCAI Approval (For Office Use Only) - Approval Expires on 02/19/2031**

Date: 2/19/2025

Name: Mohammad Karim Title: Supervisor, Health Facilities

Special Seismic Certification Valid Up to: SDS (g) = 2.25 z/h = 0

Condition of Approval (if applicable): DATE: 02/19/2025



# SPECIAL SEISMIC CERTIFICATION CERTIFIED COMPONENT MATRIX

1801293-CR-001-R1



<b>Manufacturer:</b> Hitachi Energy USA Inc. (formerly ABB)	<b>TABLE 1</b>
<b>Model Line:</b> Transformer Product Family	

**Certified Product Construction Summary:**  
NEMA 3R Enclosure

**Certified Options Summary:**  
**Enclosure and Tank:** Stainless Steel (SS) or Carbon Steel (CS). **Windings:** Copper, Aluminum or Copper-Aluminum Mix.  
**Feed:** Radial or Loop. **Front:** Live or Dead. See Tables 5-7 for certified subcomponents.  
 Hitachi Energy Transformers can be rebranded as ABB, Square D (Schneider Electric), Siemens, GE, Eaton and Sunbelt.

**Mounting Configuration:**  
 Base mounted - rigid  
 Note: Installed mounting must be of similar configuration and equivalent strength and stiffness to those tested.

**Building Code:** CBC 2022      **Seismic Certification Limits:**  $S_{DS} = 2.25g$   $z/h = 0.0$        $I_p = 1.5$

Model Line	Model (kVA)	Dimensions (in)			Weight (lbs.)	Notes	UUT
		Depth	Width	Height			
1φ Padmount	10	45.0	42.0	36.0	1,366	UUT: Al windings, CS tank	7
	10	56.0	46.0	42.0	1,800		Interp.
	15	56.0	46.0	42.0	1,994		Interp.
	25	56.0	46.0	42.0	1,869		Interp.
	30	56.0	46.0	42.0	1,900		Interp.
	38	56.0	46.0	42.0	2,018		Interp.
	45	56.0	46.0	42.0	1,975		Interp.
	50	56.0	46.0	42.0	2,063		Interp.
	75	56.0	46.0	42.0	2,290		Interp.
	100	56.0	46.0	42.0	2,668		Interp.
	113	56.0	46.0	42.0	2,150		Interp.
	150	56.0	46.0	42.0	2,299		Interp.
	167	56.0	46.0	42.0	2,300		Interp.
	200	56.0	46.0	42.0	2,355		Interp.
	225	56.0	46.0	42.0	2,669		Interp.
250	56.0	46.0	42.0	2,725	UUT: Al windings, SS tank	6	

# SPECIAL SEISMIC CERTIFICATION CERTIFIED COMPONENT MATRIX

1801293-CR-001-R1



<b>Manufacturer:</b> Hitachi Energy USA Inc. (formerly ABB)	<b>TABLE 1</b>
<b>Model Line:</b> Transformer Product Family	

**Certified Product Construction Summary:**  
NEMA 3R Enclosure

**Certified Options Summary:**  
**Enclosure and Tank:** Stainless Steel (SS) or Carbon Steel (CS). **Windings:** Copper, Aluminum or Copper-Aluminum Mix.  
**Feed:** Radial or Loop. **Front:** Live or Dead. See Tables 5-7 for certified subcomponents.  
 Hitachi Energy Transformers can be rebranded as ABB, Square D (Schneider Electric), Siemens, GE, Eaton and Sunbelt.

**Mounting Configuration:**  
 Base mounted - rigid  
 Note: Installed mounting must be of similar configuration and equivalent strength and stiffness to those tested.

**Building Code:** CBC 2022      **Seismic Certification Limits:**  $S_{DS} = 2.25 g$   $z/h = 0.0$        $I_p = 1.5$

Model Line	Model (kVA)	Dimensions (in)			Weight (lbs.)	Notes	UUT
		Depth	Width	Height			
3 $\phi$ Padmount (Carbon Steel Tank)	75	50.0	57.0	48.0	2,300	UUT: Al windings, CS tank	1
	112	75.0	74.0	73.0	7,700		Interp.
	150	76.0	76.0	73.0	8,500		Interp.
	225	80.0	84.0	77.0	9,000		Interp.
	250	82.0	88.0	77.0	9,500		Interp.
	300	82.0	92.0	77.0	10,000		Interp.
	500	92.0	102.0	77.0	12,500		Interp.
	750	95.0	102.0	77.0	13,500		Interp.
	780	95.0	102.0	77.0	14,250		Interp.
	1000	95.0	102.0	81.0	15,000		Interp.
	1100	95.0	102.0	81.0	15,500		Interp.
	1200	95.0	102.0	81.0	16,000		Interp.
	1250	95.0	102.0	81.0	16,500		Interp.
	1500	110.0	135.0	81.0	18,200		Interp.
	1750	110.0	135.0	81.0	18,800		Interp.
	2000	116.0	135.0	94.0	19,000		Interp.
	2500	116.0	135.0	94.0	19,500		Interp.
	3000	116.0	135.0	94.0	19,850	UUT: Al-Cu windings, CS tank	15

# SPECIAL SEISMIC CERTIFICATION CERTIFIED COMPONENT MATRIX

1801293-CR-001-R1



<b>Manufacturer:</b> Hitachi Energy USA Inc. (formerly ABB)	<b>TABLE 1</b>
<b>Model Line:</b> Transformer Product Family	

**Certified Product Construction Summary:**  
NEMA 3R Enclosure

**Certified Options Summary:**  
**Enclosure and Tank:** Stainless Steel (SS) or Carbon Steel (CS). **Windings:** Copper, Aluminum or Copper-Aluminum Mix.  
**Feed:** Radial or Loop. **Front:** Live or Dead. See Tables 5-7 for certified subcomponents.  
 Hitachi Energy Transformers can be rebranded as ABB, Square D (Schneider Electric), Siemens, GE, Eaton and Sunbelt.

**Mounting Configuration:**  
 Base mounted - rigid  
 Note: Installed mounting must be of similar configuration and equivalent strength and stiffness to those tested.

**Building Code:** CBC 2022      **Seismic Certification Limits:**  $S_{DS} = 2.25 g$   $z/h = 0.0$        $I_p = 1.5$

Model Line	Model (kVA)	Dimensions (in)			Weight (lbs.)	Notes	UUT
		Depth	Width	Height			
3φ Padmount (Stainless Steel Tank)	75	50.0	57.0	48.0	2,300		Interp.
	112	72.0	74.0	73.0	7,700		Interp.
	150	76.0	76.0	73.0	8,500		Interp.
	225	80.0	84.0	77.0	9,000		Interp.
	250	82.0	88.0	77.0	9,500		Interp.
	300	82.0	92.0	77.0	10,000		Interp.
	500	89.0	102.0	77.0	12,500		Interp.
	750	89.0	102.0	77.0	13,500		Interp.
	780	89.0	102.0	77.0	1,425		Interp.
	1000	89.0	102.0	81.0	15,000		Interp.
	1100	89.0	102.0	81.0	15,500		Interp.
	1200	89.0	102.0	81.0	16,000		Interp.
	1250	89.0	102.0	81.0	16,500		Interp.
	1500	89.0	135.0	81.0	16,800		Interp.
	1750	89.0	135.0	81.0	17,000		Interp.
	2000	89.0	135.0	81.0	17,050		Interp.
	2500	89.0	135.0	81.0	17,090	UUT: Cu windings, SS tank	5

# SPECIAL SEISMIC CERTIFICATION CERTIFIED COMPONENT MATRIX

1801293-CR-001-R1



<b>Manufacturer:</b> Hitachi Energy USA Inc. (formerly ABB)	<b>TABLE 2</b>
<b>Model Line:</b> Transformer Product Family	

**Certified Product Construction Summary:**  
NEMA 3R Carbon Steel Enclosure and Tank

**Certified Options Summary:**  
**Windings:** Copper (all listed models) or Aluminum (model 225 only)  
 See Tables 5-7 for certified subcomponents.  
 Hitachi Energy Transformers can be rebranded as ABB, Square D (Schneider Electric), Siemens, GE, Eaton and Sunbelt.

**Mounting Configuration:**  
 Base mounted - rigid  
 Note: Installed mounting must be of similar configuration and equivalent strength and stiffness to those tested.

**Building Code:** CBC 2022      **Seismic Certification Limits:**  $S_{DS} = 2.25 g$   $z/h = 0.0$        $I_p = 1.5$

Model Line	Model (kVA)	Dimensions (in) <sup>1</sup>			Weight (lbs.) <sup>1</sup>	Notes	UUT
		Depth	Width	Height			
3φ Substation Radial Feed Live Front	225	67.0	59.0	73.0	4,900	UUT: Al windings, CS tank	3
	225	76.0	59.0	73.0	4,900		Interp.
	300	76.0	111.0	100.9	8,360		Interp.
	500	76.0	118.0	100.9	11,110		Interp.
	750	76.0	120.0	100.9	11,880		Interp.
	1000	83.0	124.0	112.9	14,190		Interp.
	1500	98.7	128.7	112.9	17,160		Interp.
	2000	98.7	128.7	112.9	19,140		Interp.
	2500	98.7	128.7	112.9	19,200		Interp.
	3000	93.0	69.0	85.0	15,900	UUT: Cu windings, CS tank	4
3000	98.7	128.7	119.9	19,200	UUT: Cu windings, CS tank	16	

**Notes:**  
 1. Values shown are typical sizes for model kVAs. Future changes to efficiency, accessories and customization can increase weight and dimensions shown up to maximum validated values for UUT16

# SPECIAL SEISMIC CERTIFICATION CERTIFIED COMPONENT MATRIX

1801293-CR-001-R1



<b>Manufacturer:</b> Hitachi Energy USA Inc. (formerly ABB)	<b>TABLE 3</b>
<b>Model Line:</b> Transformer Product Family	

**Certified Product Construction Summary:**  
NEMA 3R Stainless Steel Enclosure and Tank

**Certified Options Summary:**  
**Windings:** Copper (all listed models) or Aluminum (radial feed model 75 and loop feed model 45 only)  
 See Tables 5-7 for certified subcomponents.  
 Hitachi Energy Transformers can be rebranded as ABB, Square D (Schneider Electric), Siemens, GE, Eaton and Sunbelt.

**Mounting Configuration:**  
 Base mounted - rigid  
 Note: Installed mounting must be of similar configuration and equivalent strength and stiffness to those tested.

**Building Code:** CBC 2022      **Seismic Certification Limits:**  $S_{DS} = 2.25g$   $z/h = 0.0$        $I_p = 1.5$

Model Line	Model (kVA)	Dimensions (in)			Weight (lbs.)	Notes	UUT
		Depth	Width	Height			
3φ UCT Radial Feed Dead Front	75	32.0	68.0	53.0	3,640	UUT: Al windings, SS tank	9
	113	26.0	62.0	46.0	3,686		Interp.
	150	30.0	62.0	46.0	4,564		Interp.
	225	30.0	70.0	54.0	7,148		Interp.
	300	30.0	62.0	50.0	6,050		Interp.
	500	34.0	70.0	58.0	8,120		Interp.
	750	34.0	70.0	62.0	10,210		Interp.
	1000	36.0	70.0	62.0	1,070		Interp.
	1500	38.0	70.0	66.0	10,500		Interp.
3φ UCT Loop Feed Dead Front	45	30.0	56.0	38.0	3,200		Interp.
	50	30.0	58.0	46.0	3,828		Interp.
	75	30.0	70.0	46.0	4,600		Interp.
	113	30.0	58.0	42.0	3,608		Interp.
	150	34.0	70.0	54.0	5,795		Interp.
	225	30.0	60.0	46.0	4,657		Interp.
	300	34.0	70.0	58.0	6,406		Interp.
	500	34.0	70.0	58.0	7,980		Interp.
	750	38.0	70.0	62.0	8,960		Interp.
	1000	36.0	70.0	62.0	10,305		Interp.
	1500	57.0	79.0	76.0	10,500	UUT: Cu windings, SS tank	8



# SPECIAL SEISMIC CERTIFICATION CERTIFIED COMPONENT MATRIX

1801293-CR-001-R1



<b>Manufacturer:</b> Hitachi Energy USA Inc. (formerly ABB)	<b>TABLE 4</b>
<b>Model Line:</b> Transformer Product Family	

**Certified Product Construction Summary:**  
NEMA 3R Stainless Steel Enclosure and Tank

**Certified Options Summary:**  
**Windings:** Copper, Aluminum or Mix Copper-Aluminum.  
 See Table 5-7 for certified subcomponents. SEOR responsible for anchorage design.  
 Hitachi Energy Transformers can be rebranded as ABB, Square D (Schneider Electric), Siemens, GE, Eaton and Sunbelt.

**Mounting Configuration:**  
 Base mounted - rigid  
 Note: Installed mounting must be of similar configuration and equivalent strength and stiffness to those tested.

**Building Code: CBC 2022**      **Seismic Certification Limits:**       $S_{DS} = 2.25 g$      $z/h = 0.0$        $I_p = 1.5$

Model Line	Model (kVA)	Dimensions (in)			Weight (lbs.)	Notes	UUT
		Depth	Width	Height			
1φ Horizontal	25	24.0	44.0	29.0	1,096	UUT: Al windings, SS tank	10
	50	24.0	40.0	30.0	1,074		Interp.
	75	28.0	40.0	30.0	1,513		Interp.
	100	24.0	40.0	32.0	1,393		Interp.
	167	24.0	40.0	42.0	2,223	UUT: Al-Cu windings, SS tank	11
1φ DUP Horizontal	25	24.0	47.0	32.0	1,513	UUT: Al windings, SS tank	12
	50	24.0	41.0	30.0	1,452		Interp.
	75	28.0	40.0	30.0	1,594		Interp.
	100	30.0	51.0	38.0	2,513	UUT: Al-Cu windings, SS tank	13

# SPECIAL SEISMIC CERTIFICATION CERTIFIED SUBCOMPONENT MATRIX

1801293-CR-001-R1



<b>Manufacturer:</b> Hitachi Energy USA Inc. (formerly ABB)	<b>Table Description:</b> Electrical Bushings	<b>TABLE 5</b>
<b>Model Line:</b> Transformer Product Family		

<b>Building Code:</b> CBC 2022	<b>Seismic Certification Limits:</b> $S_{DS} = 2.25 g$ $z/h=0.0$	$I_p = 1.5$
--------------------------------	------------------------------------------------------------------	-------------

Component Type	Manufacturer	Model	Description	Notes	UUT
Bushing - HV	ABB	2B10536H01	21.1 kV 200A - INTEGRAL STUD	UUT3: Qty.(6), UUT4: Qty.(3), UUT6: Qty.(2), UUT14: Qty.(3)	3, 4, 6, 14
		1ZUA276301-AEB	25kV 200A BUSHING, 150BIL REM STUD	Qty.(2)	15
	Cooper	2637019B02	15.2/8.3kV 600A BUSHING	Qty. (1)	15
		DB635B150	35kV 600A BUSHING	Qty. (1)	15
	Crosslink Technology, Inc.	90-345	15kV 450A EPOXY BUSHING, L-FRONT	Qty. (1)	15
		90-340	34.5kV 350A EPOXY BUSHING, L-FRONT	Qty. (1)	15
		30C2554	CROSSLINK L-FRONT 350A 34.5KV EPOXY	Qty. (3)	16
	ESNA/Elastimold	K1601-PC-T1	200A (589B821H10)	UUT8: Qty.(6), UUT9: Qty.(3), UUT10: Qty.(4), UUT11: Qty.(4), UUT12: Qty.(6), UUT13: Qty.(6)	8, 9, 10, 11, 12, 13
		K650S1-NF	25kV 600A BUSHING	Qty. (1)	15
		750S1-NF	35kV 600A BUSHING	Qty. (1)	15
	H-J Enterprises	28C2465G01	15kV 200A PORC BUSHING W/2 HL SPD		Extrap.
		28C3929H01	15kV 600A PORC BUSHING W/2 HL SPD	Qty.(3) Brass Alloy Spade Tested	1
		30C2137H01	15kV 600A PORC BUSHING W/ SNGL EYEBOLT		Interp.
		30C1975H01	15kV 800A PORC BUSHING W/ 2 HL SPD		Interp.
		28C2471G01	25kV 200A PORC BUSHING W/ SNGL EYEBOLT		Interp.
		30C1926H01	25kV 200A PORC BUSHING W/ SNGL EYEBOLT	Qty. (2)	7
	Warco	28C5998H01	15kV 110A PORC BUSHING W/2 HL SPD		Interp.
		29C1559H01	25kV 785A PORC BUSHING W/4 HL SPD		Interp.
		29C2098H01	35kV 110A PORC BUSHING W/2 HL SPD		Interp.
		29C5629H01	35kV 110A PORC BUSHING W/4 HL SPD		Interp.
1C19264H01		34.5kV 55A PORC BUSHING W/ SNGL EYEBOLT		Interp.	

# SPECIAL SEISMIC CERTIFICATION CERTIFIED SUBCOMPONENT MATRIX

1801293-CR-001-R1



<b>Manufacturer:</b> Hitachi Energy USA Inc. (formerly ABB)	<b>Table Description:</b> Electrical Bushings	<b>TABLE 5</b>
<b>Model Line:</b> Transformer Product Family		

<b>Building Code:</b> CBC 2022	<b>Seismic Certification Limits:</b> $S_{DS} = 2.25 g$ $z/h = 0.0$	$I_p = 1.5$
--------------------------------	--------------------------------------------------------------------	-------------

Component Type	Manufacturer	Model	Description	Notes	UUT
Bushings - HV	Warco	28C4488H01	35kV 460A PORC BUSHING W/2 HL SPD	Qty.(3) Bronze Spade Tested	2
		29C5672H01	35kV 460A PORC BUSHING W/4 HL SPD	Qty.(2) Cu Spades, (1) Bronze Alloy Spade	5
		29C4357H01	35kV 600A PORC BUSHING W/2 HL SPD		Extrap.
Bushings - LV	ABB	2B10357H01	0.625" DIA CU	UUT4: Qty.(4), UUT7: Qty.(3)	4, 7
		2B10567H01	1.00" DIA CU	Qty.(3)	14
		28C2288H01	1.25" DIA CU	Qty.(3)	6
	Central Moloney	2B12889H01	0.625" DIA CU	UUT10: Qty.(2), UUT12: Qty.(3)	10, 12
		1B24954H01	1.00" DIA CU	UUT11: Qty.(4), UUT13: Qty.(3)	11, 13
		1B24955H01	1.25" DIA CU	UUT8: Qty.(4), UUT9: Qty.(4)	8, 9
	Crosslink Technology, Inc.	1C23252H01	875A CU BUSH, EPOXY INSULA 4-HOLE		Extrap.
		28C4159H01	3100A CU BUSH, EPOXY INSULA 6-HOLE		Extrap.
		29C1057H01	3150A AL BUSH, EPOXY INSUL, 4-HOLE		Extrap.
		28C1016H01	3150A AL BUSH, EPOXY INSUL, 6-HOLE	Qty. (4)	2
		28C1017H01	3150A AL BUSH, EPOXY INSUL, 8-HOLE		Interp.
		28C1018H01	3150A LV Bushing 10 Hole		Interp.
		28C1022H01	4300A CU BUSH, EPOXY INSULA 6-HOLE	Qty. (4)	3
		28C1079H01	4300A LV Bushing 6 Hole		Interp.
		28C1023H01	4300A CU BUSH, EPOXY INSULA 8-HOLE		Interp.
		28C1024H01	4300A CU BUSH, EPOXY INSULA 10-HOLE		Interp.
		28C1080H01	4300A CU BUSH, EPOXY INSULA 10-HOLE		Interp.
28C4372H01	4512A CU BUSH, EPOXY INSULA 6-HOLE		Interp.		
28C4822H01	4512A LV Bushing 10 Hole		Interp.		
28C4192H01	5400A CU BUSH, EPOXY INSULA 6-HOLE		Interp.		

# SPECIAL SEISMIC CERTIFICATION CERTIFIED SUBCOMPONENT MATRIX

1801293-CR-001-R1



<b>Manufacturer:</b> Hitachi Energy USA Inc. (formerly ABB)	<b>Table Description:</b> Electrical Bushings	<b>TABLE 5</b>
<b>Model Line:</b> Transformer Product Family		

<b>Building Code:</b> CBC 2022	<b>Seismic Certification Limits:</b> $S_{DS} = 2.25 g$ $z/h=0.0$	$I_p = 1.5$
--------------------------------	------------------------------------------------------------------	-------------

Component Type	Manufacturer	Model	Description	Notes	UUT
Bushing - LV	Crosslink Technology, Inc.	29C4310H01	5400A CU BUSH, EPOXY INSULA 6-HOLE		Interp.
		28C4566H01	5400A LV Bushing 8 Hole		Interp.
		30C4663H01	5400A LV Bushing 8 Hole		Interp.
		28C4565H01	5400A CU BUSH, EPOXY INSULA 10-HOLE		Interp.
		29C2998H01	5400A LV Bushing 12 Hole		Interp.
		29C2461H01	5400A LV Bushing 14 Hole		Interp.
		29C4583H01	5400A LV BUSH, 18 HOLE, CU SPADE	Qty. (1)	15
	Daheng	30C5033H01	3150A LV Bushing 6 Hole		Extrap.
		30C5034H01	3150A LV Bushing 8 Hole		Extrap.
		29C4432H01	3150A AL BUSH, EPOXY INSUL, 10-HOLE	Qty. (4)	5
		30C5035H01	3150A LV Bushing 10 Hole		Interp.
		30C5036H01	3150A LV Bushing 12 Hole		Interp.
		30C5037H01	3150A LV bushing, 16 HOLE	Qty. (1)	15
		30C5038H01	3150A LV Bushing 20 Hole		Interp.
		30C5193H01	4300A LV Bushing, 6 HOLE	Qty. (1)	15
		30C5039H01	4300A LV Bushing 8 Hole		Interp.
		30C5040H01	4300A LV Bushing 10 Hole		Interp.
		30C5041H01	4300A LV Bushing 12 Hole		Interp.
		30C5042H01	4300A LV Bushing 16 Hole		Interp.
		30C5238H01	4300A LV Bushing, 18 HOLE	Qty. (1)	15
	ESNA/Elastimold	1601A4CS937	15KV INSERT BUSHING	Qty. (1)	15
	H-J Enterprises	28C4655H01	5400A CU-BUSH, EPOXY INSUL,8-HOLE	Qty. (4)	1
28C2810		15KV 600A 6 HOLE SPD PORCELAIN BUSHI	Qty. (4)	16	

# SPECIAL SEISMIC CERTIFICATION CERTIFIED SUBCOMPONENT MATRIX

1801293-CR-001-R1



<b>Manufacturer:</b> Hitachi Energy USA Inc. (formerly ABB)	<b>Table Description:</b> Electrical Bushings	<b>TABLE 5</b>
<b>Model Line:</b> Transformer Product Family		

<b>Building Code:</b> CBC 2022	<b>Seismic Certification Limits:</b> $S_{DS} = 2.25 g$ $z/h = 0.0$	$I_p = 1.5$
--------------------------------	--------------------------------------------------------------------	-------------

Component Type	Manufacturer	Model	Description	Notes	UUT
Bushing - Inserts	ESNA/Elastimold	1B23941H01	15 kV class	Qty. (3)	7
		1B23942H01	25 kV class	Qty. (2)	6
		4931B50H01	21.1/36.6 kV class	Qty. (3)	14
Bushing - Standoff	H-J Enterprises	POB-014	5.0 kV, 60 kV BIL	Qty. (1)	5
		POB-015	7.5 kV, 75 kV BIL		Interp.
		POB-016	8.7 kV, 95 kV BIL		Interp.
		POB-017	25 kV, 110 kV BIL		Interp.
		PO 0097-001	25 kV, 150 kV BIL	UUT5: Qty. (2), UUT7: Qty. (1)	5, 7

# SPECIAL SEISMIC CERTIFICATION CERTIFIED SUBCOMPONENT MATRIX

1801293-CR-001-R1



<b>Manufacturer:</b> Hitachi Energy USA Inc. (formerly ABB)	<b>Table Description:</b> Fuses	<b>TABLE 6</b>
<b>Model Line:</b> Transformer Product Family		

<b>Building Code:</b> CBC 2022	<b>Seismic Certification Limits:</b> $S_{DS} = 2.25 g$ $z/h=0.0$	$I_p = 1.5$
--------------------------------	------------------------------------------------------------------	-------------

Component Type	Manufacturer	Model	Description	Notes	UUT
Fusing (Isolation Link)	ABB	1B25455H01	ISOLATION LINK 1C11130G01 A1		Extrap.
		1B25455H02	ISOLATION LINK 1C11130G02 A2	Qty. (1)	7
		1B25455H03	ISOLATION LINK 1C11130G03 A3		Interp.
		1B25455H05	ISOLATION LINK 1C11130G05 A5		Interp.
		1B25455H06	ISOLATION LINK 1C11130G06 A6		Interp.
		1B25455H07	ISOLATION LINK 1C11130G07 A7	Qty. (1)	9
		RTE	3637803B01	ISOLATION LINK - MAGNEX E01	
	3637803B08		ISOLATION LINK - MAGNEX E03	Qty. (3)	10
	3637803B02		ISOLATION LINK - MAGNEX E06		Interp.
	3637803B09		ISOLATION LINK - MAGNEX E10		Interp.
	3637803B10		ISOLATION LINK - MAGNEX E12		Interp.
	3637803B03		ISOLATION LINK - MAGNEX E18/E25	Qty. (3)	11
	Fusing (Link Bay-O-Net)	RTE	3A18440H01	125A MFR'S ID: 4038361C05CB	Qty. (3)
3637803B05			ISOLATION LINK - MAGNEX E30/E40/E50		Extrap. <sup>1</sup>
Expulsion Fuse	ABB	592B581G/5750D27G	15.0 kV LINK	Qty.(1) 5750D27G14 Tested	5
		779C667G	19.9kV LINK		Interp.
		779G667G	23.0kV LINK		Interp.
		345B995G	34.5kV LINK	Qty.(2) 345B995G32 Tested	5
	ERMCO	9F54DAA	5.2 kV LINK		Extrap.
		9F54DAB	5.2 kV LINK		Extrap.

**Notes:**  
1. Subcomponent size and weight match tested subcomponent

# SPECIAL SEISMIC CERTIFICATION CERTIFIED SUBCOMPONENT MATRIX

1801293-CR-001-R1



<b>Manufacturer:</b> Hitachi Energy USA Inc. (formerly ABB)	<b>Table Description:</b> Fuses	<b>TABLE 6</b>
<b>Model Line:</b> Transformer Product Family		

<b>Building Code:</b> CBC 2022	<b>Seismic Certification Limits:</b> $S_{DS} = 2.25 g$ $z/h = 0.0$	$I_p = 1.5$
--------------------------------	--------------------------------------------------------------------	-------------

Component Type	Manufacturer	Model	Description	Notes	UUT
Expulsion Fuse	ERMCO	9F54DBA	8.4 kV LINK		Extrap.
		9F54DBB	8.4 kV LINK		Extrap.
		9F54DDA	15.0 kV LINK		Extrap.
		9F54DDA	15.0 kV LINK		Extrap.
		9F54DCA	23.0 kV LINK	Qty.(3) 9F54DCA701 Tested	12
		9F54DCB	23.0 kV LINK	Qty.(3) 9F54DCB001 Tested	12
Expulsion Fuse (Type-DO-III)	ABB	3A21026H03	3AMP DUAL SEN FUSE 1B11144G03		Extrap.
		3A21027H03	5AMP DUAL ELE FUSE 1B11145G03		Extrap.
		3A21027H04	6AMP DUAL ELE FUSE 1B11145G04		Extrap.
		3A21025H04	6AMP CUR SEN FUSE 1B11143G04		Extrap.
		3A21027H05	8AMP DUAL ELE FUSE 1B11145G05	Qty. (1)	9
		3A21026H05	8AMP DUAL SEN FUSE 1B11144G05	Qty. (2)	9
		3A21025H06	10AMP CUR SEN FUSE 1B11143G06	Qty. (1)	7
		3A21027H06	12AMP DUAL ELE FUSE 1B11145G06		Interp.
		3A21027H07	15AMP DUAL ELE FUSE 1B11145G07		Interp.
		3A21026H08	15AMP DUAL SEN FUSE 1B11144G08		Interp.
		3A21025H08	15AMP CUR SEN FUSE 1B11143G08		Interp.
		3A21027H09	25AMP DUAL ELE FUSE 1B11145G09		Interp.
		3A21026H10	25AMP DUAL SEN FUSE 1B11144G10		Interp.
		3A21025H10	25AMP CUR SEN FUSE 1B11143G10		Interp.
		3A21027H11	40AMP DUAL ELE FUSE 1B11145G11		Interp.

**Notes:**  
1. Subcomponent size and weight match tested subcomponent

# SPECIAL SEISMIC CERTIFICATION CERTIFIED SUBCOMPONENT MATRIX

1801293-CR-001-R1



<b>Manufacturer:</b> Hitachi Energy USA Inc. (formerly ABB)	<b>Table Description:</b> Fuses	<b>TABLE 6</b>
<b>Model Line:</b> Transformer Product Family		

<b>Building Code:</b> CBC 2022	<b>Seismic Certification Limits:</b> $S_{DS} = 2.25 g$ $z/h = 0.0$	$I_p = 1.5$
--------------------------------	--------------------------------------------------------------------	-------------

Component Type	Manufacturer	Model	Description	Notes	UUT
Expulsion Fuse (Type-DO-III)	ABB	3A21025H12	40AMP CUR SEN FUSE 1B11143G12		Interp.
		3A21027H12	50AMP DUAL ELE FUSE 1B11145G12		Interp.
		3A21026H12	50AMP DUAL SEN FUSE 1B11144G12		Interp.
		3A21026H14	65AMP DUAL SEN FUSE 1B11144G14		Interp.
		3A21025H14	65AMP CUR SEN FUSE 1B11143G14	Qty. (1)	6
		3A21025H16	100AMP CUR SEN FUSE 1B11143G16		Extrap. <sup>1</sup>
		3A21025H17	140AMP CUR SEN FUSE 1B11143G17		Extrap. <sup>1</sup>
Current-Limiting Fuse	Cooper	CBUC38140D100	38 kV, 140A	Qty. (2)	15
	Hi-Tech (30A-165A)	HTSS232	8.3 kV	Qty.(3) HTSS232040 Tested	9
		HTSS240	17.2 kV	Qty.(3) HTSS242150 Tested	14
		HTSS242	15.5 kV		Interp.
		HTSS252	23.0 kV	Qty.(2) HTSS252100 Tested	5
		HTSS372	38.0 kV	UUT5: Qty.(2) HTSS372100 Tested, UUT15: Qty.(2) HTSS372165 Tested	5, 15

**Notes:**  
1. Subcomponent size and weight match tested subcomponent



# SPECIAL SEISMIC CERTIFICATION CERTIFIED SUBCOMPONENT MATRIX

1801293-CR-001-R1



<b>Manufacturer:</b> Hitachi Energy USA Inc. (formerly ABB)	<b>Table Description:</b> Misc. Electrical Components	<b>TABLE 7</b>
<b>Model Line:</b> Transformer Product Family		

<b>Building Code:</b> CBC 2022	<b>Seismic Certification Limits:</b> $S_{DS} = 2.25 g$ $z/h = 0.0$	$I_p = 1.5$
--------------------------------	--------------------------------------------------------------------	-------------

Component Type	Manufacturer	Model	Description	Notes	UUT
Switch	ABB	1C23376H01	100A 1 DECK DV SWITCH	Qty. (1)	6
		1C08872H01	125A 3 DECK TAP CHANGES	UUT1: Qty. (1), UUT5: Qty. (1)	1, 5
		1C08823H01	300A 1 DECK LBOR	Qty. (1)	7
		1C08825H01	300A 3 DECK LBOR	UUT5: Qty. (1), UUT6: Qty. (1)	5, 6
		1C08872H01	3PH TC	Qty. (1)	1
		29C2190H01	3PH TC SILVER CONTACTS	UUT3: Qty. (1), UUT4: Qty. (1)	3, 4
		5543C55G47	300A 3 DECK LBOR W/ HANDLE	UUT8-11: Qty. (1) each, UUT13: Qty. (1)	8-11, 13
	Cooper	LS4BH3T12M	T_BLADE, 4 POSITION SWITCH, "LS4" FAMILY, LOAD BREAK SWITCH	Qty. (1)	15
		2237179C02M	300A TAP CHANGES	Qty. (1)	15
	RTE	8608C31H01	150A 6 DECK DV SWITCH	UUT4: Qty. (1), UUT8: Qty. (1)	4, 8
1B24985H01		150A 3 DECK DV SWITCH	UUT10: Qty. (1), UUT11: Qty. (1), UUT13: Qty. (1)	10, 11, 13	
Breaker	ERMCO	1B24028H01	T-12 BREAKER	Qty. (1)	7
		28C2517H01	T-13 BREAKER		Interp.
		2B11057H01	T-15 BREAKER	Qty. (1)	13
	RTE	29C2161H01	MAGNEX INTERRUPTER	Qty. (1)	10
		29C4597H01	MAGNEX INTERRUPTER	Qty. (1)	11
Gauges	Elmek	572015-00-04	LIQUID LEVEL GAUGE	Qty. (1)	5
	Heartland	HLG-1065	LIQUID SIGHT GAUGE	UUT7-13: Qty. (1) each	7-13
	HJ	INT001-001K-SS	VACUUM PRESSURE GAUGE	UUT1: Qty. (1), UUT2: Qty. (1), UUT4: Qty. (4)	1, 2, 4
	Qualitrol	QUAL 020-550-01	LIQUID LEVEL GAUGE	UUT4: Qty. (1), UUT6: Qty. (1)	4, 6
		QUAL 151-100-01	LIQUID TEMPERATURE GAUGE	UUT2: Qty. (1), UUT5: Qty. (1)	2, 5
		QUAL 030-017-03	LIQUID LEVEL GAUGE	UUT1: Qty. (1), UUT2: Qty. (1)	1, 2

# SPECIAL SEISMIC CERTIFICATION CERTIFIED SUBCOMPONENT MATRIX

1801293-CR-001-R1



<b>Manufacturer:</b> Hitachi Energy USA Inc. (formerly ABB)	<b>Table Description:</b> Misc. Electrical Components	<b>TABLE 7</b>
<b>Model Line:</b> Transformer Product Family		

<b>Building Code:</b> CBC 2022	<b>Seismic Certification Limits:</b> $S_{DS} = 2.25 g$ $z/h=0.0$	$I_p = 1.5$
--------------------------------	------------------------------------------------------------------	-------------

Component Type	Manufacturer	Model	Description	Notes	UUT
Pressure Relief	Hardware	3A25842H01	PRESSURE RELIEF	UUT10-13: Qty. (1) each	10-13
	Qualitrol	QUAL 201-020-01	PRESSURE RELIEF	UUT1-5: Qty. (1) each, UUT15: Qty. (1)	1-5, 15
		QUAL 202-014-02	PRESSURE RELIEF	UUT8 & 9: Qty. (1) each	8, 9
		QUAL 208-60E	PRESSURE RELIEF	Qty. (1)	15
Control Cabinet	Weigmann	8D12182M13	CONTROL CABINET	Qty. (1)	1
	South Star Corp.	3D50040	CONTROL BOX AND WIRING	Qty. (1)	16
Fans	Krenz Vent	A-9875	12" FAN	Qty. (1)	1
		...			Interp.
		A-8477	16" FAN	Qty. (1)	1
APID Pressure Rise Relay	Qualitrol	910-010-33	RAPID RISE RELAY	Qty. (1)	15
Current Transformer	ABB	1A3389	B/O CT 5485:5 MNTG INSIDE TANK	Qty. (1)	15
		2B12407	2500/5 C200 CABLE MOUNTED CT	Qty. (1)	16
Thermometer	Qualitrol	120-005-03	DIRECT MT THERM	Qty. (1)	15
Under Oil Arrester	Cooper	CLU23C36	36kV, "CLU" Arresters	Qty. (1)	15

# UNIT UNDER TEST (UUT) SUMMARY SHEET

1801293-CR-001-R1



**Manufacturer:** Hitachi Energy USA Inc. (formerly ABB)

**Model Line:** Transformer Product Family

UUT	Unit Description (mounting)	Report Number (UUT#)	Testing Lab	Year Tested	ISO 17025 Accredited?	S <sub>DS</sub>	z/h	I <sub>p</sub>
1	75kVA 3φ Padmount (NEMA 3R Painted Carbon Steel Enclosure w/o skirt)	EL:9243 (Transformer "C")	Clark Testing	2010	No <sup>1</sup>	2.25	0.0	1.5
2	3000kVA 3φ Padmount (NEMA 3R Painted Carbon Steel Enclosure w/o skirt)	EL:9243 (Transformer "B")	Clark Testing	2010	No <sup>1</sup>	2.25	0.0	1.5
3	225kVA Unit Substation (NEMA 3R Painted Carbon Steel Enclosure w/o skirt)	EL:9243 (Transformer "A")	Clark Testing	2010	No <sup>1</sup>	2.25	0.0	1.5
4	3000kVA Unit Substation (NEMA 3R Painted Carbon Steel Enclosure w/o skirt)	EL:9295	Clark Testing	2010	No <sup>1</sup>	2.25	0.0	1.5
5	2500kVA 3φ Padmount & Unit Substation (NEMA 3R Painted Carbon Steel Enclosure)	13512 (UUT5)	Environmental Testing Lab (ETL)	2014	Yes	2.25	0.0	1.5
6	250kVA 1φ Padmount & Unit Substation (NEMA 3R Painted Carbon Steel Enclosure)	13512 (UUT5)	Environmental Testing Lab (ETL)	2014	Yes	2.25	0.0	1.5
7	10kVA 1φ Padmount & Unit Substation (NEMA 3R Painted Carbon Steel Enclosure)	13512 (UUT5)	Environmental Testing Lab (ETL)	2014	Yes	2.25	0.0	1.5
8	1500kVA 3φ UCT (NEMA 3R Stainless Steel Enclosure w/o skirt)	13512 (UUT5)	Environmental Testing Lab (ETL)	2014	Yes	2.25	0.0	1.5
9	75VA 3φ UCT (NEMA 3R Stainless Steel Enclosure w/o skirt)	13512 (UUT5)	Environmental Testing Lab (ETL)	2014	Yes	2.25	0.0	1.5
10	25kVA 1φ Horizontal (NEMA 3R Stainless Steel Enclosure w/o skirt)	13512 (UUT5)	Environmental Testing Lab (ETL)	2014	Yes	2.25	0.0	1.5
11	167kVA 1φ Horizontal (NEMA 3R Stainless Steel Enclosure w/o skirt)	13512 (UUT5)	Environmental Testing Lab (ETL)	2014	Yes	2.25	0.0	1.5

**Notes:**

# UNIT UNDER TEST (UUT) SUMMARY SHEET


1801293-CR-001-R1



**Manufacturer:** Hitachi Energy USA Inc. (formerly ABB)

**Model Line:** Transformer Product Family

UUT	Unit Description (mounting)	Report Number (UUT#)	Testing Lab	Year Tested	ISO 17025 Accredited?	S <sub>DS</sub>	z/h	I <sub>P</sub>
12	25kVA 1φ DUP Horizontal (NEMA 3R Stainless Steel Enclosure w/o skirt)	13512 (UUT12)	Environmental Testing Lab (ETL)	2014	Yes	2.25	0.0	1.5
13	100kVA 1φ DUP Horizontal (NEMA 3R Stainless Steel Enclosure w/o skirt)	13512 (UUT13)	Environmental Testing Lab (ETL)	2014	Yes	2.25	0.0	1.5
14	780kVA 3φ Padmount & Unit Substation (NEMA 3R Painted Carbon Steel Enclosure w/o skirt)	13512 (UUT14)	Environmental Testing Lab (ETL)	2014	Yes	2.25	0.0	1.5
15	3000kVA 3φ Padmount (NEMA 3R Painted Carbon Steel Enclosure & Tank w/o skirt)	1801293-TR-001 (UUT15)	ERDC-CERL	2018	No <sup>1</sup>	2.25	0.0	1.5
16	3000kVA 3φ Unit Substation (NEMA 3R Painted Carbon Steel Enclosure w/o skirt)	2301373-TR-001 (UUT1)	ERDC-CERL	2024	No <sup>1</sup>	2.25	0.0	1.5



**Notes:**  
**1.** ERDC-CERL is not ISO/IEC 17025 accredited but has been reviewed by TRU Compliance and found to meet the applicable requirements of ISO/IEC 17025 testing. Review form is on file with TRU Compliance .

# UNIT UNDER TEST (UUT) SUMMARY SHEET



1801293-CR-001-R1

<b>Manufacturer:</b> Hitachi Energy USA Inc. (formerly ABB)	<b>UUT 1</b>
<b>Model Line:</b> Transformer Product Family	
<b>Model Number:</b> 75kVA 3φ Padmount <span style="float: right;"><b>Serial Number:</b> 07J804259</span>	

**Product Construction Summary:**  
NEMA 3R Painted Carbon Steel Enclosure without skirt.

**Options/Subcomponent Summary:**  
Carbon Steel Tank. Aluminum Windings. Phase: 3φ. Radial Feed. Dead Front.  
**Bushing-HV:** H-J Enterprises (28C3929H01 x3); **Bushing-LV:** H-J Enterprises (28C4655H01 x4);  
**Switch:** ABB (1C08872H01, 1C08872H01); **Gauges:** HJ (INT001-001K-SS), Qualitrol (QUAL 030-017-03);  
**Pressure Relief:** Qualitrol (QUAL 201-020-01); **Control Cabinet:** Weigmann (8D12182M13); **Fans:** Krenz Vent (A-9875, A-8477)

**UUT Properties**

Weight (lbs.)	Dimension (in)			Lowest Natural Frequency (Hz)		
	Depth	Width	Height	Front-Back	Side-Side	Vertical
2,300	50.2	56.9	48.3	26.1	26.9	>33.3

**UUT Highest Passed Seismic Run Information**

Building Code	Test Criteria	S <sub>ds</sub> (g)	z/h	I <sub>p</sub>	A <sub>FLX-H</sub> (g)	A <sub>RIG-H</sub> (g)	A <sub>FLX-V</sub> (g)	A <sub>RIG-V</sub> (g)
CBC 2022, IBC 2021	ICC-ES AC156 (2010)	2.25	0.0	1.5	2.25	0.90	1.50	0.60

**Test Mounting Details:** (Test Report: EL:9243 (Transformer "C"))



UUT1 was base - mounted rigid to the table using four (4) 1"-8 Grade 5 hex head bolts with flat washers and lock washers. Torqued to 250 ft-lbs.  
Unit maintained structural integrity and remained functional per manufacturer requirement after shake table test.  
Contents were included in testing per operating conditions.

# UNIT UNDER TEST (UUT) SUMMARY SHEET

1801293-CR-001-R1



<b>Manufacturer:</b> Hitachi Energy USA Inc. (formerly ABB)	<b>UUT 2</b>
<b>Model Line:</b> Transformer Product Family	
<b>Model Number:</b> 3000kVA 3φ Padmount	
<b>Serial Number:</b> JC153380001 (10J482001)	

**Product Construction Summary:**  
NEMA 3R Painted Carbon Steel Enclosure without skirt.

**Options/Subcomponent Summary:**  
Carbon Steel Tank. Aluminum Windings. Phase: 3φ. Loop Feed. Dead Front.  
**Bushing-HV:** Warco (28C4488H01 x3); **Bushing-LV:** Crosslink Technology, Inc. (28C1016H01 x4);  
**Gauges:** HJ (INT001-001K-SS), Qualitrol (QUAL 151-100-01, QUAL 030-017-03); **Pressure Relief:** Qualitrol (QUAL 201-020-01);

**UUT Properties**

Weight (lbs.)	Dimension (in)			Lowest Natural Frequency (Hz)		
	Depth	Width	Height	Front-Back	Side-Side	Vertical
14,400	74.8	100.6	72.0	14.3	25.2	>33.3

**UUT Highest Passed Seismic Run Information**

Building Code	Test Criteria	S <sub>DS</sub> (g)	z/h	I <sub>p</sub>	A <sub>FLX-H</sub> (g)	A <sub>RIG-H</sub> (g)	A <sub>FLX-V</sub> (g)	A <sub>RIG-V</sub> (g)
CBC 2022, IBC 2021	ICC-ES AC156 (2010)	2.25	0.0	1.5	2.25	0.90	1.50	0.60

**Test Mounting Details:** (Test Report: EL:9243 (Transformer "B"))



UUT2 was base - mounted rigid to the table using four (4) 1"-8 and two (2) 1/2"-13 Grade 5 hex head bolts with flat washers and lock washers. 1" mounting hardware was torqued to 250 ft-lbs and 1/2" mounting hardware was torqued to 75 ft-lbs. Unit maintained structural integrity and remained functional per manufacturer requirement after shake table test. Contents were included in testing per operating conditions.

# UNIT UNDER TEST (UUT) SUMMARY SHEET

1801293-CR-001-R1



<b>Manufacturer:</b> Hitachi Energy USA Inc. (formerly ABB)	<b>UUT 3</b>
<b>Model Line:</b> Transformer Product Family	
<b>Model Number:</b> 225kVA Unit Substation	
<b>Serial Number:</b> JC344180001 (10J482031)	

**Product Construction Summary:**  
NEMA 3R Painted Carbon Steel Enclosure without skirt.

**Options/Subcomponent Summary:**  
Carbon Steel Tank. Aluminum Windings. Phase: 3φ. Radial Feed. Live Front.  
**Bushing-HV:** ABB (2B10536H01 x6); **Bushing-LV:** Crosslink Technology, Inc. (28C1022H01 x4); **Switch:** ABB (29C2190H01);  
**Pressure Relief:** Qualitrol (QUAL 201-020-01)

**UUT Properties**

Weight (lbs.)	Dimension (in)			Lowest Natural Frequency (Hz)		
	Depth	Width	Height	Front-Back	Side-Side	Vertical
4,900	67.3	59.0	73.0	13.1	14.3	>33.3

**UUT Highest Passed Seismic Run Information**

Building Code	Test Criteria	S <sub>DS</sub> (g)	z/h	I <sub>P</sub>	A <sub>FLX-H</sub> (g)	A <sub>RIG-H</sub> (g)	A <sub>FLX-V</sub> (g)	A <sub>RIG-V</sub> (g)
CBC 2022, IBC 2021	ICC-ES AC156 (2010)	2.25	0.0	1.5	2.25	0.90	1.50	0.60

**Test Mounting Details:** (Test Report: EL:9243 (Transformer "A"))



UUT3 was base - mounted rigid to the table using four (4) 1"-8 Grade 5 hex head bolts with flat washers and lock washers. Torqued to 250 ft-lbs.  
Unit maintained structural integrity and remained functional per manufacturer requirement after shake table test.  
Contents were included in testing per operating conditions.

# UNIT UNDER TEST (UUT) SUMMARY SHEET

1801293-CR-001-R1



<b>Manufacturer:</b> Hitachi Energy USA Inc. (formerly ABB)	<b>UUT 4</b>
<b>Model Line:</b> Transformer Product Family	
<b>Model Number:</b> 3000kVA Unit Substation	
<b>Serial Number:</b> JC530650001 (999998)	

**Product Construction Summary:**  
NEMA 3R Painted Carbon Steel Enclosure without skirt.

**Options/Subcomponent Summary:**  
Carbon Steel Tank. Copper Windings. Phase: 3φ. Radial Feed. Live Front.  
**Bushing-HV:** ABB (2B10536H01 x3); **Bushing-LV:** ABB (2B10357H01 x4); **Switch:** ABB (29C2190H01), RTE (8608C31H01);  
**Gauges:** HJ (INT001-001K-SS x4), Qualitrol (QUAL 020-550-01); **Pressure Relief:** Qualitrol (QUAL 201-020-01);

**UUT Properties**

Weight (lbs.)	Dimension (in)			Lowest Natural Frequency (Hz)		
	Depth	Width	Height	Front-Back	Side-Side	Vertical
15,900	93.1	69.0	85.0	10.3	10.7	>33.3

**UUT Highest Passed Seismic Run Information**

Building Code	Test Criteria	S <sub>DS</sub> (g)	z/h	I <sub>p</sub>	A <sub>FLX-H</sub> (g)	A <sub>RIG-H</sub> (g)	A <sub>FLX-V</sub> (g)	A <sub>RIG-V</sub> (g)
CBC 2022, IBC 2021	ICC-ES AC156 (2010)	2.25	0.0	1.5	2.25	0.90	1.50	0.60

**Test Mounting Details:** (Test Report: EL:9295)



UUT4 was base - mounted rigid to the table using four (4) 1"-8 Grade 5 hex head bolts with flat washers and lock washers. Torqued to 400 ft-lbs.  
Unit maintained structural integrity and remained functional per manufacturer requirement after shake table test.  
Contents were included in testing per operating conditions.



# UNIT UNDER TEST (UUT) SUMMARY SHEET

1801293-CR-001-R1



<b>Manufacturer:</b>	Hitachi Energy USA Inc. (formerly ABB)	<b>UUT 5</b>
<b>Model Line:</b>	Transformer Product Family	
<b>Model Number:</b>	2500kVA 3φ Padmount & Unit Substation	
<b>Serial Number:</b>		N/A

**Product Construction Summary:**  
NEMA 3R Painted Carbon Steel Enclosure.

**Options/Subcomponent Summary:**  
Stainless Steel Tank. Copper Windings. Phase: 3φ. Loop Feed. Live Front.  
**Bushing-HV:** Warco (29C5672H01 x2); **Bushing-LV:** Daheng (29C4432H01 x4);  
**Bushing-Standoff:** H-J Enterprises (POB-014, PO 0097-001 x2); **Expulsion Fuse:** ABB (5750D27G14, 345B995G32 x2);  
**Current-Limiting Fuse:** Hi-Tech (HTSS252100 x2, HTSS372100 x2); **Switch:** ABB (1C08872H01, 1C08825H01);  
**Gauges:** Elmek (572015-00-04), Qualitrol (QUAL 151-100-01); **Pressure Relief:** Qualitrol (QUAL 201-020-01);

**UUT Properties**

Weight (lbs.)	Dimension (in)			Lowest Natural Frequency (Hz)		
	Depth	Width	Height	Front-Back	Side-Side	Vertical
17,090	89.0	135.0	81.0	5.87	10.01	28.12

**UUT Highest Passed Seismic Run Information**

Building Code	Test Criteria	S <sub>DS</sub> (g)	z/h	I <sub>p</sub>	A <sub>FLX-H</sub> (g)	A <sub>RIG-H</sub> (g)	A <sub>FLX-V</sub> (g)	A <sub>RIG-V</sub> (g)
CBC 2022, IBC 2021	ICC-ES AC156 (2010)	2.25	0.0	1.5	2.25	0.90	1.50	0.60

**Test Mounting Details:** (Test Report: 13512 (UUT5))



UUT5 was base - mounted rigid to the table using four (4) 1" Grade 5 bolts.  
Unit maintained structural integrity and remained functional per manufacturer requirement after shake table test.  
Contents were included in testing per operating conditions.

# UNIT UNDER TEST (UUT) SUMMARY SHEET

1801293-CR-001-R1



<b>Manufacturer:</b> Hitachi Energy USA Inc. (formerly ABB)	<b>UUT 6</b>
<b>Model Line:</b> Transformer Product Family	
<b>Model Number:</b> 250kVA 1φ Padmount & Unit Substation <b>Serial Number:</b> N/A	

**Product Construction Summary:**  
NEMA 3R Painted Carbon Steel Enclosure.

**Options/Subcomponent Summary:**  
Stainless Steel Tank. Aluminum Windings. Phase: 1φ. Loop Feed. Dead Front.  
**Bushing-HV:** ABB (2B10536H01 x2); **Bushing-LV:** ABB (28C2288H01 x3); **Bushing-Inserts:** ESNA/Elastimold (1B23942H01 x2);  
**Expulsion Fuse (Type-DO-III):** ABB (3A21025H14); **Switch:** ABB (1C23376H01, 1C08825H01);  
**Gauges:** Qualitrol (QUAL 020-550-01);

**UUT Properties**

Weight (lbs.)	Dimension (in)			Lowest Natural Frequency (Hz)		
	Depth	Width	Height	Front-Back	Side-Side	Vertical
2,725	56.0	46.0	42.0	11.50	12.15	14.63

**UUT Highest Passed Seismic Run Information**

Building Code	Test Criteria	S <sub>DS</sub> (g)	z/h	I <sub>P</sub>	A <sub>FLX-H</sub> (g)	A <sub>RIG-H</sub> (g)	A <sub>FLX-V</sub> (g)	A <sub>RIG-V</sub> (g)
CBC 2022, IBC 2021	ICC-ES AC156 (2010)	2.25	0.0	1.5	2.25	0.90	1.50	0.60

**Test Mounting Details:** (Test Report: 13512 (UUT6))



UUT6 was base - mounted rigid to the table using two (2) 1/2" Grade 8 bolts.  
Unit maintained structural integrity and remained functional per manufacturer requirement after shake table test.  
Contents were included in testing per operating conditions.

# UNIT UNDER TEST (UUT) SUMMARY SHEET

1801293-CR-001-R1



<b>Manufacturer:</b>	Hitachi Energy USA Inc. (formerly ABB)	<b>UUT 7</b>
<b>Model Line:</b>	Transformer Product Family	
<b>Model Number:</b>	10kVA 1φ Padmount & Unit Substation	
<b>Serial Number:</b>		N/A

**Product Construction Summary:**  
NEMA 3R Painted Carbon Steel Enclosure.

**Options/Subcomponent Summary:**  
Carbon Steel Tank. Aluminum Windings. Phase: 1φ. Radial Feed. Live Front.  
**Bushing-HV:** H-J Enterprises (30C1926H01 x2); **Bushing-LV:** ABB (2B10357H01 x3);  
**Bushing-Inserts:** ESNA/Elastimold (1B23941H01 x3); **Bushing-Standoff:** H-J Enterprises (PO 0097-001);  
**Fusing (Isolation Link):** ABB (1B25455H02); **Expulsion Fuse (Type-DO-III):** ABB (3A21025H06);  
**Switch:** ABB (1C08823H01); **Breaker:** ERMCO (1B24028H01); **Gauges:** Heartland (HLG-1065);

**UUT Properties**

Weight (lbs.)	Dimension (in)			Lowest Natural Frequency (Hz)		
	Depth	Width	Height	Front-Back	Side-Side	Vertical
1,366	45.0	42.0	36.0	11.30	15.01	11.75

**UUT Highest Passed Seismic Run Information**

Building Code	Test Criteria	S <sub>ds</sub> (g)	z/h	I <sub>p</sub>	A <sub>FLX-H</sub> (g)	A <sub>RIG-H</sub> (g)	A <sub>FLX-V</sub> (g)	A <sub>RIG-V</sub> (g)
CBC 2022, IBC 2021	ICC-ES AC156 (2010)	2.25	0.0	1.5	2.25	0.90	1.50	0.60

**Test Mounting Details:** (Test Report: 13512 (UUT7))



UUT 7



UUT7 was base - mounted rigid to the table using two (2) 1/2" Grade 8 bolts.  
Unit maintained structural integrity and remained functional per manufacturer requirement after shake table test.  
Contents were included in testing per operating conditions.

# UNIT UNDER TEST (UUT) SUMMARY SHEET

1801293-CR-001-R1



<b>Manufacturer:</b> Hitachi Energy USA Inc. (formerly ABB)	<b>UUT 8</b>
<b>Model Line:</b> Transformer Product Family	
<b>Model Number:</b> 1500kVA 3φ UCT <b>Serial Number:</b> N/A	

**Product Construction Summary:**  
NEMA 3R Stainless Steel Enclosure without skirt.

**Options/Subcomponent Summary:**  
Stainless Steel Tank. Copper Windings. Phase: 3φ. Loop Feed. Dead Front.  
**Bushing-HV:** ESNA/Elastimold (K1601-PC-T1 x6); **Bushing-LV:** Central Moloney (1B24955H01 x4);  
**Switch:** ABB (5543C55G47), RTE (8608C31H01); **Gauges:** Heartland (HLG-1065); **Pressure Relief:** Qualitrol (QUAL 202-014-02);

**UUT Properties**

Weight (lbs.)	Dimension (in)			Lowest Natural Frequency (Hz)		
	Depth	Width	Height	Front-Back	Side-Side	Vertical
10,500	57.0	79.0	76.0	9.24	9.33	>33.33

**UUT Highest Passed Seismic Run Information**

Building Code	Test Criteria	S <sub>DS</sub> (g)	z/h	I <sub>p</sub>	A <sub>FLX-H</sub> (g)	A <sub>RIG-H</sub> (g)	A <sub>FLX-V</sub> (g)	A <sub>RIG-V</sub> (g)
CBC 2022, IBC 2021	ICC-ES AC156 (2010)	2.25	0.0	1.5	2.25	0.90	1.50	0.60

**Test Mounting Details:** (Test Report: 13512 (UUT8))



UUT8 was base - mounted rigid to the table using four (4) 1" Grade 5 bolts.  
Unit maintained structural integrity and remained functional per manufacturer requirement after shake table test.  
Contents were included in testing per operating conditions.

# UNIT UNDER TEST (UUT) SUMMARY SHEET

1801293-CR-001-R1



<b>Manufacturer:</b> Hitachi Energy USA Inc. (formerly ABB)	<b>UUT 9</b>
<b>Model Line:</b> Transformer Product Family	
<b>Model Number:</b> 75VA 3 $\phi$ UCT <span style="float: right;"><b>Serial Number:</b> N/A</span>	

**Product Construction Summary:**  
NEMA 3R Stainless Steel Enclosure without skirt.

**Options/Subcomponent Summary:**  
Stainless Steel Tank. Aluminum Windings. Phase: 3 $\phi$ . Radial Feed. Dead Front.  
**Bushing-HV:** ESNA/Elastimold (K1601-PC-T1 x3); **Bushing-LV:** Central Moloney (1B24955H01 x4);  
**Fusing (Isolation Link):** ABB (1B25455H07); **Expulsion Fuse (Type-D0-III):** ABB (3A21027H05, 3A21026H05 x2);  
**Current-Limiting Fuse:** Hi-Tech (HTSS232040 x3); **Switch:** ABB (5543C55G47); **Gauges:** Heatland (HLG-1065);  
**Pressure Relief:** Qualitrol (QUAL 202-014-02);

<i>UUT Properties</i>						
Weight (lbs.)	Dimension (in)			Lowest Natural Frequency (Hz)		
	Depth	Width	Height	Front-Back	Side-Side	Vertical
3,640	32.0	68.0	53.0	15.01	15.64	31.88

<i>UUT Highest Passed Seismic Run Information</i>									
Building Code	Test Criteria	S <sub>DS</sub> (g)	z/h	I <sub>P</sub>	A <sub>FLX-H</sub> (g)	A <sub>RIG-H</sub> (g)	A <sub>FLX-V</sub> (g)	A <sub>RIG-V</sub> (g)	
CBC 2022, IBC 2021	ICC-ES AC156 (2010)	2.25	0.0	1.5	2.25	0.90	1.50	0.60	

**Test Mounting Details:** (Test Report: 13512 (UUT9))



UUT9 was base - mounted rigid to the table using four (4) 1" Grade 5 bolts.  
Unit maintained structural integrity and remained functional per manufacturer requirement after shake table test.  
Contents were included in testing per operating conditions.

# UNIT UNDER TEST (UUT) SUMMARY SHEET

1801293-CR-001-R1



<b>Manufacturer:</b> Hitachi Energy USA Inc. (formerly ABB)	<b>UUT 10</b>
<b>Model Line:</b> Transformer Product Family	
<b>Model Number:</b> 25kVA 1φ Horizontal <b>Serial Number:</b> N/A	

**Product Construction Summary:**  
NEMA 3R Stainless Steel Enclosure without skirt.

**Options/Subcomponent Summary:**  
Stainless Steel Tank. Aluminum Windings. Phase: 1φ. Radial Feed. Dead Front.  
**Bushing-HV:** ESNA/Elastimold (K1601-PC-T1 x4); **Bushing-LV:** Central Moloney (2B12889H01 x2);  
**Fusing (Isolation Link):** RTE (3637803B08 x3); **Switch:** ABB (5543C55G47), RTE (1B24985H01); **Breaker:** RTE (29C2161H01);  
**Gauges:** Heartland (HLG-1065); **Pressure Relief:** Hardware (3A25842H01);

**UUT Properties**

Weight (lbs.)	Dimension (in)			Lowest Natural Frequency (Hz)		
	Depth	Width	Height	Front-Back	Side-Side	Vertical
1,096	24.0	44.0	29.0	31.69	9.85	25.90

**UUT Highest Passed Seismic Run Information**

Building Code	Test Criteria	S <sub>DS</sub> (g)	z/h	I <sub>p</sub>	A <sub>FLX-H</sub> (g)	A <sub>RIG-H</sub> (g)	A <sub>FLX-V</sub> (g)	A <sub>RIG-V</sub> (g)
CBC 2022, IBC 2021	ICC-ES AC156 (2010)	2.25	0.0	1.5	2.25	0.90	1.50	0.60

**Test Mounting Details:** (Test Report: 13512 (UUT10))



UUT10 was base - mounted rigid to the table using two (2) 1" Grade 5 bolts.  
Unit maintained structural integrity and remained functional per manufacturer requirement after shake table test.  
Contents were included in testing per operating conditions.

# UNIT UNDER TEST (UUT) SUMMARY SHEET

1801293-CR-001-R1



<b>Manufacturer:</b> Hitachi Energy USA Inc. (formerly ABB)	<b>UUT 11</b>
<b>Model Line:</b> Transformer Product Family	
<b>Model Number:</b> 167kVA 1φ Horizontal <b>Serial Number:</b> N/A	

**Product Construction Summary:**  
NEMA 3R Stainless Steel Enclosure without skirt.

**Options/Subcomponent Summary:**  
Stainless Steel Tank. Aluminum-Copper Windings. Phase: 1φ. Radial Feed. Dead Front.  
**Bushing-HV:** ESNA/Elastimold (K1601-PC-T1 x4); **Bushing-LV:** Central Moloney (1B24954H01 x4);  
**Fusing (Isolation Link):** RTE (3637803B03 x3); **Switch:** ABB (5543C55G47), RTE (1B24985H01); **Breaker:** RTE (29C4597H01);  
**Gauges:** Heartland (HLG-1065); **Pressure Relief:** Hardware (3A25842H01);

**UUT Properties**

Weight (lbs.)	Dimension (in)			Lowest Natural Frequency (Hz)		
	Depth	Width	Height	Front-Back	Side-Side	Vertical
2,223	24.0	40.0	42.0	18.68	5.77	>33.33

**UUT Highest Passed Seismic Run Information**

Building Code	Test Criteria	S <sub>DS</sub> (g)	z/h	I <sub>p</sub>	A <sub>FLX-H</sub> (g)	A <sub>RIG-H</sub> (g)	A <sub>FLX-V</sub> (g)	A <sub>RIG-V</sub> (g)
CBC 2022, IBC 2021	ICC-ES AC156 (2010)	2.25	0.0	1.5	2.25	0.90	1.50	0.60

**Test Mounting Details:** (Test Report: 13512 (UUT11))



UUT11 was base - mounted rigid to the table using two (2) 1" Grade 5 bolts.  
Unit maintained structural integrity and remained functional per manufacturer requirement after shake table test.  
Contents were included in testing per operating conditions.

# UNIT UNDER TEST (UUT) SUMMARY SHEET

1801293-CR-001-R1



<b>Manufacturer:</b> Hitachi Energy USA Inc. (formerly ABB)	<b>UUT 12</b>
<b>Model Line:</b> Transformer Product Family	
<b>Model Number:</b> 25kVA 1φ DUP Horizontal <b>Serial Number:</b> N/A	

**Product Construction Summary:**  
NEMA 3R Stainless Steel Enclosure without skirt.

**Options/Subcomponent Summary:**  
Stainless Steel Tank. Aluminum Windings. Phase: 1φ. Radial Feed. Dead Front.  
**Bushing-HV:** ESNA/Elastimold (K1601-PC-T1 x6); **Bushing-LV:** Central Moloney (2B12889H01 x3);  
**Expulsion Fuse:** ERMCO (9F54DCA701 x3, 9F54DCB001 x3); **Gauges:** Heartland (HLG-1065);  
**Pressure Relief:** Hardware (3A25842H01);

**UUT Properties**

Weight (lbs.)	Dimension (in)			Lowest Natural Frequency (Hz)		
	Depth	Width	Height	Front-Back	Side-Side	Vertical
1,513	24.0	47.0	32.0	>33.33	11.08	26.20

**UUT Highest Passed Seismic Run Information**

Building Code	Test Criteria	S <sub>DS</sub> (g)	z/h	I <sub>p</sub>	A <sub>FLX-H</sub> (g)	A <sub>RIG-H</sub> (g)	A <sub>FLX-V</sub> (g)	A <sub>RIG-V</sub> (g)
CBC 2022, IBC 2021	ICC-ES AC156 (2010)	2.25	0.0	1.5	2.25	0.90	1.50	0.60

**Test Mounting Details:** (Test Report: 13512 (UUT12))



UUT12 was base - mounted rigid to the table using two (2) 1" Grade 5 bolts.  
Unit maintained structural integrity and remained functional per manufacturer requirement after shake table test.  
Contents were included in testing per operating conditions.



# UNIT UNDER TEST (UUT) SUMMARY SHEET

1801293-CR-001-R1



<b>Manufacturer:</b> Hitachi Energy USA Inc. (formerly ABB)	<b>UUT 13</b>
<b>Model Line:</b> Transformer Product Family	
<b>Model Number:</b> 100kVA 1φ DUP Horizontal <b>Serial Number:</b> N/A	

**Product Construction Summary:**  
NEMA 3R Stainless Steel Enclosure without skirt.

**Options/Subcomponent Summary:**  
Stainless Steel Tank. Aluminum-Copper Windings. Phase: 1φ. Radial Feed. Dead Front.  
**Bushing-HV:** ESNA/Elastimold (K1601-PC-T1 x6); **Bushing-LV:** Central Moloney (1B24954H01 x3);  
**Switch:** ABB (5543C55G47), RTE (1B24985H01); **Breaker:** ERMCO (2B11057H01); **Gauges:** Heartland (HLG-1065);  
**Pressure Relief:** Hardware (3A25842H01);

Weight (lbs.)	Dimension (in)			Lowest Natural Frequency (Hz)		
	Depth	Width	Height	Front-Back	Side-Side	Vertical
2,513	30.0	51.0	38.0	>33.33	5.92	15.90

UUT Highest Passed Seismic Run Information									
Building Code	Test Criteria	S <sub>DS</sub> (g)	z/h	I <sub>p</sub>	A <sub>FLX-H</sub> (g)	A <sub>RIG-H</sub> (g)	A <sub>FLX-V</sub> (g)	A <sub>RIG-V</sub> (g)	
CBC 2022, IBC 2021	ICC-ES AC156 (2010)	2.25	0.0	1.5	2.25	0.90	1.50	0.60	

**Test Mounting Details:** (Test Report: 13512 (UUT13))



UUT 13



UUT13 was base - mounted rigid to the table using two (2) 1" Grade 5 bolts.  
Unit maintained structural integrity and remained functional per manufacturer requirement after shake table test.  
Contents were included in testing per operating conditions.

# UNIT UNDER TEST (UUT) SUMMARY SHEET

1801293-CR-001-R1



<b>Manufacturer:</b>	Hitachi Energy USA Inc. (formerly ABB)	<b>UUT 14</b>
<b>Model Line:</b>	Transformer Product Family	
<b>Model Number:</b>	780kVA 3φ Padmount & Unit Substation	
<b>Serial Number:</b>		N/A

**Product Construction Summary:**  
NEMA 3R Painted Carbon Steel Enclosure without skirt.

**Options/Subcomponent Summary:**  
Carbon Steel Tank. Aluminum-Copper Windings. Phase: 3φ. Radial Feed. Dead Front.  
**Bushing-HV:** ABB (2B10536H01 x3); **Bushing-LV:** ABB (2B10567H01 x3); **Bushing-Inserts:** ESNA/Elastimold (4931B50H01 x3);  
**Fusing (Link Bay-O-Net):** RTE (3A18440H01 x3); **Current-Limiting Fuse:** Hi-Tech (HTSS242150 x3);

**UUT Properties**

Weight (lbs.)	Dimension (in)			Lowest Natural Frequency (Hz)		
	Depth	Width	Height	Front-Back	Side-Side	Vertical
9,990	71.0	70.0	72.0	10.39	29.65	10.87

**UUT Highest Passed Seismic Run Information**

Building Code	Test Criteria	S <sub>DS</sub> (g)	z/h	I <sub>p</sub>	A <sub>FLX-H</sub> (g)	A <sub>RIG-H</sub> (g)	A <sub>FLX-V</sub> (g)	A <sub>RIG-V</sub> (g)
CBC 2022, IBC 2021	ICC-ES AC156 (2010)	2.25	0.0	1.5	2.25	0.90	1.50	0.60

**Test Mounting Details:** (Test Report: 13512 (UUT14))



UUT14 was base - mounted rigid to the table using four (4) 1" Grade 5 bolts.  
Unit maintained structural integrity and remained functional per manufacturer requirement after shake table test.  
Contents were included in testing per operating conditions.

# UNIT UNDER TEST (UUT) SUMMARY SHEET



1801293-CR-001-R1

<b>Manufacturer:</b>	Hitachi Energy USA Inc. (formerly ABB)	<b>UUT 15</b>
<b>Model Line:</b>	Transformer Product Family	
<b>Model Number:</b>	3000kVA 3φ Padmount	
		<b>Serial Number:</b> 18JC092760001

**Product Construction Summary:**  
NEMA 3R Painted Carbon Steel Enclosure without skirt.

**Options/Subcomponent Summary:**  
Carbon Steel Tank. Aluminum (high voltage) & Copper Windings (low voltage). Phase: 3φ. Loop & Radial Feed. Live & Dead Front.  
**Bushing-HV:** ABB (1ZUA276301-AEB x2), Cooper (2637019B02, DB635B150), Crosslink Technology, Inc. (90-345, 90-340), ESNA/Elastimold (K650S1-NF, 750S1-NF); **Bushing-LV:** Crosslink Technology (29C4583H01), ESNA/Elastimold (1601A4CS937), Daheng (30C5037H01, 30C5193H01, 30C5238H01); **Switch:** Cooper (LS4BH3T12M, 2237179C02M);  
**Current-Limiting Fuse:** Cooper (CBUC38140D100 x2), Hi-Tech (HTSS372165 x2); **Thermometer:** Qualitrol (120-005-03);  
**Pressure Relief:** Qualitrol (QUAL 201-020-01, QUAL 208-60E); **Current Transformer:** ABB (1A3389);  
**APID Pressure Rise Relay:** Qualitrol (910-010-33); **Under Oil Arrester:** Cooper (CLU23C36);

**UUT Properties**

Weight (lbs.)	Dimension (in)			Lowest Natural Frequency (Hz)		
	Depth	Width	Height	Front-Back	Side-Side	Vertical
19,850	116.4	134.6	93.5	13.0	20.0	>33.3

**UUT Highest Passed Seismic Run Information**

Building Code	Test Criteria	S <sub>DS</sub> (g)	z/h	I <sub>p</sub>	A <sub>FLX-H</sub> (g)	A <sub>RIG-H</sub> (g)	A <sub>FLX-V</sub> (g)	A <sub>RIG-V</sub> (g)
CBC 2022, IBC 2021	ICC-ES AC156 (2010)	2.25	0.0	1.5	2.25	0.90	1.50	0.60

**Test Mounting Details:** (Test Report: 1801293-TR-001 (UUT15))



UUT15 was base - mounted rigid to the table using four (4) 1" Grade 8 bolts with flat washers and lock washers. Unit maintained structural integrity and remained functional per manufacturer requirement after shake table test. Contents were included in testing per operating conditions.

# UNIT UNDER TEST (UUT) SUMMARY SHEET

1801293-CR-001-R1



<b>Manufacturer:</b> Hitachi Energy USA Inc. (formerly ABB)	<b>UUT 16</b>
<b>Model Line:</b> Transformer Product Family	
<b>Model Number:</b> 3000kVA 3φ Unit Substation <b>Serial Number:</b> JC259320001	

**Product Construction Summary:**  
NEMA 3R Painted Carbon Steel Enclosure without skirt.

**Options/Subcomponent Summary:**  
Carbon Steel Tank. Copper Windings. Phase: 3φ. Radial Feed. Live Front.  
**Bushing-HV:** Crosslink Technology, Inc. (30C2554 x3); **Bushing-LV:** H-J Enterprises (28C2810 x4);  
**Control Cabinet:** South Star Corp. (3D50040); **Current Transformer:** ABB (2B12407)

**UUT Properties**

Weight (lbs.)	Dimension (in)			Lowest Natural Frequency (Hz)		
	Depth	Width	Height	Front-Back	Side-Side	Vertical
19,200	98.7	128.7	119.9	11.20	13.59	23.26

**UUT Highest Passed Seismic Run Information**

Building Code	Test Criteria	S <sub>DS</sub> (g)	z/h	I <sub>p</sub>	A <sub>FLX-H</sub> (g)	A <sub>RIG-H</sub> (g)	A <sub>FLX-V</sub> (g)	A <sub>RIG-V</sub> (g)
CBC 2022, IBC 2021	ICC-ES AC156 (2010) 2/19/2025	2.25	0.0	1.5	2.25	0.90	1.50	0.60

**Test Mounting Details:** (Test Report: 2301373-TR-001 (UUT1))



UUT16 was base - mounted rigid to the table using four (4) 1" Grade 8 bolts and washers.  
Unit maintained structural integrity and remained functional per manufacturer requirement after shake table test.  
Contents were included in testing per operating conditions.