

DEPARTMENT OF HEALTH CARE ACCESS AND INFORMATION FACILITIES DEVELOPMENT DIVISION

OFFICE USE ONLY APPLICATION FOR HCAI SPECIAL SEISMIC **CERTIFICATION PREAPPROVAL (OSP)** APPLICATION #: OSP-0122 **HCAI Special Seismic Certification Preapproval (OSP)** Renewal Type: New **Manufacturer Information** Manufacturer: Loren Cook Company Manufacturer's Technical Representative: Bradley Skidmore Mailing Address: 2015 East Dale St., Springfield, MO 65808 Telephone: (417) 869-6474 Email: bskidmore@lorencook.com **Product Information** Product Name: Air Handling Units Product Type: Fans Product Model Number: 90ASP, 100ASP, 120ASP, 150ASP 180ASP, 200ASP Supply fans with carbon steel housings and forward curved carbon steel wheels. General Description: Rigid, Rigid mounted on 9-1/2" tall Aluminum or Carbon Steel curb or 24" tall Carbon Steel curb. Mounting Description: None Tested Seismic Enhancements: **Applicant Information** Applicant Company Name: VMC Group Contact Person: John Giuliano Mailing Address: Main Street, Bloomingdale, NJ 07403

Email: john.giuliano@thevmcgroup.com





Page 1 of 7

STATE OF CALIFORNIA - HEALTH AND HUMAN SERVICES AGENCY

Telephone: (973) 838-1780

Title: President



DEPARTMENT OF HEALTH CARE ACCESS AND INFORMATION FACILITIES DEVELOPMENT DIVISION

200	
California Licensed Structural Enginee	r Responsible for the Engineering and Test Report(s)
Company Name: THE VMC GROUP	
Name: Kenneth Tarlow	California License Number: S2851
Mailing Address: 980 9th Street, 16th Floor, S	Gacramento, CA 95814
Telephone: (832) 627-2214	Email: ken.tarlow@thevmcgroup.com
Certification Method	
GR-63-Core X ICC-ES AC1	156
Other (Please Specify):	
	EOR CODE CO
Testing Laboratory	D. M.
Company Name: ELEMENT MATERIALS TE	CHNOLOGY
Contact Person: Kent L. Erickson	7
Mailing Address: 9725 Girard Ave South, Min	neapolis MN 55431
Telephone: (952) 888-7795	Email: kle@environlab.com
\ <u>C</u>	DATE: 05/27/2022





05/27/2022 OSP-0122 Page 2 of 7



DEPARTMENT OF HEALTH CARE ACCESS AND INFORMATION FACILITIES DEVELOPMENT DIVISION

Seismic Parameters	Seismic Parameters				
Design Basis of Equipment or Components (Fp/Wp) = 1.71					
SDS (Design spectral response acceleration at short period, g) = 2.27					
ap (Amplification factor) =	ap (Amplification factor) = 2.5				
R _P (Response modification factor) =	6.0				
Ω_0 (System overstrength factor) =	2.0				
Ip (Importance factor) =	1.5				
z/h (Height ratio factor) =	1				
Natural frequencies (Hz) =	See Attachment				
Overall dimensions and weight =	See Attachment				

HCAI A	pproval (For Office Use Only) - Approval Expires on 05/27/2028	7	
Date:	5/27/2022 OSP-0122	12	
Name:	Mohammad Karim	Title:	Supervisor, Health Facilities
Special	Seismic Certification Valid Up to: Sps (g) = 2.27	z/h =	1
Conditio	on of Approval (if applicable): DATE 05/27/2022	0	





05/27/2022 OSP-0122 Page 3 of 7

Table 1 - Certified Supply Fans

Model Line Model		Overall Dimensions [in]		Material	Mounting Description	Weight [UUT	
Wiodel Lille	Number	Depth	Width	Height	Waterial	Mounting Description	lb]	001
	90 ASP	33	33	26.5		Rigid Base Mounted to 9-1/2" tall Aluminum Curb	263	UUT-1
	90 ASP	33	33	26.5			263	Interpolated
	100 ASP	38.5	38.5	30			335	Interpolated
ASP	120 ASP	42.5	42.5	33	16 Gauge Galvanized	Rigid Base Mounted on Carbon	385	Interpolated
[Belt Drive]	150 ASP	46	46	36	Carbon Steel	Steel Curb up to 24" Tall	435	Interpolated
	180 ASP	56	56	40 R	CODE		630	Interpolated
	200 ASP	68	68	47	012		925	Interpolated
	200 ASP	68	68	47	CA	Rigid Base Mounted to 24" tall Carbon Steel Curb	925	UUT-2



Table 2 - Certified Fan Motors

Model Number	Rating [hp]	Frame	Manufacturer	Weight [lb]	UUT
EM3116T	1	145 T		34	UUT-1
EM3154T	1.5	145 1		37	Interpolated
EM3157T	2	184 T	Baldor	40	Interpolated
EM3218T	5	104 1		84	Interpolated
EM3311T	7.5	213 T		115	UUT-2

Table 3 - Certified Motorized Damper

Model Number	Material	Manufacturer	Weight [lb]	UUT
BDMI-18	Aluminum		18	UUT-1
BDMI-22	Aluminum		22	Interpolated
BDMI-26	Aluminum	Ruskin	25	Interpolated
BDMI-30	Aluminum		35	Interpolated
BDMI-42	Aluminum	ORC	UDE73	UUT-2

Table 4 - Certified Filters

Madal Number		imensions [in]		Monufacturer	Waight Lib 1	UUT	
Model Number -	Depth	Width	Height	Manufacturer	Weight [lb]		
9 ASP	1/4/	10.25			0.75	UUT-1	
10 ASP	1/8///	12	24	m	1	Interpolated	
12 ASP	1	16	28	Loren Cook	1.75	Interpolated	
15 ASP	1 0	BY 16/Iohar	nmad 28 arim	Loren Cook	1.75	Interpolated	
18 ASP	1	20	32		2.5	Interpolated	
20 ASP	1	27.75	44		4.5	UUT-2	



UNIT UNDER TEST (UUT) Summary Sheet

UUT-1

Test Report: 42529-1

Model Line	Model Number	Manufacturer
ASP	90 ASP	Loren Cook Company

Product Construction Summary

Galvanized Carbon Steel Enclosure on 9-1/2" Aluminum Curb

Options / Subcomponent Summary

Fan Motor, Motorized Damper, Filters


UUT Properties

			o i Propertie	.5						
Weight		Dimensions [in]					Lowest Nat. Freq. [Hz]			
[lbs]	Length Width Heigh		ight	F-B	S-S	V				
263	33.0	33	99P-012	2 2	6.5	24.0	16.1	16.6		
	UUT I	lighest Pas	sed Seismic	Run Infor	mation					
Building Code	Test Criteria	Sps/loh	am z/h ad	Karlm	A _{FLX-H}	A _{RIG-H}	A _{FLX-V}	A _{RIG-V}		
CBC 2019	ICC-ES AC156	2.27	1.0	1.5	3.63	2.72	1.52	0.61		
OBO 2019		DATE.	05/07/0	000	-	-	-	-		

Test Mounting Details

The unit was attached to the curb using (12) 12-14x2" Grade 5 self-drilling sheet metal screws through the fan housing into the curb. The curb was attached to the shake table using (12) 5/16" diameter Grade 5 fasteners.





Vertical axis Horizontal axis

All units were filled with contents and maintained structural integrity and functionality after AC-156 test.



UNIT UNDER TEST (UUT) Summary Sheet

UUT-2

Test Report: 42529-1

Model Line	Model Number	Manufacturer
ASP	200 ASP	Loren Cook Company

Product Construction Summary

Galvanized Carbon Steel Enclosure on 24" Carbon Steel Curb

Options / Subcomponent Summary

Fan Motor, Motorized Damper, Filters

UUT Properties

			O i Propertie	,s	9,						
Weight	43	Dimensions [in]						Lowest Nat. Freq. [Hz]			
[lbs]	Length Width Heigh				ight	F-B	S-S	V			
925	68.0	(6)	®P-012	2 4	7.0	10.4	8.1	29.2			
	UUT	Highest Pas	sed Seismic	Run Infor	mation			-			
Building Code	Test <mark>Criter</mark> ia	Sps/or	am <mark>z/h</mark>	Karlm	A _{FLX-H}	A _{RIG-H}	A _{FLX-V}	A _{RIG-V}			
CBC 2019	ICC-ES AC156	2.27	1.0	1.5	3.63	2.72	1.52	0.61			
ODC 2019	ICC-ES ACTSO	DATE.	05/07/0	000	-	-	-	-			

Test Mounting Details

The unit was attached to the curb using(12) 12-14x2" Grade 5 self-drilling sheet metal screws through the fan housing into the curb. The curb was attached to the shake table using (20) 5/16" diameter Grade 5 fasteners.





Vertical Axis Horizontal Axis

All units were filled with contents and maintained structural integrity and functionality after AC-156 test.