

# DEPARTMENT OF HEALTH CARE ACCESS AND INFORMATION FACILITIES DEVELOPMENT DIVISION

## OFFICE USE ONLY APPLICATION FOR HCAI SPECIAL SEISMIC CERTIFICATION PREAPPROVAL (OSP) APPLICATION #: OSP-0158 **HCAI Special Seismic Certification Preapproval (OSP)** Type: New Renewal **Manufacturer Information** Manufacturer: Firetrol, Inc Manufacturer's Technical Representative: Thomas Feighery Mailing Address: 3362 Apex Peakway Apex, NC 27502 Tom.Feighery@firetrol.com Telephone: (919) 460-5228 Email: **Product Information** Product Name: Electrical Control Panels on Life Safety/Critical Branch Product Type: Fire Protection & Security Panels Product Model Number: See Attached Certified Components Listing General Description: Firetrol FTA Fire Pump Controllers and accessories. Enclosures are Nema 2, 3R, 4, 12, or 4X, constructed of cold-rolled steel, stainless steel, or polycarbonate. Certified components include but are not limited to: various enclosure sizes, backplates, leg enclosures, circuit breakers, isolation switches, transformers, contactors, soft starters, autotransformers, resistor banks, fusible disconnects, and automatic transfer switches. Rigid, Floor/Wall Mounted Mounting Description: None Tested Seismic Enhancements: **Applicant Information** Applicant Company Name: Dynamic Certification Labatories Contact Person: Kelly Laplace Mailing Address: 1315 Greg Street, Suite 109 Sparks, NV 89431





STATE OF CALIFORNIA - HEALTH AND HUMAN SERVICES AGENCY

Telephone: (775) 358-5085

Title: Business Manager

01/18/2023 OSP-0158 Page 1 of 30

Email: kelly@shaketest.com



# DEPARTMENT OF HEALTH CARE ACCESS AND INFORMATION FACILITIES DEVELOPMENT DIVISION

California Licensed Structural Engineer Responsible for the Engineering and Test Report(s)
Company Name: THE VMC GROUP
Name: Kenneth Tarlow California License Number: S2851
Mailing Address: 980 9th Street, 16th Floor Sacramento, CA 95814
Telephone: (832) 627-2214 Email: ken.tarlow@thevmcgroup.com
Certification Method
☐ GR-63-Core
Other (Please Specify):
EOR CODE CO.
Testing Laboratory
Company Name: DYNAMIC CERTIFICATION LABORATORY (DCL)
Contact Person: Kelly Laplace
Mailing Address: 1315 Greg St., Ste 109 Sparks, NV 89431
Telephone: (775) 358-5085 Email: Kelly@shaketest.com
Company Name: WYLE LABORATIORIES
Contact Person: Don Smith
Mailing Address: 7800 Highway 20 West Huntsville, AL 35806
Telephone: (256) 837-4411 Email: Don.Smith@wyle.com





01/18/2023 OSP-0158 Page 2 of 30



# DEPARTMENT OF HEALTH CARE ACCESS AND INFORMATION FACILITIES DEVELOPMENT DIVISION

Seismic Parameters	
Design Basis of Equipment or Components	s(Fp/Wp) = 1.35
SDS (Design spectral response accele	eration at short period, g) = 1.8
a <sub>p</sub> (Amplification factor) =	2.5
Rp (Response modification factor) =	6.0
$\Omega_0$ (System overstrength factor) =	2.0
Ip (Importance factor) =	1.5
z/h (Height ratio factor) =	1
Natural frequencies (Hz) =	See Attachment
Overall dimensions and weight =	See Attachment

HCAI Approval (For Office Use Only) - Approval Expires on 01/18/2029								
Date:	01/18/2023 OSP-0158	MAI						
Name:	Mohammad Karim	Title:	Supervisor, Health Facilities					
Special	Seismic Certification Valid Up to: SDS (g) = 1.8	z/h =	1					
Conditio	on of Approval (if applicable): DATE: 01/18/2023							





01/18/2023 OSP-0158 Page 3 of 30

## **Table 1 - Certified Components - Wall Mount**

(()) DCL
DYNAMIC
GERTIFICATION

DCL Project Number:19012-2201Manufacturer:Firetrol, Inc

Mounting Configuration:Rigid Wall MountCertified Seismic Level: $S_{DS} = 1.80g$ , z/h=1.0

Model Number	Model Line	Notes	Max.	Dimension	ns (in)	Max. Weight	Unit
Woder Number	Wiodel Line	Notes	Depth	Width	Height	(lb.)	Oilit
FTA550F-AG014B-BW	FTA550F Across-the-Line Jockey Pump	Across-the-Line Jockey Pump Controller	8	14	16	15	UUT-11
FTA550F-AG002D-AM-NZ	Controller	Across-the-Line Jockey Fulfip Controller	8	14	16	15	UUT-12
FTA500-AF-01B-BN	FTA500 Across-the-Line Jockey Pump	Jockey Pump Controller with Fusible Disconnect	8	18	24	44	UUT-04A
FTA500-AF-50B-BN	Controller	Jockey Fullip Controller with Lusible Disconnect	8	18	24	50	UUT-02A
FTA500-AA-50B-BN		Jockey Pump Controller with Circuit Breaker	8	18	24	50	UUT-01A
FTA550E-AA013B-BW	FTA550E Across-the-Line Jockey Pump	Across-the-Line Jockey Pump Controller	8	20	24	57	UUT-09
FTA550E-AA050B-BW	Controller	Across-the-Line Jockey Fullip Controller	8	20	24	66	UUT-10
FTA1100-JL24N	FTA 1100 Diesel Engine Fire	Diesel Engine Controller	12	26	36	160	UUT-13
FTA1100-JL12N	Pump Controllers	SP-0158 Eligille Collitoller	12	26	36	160	UUT-14

BY: Mohammad Karim

DATE: 01/18/2023

## Table 2 - Certified Components - Base Mount

DCL Project Number: 19012-2201
Manufacturer: Firetrol, Inc

Mounting Configuration: Rigid Base Mount
Certified Seismic Level: S<sub>DS</sub> = 1.80g, z/h=1.0

Model Number	Model Line	Notes	Max. Dimensions (in)			Max. Weight	Unit
Woder Namber	Wiodel Lille	Notes	Depth	Width	Height	(lb.)	Offic
916750-001	Soft Starter and Autotransformer	25HP, 480V Autotransformer	14	26	68	240	UUT-08B
916750	Soft Starter and Autotransformer	552A Soft Starter and 200HP, 380V Autotransformer	14	26	68	580	UUT-08A
FTA1930-AM50B		Soft-start Electric Controller	12	38	60	280	UUT-06
FTA1350-AM200B		Wye-Delta Start Electric Controller	14	41	68	380	UUT-04B
FTA1800-AM100B	FTA 900/901/950/951 Electric Fire	Autotransformer Start Controller	12	38	60	418	UUT-05
FTA1000-AM300F	Pump Controllers and FTA 1000-1930	Across-the-Line Electric Controller	18	36	80	575	UUT-02B
FTA1930-AM150B-TS	Diesel Engine Fire Pump	Soft-start Electric Controller with Standard ATS	12	76	60	645	UUT-01B
FTA950-AM150B	Controllers	3011-Start Electric Controller With Standard A13	12	/0	00	043	001-018
FTA1000-AM100B-TAB		Across-the-Line Electric Controller with E-Bypass ATS	24	71	70	750	UUT-03B
FTA951-AM100B		Across-the-Line Electric Controller with E-Bypass A13	24	/1	70	750	001-036
FTA1100-JL24N	FTA 1100 Diesel Engine Fire	Diesel Engine Controller Type 2 Enclosure	12	26	48	192	UUT-03A
FTA1100-JL24N-FDP	Pump Controllers	Diesel Engine Controller SS Type 4X Enclosure	12	26	60	208	UUT-07
J7ACTBB30600N5XM	J-Bypass ATS	J-Bypass ATS Type 3R Enclosure	37	49	95	1762	UUT-02C

## Table 3 - Certified Subcomponents/Rigid Wall Mount - Enclosures



DCL Project Number: 19012-2201

Subcomponent No.		Dimensions (in)		Manufacturer	Material	NEMA Enclosure	Unit
Subcomponent No.	Depth	Width	Height		Material	NEIVIA ETICIOSUTE	Offic
915221	8.0	14.0	15.5		Polycarbonate	2/12/3R/4/4X	UUT-11, UUT-12
EN-1366	8.0	18.0	24.0	1	14 GA CRS	2	UUT-01A, UUT-02A,
LN-1300	8.0	18.0	24.0	Firetrol, Inc	2	UUT-04A	
EN-2254	8.0	20.0	24.0	]	14 GA CRS	2/12/3R/4	UUT-09, UUT-10
EN-1240	12.0	26.0	48.0		14 GA CRS	2	UUT-13, UUT-14

CL Project Number:	19012-2201	OFO	THE COURT OF THE C		
		Backplates			
Subcomponent No.	Manufacturer	Description	Material	Approx. Weight (lb.)	Unit
PL-2027		Backplate	0.80THK 5052-H32 Aluminum	1	UUT-11, UUT-12
PL-2035	Firetrol, Inc	Backplate	0.100THK 5052-H32 Aluminum	3	UUT-09, UUT-10
PL-1366		Backplate	- 14 GA CRS	5	UUT-01A, UUT-02A
		Circuit Breakers		111	
Subcomponent No.	Manufacturer	Description	Material	Approx. Weight (lb.)	Unit
PL-1366		Thermal Magnetic Molded Case Circuit Breaker, 150A Frame		7	UUT-01A
PL-2027	АВВ	Thermal Magnetic Molded Case Circuit Breaker, 100A Frame	Plastic	7	UUT-10
PL-2035		Thermal Magnetic Molded Case Circuit Breaker, 15A Frame		707	UUT-09
		Transformers			
Subcomponent No.	Manufacturer	Description	Material	Approx. Weight (lb.)	Unit
917248		Control 58VA, 208/230/400/460/575-24V		3	UUT-09, UUT-10, UUT-11, UUT-12
TF-0200	Firetrol, Inc	Control 50VA, 240V/480-120V	Laminated Steel (Varnished)	3	Interpolated
TF-0202		Control 150VA, 240/480-120V		5	UUT-10
		Contactors			
Subcomponent No.	Manufacturer	Description	Material	Approx. Weight (lb.)	Unit
CT-1701		A12 Frame		<1	UUT-04A
CT-1706		1A, 24-60VAC, 20-60VDC		<1	UUT-09
CT-2252	ABB	25.3A, 20-60VAC, 20-60VDC	Plastic	<1	UUT-11
CT-2254		25.3A, 48-130VAC/DC Coil		<1	UUT-12
CT-2253		32.2A, 20-60VAC, 20-60VDC		<1	Interpolated
CT-1750		80A, 110-120VAC		2	UUT-10

## Table 4 - Certified Subcomponents/Rigid Wall Mount Cont.



DCL Project Number: 19012-2201

		Fusible Disconnec	t					
Subcomponent No.	Manufacturer	Description	Material	Approx. Weight (lb.)	Unit			
DC-1047	ABB	30A	Plastic	<1	UUT-04A			
DC-1049	ADB	100A	Flastic	2	UUT-02A			
	Control Units							
Subcomponent No.	Manufacturer	Description	Material	Approx. Weight (lb.)	Unit			
905102	Firetrol, Inc	Jockey XG Pump Control Unit	Plastic	<1	UUT-09, UUT-10,			
905102	Filetioi, ilic		NK CODE C	<1	UUT-11, UUT-12			
		Manual Motor Protect	ctors					
Subcomponent No.	Manufacturer	Description	Material	Approx. Weight	Unit			
		/ . \ \	PUBLIC LENGTH A DIVAN A DAMPA PRO SYNYAYA	(lb.)				
DC-1081		0.63-1.0A	I W YANNYA W WWW.	(lb.) <1	UUT-11			
DC-1081 DC-1082		0.63-1.0A 1.0-1.6A	HOAT		UUT-11 Interpolated			
			HCAi	<1				
DC-1082		1.0-1.6A	HCAI	<1 <1	Interpolated			
DC-1082 DC-1083		1.0-1.6A 1.6-2.5A	<b>HCA</b> 1 OSP-0158	<1 <1 <1	Interpolated Interpolated			
DC-1082 DC-1083 DC-1804	ABB	1.0-1.6A 1.6-2.5A 2.5-4.0A	OSP-0158 Plastic	<1 <1 <1 <1	Interpolated Interpolated Interpolated			
DC-1082 DC-1083 DC-1804 DC-1805	ABB	1.0-1.6A 1.6-2.5A 2.5-4.0A 4.0-6.3A		<1 <1 <1 <1 <1 <1	Interpolated Interpolated Interpolated Interpolated			
DC-1082 DC-1083 DC-1804 DC-1805 DC-1806	ABB	1.0-1.6A 1.6-2.5A 2.5-4.0A 4.0-6.3A 6.3-10.0A 8.0-12.0A 10.0-16.0A	Plastic	<1 <1 <1 <1 <1 <1 <1 <1 <1 <1 <1 <1 <1 <	Interpolated Interpolated Interpolated Interpolated Interpolated Interpolated			
DC-1082 DC-1083 DC-1804 DC-1805 DC-1806 DC-1807	ABB	1.0 <sub>-</sub> 1.6A 1.6-2.5A 2.5-4.0A 4.0-6.3A 6.3-10.0A 8.0-12.0A		<1 <1 <1 <1 <1 <1 <1 <1 <1 <1 <1 <1 <1 <	Interpolated Interpolated Interpolated Interpolated Interpolated Interpolated Interpolated			
DC-1082 DC-1083 DC-1804 DC-1805 DC-1806 DC-1807 DC-1088	ABB	1.0-1.6A 1.6-2.5A 2.5-4.0A 4.0-6.3A 6.3-10.0A 8.0-12.0A 10.0-16.0A	Plastic	<1 <1 <1 <1 <1 <1 <1 <1 <1 <1 <1 <1 <1 <	Interpolated Interpolated Interpolated Interpolated Interpolated Interpolated Interpolated Interpolated			

## Table 5 - Certified Subcomponents/Rigid Base Mount - Enclosures

DCL Project Number: 19012-2201

Subcomponent No.		Dimensions (in)		Manufacturer	Material	NEMA Enclosure	Unit
Subcomponent No.	Depth	Width	Height	Manufacturer	iviaterial	INLIVIA LIICIOSUI E	Offic
EN-1240	12.0	26.0	48.0		14 GA CRS	2	UUT-03A
EN-1218, EN-2219	14.0	26.0	68.0		14 GA CRS	2	UUT-08A, UUT-08B
EN-1173, EN-1210,	12.0	76.0	60.0		14 GA CRS	2	UUT-01B
EN-1212	12.0	76.0	1 2 2 00:0		14 GA CKS	2	001-018
EN-1211	12.0	38.0	60.0		14 GA 316 SS	2	UUT-06
EN-1985-001	12.0	26.0	60.0	Firetrol, Inc	14 GA CRS	4X	UUT-07
EN-1216	14.0	41.0	68.0		14 GA CRS	2	UUT-04B
EN-1211	12.0	38.0	60.0		14 GA CRS	2	UUT-05
EN-1215, EN-1246	18.0	71.0	68.0		14 GA CRS	2	UUT-03B
EN-1213	18.0	36.0	80.0		12 GA CRS	2	UUT-02B
806143-021	37.0	49.0	95.0		11 GA CRS	3R	UUT-02C

Notes:

Height includes 12-inch legs for floor-standing units

## Table 6 - Certified Subcomponents/Rigid Base Mount



DCL Project Number: 19012-2201

OCL Project Number:	19012-2201	Backplates			
Subcomponent No.	Manufacturer	Description	Material	Approx. Weight (lb.)	Unit
PL-1219		Backplate, Relay Board	14 GA CRS	5	UUT-01B
PL-1220		Backplate, PTR 48"	14 GA CRS	13	UUT-01B
PL-1222	Firetrol, Inc	Backplate, PTR 80"	12 GA CRS	16	UUT-02B
PL-1221	Thetroi, inc	Backplate, PTR 56"	14 GA CRS	18	UUT-03B
PL-1240		Backplate, 36"	14 GA CRS	20	UUT-03A
PL-1937		Backplate, 48"	14 GA CRS	25	UUT-07
		Legs	OR CUDE C		
Subcomponent No.	Manufacturer	Description	Material	Approx. Weight (lb.)	Unit
LG-1045		Leg Enclosure, 12"H x 12"D	14 GA CRS	7	UUT-01B
LG-1046		Leg Enclosure, 12"H x 14"D	14 GA CRS	7	UUT-05
LG-1366		Leg Enclosure, 12"H x 12"D	14 GA 316 SS	7	UUT-07
LG-1048		Leg Enclosure, 6"H x 12"D	3/16" CRS	7	Interpolated
LG-1049	Firetrol, Inc	Leg Enclosure, 6"H x 14"D	3/16" CRS	7	Interpolated
LG-1152		Leg Enclosure, 12"H x 14"D	14 GA 316 SS	7	Interpolated
LG-1045		Leg Enclosure, 12"H x 12"D	14 GA CRS	7 7	UUT-03A
LG-1366		Leg Enclosure, 12"H x 12"D	14 GA 316 SS	7	UUT-07
LG-1155		Leg Enclosure, 12"H x 18"D	14 GA CRS	9	UUT-03B
		Isolation Switche			
Subcomponent No.	Manufacturer	Description	Material	Approx. Weight (lb.)	Unit
DC-1055/DC-1056		Molded Case Isolation Switch, 150/225A Frame	E: 01/18/2023	<u>Ce1</u>	UUT-06
CC-4201/CC-4205		Breaker used as Isolation Switch, 150, 175A (250A Frame)		6	Same as UUT-06
DC-1057		Molded Case Isolation Switch, 250A Frame		6	UUT-01B
DC-1096	ABB	Molded Case Isolation Switch, 250A Frame	Plastic	6	Same as UUT-01B
DC-1058		Molded Case Isolation Switch, 400A Frame	BUILDING	9	UUT-04B
DC-1059/DC-1060		Molded Case Isolation Switch, 600/800A Frame		22	UUT-02B
		Contactors			
Subcomponent No.	Manufacturer	Description	Material	Approx. Weight (lb.)	Unit
CT-1744*/CT-1754*		A50/A75 Frame		2	UUT-04B
CT-2217/CT-2219		AF116/AF140 Frame		4	Interpolated
CT-1764*/CT-1774*		A95/A110 Frame		5	UUT-04B
CT-2221/CT-2223	1	AF190/AF205 Frame		6	Interpolated
CT-1806*/CT-1816*	ADD	A145/A185 Frame	Dlastic	7	UUT-05
CT-2225/CT-2227	ABB	AF265/AF305 Frame	Plastic	10	Interpolated
CT-1826*/CT-1836*/ CT-1846*	]	A210/A260/A300 Frame		13	UUT-01B
CT-1851*/CT-1861*	1	AF400/AF460 Frame	†	26	Interpolated

Notes

The 6"H leg enclosures are approved because the 12"H (the weakest configuration) was tested. 3/16" CRS is stronger than 14 GA CRS.

\*Part number shown is a contactor with a 460V coil. 208, 220, and 220/440V coils may also be used.

## Table 6 - Certified Subcomponents/Rigid Base Mount Cont.



DCL Project Number: 19012-2201

		Control Units			
Subcomponent No.	Manufacturer	Description	Material	Approx. Weight (lb.)	Unit
AS-2001		Battery Charger, 12/24VVDC	Aluminum	3	UUT-07
473670-006		Group 1 ATS Control Unit	Plastic	5	UUT-01B
AS-1198/1199	Firetrol, Inc	Mark II Fire Pump Control Unit	CRS Zinc Plate	7	UUT-04B
AS-2000	!	Mark II Fire Pump Control Unit	CK3 ZITIC Flate	7	UUT-07
601800-002		Group 5 ATS Control Unit	Plastic	11	UUT-03B
		Transformers	- 600		
Subcomponent No.	Manufacturer	Description	Material (	Approx. Weight (lb.)	Unit
TF-0204		Control 250VA, 220V-480V		10	UUT-04B
TF-0206	Firetrol, Inc	Control 250VA, 208V	Control 250VA, 208V  12VDC Charger  Laminated Steel (Varnished)	10	Interpolated
TF-1370		12VDC Charger		11	Interpolated
TF-1371		24VVDC Charger		17	UUT-07
		Circuit Breakers	turi Niladi Almasa Karih Miladi karih XXXXXXXX		
Subcomponent No.	Manufacturer	Description	OSP Material 8	Approx. Weight (lb.)	Unit
CC-3091/CC-4053	Manufacturer	Molded Case Circuit Breaker.		33333	
		150/225A Frame		7	UUT-06
CC 4201/CC 4205			Johannad Karim	7	UUT-06 Same as
CC-4201/CC-4205		150/225A Frame	Mohammad Karim		
CC-4201/CC-4205 PL-1220		150/225A Frame Molded Case Circuit Breaker, 150, 175A (250A Frame) Molded Case Circuit Breaker,		7	Same as
PL-1220	ABB	150/225A Frame Molded Case Circuit Breaker, 150, 175A (250A Frame)		6 7	Same as UUT-06
	ABB	150/225A Frame Molded Case Circuit Breaker, 150, 175A (250A Frame) Molded Case Circuit Breaker, 250A Frame Molded Case Circuit Breaker,	Mohammad Karim E: 01/18/2023	6	Same as UUT-06 UUT-01B Same as
PL-1220	ABB	150/225A Frame Molded Case Circuit Breaker, 150, 175A (250A Frame) Molded Case Circuit Breaker, 250A Frame		6 7	Same as UUT-06 UUT-01B

<sup>1.</sup> CC-4097 was previously PL-1221

<sup>2.</sup> CC-4167 was previously PL-1222

## . Table 6 - Certified Subcomponents/Rigid Base Mount Cont.



DCL Project Number: 19012-2201

		Soft Starters			
Subcomponent No.	Manufacturer	Description	Material	Approx. Weight (lb.)	Unit
VF-1689		65A		26	UUT-06
VF-1690		56A		27	Interpolated
VF-1691	Benshaw	240A	Aluminum	37	UUT-01B
VF-1693		720A		110	Interpolated
VF-1692		552A		110	UUT-08A
		Autotransformers	- 600		
Subcomponent No.	Manufacturer	Description	Material (	Approx. Weight (lb.)	Unit
TF-1039		25/30 HP		51	UUT-08B
TF-1064	Hammond	100 HP	Laminated Steel (Varnished)	140	UUT-05
TF-1084		250 HP	Laminated Steel (Varnished)	245	Interpolated
TF-1078		200 HP		280	UUT-08A
		Automatic Transfer Sw	itches	17.	
Subcomponent No.	Manufacturer	Description	OSP Material 8	Approx. Weight (lb.)	Unit
9403104, 9403150,		D Frame STD ATS 30-230A		20	UUT-01B
ATS3100, 7ATS3150 9403260, 9403400,					
ATS3260, 7ATS3400		E Frame STD ATS 260/400A	Mohammad Karim	45	UUT-03B
9403400, 9403800, 4031000, 7ATS3400, ATS3800, 7ATS31000	Firetrol, Inc	H Frame STD ATS 600/800/1000A	Plastic F: 01/18/2023	142	Interpolated
ATB3150, 7ATB3260, 7ATB3400		E Frame BYPASS ATS 260/400A		145	UUT-03B
ATB3150, 7ATB3260, ATB3400, 7ATB3600		J Frame BYPASS ATS 400/600A		600	UUT-02C
		Resistor Banks			
Subcomponent No.	Manufacturer	Description	Material	Approx. Weight (lb.)	Unit
RS-4601	Post Glover	Resistor Set	RI IT Stainless Steel	9	Extrapolated*
	FOST GIONEL	ו הפאאנטו אפנ	Stalliess steel	15	UUT-04B

### **Special Seismic Certification** Table 7 - Tested Units



DCL Project Number:
Manufacturer:
Mounting Configuration 19012-2201 Firetrol, Inc

Wall and Base Mount

	Model Line	Notes –		Dimensi	ons (in)	Max. Weight	Mounting	Sds (g)	Unit
Model Number	Model Line	Notes	Depth	Width	Height	(lb.)	Configuration	Sas (g)	Unit
FTA550F-AG014B-BW	FTA550F Across-the-Line		8	14	16	15		2.50	UUT-1
FTA550F-AG002D-AM-NZ	Jockey Pump Controller	Across-the-Line Jockey Pump Controller	8	14	16	15		2.50	UUT-12
FTA550E-AA013B-BW	FTA550E Across-the-Line	Across-the-Line Jockey Pullip Controller	8	20	24	57		2.50	UUT-09
FTA550E-AA050B-BW	Jockey Pump Controller		8	20	24	66		2.50	UUT-10
FTA500-AF-01B-BN		Jockey Pump Controller with Fusible Disconnect	8	18	24	44	Wall Mount	2.50	UUT-04
FTA500-AF-50B-BN	FTA500 Across-the-Line	Line , 1 OK CODE 8	8	18	24	50	wan wount	1.80	UUT-02
FTA500-AA-50B-BN	Jockey Pump Controller	Jockey Pump Controller with Circuit Breaker	0,8	18	24	50		1.93	UUT-01
FTA1100-JL24N		5: JEHUNGHAMAN AND AND AND AND AND AND AND AND AND A	12	26	36	160		2.50	UUT-1
FTA1100-JL12N	TA 1100 Diesel Engine Fire Pump	Diesel Engine Controller	12	26	36	160		2.50	UUT-1
FTA1100-JL24N	Controllers	Diesel Engine Controller Type 2 Enclosure	12	26	48	192		1.80	UUT-03
FTA1100-JL24N-FDP		Diesel Engine Controller SS Type 4X Enclosure	12	26	60	208		2.50	UUT-0
916750-001	Soft Starter and	25HP, 480V Autotransformer	14	26	68	240		2.50	UUT-08
916750	Autotransformer	552A Soft Starter and 200HP, 380V  Autotransformer	14	26	68	580		2.50	UUT-08
FTA1930-AM50B		Soft-start Electric Controller	12	38	60	280		2.50	UUT-0
FTA1350-AM200B	FTA 900/901/950/951	Wye-Delta Start Electric Controller	14	41	68	380	Base Mount	2.50	UUT-04
FTA1800-AM100B	Electric Fire Pump Controllers and	Autotransformer Start Controller	12	38	60	418		2.50	UUT-0
FTA1000-AM300F	· · · · · · · · · · · · · · · · · · ·	Across-the-Line Electric Controller	18	36	80	575		1.80	UUT-02
FTA1930-AM150B-TS		Soft-start Electric Controller with Standard ATS	312	76	C60	645		1.80	UUT-01
FTA950-AM150B			O 12		00	043		1.00	001-01
	Controllers		24	71	70	750		1.80	UUT-03
J7ACTBB30600N5XM	J-Bypass ATS	J-Bypass ATS Type 3R Enclosure	37	49	95	1762		1.93	UUT-02
FTA1930-AM150B-TS FTA950-AM150B FTA1000-AM100B-TAB FTA951-AM100B	FTA 1000-1930 Diesel Engine Fire Pump Controllers	Across-the-Line Electric Controller  Soft-start Electric Controller with Standard ATS  Across-the-Line Electric Controller with  E-Bypass ATS	3 <sub>12</sub> 24 37	76 71	60 70		750	750	645     1.80       750     1.80

# UUT-01A Unit Under Test (UUT) Summary Sheet



DCL Project Number: 19012-2201

Manufacturer: Firetrol, Inc

**Product Line:** Fire Pump Controllers and Accessories **Test Laboratory:** DCL (Report No. 99864-1001, UUT1)

Model Number: FTA500-AA-50B-BN

**Product Construction Summary:** 

14 gage painted, cold rolled steel enclosure, NEMA 2

#### **Options / Component Summary:**

FTA500 Low Voltage Across-the-Line Jockey Pump Controller with A75 contactor and 100 Amp circuit breaker

Note: The UUT was operational before and after shaking and was full of operating content during the tests. The structural integrity of the component attachment system and force-resisting systems was maintained.

			FUTU	UT Properties	-01			
Woight (lh)		Di	mensions (incl	Lowest Natural Frequency (Hz)				
Weight (lb)	Depth	Width		He	ight	Front-Back	Side-Side	Vertical
50	8		18		24	N/A	N/A	N/A
		4	Seismi	c Test Paramet	ers			
<b>Building Code</b>	Test Criteria	Sds (g)	z/h	lp.	Aflx-H (g)	Arig-H (g)	Aflx-V (g)	Arig-V (g)
CBC 2022	ICC-ES AC156	1.93	8 <b>Y:40</b> loh	amn <del>1</del> 5d K	arin3.09	2.32	1.29	0.51

#### **Unit Mounting Description:**



The rigid-mount support system consisted of a rigid steel frame, a stud wall composed of 16-gage steel studs at 24-inches on center, and backing plates to accommodate the UUT as per manufacturer's instructions. An overall view of the support system and UUT is shown above. The support system, including rigid steel frame and its attachment to the shake table platform, was provided by DCL. The fixturing wall was attached to the shake table using M12 threaded rod at a spacing of approximately 12-inches on center. The UUT was attached to the fixturing wall at four corners utilizing 1/4-inch 20x1 hex cap bolts and the existing openings in the back of the back-box. (note: attachment in the field need not match the test, but must be acceptable to the engineer of record)

# UUT-01B Unit Under Test (UUT) Summary Sheet



DCL Project Number: 19012-2201

Manufacturer: Firetrol, Inc

**Product Line:** Fire Pump Controllers and Accessories

Test Laboratory: Wyle (Report No. T57168-1)

Model Number: FTA1930-AM150B-TS, FTA950-AM150B

**Product Construction Summary:** 

14 gage painted, cold rolled steel enclosure, NEMA 2

#### Options / Component Summary:

FTA1930 Soft Start Fire Pump Controller w/Mark II XG and D-Frame ATS

Note: The UUT was operational before and after shaking and was full of operating content during the tests. The structural integrity of the component attachment system and force-resisting systems was maintained.

			FORU	UT Properties	-01			
Weight (lh)		D	imensions (inc	Lowest Natural Frequency (Hz)				
Weight (lb)	Depth	N	/idth	Height		Front-Back	Side-Side	Vertical
644	12		76		50	7 7	18	>33
	-	4	Seismi	c Test Paramet	ers			
<b>Building Code</b>	Test Criteria	Sds (g)	z/h	lp.	Aflx-H (g)	Arig-H (g)	Aflx-V (g)	Arig-V (g)
CBC 2022	ICC-ES AC156	1.8	BY:49loh	amn <del>1</del> 5d K	arir2.88	2.16	1.20	0.48

#### **Unit Mounting Description:**



The UUT was bolted to a Wyle-fabricated test fixture using twelve 1/2-inch Grade 5 bolts. The test fixture was welded to the seismic test table so that the horizontal axes of the UUT were colinear with the horizontal axes of the test table.

## UUT-02A Unit Under Test (UUT) Summary Sheet



DCL Project Number: 19012-2201

Manufacturer: Firetrol, Inc

**Product Line:** Fire Pump Controllers and Accessories **Test Laboratory:** DCL (Report No. 99864-1001, UUT2)

Model Number: FTA500-AF-50B-BN

Product Construction Summary:

14 gage painted, cold rolled steel enclosure, NEMA 2

Options / Component Summary:

FTA500 Low Voltage Across-the-Line Jockey Pump Controller with A75 contactor and 100 Amp fusible disconnect

Note: The UUT was operational before and after shaking and was full of operating content during the tests. The structural integrity of the component attachment system and force-resisting systems was maintained.

			FORU	UT Properties	-01			
Weight (lh)		D	imensions (inc	Lowest Natural Frequency (Hz)				
Weight (lb)	Depth	N	/idth	th Height		Front-Back	Side-Side	Vertical
50	8		18	\\\\\\\\\\\\\\\\\\\\\\\\\\\\\\\\\\\\\\	24	/ N/A	N/A	N/A
	-	4	Seismi	c Test Paramet	ers			
<b>Building Code</b>	Test Criteria	Sds (g)	z/h	lp.	Aflx-H (g)	Arig-H (g)	Aflx-V (g)	Arig-V (g)
CBC 2022	ICC-ES AC156	1.93	BY:400h	amn <del>1</del> 5d K	arir³,09	2.32	1.29	0.51

#### Unit Mounting Description:



The rigid-mount support system consisted of a rigid steel frame, a stud wall composed of 16-gage steel studs at 24-inches on center, and backing plates to accommodate the UUT as per manufacturer's instructions. An overall view of the support system and UUT is shown above. The support system, including rigid steel frame and its attachment to the shake table platform, was provided by DCL. The fixturing wall was attached to the shake table using M12 threaded rod at a spacing of approximately 12-inches on center. The UUT was attached to the fixturing wall at four corners utilizing 1/4-inch 20x1 hex cap bolts and the existing openings in the back of the back-box.

# UUT-02B Unit Under Test (UUT) Summary Sheet



DCL Project Number: 19012-2201

Manufacturer: Firetrol, Inc

**Product Line:** Fire Pump Controllers and Accessories

Test Laboratory: Wyle (Report No. T57168-2)

Model Number: FTA1000-AM300F

Product Construction Summary:

14 gage painted, cold rolled steel enclosure, NEMA 2

Options / Component Summary:

FTA1000 Across-the-Line Fire Pump Controller w/ Mark II XG

Note: The UUT was operational before and after shaking and was full of operating content during the tests. The structural integrity of the component attachment system and force-resisting systems was maintained.

			FOTU	JT Properties	-01			
Woight (lh)			Dimensions (incl	Lowest	Lowest Natural Frequency (Hz)			
Weight (lb)	Depth	(1)	<b>Width</b>	Height		Front-Back	Side-Side	Vertical
600	18		36	3-14-10-14-18	30	9	11	>33
		14/	Seismi	c Test Paramet	ers			
<b>Building Code</b>	Test Criteria	Sds (g)	z/h	Ip.	Aflx-H (g)	Arig-H (g)	Aflx-V (g)	Arig-V (g)
CBC 2022	ICC-ES AC156	1.8	BY:49oh	amn <del>1</del> ād K	arir2,88	2.16	1.20	0.48

#### **Unit Mounting Description:**



The UUT was bolted to a Wyle-fabricated test fixture using six 1/2-inch Grade 5 bolts. The test fixture was welded to the seismic test table so that the horizontal axes of the UUT were colinear with the horizontal axes of the test table.

## UUT-02C Unit Under Test (UUT) Summary Sheet



DCL Project Number: 19012-2201

Manufacturer: Firetrol, Inc

**Product Line:** Fire Pump Controllers and Accessories

Test Laboratory: Wyle (Report No. 58168R10-2)

Model Number: J7ACTBB30600N5XM

**Product Construction Summary:** 

14 gage painted, cold rolled steel enclosure, NEMA 3R

#### Options / Component Summary:

J 600 Amp bypass switch, 480V, 50-60 Hz, 3 phase, 3 poles w/ an additional switched neutral

Note: The UUT was operational before and after shaking and was full of operating content during the tests. The structural integrity of the component attachment system and force-resisting systems was maintained.

			FORU	UT Properties	-01				
Dimensions (inches)  Lowest Natural Frequency (Hz)									
Weight (lb)	Depth	130	Vidth	Height		Front-Back	Side-Side	Vertical	
1,726	37		49	· · · · · · · · · · · · · · · · · · ·	95	8.6	9.5	>33	
		4	Seismi	c Test Paramet	ers				
Building Code	Test Criteria	Sds (g)	z/h	lp	Aflx-H (g)	Arig-H (g)	Aflx-V (g)	Arig-V (g)	
CBC 2022	ICC-ES AC156	2.5	BY:40loh	amn <del>1</del> 5d K	arir4.00	3.00	1.68	0.67	

#### **Unit Mounting Description:**



The UUT was bolted to a Wyle-fabricated test fixture using eight 1/2-inch Grade 5 bolts. The test fixture was welded to the seismic test table so that the horizontal axes of the UUT were colinear with the horizontal axes of the test table.

# UUT-03A Unit Under Test (UUT) Summary Sheet



DCL Project Number: 19012-2201

Manufacturer: Firetrol, Inc

**Product Line:** Fire Pump Controllers and Accessories **Test Laboratory:** Wyle (Report No. 54614R07, EUT3)

Model Number: FTA1100-JL24N

Product Construction Summary:

14 gage painted, cold rolled steel enclosure, NEMA 2

Options / Component Summary:

FTA1100 Mark II Diesel Engine Fire Pump Controller

Note: The UUT was operational before and after shaking and was full of operating content during the tests. The structural integrity of the component attachment system and force-resisting systems was maintained.

			FORU	JT Properties	-01			
Weight (lb)		1	<mark>Oimensio</mark> ns (inch	Lowest Natural Frequency (Hz)				
weight (ib)	Depth	V	Vidth	<b>A</b> He	ight	Front-Back Side-Side		Vertical
192	12		26	4	8	7 11	19	30
		44/	Seismi	Test Paramet	ers			
<b>Building Code</b>	Test Criteria	Sds (g)	z/h	Ip.	Aflx-H (g)	Arig-H (g)	Aflx-V (g)	Arig-V (g)
CBC 2022	ICC-ES AC156	1.8	BY:40oh	amm <del>1</del> 5d K	arir <sup>2,88</sup>	2.16	1.20	0.48

#### **Unit Mounting Description:**



The UUT was bolted to a Wyle-fabricated test fixture using six 1/2-inch Grade 5 bolts. The test fixture was welded to the seismic test table so that the horizontal axes of the UUT were colinear with the horizontal axes of the test table.

## UUT-03B Unit Under Test (UUT) Summary Sheet



DCL Project Number: 19012-2201

Manufacturer: Firetrol, Inc

**Product Line:** Fire Pump Controllers and Accessories

Test Laboratory: Wyle (Report No. T57345-3)

Model Number: FTA1000-AM100B-TAB, FTA951-AM100B

**Product Construction Summary:** 

14 gage painted, cold rolled steel enclosure. NEMA 2

Options / Component Summary:

ASCO FTA1000 Across-the-Line Fire Pump Controller w/ Mark II XG and E-Bypass ATS

Note: The UUT was operational before and after shaking and was full of operating content during the tests. The structural integrity of the component attachment system and force-resisting systems was maintained.

			FORU	UT Properties	-01			
Maight (lh)		Ď	imensions (inc	Lowest Natural Frequency (Hz)				
Weight (lb)	Depth	N	Vidth Height		Front-Back	Side-Side	Vertical	
800	24		71	XXX	70	8.5	10	>33
		4	Seismi	c Test Paramet	ers			
<b>Building Code</b>	Test Criteria	Sds (g)	z/h	lp.	Aflx-H (g)	Arig-H (g)	Aflx-V (g)	Arig-V (g)
CBC 2022	ICC-ES AC156	1.8	BY:40loh	amn <del>1</del> 5d K	arir2.88	2.16	1.20	0.48

#### **Unit Mounting Description:**



The UUT was bolted to a Wyle-fabricated test fixture using twelve 1/2-inch Grade 5 bolts. The test fixture was welded to the seismic test table so that the horizontal axes of the UUT were colinear with the horizontal axes of the test table.

## UUT-04A Unit Under Test (UUT) Summary Sheet



DCL Project Number: 19012-2201

Manufacturer: Firetrol, Inc

**Product Line:** Fire Pump Controllers and Accessories **Test Laboratory:** Wyle (Report No. T57168-4, UUT4)

Model Number: FTA500-AF-01B-BN

14 gage painted, cold rolled steel enclosure, NEMA 2

#### Options / Component Summary:

**Product Construction Summary:** 

FTA500 Low Voltage Across-the-Line Jockey Pump Controller with A12 contactor and 30 Amp fusible disconnect

Note: The UUT was operational before and after shaking and was full of operating content during the tests. The structural integrity of the component attachment system and force-resisting systems was maintained.

			O. O.	UT Properties	-01			
Weight (lh)		D	imensions (incl	Lowest Natural Frequency (Hz)				
Weight (lb)	Depth	Width		He	Height		Side-Side	Vertical
44	8		18	2	24	N/A	N/A	N/A
		14/	Seismi	ic Test Paramet	ers			
Building Code	Test Criteria	Sds (g)	z/h	lp.	Aflx-H (g)	Arig-H (g)	Aflx-V (g)	Arig-V (g)
CBC 2022	ICC-ES AC156	1.8	BY:40oh	amn <del>1</del> ād K	arin2.88	2.16	1.20	0.48

DATE: 01/18/2023

#### **Unit Mounting Description:**





The UUT was bolted to a Wyle-fabricated test fixture using three 5/16-inch Grade 5 bolts. The test fixture was welded to the seismic test table so that the horizontal axes of the UUT were colinear with the horizontal axes of the test table.

#### Overall view of UUT-04A

01/18/2023 OSP-0158 Page 18 of 30

## UUT-04B Unit Under Test (UUT) Summary Sheet



DCL Project Number: 19012-2201

Manufacturer: Firetrol, Inc.

**Product Line:** Fire Pump Controllers and Accessories

Test Laboratory: Wyle (Report No. 58168R10-4)

Model Number: FTA1350-AM200B

Product Construction Summary:

14 gage painted, cold rolled steel enclosure, NEMA 2

#### Options / Component Summary:

FTA1350 Electric Motor Fire Pump Controller, Wye-Delta Start, 480 Vac, 50/60Hz, Three Phase

Note: The UUT was operational before and after shaking and was full of operating content during the tests. The structural integrity of the component attachment system and force-resisting systems was maintained.

			FORU	UT Properties	-01				
Maight (lh)		É	imensions (incl	hes)	Lowest Natural Frequency (H				
Weight (lb)	Depth	/\/N	/idth Height		Front-Back	Side-Side	Vertical		
380	14		41	\\\\\\\\\\\\\\\\\\\\\\\\\\\\\\\\\\\\\\	58	12.5	33		
		4	Seismi	c Test Paramet	ers				
<b>Building Code</b>	Test Criteria	Sds (g)	z/h	lp	Aflx-H (g)	Arig-H (g)	Aflx-V (g)	Arig-V (g)	
CBC 2022	ICC-ES AC156	2.5	BY:400h	amn <del>1</del> 5d K	arir4.00	3.00	1.68	0.67	

#### **Unit Mounting Description:**



UUT4B is shown in the front-center of the test units in the above photo. The UUT was bolted to a Wyle-fabricated test fixture using six 5/16-inch Grade 5 bolts. The test fixture was welded to the seismic test table so that the horizontal axes of the UUT were colinear with the horizontal axes of the test table.

#### Overall view of UUT-04B

01/18/2023 OSP-0158 Page 19 of 30

# UUT-05 Unit Under Test (UUT) Summary Sheet



DCL Project Number: 19012-2201

Manufacturer: Firetrol, Inc.

**Product Line:** Fire Pump Controllers and Accessories

Test Laboratory: Wyle (Report No. 58168R10-5)

Model Number: FTA1800-AM100B

Product Construction Summary:

Single door, 14 gage CRS enclosure, welded construction, NEMA 2

#### Options / Component Summary:

FTA 1800 Autotransformer Start Electric Controller with Mark II XG operator interface and a water pressure transducer

Note: The UUT was operational before and after shaking and was full of operating content during the tests. The structural integrity of the component attachment system and force-resisting systems was maintained.

			FORU	UT Properties	-01			
Weight (lh)		D	imensions (incl	Lowest	Lowest Natural Frequency (Hz)			
Weight (lb)	Depth	N	/idth	<b>M</b> A He	ight	Front-Back	Side-Side	Vertical
418	14		38	h	50	10	15	>33
		4	Seismi	c Test Paramet	ers			
<b>Building Code</b>	Test Criteria	Sds (g)	z/h	lp.	Aflx-H (g)	Arig-H (g)	Aflx-V (g)	Arig-V (g)
CBC 2022	ICC-ES AC156	2.5	BY:49oh	amn <del>1</del> ād K	arir4.00	3.00	1.68	0.67

#### **Unit Mounting Description:**



The UUT was bolted to a Wyle-fabricated test fixture using six 5/16-inch Grade 5 bolts. The test fixture was welded to the seismic test table so that the horizontal axes of the UUT were colinear with the horizontal axes of the test table.

# UUT-06 Unit Under Test (UUT) Summary Sheet



DCL Project Number: 19012-2201

Manufacturer: Firetrol, Inc

**Product Line:** Fire Pump Controllers and Accessories

Test Laboratory: Wyle (Report No. 58168R10-6)

Model Number: FTA1930-AM50B

Product Construction Summary:

Single door, 14 gage CRS enclosure, welded construction, NEMA 2

#### Options / Component Summary:

FTA1930 Soft Start Electric Controller with Mark II XG Operator Interface and a water pressure transducer

Note: The UUT was operational before and after shaking and was full of operating content during the tests. The structural integrity of the component attachment system and force-resisting systems was maintained.

UUT Properties										
Moight (lb)		D	imensions (incl	Lowest Natural Frequency (Hz)						
Weight (lb)	Depth	W	<mark>/idth</mark>	<b>A</b> He	ight	Front-Back	Front-Back Side-Side Ve			
280	12	50	7 9	21.5	>33					
		4	Seismi	c Test Paramet	ers					
<b>Building Code</b>	Test Criteria	Aflx-H (g)	Arig-H (g)	Aflx-V (g)	Arig-V (g)					
CBC 2022	ICC-ES AC156	2.5	BY:191oh	ammad K	arir4.00	3.00	1.68	0.67		

#### **Unit Mounting Description:**



The UUT was bolted to a Wyle-fabricated test fixture using six 5/16-inch Grade 5 bolts. The test fixture was welded to the seismic test table so that the horizontal axes of the UUT were colinear with the horizontal axes of the test table.

# UUT-07 Unit Under Test (UUT) Summary Sheet



DCL Project Number: 19012-2201

Manufacturer: Firetrol, Inc

**Product Line:** Fire Pump Controllers and Accessories

Test Laboratory: Wyle (Report No. 58168R10-7)

Model Number: FTA1100-JL24N-FDP

**Product Construction Summary:** 

Single door, 14 gage 316 painted stainless steel enclosure, welded construction, NEMA 4X

#### Options / Component Summary:

FTA1100 Diesel Engine Fire Pump Controller SS with Mark II XG operator interface, two 24 V engine battery chargers and a water pressure transducer.

Note: The UUT was operational before and after shaking and was full of operating content during the tests. The structural integrity of the component attachment system and force-resisting systems was maintained.

			, Jul	JT Properties	1/0,			
Maight (lh)		1,5	<mark>Dim</mark> ensions (inch	es)		Lowest Natural Frequency (Hz)		
Weight (lb)	Depth		Width	He	ight	Front-Back	Side-Side	Vertical
208	12	4	26	P-01560		12.5	19.6	>33
			Seismic	Test Paramet	ers	m		
<b>Building Code</b>	Test Criteria	Sds (g)	z/h	lp	Aflx-H (g)	Arig-H (g)	Aflx-V (g)	Arig-V (g)
CBC 2022	ICC-ES AC156	2.5	DY, IVIONA	ammad K 1.5	4.00	3.00	1.68	0.67

01/18/2023

#### **Unit Mounting Description:**



The UUT was bolted to a Wyle-fabricated test fixture using six 5/16-inch Grade 5 bolts. The test fixture was welded to the seismic test table so that the horizontal axes of the UUT were colinear with the horizontal axes of the test table.

# UUT-08A Unit Under Test (UUT) Summary Sheet



DCL Project Number: 19012-2201

Manufacturer: Firetrol, Inc.

**Product Line:** Fire Pump Controllers and Accessories

Test Laboratory: DCL (Report No. 99841-1101)

Model Number: 916750

Product Construction Summary:

Single door, 14 gage CRS enclosure, welded construction, NEMA 2

**Options / Component Summary:** 

552A Soft Starter and 200HP, 380V Autotransformer

Note: The UUT was operational before and after shaking and was full of operating content during the tests. The structural integrity of the component attachment system and force-resisting systems was maintained.

			FOR	UT Properties	-01			
Maight (lh)		Ĺ	imensions (inc	Lowest Natural Frequency (Hz)				
Weight (lb)	Depth	V	Vidth	<b>₩</b> WHe	ight	Front-Back	Side-Side	Vertical
580	14		26	- 68		7 9	9	>33
		4	Seism	ic Test Paramet	ers			
<b>Building Code</b>	Test Criteria	Sds (g)	z/h	lp.	Aflx-H (g)	Arig-H (g)	Aflx-V (g)	Arig-V (g)
CBC 2022	ICC-ES AC156	2.5	BY:40loh	amn <del>15</del> d K	arir4.00	3.00	1.68	0.67

#### **Unit Mounting Description:**



The UUT was bolted to a DCL-fabricated test fixture using six 1/2-inch Grade 5 bolts (3 per leg). The test fixture was attached to the seismic test table with M12 threaded rod, spaced approximately 8-inches on center, so that the horizontal axes of the UUT were colinear with the horizontal axes of the test table.

# UUT-08B Unit Under Test (UUT) Summary Sheet



DCL Project Number: 19012-2201

Manufacturer: Firetrol, Inc

**Product Line:** Fire Pump Controllers and Accessories

Test Laboratory: DCL (Report No. 99841-1101)

Model Number: 916750-001

Product Construction Summary:

Single door, 14 gage CRS enclosure, welded construction, NEMA 2

**Options / Component Summary:** 

25HP, 480V Autotransformer

Note: The UUT was operational before and after shaking and was full of operating content during the tests. The structural integrity of the component attachment system and force-resisting systems was maintained.

			FORU	UT Properties	-01				
Woight (lh)		Dimensions (inches)					Lowest Natural Frequency (Hz)		
Weight (lb)	Depth	W	idth	<b>A</b> He	ight	Front-Back	Side-Side	Vertical	
240	14		26	68		8.5	8.8	>33	
		4	Seismi	c Test Paramet	ers				
<b>Building Code</b>	Test Criteria	Sds (g)	z/h	Ip.	Aflx-H (g)	Arig-H (g)	Aflx-V (g)	Arig-V (g)	
CBC 2022	ICC-ES AC156	2.5	BY:191oh	amm <del>1</del> 5d K	arir4.00	3.00	1.68	0.67	

#### **Unit Mounting Description:**



The UUT was bolted to a DCL-fabricated test fixture using six 1/2-inch Grade 5 bolts (3 per leg). The test fixture was attached to the seismic test table with M12 threaded rod, spaced approximately 8-inches on center, so that the horizontal axes of the UUT were colinear with the horizontal axes of the test table.

## UUT-09 Unit Under Test (UUT) Summary Sheet



**DCL Project Number:** 19012-2201

Manufacturer: Firetrol, Inc

**Product Line:** Fire Pump Controllers and Accessories **Test Laboratory:** DCL (Report No. 99683-1201)

Model Number: FTA550E-AA013B-BW

**Product Construction Summary:** 

NEMA Type 2 painted cold rolled steel enclosure

#### **Options / Component Summary:**

Programmable running period timer, circuit breaker, 1/3 HP, 480V-3Phase and contacts for remote indication and system pressure

Note: The UUT was operational before and after shaking and was full of operating content during the tests. The structural integrity of the component attachment system and force-resisting systems was maintained.

			FOTU	UT Properties	-01			
Operating Weight		1	<mark>Dimensio</mark> ns (inch	Lowest Natural Frequency (Hz)				
(lb)	Depth	Width		Height		Front-Back	Side-Side	Vertical
57	8		20	24		N/A	N/A	N/A
		4	Seismi	c Test Paramet	ers			
<b>Building Code</b>	Test Criteria	Sds (g)	z/h	Ip.	Aflx-H (g)	Arig-H (g)	Aflx-V (g)	Arig-V (g)
CBC 2022	ICC-ES AC156	2.5	BY:1Moh	amm <del>lá</del> d K	arin <sup>4.00</sup>	3.00	1.67	0.67

#### **Unit Mounting Description:**



Unit attached to DCL steel stud wall shake table interface fixture with four 3/8-inch diameter Grade 5 bolts, using the manufacturer-provided mounting holes at the back of the enclosure.

# UUT-10 Unit Under Test (UUT) Summary Sheet



DCL Project Number: 19012-2201

Manufacturer: Firetrol, Inc

**Product Line:** Fire Pump Controllers and Accessories **Test Laboratory:** DCL (Report No. 99683-1201)

Model Number: FTA550E-AA050B-BW

**Product Construction Summary:** 

NEMA Type 2 painted cold rolled steel enclosure

#### Options / Component Summary:

Programmable running period timer, circuit breaker, 50 HP, 480V-3Phase and contacts for remote indication and system pressure

Note: The UUT was operational before and after shaking and was full of operating content during the tests. The structural integrity of the component attachment system and force-resisting systems was maintained.

			FOTU	JT Properties	-01			
Operating Weight			D <mark>imensio</mark> ns (inch	Lowest Natural Frequency (Hz)				
(lb)	Depth	Width		Height		Front-Back	Side-Side	Vertical
66	8		20	24		N/A	N/A	N/A
		4	Seismi	Test Paramet	ers			
<b>Building Code</b>	Test Criteria	Sds (g)	z/h	lp	Aflx-H (g)	Arig-H (g)	Aflx-V (g)	Arig-V (g)
CBC 2022	ICC-ES AC156	2.5	BY:1Moha	mm <del>lá</del> d K	arin <sup>4.00</sup>	3.00	1.67	0.67

#### **Unit Mounting Description:**



Unit attached to DCL steel stud wall shake table interface fixture with four 3/8-inch diameter Grade 5 bolts, using the manufacturer-provided mounting holes at the back of the enclosure.

## UUT-11 Unit Under Test (UUT) Summary Sheet



DCL Project Number: 19012-2201

Manufacturer: Firetrol, Inc

**Product Line:** Fire Pump Controllers and Accessories **Test Laboratory:** DCL (Report No. 99683-1201)

Model Number: FTA550F-AG014B-BW

**Product Construction Summary:** 

NEMA Type 2/3R/4/4X/12 polycarbonate enclosure

#### Options / Component Summary:

Programmable running period timer, manual motor protector, 1/4 HP, 480V-3Phase and contacts for remote indication and phase failure/reversal

Note: The UUT was operational before and after shaking and was full of operating content during the tests. The structural integrity of the component attachment system and force-resisting systems was maintained.

			UU	IT Properties	1/10)			
<b>Operating Weight</b>			<mark>Dim</mark> ensions (inch	Lowest Natural Frequency (Hz)				
(lb)	Depth		Width		Front-Back	Side-Side	Vertical	
15	8	TI (	14	D 015 <sup>15.5</sup>		N/A	N/A	N/A
		Q	Seismic	Test Paramet	ters			
<b>Building Code</b>	Test Criteria	Sds (g)	z/h	lp	Aflx-H (g)	Arig-H (g)	Aflx-V (g)	Arig-V (g)
CBC 2022	ICC-ES AC156	2.5	BY: Mona	immad K 1.5	4.00	3.00	1.67	0.67

#### **Unit Mounting Description:**



Unit attached to DCL steel stud wall shake table interface fixture with four 3/8-inch diameter Grade 5 bolts, using the manufacturer-provided mounting holes at the back of the enclosure.

## UUT-12 Unit Under Test (UUT) Summary Sheet



DCL Project Number: 19012-2201

Manufacturer: Firetrol, Inc

Product Line: Fire Pump Controllers and Accessories
Test Laboratory: DCL (Report No. 99683-1201)

Model Number: FTA550F-AG002D-AM-NZ

#### **Product Construction Summary:**

NEMA Type 2/3R/4/4X/12 polycarbonate enclosure

#### Options / Component Summary:

Programmable running period timer, manual motor protector, 2 HP, 110V-1Phase; contacts for remote indication, failed to start; interlock output contacts to prevent jockey pump from starting during main controller operation

Note: The UUT was operational before and after shaking and was full of operating content during the tests. The structural integrity of the component attachment system and force-resisting systems was maintained.

			UU	IT Properties	1/10)			
Operating Weight		13	<mark>Dim</mark> ensions (inch	Lowest Natural Frequency (Hz)				
(lb)	Depth	Width		Height		Front-Back	Side-Side	Vertical
15	8	4	14	D 015 <sup>15.5</sup>		N/A	N/A	N/A
			Seismic	Test Parameto	ers	M		
Building Code	Test Criteria	Sds (g)	z/h	lp	Aflx-H (g)	Arig-H (g)	Aflx-V (g)	Arig-V (g)
CBC 2022	ICC-ES AC156	2.5	BY: IVIONS	immad K 1.5	4.00	3.00	1.67	0.67

#### **Unit Mounting Description:**



Unit attached to DCL steel stud wall shake table interface fixture with four 3/8-inch diameter Grade 5 bolts, using the manufacturer-provided mounting holes at the back of the enclosure.

# UUT-13 Unit Under Test (UUT) Summary Sheet



DCL Project Number: 19012-2201

Manufacturer: Firetrol, Inc

**Product Line:** Fire Pump Controllers and Accessories **Test Laboratory:** DCL (Report No. 99683-1201)

Model Number: FTA1100-JL24N

Product Construction Summary:

NEMA Type 2, painted cold rolled steel enclosure

#### **Options / Component Summary:**

Diesel engine fire pump controller, Mark II controller, lead acid battery, 24V DC, negative ground

Note: The UUT was operational before and after shaking and was full of operating content during the tests. The structural integrity of the component attachment system and force-resisting systems was maintained.

			FONU	JT Properties	-01			
Operating Weight		1	<mark>Dimensio</mark> ns (incl	Lowest Natural Frequency (Hz)				
(lb)	Depth	Width		Height		Front-Back	Side-Side	Vertical
160	12		26	36		N/A	N/A	N/A
		4	Seismi	Test Paramet	ers			
<b>Building Code</b>	Test Criteria	Sds (g)	z/h	Ip	Aflx-H (g)	Arig-H (g)	Aflx-V (g)	Arig-V (g)
CBC 2022	ICC-ES AC156	2.5	BY:100h	amm <del>lá</del> d K	arin <sup>4.00</sup>	3.00	1.67	0.67

#### **Unit Mounting Description:**



Unit attached to DCL steel stud wall shake table interface fixture with four 1/2-inch diameter Grade 5 bolts, using the manufacturer-provided mounting tabs at the back of the enclosure.

# UUT-14 Unit Under Test (UUT) Summary Sheet



DCL Project Number: 19012-2201

Manufacturer: Firetrol, Inc

**Product Line:** Fire Pump Controllers and Accessories **Test Laboratory:** DCL (Report No. 99683-1201)

Model Number: FTA1100-JL12N

Product Construction Summary:

NEMA Type 2, painted cold rolled steel enclosure

#### **Options / Component Summary:**

Diesel engine fire pump controller, Mark II controller, lead acid battery, 12V DC, negative ground

Note: The UUT was operational before and after shaking and was full of operating content during the tests. The structural integrity of the component attachment system and force-resisting systems was maintained.

			FOTU	JT Properties	-01			
Operating Weight		1	<mark>Dimensio</mark> ns (inch	Lowest Natural Frequency (Hz)				
(lb)	Depth	Width		Height		Front-Back	Side-Side	Vertical
160	12		26	36		N/A	N/A	N/A
		4	Seismi	Test Paramet	ers			
<b>Building Code</b>	Test Criteria	Sds (g)	z/h	Ip	Aflx-H (g)	Arig-H (g)	Aflx-V (g)	Arig-V (g)
CBC 2010	ICC-ES AC156	2.5	BY:1Moh	amm <del>lá</del> d K	arin <sup>4.00</sup>	3.00	1.67	0.67

#### **Unit Mounting Description:**



Unit attached to DCL steel stud wall shake table interface fixture with four 1/2-inch diameter Grade 5 bolts, using the manufacturer-provided mounting tabs at the back of the enclosure.