

DEPARTMENT OF HEALTH CARE ACCESS AND INFORMATION FACILITIES DEVELOPMENT DIVISION

OFFICE USE ONLY APPLICATION FOR HCAI SPECIAL SEISMIC **CERTIFICATION PREAPPROVAL (OSP)** APPLICATION #: OSP-0166 **HCAI Special Seismic Certification Preapproval (OSP)** Type: New Renewal **Manufacturer Information** Manufacturer: TK Elevator Manufacturer's Technical Representative: Ray Nooner Mailing Address: 9280 Crestwyn Hills Drive, Memphis, TN 38125 Telephone: (901) 261-1800 Email: Ray.nooner@tkelevator.com **Product Information** Product Name: Elevator Equipment Product Type: Elevator Controllers Product Model Number: Varies, see attachment. Carbon steel cabinets with internal electrical components. General Description: Mounting Description: Rigid, Wall Mounted Seismic enhancements made to the test units and/or modifications required to address Tested Seismic Enhancements: anomalies during the tests shall be incorporated into the production units. **Applicant Information** Applicant Company Name: TRU Compliance, by Structural Integrity Associates, Inc. Contact Person: Daniel Zentner Mailing Address: 5215 Hellyer Ave. Suite 210, San Jose, CA 95138

Email: dzentner@structint.com





STATE OF CALIFORNIA - HEALTH AND HUMAN SERVICES AGENCY

Telephone: (541) 292-5839

Title: Program Manager

08/18/2022 OSP-0166 Page 1 of 15



DEPARTMENT OF HEALTH CARE ACCESS AND INFORMATION FACILITIES DEVELOPMENT DIVISION

•
California Licensed Structural Engineer Responsible for the Engineering and Test Report(s)
Company Name: STRUCTURAL INTEGRITY ASSOCIATES, INC.
Name: Andrew Coughlin California License Number: S6082
Mailing Address: 5215 Hellyer Ave, Suite 101, San Jose, CA 95138-1025
Telephone: (415) 635-8461 Email: acoughlin@structint.com
Certification Method
☐ GR-63-Core
Other (Please Specify):
EOR CODE CO.
Testing Laboratory
Company Name: NATIONAL TECHNICAL SYSTEMS (NTS)
Contact Person: Robert Bridges
Mailing Address: 7800 Highway 20 West, Huntsville AL 35806
Telephone: (256) 837-4411 By Email: Robert.Bridges@nts.com
DATE: 08/18/2022
A Street Control of the Control of t







08/18/2022 OSP-0166 Page 2 of 15



DEPARTMENT OF HEALTH CARE ACCESS AND INFORMATION FACILITIES DEVELOPMENT DIVISION

Seismic Parameters	eismic Parameters							
Design Basis of Equipment or Components (F _p /W _p) = 1.08								
SDS (Design spectral response acceleration at short period, g) = 1.5								
ap (Amplification factor) =	1.0							
R _P (Response modification factor) =	2.5							
Ω_0 (System overstrength factor) =	2.0							
Ip (Importance factor) =	1.5							
z/h (Height ratio factor) =	1 and 0							
Natural frequencies (Hz) =	See Attachment							
Overall dimensions and weight =	See Attachment							

HCAI A	approval (For Office Use Only) - Approval Expires on 08/18	3/2028	
Date:	8/18/2022 OSP-0166	16	
Name:	Mohammad Karim	Title:	Supervisor, Health Facilities
Special :	Seismic Certification Valid Up to: Sps (g) = 1.5	z/h =	See Above
Conditio	on of Approval (if applicable): DATE 08/18/2022		





08/18/2022 OSP-0166 Page 3 of 15

TK Elevator Manufacturing, Inc.



Manufacturer:



Model Line:	Hydraulic Controller						I I A	DLE 1
Certified Product Cons	truction Summary:						·	
NEMA 1, 11 Gauge Carbo	n Steel Enclosure							
Certified Options Summ	marv:							
See Tables 2 - 7 for a con		ied compor	nents.					
	-							
Manustina Configuratio			COL					
Mounting Configuration Wall mounted - rigid	n:	EOF	COL	ECO	1			
Note: Installed mounting confi	iguration must be of simila	ar configuratio	n and equiva	lent strength	and stiffnes	s to thos	e tested.	
Building Code: CBC 202			Y ANN	on Limits:	S _{DS} =	1.5 g	z/h=1.0	/ _P = 1.5
Building Code. CBC 202				XXXXXXVVVXXXXX	S DS=	1.5 g	z/h=0.0	7 p- 1.3
Model Line	Modet		nensions	1	Weight	m)	Notes	UUT
Hydraulic Controller	TAC32	Depth	Width	Height 28.0rin	(lb)	LILITS	133lbs	5.6
Trydradiic Controller	TAC32	B\/9.0 _{/10}	hann	10 20:0rin	n 170	0013.	133003	5, 6
			00/46	/0000				
	12	DAIL:	08/18	3/2022		5/		
			+		WAY S			
				MAMA				
		1						
		B	III DI	NG				
			OILD.	1				

TRU PROJECT NO. 2200407



Manufacturer: Model Line:	TK Elevator Manufacturing, Hydraulic Controller		TABLE 2		
Building Code: CBC 2	2022	Seismic Certification Limits:	$S_{DS} = 1.5 g$ $z/h = 1.0$ $S_{DS} = 1.5 g$ $z/h = 0.0$	I _P = 1.5	
Component Type	Manufacturer	Model	Description	Not	tes UUT
Contactors	Siemens	298AG4 Contactor 298BE1 Mini, 4-po	r, 3-pole, AC		3, 6
		OSP-0	0166		
		O BY: Mohamm	ad Karim O		
		DATE: 08/1	8/2022		
		VIABUILD	INGCOY		

Page 5 of 15

TRU PROJECT NO. 2200407



Manufacturer: TK Elevator Manufacturing, Inc. Table Description: Starters TABLE 3 Model Line: Hydraulic Controller $S_{DS} = 1.5 g z/h = 1.0$ Seismic Certification Limits: **Building Code: CBC 2022** $I_{P} = 1.5$ $S_{DS} = 1.5 g z/h = 0.0$ Description **Component Type** Manufacturer Model UUT **Notes** 200-460V, 22A 787AF1 Extrap. 200-460V, 55A 787AF3 Extrap. 200-460V, 68A 787AF11 Obsolete Model 2, 5 200-460V,80A 787AF12 Interp. **Electronic Starter** Siemens 200-460V, 105A 787AF5 Interp. 200-460V, 157A 787AF9 Interp. 200-460V, 130A 787AF7 Interp. 200-230V, 252A 3,6 787AF14

TRU PROJECT NO. 2200407



Manufacturer: Model Line:	TK Elevator Manufacturin Hydraulic Controller	ng, Inc.	Table Description: Fuses		TABLE 4
Building Code: CBC 2	-	Seismic Certificati	Son Limits: $S_{DS} = 1.5 g$ $z/h = 1.0$ $S_{DS} = 1.5 g$ $z/h = 0.0$	1 _p = 1.5	
Component Type	Manufacturer	Model	R CODE Description	Note	s UUT
Fuseblock DIN Rail	Bussman	412BE2	600V, 30A, 2-pole		5, 6
		409BP23	600V, 4A		2,5
Fues Daniel FNO	Ducaman	409BP24	600V, 5A		Interp
Fuse Panel FNQ	Bussman	409BP25	600V, 6AO 166		Interp
		409BP28	600V, 8A	Obsolete Model	6
		409CW500 BV · V	250V, 0.5Aad Karim		Extrap
Fuse Panel 2AG	Bussman	409CW1000	250V, 1A		Extrap
ruse Pallet 2AG	Dussillali	409CW2000	250V, 2A 250V 3A		5
		409CW3000	250V, 3A	Obsolete Model	6
Fuse Panel MDA	Bussman	409BR10	4A +		5, 6
		MAL	UILDING		

TRU PROJECT NO. 2200407



Table Description: Power Supplies Manufacturer: TK Elevator Manufacturing, Inc. **TABLE 5** Model Line: Hydraulic Controller $S_{DS} = 1.5 g z/h = 1.0$ Seismic Certification Limits: **Building Code: CBC 2022** $I_{P} = 1.5$ $S_{DS} = 1.5 g z/h = 0.0$ Description **Component Type** Manufacturer Model UUT **Notes** 24VDC, 50W 672BW1 2, 3, 5 24VDC, 60W 672DE001 Interp. 24VDC, 120W 672DE002 Interp. **Power Supplies** Lambda 48VDC, 120W 672DF001 Interp. 672BY1 24VDC, 150W Interp. 672CC1 48VDC, 150W Karim Obsolete Model 3

TRU PROJECT NO. 2200407



Manufacturer: Model Line:	TK Elevator Manufacturing Hydraulic Controller		TABLE 6			
Building Code: CBC 2	2022	Seismic Certific	Seismic Certification Limits: $S_{DS} = 1.5 g z/h = 1.0$ $S_{DS} = 1.5 g z/h = 0.0$			
Component Type	Manufacturer	Model	OR COL	Description	Not	tes UUT
Relays	Tyco	690AJ8 BY:	208-480VA0 OSP-0 Mohamma TE: 08/18	166 A		3,5

TRU PROJECT NO. 2200407



Manufacturer: Model Line:	TK Elevator Manufacturing, Hydraulic Controller	Inc.	Table Description: Transformers		TABLE 7
Building Code: CBC 2		Seismic Certificati	Son Limits: $S_{DS} = 1.5 g$ $z/h = 1.0$ $S_{DS} = 1.5 g$ $z/h = 0.0$	I _P = 1.5	
Component Type	Manufacturer	Model	R CODE Description	No	tes UUT
Trasnformers	GE	874DJ 87 <mark>4</mark> EM	Single Phase, 0.25kVA, 115-575V Single Phase, 0.5kVA, 208-600V	Obsolete Model	3 Interp.
		874DA	Single Phase, 0.5kVA, 115-600V OSP-0166 phammad Karim 08/18/2022		5, 6
			UILDING		





Manufactu Model Line		r Manufacturing, Inc Controller						
UUT	Unit Description	Report Number	Testing Lab	Year Tested	ISO 17025 Accredited?	S _{DS}	z/h	I _P
2	TAC22	57906R10-1 (UUT2)	National Technical Systems - Huntsville	2010	Yes	1.5 1.5	1.0 0.0	1.5
3	TAC22 Tall	57906R10-2 (UUT1)	National Technical Systems - Huntsville	2010	Yes	1.5 1.5	1.0 0.0	1.5
5	TAC32	57906R10-3 (UUT1)	National Technical Systems - Huntsville	2010	Yes	1.5 1.5	1.0 0.0	1.5
6	TAC32	57906R10-3 (UUT2)	National Technical Systems - Huntsville	2010	Yes	1.5 1.5	1.0 0.0	1.5
		o BY: M	ohammad Ka	rim	0			
		DATE	: 08/18/202	2	019			
		PNIA		CODY				
			ROILDING					

TRU PROJECT NO. 2200407



UUT 2

Manufacturer: TK Elevator Manufacturing, Inc.

Model Line: Hydraulic Controller

Model Number: TAC22 Serial Number: N/A

Product Construction Summary:

NEMA 1 Enclosure Type

Options/Subcomponent Summary:

Contactors: Siemens (298AG2, 804BC1, 804BC2); Electronic Starter: Siemens (787AF11); Fuseblock DIN Rail: Bussman (412BF1, 412BC1); Fuse Panel FNQ: Bussman (409BP23); Fuse Panel MDA: Bussman (409BR5, 409BR7); Power Supplies: Lambda (672BW1);

Relays: Tyco (690CA3, 690CA5, 690CJ1)

			UUTF	Properties		7				
Weight		Dimension (in	Dimension (in)				t Natural	Frequen	cy (Hz)	
(lb)	lb) Depth Width Sheight 66 Front-Back		Width OS Height 66 Front-Back		Side	-Side	Ver	tical		
165	12.0	33.0		33.0	N/A		N/A N/		N	/A
		UUT Highes	t Passed	Seismic Rur	Inform	ation				
Buildi	ng Code	Test Criteria		S _{DS} (g)	z/h I _P		A _{FLX-H} (g)	A _{RIG-H} (g)	A _{FLX-V} (g)	A _{RIG-V} (g)
CBC 2022		ICC-ESAC156 08/		/18/202 1.5	2 1.0 0.0	1.5	2.40	1.80	1.00	0.40

Test Mounting Details:



Wall Mounted - Rigid to fixture using six (6) 3/8"-16 Grade 5 bolts and washers.

Unit maintained structural integrity and remained functional per manufacturer requirement after shake table test. Contents were included in testing per operating conditions.

844-TRU-0200 | info@trucompliance.com

TRU Compliance, by Structural Integrity Associates, Inc.

TRU PROJECT NO. 2200407



UUT3

Manufacturer: TK Elevator Manufacturing, Inc.

Model Line: Hydraulic Controller

Model Number: TAC22 Tall Serial Number: N/A

Product Construction Summary:

NEMA 1 Enclosure Type

Options/Subcomponent Summary:

Contactors: Siemens (298AG4, 298BE1, 804BC1, 804BC2); Electronic Starter: Siemens (787AF14);

Fuseblock DIN Rail: Bussman (412BF1, 412BC1); Fuse Panel FNQ: Bussman (409BP20);

Fuse Panel MDA: Bussman (409BR5, 409BR7, 409BR9, 409BR11); Power Supplies: Lambda (672BW1, 672CC1);

Relays: Tyco (690CA3, 690CA5, 690AJ8, 690CJ1); Transformers: GE (874DJ)

			UUT Pr	roperties		7				
Weight		Dimension (in	Dimension (in) Lowest Natural Fi				Frequen	requency (Hz)		
(lb) Depth		Width	h OS Height 66		Front-Back		Side-Side		Vertical	
168	10.6	33.0	XXX XXXXXX 4	2.0	N/A		N/A		N	/A
		UUT Highes	st Passed S	eismic Rur	Informa	ation				
Buildi	ng Code	Test Criteria S		S _{DS} (g)	z/h	z/h I _P		A _{RIG-H} (g)	A _{FLX-V} (g)	A _{RIG-V} (g)
CBC 2022		ICC-ES AC156 08/		18 ^{1.5} 02 1.5	2 1.0 0.0	1.5	2.40	1.80	1.00	0.40

Test Mounting Details:



Wall Mounted - Rigid to fixture using six (6) 3/8"-16 Grade 5 bolts and washers.

Unit maintained structural integrity and remained functional per manufacturer requirement after shake table test. Contents were included in testing per operating conditions.

TRU Compliance, by Structural Integrity Associates, Inc. 844-TRU-0200 | info@trucompliance.com

TRU PROJECT NO. 2200407



UUT5

Manufacturer: TK Elevator Manufacturing, Inc.

Model Line: Hydraulic Controller

Model Number: TAC32 Serial Number: N/A

Product Construction Summary:

NEMA 1 Enclosure Type

Options/Subcomponent Summary:

Fuseblock DIN Rail: Bussman (412BE2); Fuse Panel FNQ: Bussman (409BP23); Fuse Panel 2AG: Bussman (409CW2000);

Fuse Panel MDA: Bussman (409BR10); Power Supplies: Lambda (672BW1); Relays: Tyco (690AJ8);

Transformers: GE (874DA); Electronic Starter: Siemens (787AF11)

			UUT Pr	operties		7				
Weight		Dimension (in	YlmWedMired	Xv.VVX x X x X X X X X X X X X X X X X X X	Lowest Natural Frequency (Hz)					
(lb) Depth		Width	Width OS Height 66		Front-Back		Side-Side		Vertical	
133	9.0	33.0	XXX XXXXXX 2	8.0	N/A		N/A		N/A	
		UUT Highe:	st Passed S	eismic Rur	Informa	ation				
Buildi	ng Code	Test Criteria		S _{DS} (g)	z/h	I _P	A _{FLX-H} (g)	A _{RIG-H} (g)	A _{FLX-V} (g)	A _{RIG-V} (g)
CBC 2022		ICC-ES AC156 08/		18/202 1.5	2 1.0 0.0	1.5	2.40	1.80	1.00	0.40

Test Mounting Details:



Wall Mounted - Rigid to fixture using six (6) 3/8"-16 Grade 5 bolts and washers.

Unit maintained structural integrity and remained functional per manufacturer requirement after shake table test. Contents were included in testing per operating conditions.

TRU PROJECT NO. 2200407



UUT 6

Manufacturer: TK Elevator Manufacturing, Inc.

Model Line: Hydraulic Controller

Model Number: TAC32 Serial Number: N/A

Product Construction Summary:

NEMA 1 Enclosure Type

Options/Subcomponent Summary:

Contactors: Siemens (298AG4); Electronic Starter: Siemens (787AF14); Fuseblock DIN Rail: Bussman (412BE2);

Fuse Panel FNQ: Bussman(409BP28); Fuse Panel 2AG: Bussman (409CW3000); Fuse Panel MDA: Bussman (409BR10);

Transformers: GE (874DA)

		14,	UUTP	Properties		7					
Weight	Dimension (in)				Lowest Natural Frequency (Hz)						
(lb)	Depth	Width	OS Height 66		Front-Back		Side-Side		Vertical		
170	9.0	33.0		28.0		N/A		N/A		N/A	
		UUT Highes	t Passed .	Seismic Run	Inform	ation					
Building Code		Test Criteria		S _{DS} (g)	z/h	I _P	A _{FLX-H} (g)	A _{RIG-H} (g)	A _{FLX-V} (g)	A _{RIG-V} (g)	
CBC 2022		ICC-ES AC156 08/		/18 ^{1.5} 02	2 1.0	1.5	2.40	1.80	1.00	0.40	

Test Mounting Details:



Wall Mounted - Rigid to fixture using six (6) 3/8"-16 Grade 5 bolts and washers.

Unit maintained structural integrity and remained functional per manufacturer requirement after shake table test. Contents were included in testing per operating conditions.

844-TRU-0200 | info@trucompliance.com

TRU Compliance, by Structural Integrity Associates, Inc.