

OFFICE OF STATEWIDE HEALTH PLANNING AND DEVELOPMENT FACILITIES DEVELOPMENT DIVISION

OFFICE USE ONLY APPLICATION FOR OSHPD SPECIAL SEISMIC **CERTIFICATION PREAPPROVAL (OSP) APPLICATION #: OSP-0170** OSHPD Special Seismic Certification Preapproval (OSP) X Type: New Renewal Manufacturer Information Manufacturer: KKT Chillers - ait-deutschland Manufacturer's Technical Representative: Markus Zobler Mailing Address: Industriestrasse 3, Kasendorf, Ge 95359 Telephone: (92289) 906-1580 Email: markus.zobler@ait-deutschland.eu Product Information Product Name: Chillers Product Type: Chillers - CT Scanners Product Model Number: See Attachment 1 General Description: Air-cooled water cooling systems intended to provide chilled water to Siemens MRI medical Imaging systems. Mounting Description: See Certified Product Tables Seismic enhancements made to the test units and/or modifications required to address **Tested Seismic Enhancements:** anomalies during the tests shall be incorporated into the production units. Applicant Information Applicant Company Name: WE Gundy & Associates, Inc Contact Person: Travis Soppe Mailing Address: PO Box 9121, Boise, ID 83707 Telephone: (208) 342-5989 Email: tsoppe@wegai.com Title: President

"Access to Safe. Quality Healthcare Environments that Meet California's Diverse and Dynamic Need

STATE OF CALIFORNIA – HEALTH AND HUMAN SERVICES AGENCY



OFFICE OF STATEWIDE HEALTH PLANNING AND DEVELOPMENT FACILITIES DEVELOPMENT DIVISION

California Licensed Structural Engineer Responsible for the Engineering and Test Report(s)									
Company Name: W.E. GUNDY & ASOCIATES INC.									
Name: Travis Soppe California License Number: S6115									
Mailing Address: P.O. Box 9121, Boise, ID 83707									
Telephone: (208) 342-5989 Email: tsoppe@wegai.com									
Certification Method									
GR-63-Core X ICC-ES AC156 IEEE 344 IEEE 693 NEBS 3									
Other (Please Specify):									
FOR CODE CO									
Testing Laboratory									
Company Name: ENVIRONMENTAL TESTING LABORATORIES, INC. (ETL)									
Contact Person: Brady Richard									
Mailing Address: 11034 Indian Trail, Dallas TX 75229-3513									
Telephone: (972) 247-9657 Email: brady@etIdallas.com									
DATE: 09/20/2021									
S. S.									
FILLORNIA BUILDING CODE. 250									
BUILDING									





OFFICE OF STATEWIDE HEALTH PLANNING AND DEVELOPMENT FACILITIES DEVELOPMENT DIVISION

Seismic Parameters									
Design Basis of Equipment or Components	s (Fp/Wp) = See Attachments								
SDS (Design spectral response accel	eration at short period, g) = 2.0 at z/h	= 1 and 2.	15 at z/h = 0						
a _P (Amplification factor) = See Attachment									
R _p (Response modification factor) = See Attachment									
Ω_0 (System overstrength factor) =	br) = 2.0 <u>1.5</u> <u>1 and 0</u> See Attachment								
lp (Importance factor) =	nodification factor) = See Attachment rstrength factor) = 2.0 actor) = 1.5 i factor) = 1 and 0 cies (Hz) = See Attachment ons and weight = See Attachment For Office Use Only) - Approval Expires on 09/27/2027								
z/h (Height ratio factor) =	Basis of Equipment or Components (Fp/Wp) = See Attachments DDS (Design spectral response acceleration at short period, g) = 2.0 at z/h = 1 and 2.15 at z/h = 0 p (Amplification factor) = See Attachment top (Response modification factor) = See Attachment top (Response modification factor) = See Attachment top (Importance factor) = 1.5 th (Height ratio factor) = 1 and 0 latural frequencies (Hz) = See Attachment Deverall dimensions and weight = See Attachment Deverall dimensions and weight = See Attachment D/Approval (For Office Use Only) - Approval Expires on 09/27/2027 Title: g/20/2021 OSP-0170 Mohammad Aliaari Title: Seismic Certification Valid Up to: Sps (g) = See Above DATE: 09/20/2021								
z/h (Height ratio factor) =1 and 0Natural frequencies (Hz) =See Attachment									
	WED FOR MAN								
OSHPD Approval (For Office Use Only	() - Approval Expires on 09/27/20	272							
Date: 9/20/2021	OSP-0170	m							
Name: Mohammad Aliaari		Title:	Senior Structural Engineer						
Special Seismic Certification Valid Up to: S	DS (g) = See Above	_ z/h =	See Above						
Condition of Approval (if applicable):	DATE: 09/20/2021	$\Box / /$							
	THORNIA BUILDING CODE	6102							

"Access to Safe. Quality Healthcare Environments that Meet California's Diverse and Dynamic Needs"

OSHPD

KKT Chillers - AIT Deutschland GmbH SPECIAL SEISMIC CERTIFICATION CERTIFIED SYSTEM AND COMPONENTS



Manufacturer: KKT Chillers - AIT Deutschland GmbH

System: KKT Chillers for use with Siemens Medical Equipment

System Component ¹	Type	Di	mensions (i	in)	Weight ²	Mounting	UUT ³
	Туре	Width	Depth	Height	(lb)		
ECO 133L	Chiller	84.4	43.3	80.7	1651	isolated floor	UUT _x -1
ECO 133L IFP	Interface Panel	45.1	7.1	31.5	148	rigid wall	UUT _x -2
ECO 122L	Chiller	84.5	43.3	68.9	1481	isolated floor	UUT _y -1
ECO 122L IFP	Interface Panel	45.1	7.1	31.5	163	rigid wall	UUT _y -2

¹ All components are manufactured by KKT - AIT Deutschland GmbH unless noted. The part numbers listed uniquely identify the type of component, manufacturer, and material of construction for each sub-componenent within the tested units.

² Weight includes normal operating fluid present during seismic test.

³ Subscript indicates the test report in which the units were qualified: Aligari

x - SQ35-11103-01, y - SQ<mark>35-13</mark>03-01

⁴ ECO 133L and 122L Chillers were tested with factory installed seismic kit see summary sheets for details.

CALIKORNIA BU

SEISMIC CERTIFICATION LIMITS

VG CODE:20

System Component	Code	S _{DS} (g)	z / h	I _P	a _P	R _P	Ω₀	$\mathbf{F}_{\mathbf{P}}$ / $\mathbf{W}_{\mathbf{P}}$
Chillers 6102	9	2.00	1.0	1.50	2.5	2.0	2.0	4.50
	7-	2.15	0					1.61
Interface Panels	BC SCE	2.00	1.0	1.50	1.0	2.5	2.0	1.44
	A C	2.50	0					1.13

UUT_x-1

UNIT UNDER TEST (UUT) SUMMARY SHEET



Mounting Details: Isolated floor mounted on 4 - AMC Mecanocaucho Marine Mount isolation devices. Each isolator mounts to the floor with (2) $\frac{1}{2}$ " Grade 5 bolts



UUT_x-2

UNIT UNDER TEST (UUT) SUMMARY SHEET



Mounting Details: Rigid wall mounted with (4) #12 Tek screws with 1/2" O.D. washers



SEISMIC TEST PARAMETERS

Building Code / Test Criteria	S _{DS} (g)	z / h	Ip	Aflx-H (g)	Arig-H (g)	AFLX-V (g)	Arig-v (g)
CBC 2019 / ICC-ES AC156	2.00	1.0	1.5	3.20	2.40		
	2.50	0.0	1.5			1.67	0.67

Note: The unit was full of contents during testing and remained functional before and after the ICC-ES AC156 test. The unit maintained structural integrity during and after the ICC-ES AC156 test.

UUT_y-1

UNIT UNDER TEST (UUT) SUMMARY SHEET



Mounting Details: Isolated floor mounted on 4 - AMC Mecanocaucho Marine Mount isolation devices. Each isolator mounts to the floor with (2) $\frac{1}{2}$ " Grade 5 bolts



UNIT UNDER TEST (UUT) SUMMARY SHEET



Mounting Details: Rigid wall mounted with (4) ¹/₄" sheet metal screws with 1-¹/₂" O.D. washers

