



**OFFICE OF STATEWIDE HEALTH PLANNING AND DEVELOPMENT  
FACILITIES DEVELOPMENT DIVISION**

**APPLICATION FOR OSHPD SPECIAL SEISMIC  
CERTIFICATION PREAPPROVAL (OSP)**

OFFICE USE ONLY

**APPLICATION #: OSP-0201**

**OSHPD Special Seismic Certification Preapproval (OSP)**

Type:  New  Renewal

**Manufacturer Information**

Manufacturer: Functional Devices, Inc.

Manufacturer's Technical Representative: Samuel Klennert

Mailing Address: 101 Commerce Drive, Sharpsville, IN 46068

Telephone: (765) 416-6810

Email: s.klennert@functionaldevices.com

**Product Information**

Product Name: Power Isolation and Correction Systems

Product Type: Power Isolation and Correction Systems

Product Model Number: See attachments

General Description: Units are 40 VA to 500VA AC power supplies with transformers capable of converting voltage

Mounting Description: Rigid, Wall Mounted

Tested Seismic Enhancements: None

DATE: 09/21/2020

**Applicant Information**

Applicant Company Name: The VMC Group

Contact Person: John Giuliano

Mailing Address: 113 Main Street, Bloomingdale, NJ 07403

Telephone: (973) 838-1780

Email: john.giuliano@thvmcgroup.com

Title: President





**OFFICE OF STATEWIDE HEALTH PLANNING AND DEVELOPMENT  
FACILITIES DEVELOPMENT DIVISION**

**California Licensed Structural Engineer Responsible for the Engineering and Test Report(s)**


Company Name: THE VMC GROUP  
Name: Kenneth Tarlow California License Number: S2851  
Mailing Address: 980 9th Street, 16th Floor, Sacramento, CA 95814  
Telephone: (916) 449-9918 Email: ken.tarlow@thevmcgroup.com

**Certification Method**

GR-63-Core     ICC-ES AC156     IEEE 344     IEEE 693     NEBS 3  
 Other (Please Specify): \_\_\_\_\_

**Testing Laboratory**

Company Name: DYNAMIC CERTIFICATION LABORATORY (DCL)  
Contact Person: Josh Sailer  
Mailing Address: 1315 Greg St., Ste 109, Sparks NV 89431  
Telephone: (775) 358-5085 Email: josh@shaketest.com





**OFFICE OF STATEWIDE HEALTH PLANNING AND DEVELOPMENT  
FACILITIES DEVELOPMENT DIVISION**

**Seismic Parameters**

Design Basis of Equipment or Components ( $F_p/W_p$ ) = 1.39

SDS (Design spectral response acceleration at short period, g) = 1.93

$a_p$  (Amplification factor) = 1

$R_p$  (Response modification factor) = 2.5

$\Omega_0$  (System overstrength factor) = 2.0

$I_p$  (Importance factor) = 1.5

$z/h$  (Height ratio factor) = 1

Natural frequencies (Hz) = See attachments

Overall dimensions and weight = See attachments


**OSHPD Approval (For Office Use Only) - Approval Expires on 12/31/2025**

Date: 9/21/2020

Name: Mohammad Aliaari Title: Senior Structural Engineer

Special Seismic Certification Valid Up to: SDS (g) = 1.93  $z/h$  = 1

Condition of Approval (if applicable): DATE: 09/21/2020



# Functional Devices - PSH AC Power Supplies

## Table 1 - Certified Components

**Manufacturer:** Functional Devices  
**Mounting:** Rigid Wall Mounted  
**Test Levels:** Sds = 1.93g, z/h=1.0  
**Material:** Cold Rolled Carbon Steel (NEMA 1)

Model	Dimensions (in)			Weight (lb)	Gage	UUT
	Depth	Width	Height			
PSH40A	4.5	4.5	5.4	3.1	18	UUT 1
PSH75A	4.5	4.5	5.4	4.5		Interpolated
PSH100A	4.5	4.5	5.4	4.6		Interpolated
PSH40A-40A	4.5	4.5	8.6	5.4		Interpolated
PSH40A-75A	4.5	4.5	8.6	6.8		Interpolated
PSH40A-100A	4.5	4.5	8.6	6.9		Interpolated
PSH75A-75A	4.5	4.5	8.6	8.4		Interpolated
PSH75A-100A	4.5	4.5	8.6	8.5		Interpolated
PSH100A-100A	4.5	4.5	8.6	8.6		Interpolated
PSH300A	6.0	12.0	12.0	18.1		16
PSH300A-LVC <sup>2</sup>	6.0	12.0	12.0	19.6	Interpolated	
PSH300AB10-LVC <sup>2</sup>	6.0	12.0	12.0	19.7	Interpolated	
PSH500A	6.0	12.0	12.0	30.2	UUT 2	
PSH500A-LVC <sup>2</sup>	6.0	12.0	12.0	31.5	Extrapolated <sup>1</sup>	
PSH500AB10-LVC <sup>2</sup>	6.0	12.0	12.0	31.6	Extrapolated <sup>1</sup>	

Notes:

- Subcomponents in extrapolated units are bookended by UUT1 and UUT2 tests.
- B10 = 10 amp main breaker switch, LVC = Low Voltage Compartment.

## Functional Devices - PSH AC Power Supplies

### Table 2 - Certified Subcomponents - Enclosures

**Manufacturer:** Functional Devices  
**Material:** Cold Rolled Carbon Steel (NEMA 1)

Model	Gage	Dimensions			Weight (lb)	UUT
		Depth	Width	Height		
140793/140792 <sup>1</sup>	18	3.8	5.1	4.3	1.6	UUT 1
140827/140787 <sup>1</sup>		3.8	8.3	4.3	2.2	Interpolated
141432	16	6.0	12.0	12.0	9.8	Interpolated
141460		6.0	12.0	12.0	9.8	Interpolated
140946		6.0	12.0	12.0	10.7	UUT 2
141432-LVC <sup>3</sup>		6.0	12.0	12.0	11.0	Extrapolated
141460-LVC <sup>3</sup>		6.0	12.0	12.0	11.0	Extrapolated

Note:

1. Enclosure models are physically identical; model numbering difference is based on marketing only.
2. All enclosures come with an associated lid. The lid is included in the weight of the enclosure.
3. LVC = Low Voltage Compartment; these enclosures have extra dividers inside the enclosure to separate the low and high voltage compartments.

### Table 3 - Certified Subcomponents - Transformers

**Manufacturer:** Functional Devices

Model	Material	Dimensions (in)			Weight (lb)	UUT
		Depth	Width	Height		
TR40VA020	Laminated sheet steel core wound with enameled copper wire	2.4	3.3	1.9	1.5	UUT 1
560021		2.5	4.0	2.5	2.8	Interpolated
560058		2.7	4.1	2.6	2.6	Interpolated
TR300VA003		4.5	3.5	4.0	8.2	Interpolated
TR500VA003		5.3	4.3	4.4	19.8	UUT 2

### Table 4 - Certified Subcomponents - Receptacles

**Manufacturer:** Functional Devices

Model	Material	Dimensions (in)			Weight (lb)	UUT
		Depth	Width	Height		
210309	Plastic	1.0	1.0	0.8	<1	UUT1, UUT2

## Functional Devices - PSH AC Power Supplies

### Table 5 - Certified Subcomponents - Switches

Manufacturer: Functional Devices

Model	Material	Dimensions (in)			Weight (lb)	UUT
		Depth	Width	Height		
517012	Plastic	0.6	1.3	1.3	<1	UUT1, UUT2

### Table 6 - Certified Subcomponents - Breakers

Manufacturer: Functional Devices

Model	Material	Dimensions (in)			Weight (lb)	UUT
		Depth	Width	Height		
517013	Plastic	0.8	0.8	2.0	<1	UUT1, UUT2

### Table 7 - Tested Units

Manufacturer: Functional Devices

Test Levels: Sds = 1.93g, z/h=1.0


Material: Cold Rolled Carbon Steel (NEMA 1)

Model	Gage	Dimensions (in)			Weight (lb)	UUT
		Depth	Width	Height		
PSH40A	18	4.5	4.5	5.4	3.1	UUT 1
PSH500A	16	6.0	12.0	12.0	30.2	UUT 2

BY: Mohammad Aliaari

DATE: 09/21/2020

REVIEWED FOR CODE COMPLIANCE  
 CALIFORNIA BUILDING CODE, 2019

<b>UUT 1</b>		
<b>UNIT UNDER TEST (UUT) Sheets</b>		
<b>Manufacturer:</b>	Functional Devices	
<b>Product Line:</b>	PSH AC Power Supplies	
<b>Model Number</b>	PSH40A	
<b>Mounting:</b>	Rigid Wall Mounted	
<b>DCL Test Report:</b>	23258-1601	

**Product Construction Summary**  
 18 gage cold-rolled carbon steel, coated with smooth powder paint

**Options / Subcomponent Summary**  
 Enclosed single 40 VA power supply, 120 to 24 Vac

UUT Properties						
Weight (lb)	Dimensions (in)			Lowest Natural Frequency (Hz)		
	Length	Width	Height	F-B	S-S	V
3.1	4.5	4.5	5.4	N/A	N/A	N/A


UUT Highest Passed Seismic Run Information								
Building Code	Test Criteria	S <sub>DS</sub> (g)	z/h	I <sub>P</sub>	A <sub>FLX-H</sub> (g)	A <sub>RIG-H</sub> (g)	A <sub>FLX-V</sub> (g)	A <sub>RIG-V</sub> (g)
CBC 2019	ICC-ES AC156	1.93	1	1.5	3.09	2.32	1.29	0.51

**Test Mounting Details**

The UUT was attached to the fixturing wall utilizing three (3) #14 sheet metal screws and the existing openings in the back of the back-box.



All units were filled with contents and maintained structural integrity and functionality after shake table test

<b>UUT 2</b>		
<b>UNIT UNDER TEST (UUT) Sheets</b>		
<b>Manufacturer:</b>	Functional Devices	
<b>Product Line:</b>	PSH AC Power Supplies	
<b>Model Number</b>	PSH500A	
<b>Mounting:</b>	Rigid Wall Mounted	
<b>DCL Test Report:</b>	23258-1601	

**Product Construction Summary**  
 16 gage cold-rolled carbon steel, coated with smooth powder paint

**Options / Subcomponent Summary**  
 Enclosed 500VA power supply with five 100A Class 2 outputs, 480/277/240/120 Vac to 24Vac

UUT Properties						
Weight (lb)	Dimensions (in)			Lowest Natural Frequency (Hz)		
	Length	Width	Height	F-B	S-S	V
30.2	6	12	12	N/A	N/A	N/A

UUT Highest Passed Seismic Run Information								
Building Code	Test Criteria	S <sub>DS</sub> (g)	z/h	I <sub>P</sub>	A <sub>FLX-H</sub> (g)	A <sub>RIG-H</sub> (g)	A <sub>FLX-V</sub> (g)	A <sub>RIG-V</sub> (g)
CBC 2019	ICC-ES AC156	1.93	1	1.5	3.09	2.32	1.29	0.51

**Test Mounting Details**

The UUT was attached to the fixturing wall utilizing four (4) #14 sheet metal screws and the existing openings in the back of the back-box



All units were filled with contents and maintained structural integrity and functionality after shake table test