

### DEPARTMENT OF HEALTH CARE ACCESS AND INFORMATION OFFICE OF STATEWIDE HOSPITAL PLANNING AND DEVELOPMENT

APPLICATION FOR HCAI SPECIAL SEISMIC	OFFICE USE ONLY
CERTIFICATION PREAPPROVAL (OSP)	APPLICATION #: OSP-0204
HCAI Special Seismic Certification Preapproval (OSP)	
Type: New X Renewal	
Manufacturer Information	
Manufacturer: Multistack, LLC	
Manufacturer's Technical Representative: Darrin Anderson	
Mailing Address: 1065 Maple Ave, Sparta, WI 54656	
Telephone: (608) 366-2400 Email: DAnderson@mu	ltistack.com
Product Information	
Product Name: See attached summary table.	
Product Model Number(s): MFW MagLev Flooded Chiller, Gen 1-5	E.
Product Category: Chillers OSP-0204	1 G
Product Sub-Category: Chillers - Water Cooled	
General Description: Water cooled mag lev flooded chillers in stacked an 4,500 pounds to 22,300 pounds.	nd side-by-side configuration ranging in size from
Mounting Description: Flexible base mount with neoprene pads or rigidly l	base mounted.
Tested Seismic Enhancements: None	
Applicant Information	
Applicant Company Name: VMC	04
Contact Person: Kelly Laplace	
Mailing Address: 113 Main St., Bloomingdale, NJ 07403	
Telephone: (775) 358-5085 Email: kelly.laplace@th	evmcgroup.com
Title: Vice President of Sales: Test and Measurement Division	



STATE OF CALIFORNIA – HEALTH AND HUMAN SERVICES AGENCY

"A healthier California where all receive equitable, affordable, and quality health care"

OSP-0204



### DEPARTMENT OF HEALTH CARE ACCESS AND INFORMATION OFFICE OF STATEWIDE HOSPITAL PLANNING AND DEVELOPMENT

California Licensed Structural Engineer Responsible for the Engineering and Test Report(s)
Company Name: THE VMC GROUP
Name: Kenneth Tarlow California License Number: S2851
Mailing Address: 980 9th Street, 16th Floor, Sacramento, CA 95814
Telephone: (832) 627-2214 Email: ken.tarlow@thevmcgroup.com
Certification Method
GR-63-Core X ICC-ES AC156 IEEE 344 IEEE 693 NEBS 3
Other (Please Specify):
FOR CODE CO.
Testing Laboratory
Company Name: U.S. ARMY ENGINEER RESEARCH AND DEVELOPMENT CENTER, CONSTRUCTION ENGINEERING RESEARCH LABORATORY (CERL)
Contact Person: James Wilcoski
Mailing Address: 2902 Newmark Dr., Champaign IL 61822-1076
Telephone: (217) 373-4565 BY Email: james.wilcoski@usace.army.mil
Company Name: DYNAMIC CERTIFICATION LABORATORY (DCL)
Contact Person: Josh Sailer
Mailing Address: 1315 Greg St., Ste 109, Sparks NV 89431
Telephone: (775) 358-5085 Email: josh@shaketest.com
Company Name: UNIVERSITY OF CALIFORNIA, BERKELEY (PEER)
Contact Person: Amarnath Kasalanati
Mailing Address: 325 Davis Hall, Berkeley CA 94720-1729
Telephone: (510) 642-3437 Email: amarnath1@berkley.edu



STATE OF CALIFORNIA – HEALTH AND HUMAN SERVICES AGENCY

"A healthier California where all receive equitable, affordable, and quality health care"

OSP-0204



### DEPARTMENT OF HEALTH CARE ACCESS AND INFORMATION OFFICE OF STATEWIDE HOSPITAL PLANNING AND DEVELOPMENT

Seismic Parameters			
Design Basis of Equipment or Component	s (Fp/Wp) =3.60 (isolated); 1.44 (Rig	id)	
SDS (Design spectral response acce	eleration at short period, g) = $2.00$		
ap (Amplification factor) =	2.5 (Isolated); 1 (Rigid)		
R <sub>P</sub> (Response modification factor) =	2.5		
$\Omega_0$ (System overstrength factor) =	2.5		
lp (Importance factor) =	1.5		
z/h (Height ratio factor) =	1		
Natural frequencies (Hz) =	See attachment		
Overall dimensions and weight =	See attachment ODF	-	
HCAI Approval (For Office Use Only)	- Approval Expires on 03/12/2031		
Date: 3/12/2025	OSP-0204	C.F.	
Name: Mohammad Karim			Supervisor, Health Facilities
Special Seismic Certification Valid <mark>Up to:</mark> S	SDS (g) = 2.0	z/h =	1
Condition of Approval (if applicable):	DATE: 03/12/2025		
	PRVIA BUILDING COD	202	



"A healthier California where all receive equitable, affordable, and quality health care" STATE OF CALIFORNIA – HEALTH AND HUMAN SERVICES AGENCY

OSP-0204

## Special Seismic Certification Table 1 - Certified Components



DCL Project Number: 09698-2401

Manufacturer: Multistack

Product Line: MFW MagLev Flooded Chiller, Gen 1-5

Product Contruction Summary: Painted shell (carbon steel) and tube (copper) heat exchanger.

Mounting: Isolated Base Mounted with Neoprene Pads or Rigid Base Mounted

Certified Seismic Levels: Sds 2.00g z/h=1.0

Old Model Number	New Model Number		Dimensions [in.]		Weight	Certified Installation	Unit*
Old Model Number	New Wodel Number	Depth Width Height		[ lb. ]	Certified installation	Unit	
N/A	MFW0095	139	33	64	4,500		Extrapolated
N/A	MFW0102	139	33	64	4,500		Extrapolated
MS0122FC1	MFW0122	139	33	64	4,500		Extrapolated
MS0132FC1	MFW0132	139	33	64	4,670		UUT-6
N/A	MFW0135	139	35	77	6,270		Interpolated
MS0152FC1	MFW0152	139	35	77	6,270		Interpolated
MS0162FC1	MFW0162	139	35	77	6,990		Interpolated
N/A	MFW0125	139	35	77	6,990		Interpolated
N/A	MFW0115	139	R (35)]	F 77	6,990		Interpolated
MS0192FC1	MFW0192	141	36		7,150		Interpolated
MS0202FC1	MFW0202	141	36	77	7,860		Interpolated
N/A	MFW0212	141	36	77	7,860		Interpolated
N/A	MFW0175	142	35	77	8,670		Interpolated
N/A	MFW0185	142	35	77	8,670		Interpolated
N/A	MFW0205	142		77	8,670		Interpolated
N/A	MFW0235	142	JOI <sub>35</sub> -02	- <del>04</del> 77	8,670		Interpolated
MS0242FC1	MFW0242	142	35	77	8,67 <mark>0</mark>		Interpolated
N/A	MFW0252		35		8,670		Interpolated
N/A	MF <mark>W0265</mark>	D 142	211a1 <sub>35</sub> 111a		8,670	Rigid and Isolated Base Mounted	Interpolated
N/A	MFW0285	143	37	77	9,840	Widditted	Interpolated
MS0292FC1	MFW0292	143	37 / 4 0		9,84 <mark>0</mark>		Interpolated
N/A	MFW0305	J 143	U <sub>37</sub> /12	/2043	9,840		Interpolated
MS0332FC1	MFW0332	143	37	77	9,960		Interpolated
MS0392FC1	MFW0392	143	40	81	11,350		Interpolated
N/A	MFW0295	168	40	89	13,050		Interpolated
N/A	MFW0402	168	40	89	13,050		Interpolated
MS0412FC1	MFW0412	168	40	89	13,050		Interpolated
N/A	MFW0415	172	48	94	15,350		Interpolated
N/A	MFW0425	172	48	94	15,350		Interpolated
MS0482FC1	MFW0482	172	48	94	15,350		UUT-5
MS0542FC1	MFW0542	171	82	82	17,660		Interpolated
MS0602FC1	MFW0602	171	86	86	19,560		Interpolated
MS0612FC1	MFW0612	171	86	86	20,100		Interpolated
MS0622FC1	MFW0622	171	86	86	20,160		Interpolated
MS0702FC1	MFW0702	147	90	86	21,150		Interpolated
MS0703FC1	MFW0703	149	90	90	20,800		Interpolated
MS0803FC1	MFW0803	149	101	96	22,300		UUT-7

\* The type of refrigerant does not affect the physical build of the unit.

# Special Seismic Certification

#### Nomenclature Chart



DCL Project Number: 09698-2401

Manufacturer: Multistack

Product Line: MFW MagLev Flooded Chiller, Gen 1-5 Mounting: Rigid and Isolated Base Mounted with Neoprene Pads or Rigid Base Mounted

<u>1</u>	<u>MFW 010 2</u>		
	1 2 3		
Allowable Value	Description	Certified Installation	Unit
MS	Branding		UUT-5, UUT-6, UUT-7
MSF	Branding	N/A	Same as tested
MFW	Branding		Same as tested
009	90 Tons of refrigeration		Extrapolated
010	100 Tons of refrigeration	] [	Extrapolated
011	110 Tons of refrigeration		Extrapolated
012	120 Tons of refrigeration		Extrapolated
013	130 Tons of refrigeration		UUT-6
015	150 Tons of refrigeration		Interpolated
016	160 Tons of refrigeration		Interpolated
017	170 Tons of refrigeration		Interpolated
018	180 Tons of refrigeration		Interpolated
019	190 Tons of refrigeration		Interpolated
020	200 Tons of refrigeration		Interpolated
021	210 Tons of refrigeration		Interpolated
023	230 Tons of refrigeration		Interpolated
024 BY	240 Tons of refrigeration		Interpolated
025	250 Tons of refrigeration		Interpolated
026	260 Tons of refrigeration	Rigid and Isolated Base Mounted	Interpolated
028 D 2	280 Tons of refrigeration		Interpolated
029	290 Tons of refrigeration		Interpolated
030	300 Tons of refrigeration		Interpolated
033	330 Tons of refrigeration		Interpolated
039	390 Tons of refrigeration		Interpolated
040	400 Tons of refrigeration		Interpolated
041	410 Tons of refrigeration		Interpolated
042	420 Tons of refrigeration		Interpolated
048	-480 Tons of refrigeration		UUT-5
054	540 Tons of refrigeration		Interpolated
060	600 Tons of refrigeration		Interpolated
061	610 Tons of refrigeration		Interpolated
062	620 Tons of refrigeration		Interpolated
070	700 Tons of refrigeration		Interpolated
080	800 Tons of refrigeration		UUT-7
1	Generation 1		Same as tested
2	Generation 2		UUT5, UUT6
3	Generation 3	N/A	UUT-7
4	Generation 4		Same as tested
5	Generation 5		Same as tested
d is	080 1 2 3 4	080800 Tons of refrigeration1Generation 12Generation 23Generation 34Generation 45Generation 5	080800 Tons of refrigeration1Generation 12Generation 23Generation 34Generation 45Generation 5

## Special Seismic Certification Table 2 - Certified Subcomponents



DCL Project Number: 09698-2401

Subcomponent Type [Manufacturer]	Part Number	Dimensions	Material	Certified Installation	Weight [ lb. ]	Unit
[manadatarer]	TTS-300	31.0" x 20.4" x 19.2"			265	UUT-6
-	TGS-230	31.0" x 20.4" x 19.2"			265	Interpolated
•	TTS-350	31.0" x 20.4" x 19.2"			290	Interpolated
•	TGS-310	31.0" x 20.4" x 19.2"			290	Interpolated
	TTS-400	31.0" x 20.4" x 19.2"			290	UUT-5
	TGS-390	31.0" x 20.4" x 19.2"			290	Interpolated
Compressors* [Danfoss	TTS-450	31.0" x 20.4" x 19.2"	Iron, Aluminum, Copper,	Rigid and Isolated Base	290	Interpolated
Turbocor]	TGS-380	31.0" x 20.4" x 19.2"	Plastic	Mounted	290	Interpolated
	TTS-500	31.0" x 20.4" x 19.2"			318	UUT-5
	TGS-490	31.0" x 20.4" x 19.2"			318	Interpolated
	TTS-700	31.0" x 20.4" x 19.2"			318	UUT-7
	TGS-520	31.0" x 20.4" x 19.2"			318	Interpolated
	VTX-1600	44.5" x 26.9" x 29.5"	CODE		977	Interpolated
	VTT-1200	44.5" x 26.9" x 29.5"	LODECO		977	UUT-7
	HSE1210	12" dia x 10' tube			1300	Extrapolated
	HSE1410	14" dia x 10' tube		0	1620	UUT-6
	HSE1610	16" dia x 10' tube			1910	Interpolated
	HSE1810 18" dia x 10' tube		Y.	2320	Interpolated	
Ī	HSE2010	20" dia x 10' tube	D 000 4		2570	Interpolated
Condensers [Standard	HSE2212	22" dia x 12' tube	P-0204	Rigid and Isolated Base	3100	Interpolated
Refrigeration]	HSE2412	24" dia x 12' tube	Iron, Copper	Mounted	4620	UUT-5
-	HSE2612	26" dia x 12' tube			5950	Interpolated
•	HSE2812	28" dia x 12' tube	ammad Karim		6510	Interpolated
•	HSE3010	30" dia x 10' tube			6800	Interpolated
-	HSE3012	30" dia x 12' tube			7520	Interpolated
	HSE3210	32" dia x 10' tube	03/12/2025		7550	UUT-7
	FEV1410	14" dia x 10' tube			1190	Extrapolated
Ī	FEV1610	16" dia x 10' tube		S O	1490	UUT-6
Ī	FEV1810	18" dia x 10' tube			1810	Interpolated
-	FEV2010	20" dia x 10' tube		4.	2100	Interpolated
Evaporators [Standard	FEV2212	22" dia x 12' tube		Rigid and Isolated Base	2970	Interpolated
Refrigeration]	FEV2412	24" dia x 12' tube	Iron, Copper	Mounted	3790	Interpolated
-	FEV2612	26" dia x 12' tube	TI DING		4120	UUT-5
Ī	FEV2812	28" dia x 12' tube	LDIN		7050	Interpolated
Ī	FEV3012	30" dia x 12' tube			8070	Interpolated
	FEV3210	32" dia x 10' tube			8230	UUT-7
Condenser/Evaporator xpansion Valves [Carel]	E7V	16.4" x 5.3" x 16.8"	Copper, Iron, Brass, Stainless Steel, Nylon	Rigid and Isolated Base Mounted	9	UUT-6
Expansion Valves	Y12-31	11.0" x 5.5" x 2.5"	Copper, Iron, Brass, Stainless	Rigid and Isolated Base	15	UUT-5
[Sporlan]	SEHI-T	14.4" x 6.5" x 3.5"	Steel, Nylon	Mounted	20	UUT-7

\* TTS uses R134a and R513a refrigerants, TGS uses R1234ze and R515b refrigerants, VTT uses R134a and R513a refrigerants and VTX uses R134a, R513a, R515b, or R1234ze refrigerants.

## Special Seismic Certification Table 3 - Certified Subcomponents



DCL Project Number: 09698-2401

Product Line: MFW MagL	ev Flooded Chiller, C	Gen 1-5					
Subcomponent Type [Manufacturer]	Part Number	Dimensions	Materia	I	Certified Installation	Weight [ lb. ]	Unit
	V200THx40	9.6 "x 20.6" x 4.0"				58	UUT-6
	V200THx60	9.6" x 20.6" x 5.8"				76	Interpolated
	V200THx80	9.6" x 20.6" x 7.6"				95	Interpolated
Economizer [SWEP]	FS250x120	8.0" x 24.4" x 9.6"	Stainless St	eel	Rigid and Isolated Base Mounted	111	UUT-7
	V200THx130	9.6" x 20.6" x 12.1"			Basembantea	141	Interpolated
	S400x120	12.0" x 27.3" x 11.5"				219	Interpolated
	S400THx120	12.0" x 27.3" x 11.5"				219	UUT-5
	SERI-G	7.3" x 4.6" x 1.9"				5	UUT-6
Economizer Expansion Valves [Sporlan]	SERI-K	7.9" x 4.9" x 1.9"	Copper, Iron, Brass, Stainless Steel, Nylon		Rigid and Isolated Base Mounted	7	UUT-5
-	SERI-J	7.5" x 4.8" x 1.9"	R CODF	Ca		6	UUT-7
Subcomponent Type [Manufacturer]	Part Number	Description	Quantity in Material Each Subassembly		Certified Installation	Weight of Each Component in Subassembly (Combined Weight) [ Ib. ]	Unit
	FLEXSYS	<u></u>	WerMinserAveWitzzah	4	2	60, 80, 80, 90 (310)	Extrapolated
	FLEXSYS	A (	DSP-0204	4 3	<b>F</b>	90, 130,100 (320)	Extrapolated
	FLEXSYS			4		130, 90,130,100 (450)	UUT-6
Flexsys Control System [Multistack]	FLEXSYS	Control Panels as Subassembly	Aluminum, Plastic	Karim	Rigid and Isolated Base Mounted	130, 130, 90, 130, 100 (580)	UUT-5
	FLEXSYS			6		130(4), 90, 400 (1010)	Interpolated
	FLEXSYS	<b>C</b>	: 03/12/2	0254	2	400, 275, 110, 275 (1060)	Interpolated
	FLEXSYS			5	20	450, 275, 110, 275, 130 (1240)	UUT-7
		PRIAE	BUILDIN	G COT	Se.		

### Special Seismic Certification Table 4 - Tested Units



DCL Project Number: 09698-2401

Manufacturer: Multistack

Product Line: MFW MagLev Flooded Chiller, Gen 1-5

Mounting: Isolated Base Mounted with Neoprene Pads or Rigid Base Mounted

a	<u>.</u>		<u></u>	// 10
Certified	Seismic L	evels:	Sds 2 00g	77/h=1()

certifica scistile Leve											
Old Model Number	ld Model Number	Report Number / Name	Di	mensions [in.]		Weight	Mounting	Unit			
Old Woder Number		Report Number / Name	Depth	Width	Height	[ lb. ]	Woulding	onit			
MS0482FC1	MFW0482	60413-1301_Test Report	172	48	94	15,350	Isolated Base	UUT-5			
MS0132FC1	MFW0132	60413-1301_Test Report	139	33	64	4,670	Isolated Base	UUT-6			
MS0803FC1	MFW0803	Water Cooled Flooded OSP Test Report_R1	149	101	96	22,300	Rigid Base	UUT-7			



## **UNIT UNDER TEST (UUT) Summary Sheet**

## UUT-5



Manufacturer: Multistack, LLC

Product Line: MFW Mag Lev Flooded Chiller Line, Gen 1-5

Model Number (Old / Current): MS0482FC1 / MFW0482

Mounting: Isolated base mounted

Product Construction Summary: Painted carbon steel shell and copper tube heat exchanger.

**Options / Component Summary:** 

Compressor: (1) Danfoss TT-500, (1) Danfoss TT-400, Condenser: (1) Standard Refrigeration HSE2412, Evaporator: (1) Standard Refrigeration FEV2612, Expansion Valves: (4) Sporlan Y12-31, Econimizer: (1) SWEP S400THx120, Econimizer Expansion Valves: (1) Sporlan SERI-K Flexsys Control System: (5) Multistack Flexsys

Note: The UUT was operational before and after shaking and was full of operating content during the tests. The structural integrity of the component and attachment system and force-resisting systems was maintained.

		EV.	UUT Pro	operties	MS.			
Tested at a		arating Waight (lb)		Dimensions (in		Lowest N	Natural Freque	ency (Hz)
Tested unit	Operating Weight (Ib)		Depth	Width	Height	Front-Back	Side-Side	Vertical
UUT-5	15,350	15,350		48.0	94.4	6.5	5.5	18.3
	R		Seismic Test	Parameters	r			
Building Code	Test Criteria	Sds (g)	z/h	lp	Aflx-H (g)	Arig-H (g)	Aflx-V (g)	Arig-V (g)
CBC 2022	ICC-ES AC156	2.0	Moham	nad <u>ı</u> sarır	n <sub>3.20</sub>	2.40	1.33	0.53

#### Unit Mounting Description:

UUT-5 was attached to shake table interface plate with 3/8" thick neoprene pads and four (4) 3/4" diameter Grade 5 steel bolts per support frame (8 bolts total) to the test fixture.



Overall view of UUT-5

RTIFICATION

ABORATORIES.LLC

## **UNIT UNDER TEST (UUT) Summary Sheet**

## UUT-6



Manufacturer: Multistack, LLC

Product Line: MFW Mag Lev Flooded Chiller Line, Gen 1-5

Model Number (Old / Current): MS0132FC1 / MFW0132

Mounting: Isolated base mounted

Product Construction Summary: Painted carbon steel shell and copper tube heat exchanger.

#### **Options / Component Summary:**

Compressor: (2) Danfoss TT-300, Condenser: (1) Standard Refrigeration HSE1410, Evaporator: (1) Standard Refrigeration FEV1610, Condenser/Evaporator Expansion Valves: (2) Carel E7V, Econimizer: (1) SWEP V200THx40, Econimizer Expansion Valves: (1) Sporlan SERI-G, Flexsys Control System: (4) Multistack Flexsys

Note: The UUT was operational before and after shaking and was full of operating content during the tests. The structural integrity of the component and attachment system and force-resisting systems was maintained.

		Operating Weight (Ib) Dimensions (in)		Lowest Natural Frequency (Hz)				
Tested unit	Operating we	ignt (ib)	Depth	Width	Height	Front-Back	Vertical	
UUT-6	4,670		139.1	32.5	63.8	8.5	7.3	14.5
	4		Seismic Test	Parameters				
Building Code	Test Criteria	Sds (g)	z/h	lp	Aflx-H (g)	Arig-H (g)	Aflx-V (g)	Arig-V (g
CBC 2022	ICC-ES AC156	2.0	1.0	1.5	3.20	2.40	1.33	0.53

#### Unit Mounting Description:

UUT-6 was attached to shake table interface plate with 3/8'' thick neoprene pads and four (4) 3/4'' diameter Grade 5 steel bolts per support frame (8 bolts total) to the test fixture.



Overall view of UUT-6

ERTIFICATION

## **UNIT UNDER TEST (UUT) Summary Sheet**



## UUT-7

Test Report Name: Water Cooled Flooded OSP Test Report\_R1

Manufacturer: Multistack, LLC

Product Line: MFW Mag Lev Flooded Chiller Line, Gen 1-5

Model Number (Old / Current): MS0803FC1 / MFW0803

Mounting: Rigid base mounted

Product Construction Summary: Painted carbon steel shell and copper tube heat exchanger.

Options / Component Summary:

Compressor: (1) Danfoss TT-700, (2) Danfoss VTT-1200, Condenser: (1) Standard Refrigeration HSE3210, Evaporator: (1) Standard Refrigeration FEV3210, Expansion Valves: (2) Sporlan SEHI-T, Econimizer: (2) SWEP FS250-120, Econimizer Expansion Valves: (2) Sporlan SERI-J, Flexsys Control System: (5) Multistack Flexsys

Note: The UUT was operational before and after shaking and was full of operating content during the tests. The structural integrity of the component and attachment system and force-resisting systems was maintained.

		OF	UUT Pro	perties	1				
Tested unit				Dimensions (in	1)	Lowest N	Lowest Natural Frequency (Hz)		
Tested unit	Operating We	ight (ID)	Depth	Width	Height	Front-Back	Side-Side	Vertical	
UUT-7	22,300		149.0	101.0	96.0	13.0	11.8	11.2	
	8		Seismic Test	Parameters					
Building Code	Test Criteria	Sds (g)	z/h	lp	Aflx-H (g)	Arig-H (g)	Aflx-V (g)	Arig-V (g)	
CBC 2022	ICC-ES AC156	2.0	Mol <sup>1.0</sup> mn	nad <sup>1</sup> l§ari	m 3.20	2.40	1.33	0.53	

#### Unit Mounting Description:

UUT-7 was attached to the shake table interface plate with (16)  $\frac{3}{4}$  diameter bolts to the test fixture.



Overall view of UUT-7