

DEPARTMENT OF HEALTH CARE ACCESS AND INFORMATION OFFICE OF STATEWIDE HOSPITAL PLANNING AND DEVELOPMENT

OFFICE USE ONLY APPLICATION FOR HCAI SPECIAL SEISMIC CERTIFICATION PREAPPROVAL (OSP) APPLICATION #: OSP-0208 **HCAI Special Seismic Certification Preapproval (OSP)** Type: New Renewal **Manufacturer Information** Manufacturer: Lescure Manufacturing LLC Manufacturer's Technical Representative: Mike Lescure Mailing Address: 2301 Arnold Industrial Way, Suite C, Concord, CA 94520 Telephone: (925) 283-2528 Email: mlescure@lescurecompany.com **Product Information** Product Name: Lescure Fuel Oil Control System Product Model Number(s): 248204-MCP001, 248204-RPC001, 248204-FPC001 Product Category: Motor Control Centers Product Sub-Category: Pump Control Panels General Description: master control panel, return pump system, and filtration system for diesel generators Base Mounted Rigid -Mounting Description: None Tested Seismic Enhancements: **Applicant Information** Applicant Company Name: Lescure Manufacturing LLC Contact Person: Mitch Wiley

Email: mwiley@lescurecompany.com

Title: Superintendent

Telephone: (925) 283-2528

- 1111



Mailing Address: 2301 Arnold Industrial Way Suite C., Concord, CA 94520

04/23/2025 OSP-0208 Page 1 of 15



DEPARTMENT OF HEALTH CARE ACCESS AND INFORMATION OFFICE OF STATEWIDE HOSPITAL PLANNING AND DEVELOPMENT

| 20111971 | | | | | | | |
|---|--|--|----------------------|--------|--|--|--|
| California Licensed Structural Eng | ineer Resp | onsible for the Engin | eering and Test Repo | rt(s) | | | |
| Company Name: MIYAMOTO INTERNA | TIONAL INC. | | | | | | |
| Name: Amir Gilani | me: Amir Gilani California License Number: S4733 | | | | | | |
| Mailing Address: 1450 Halyard Drive Su | ite 1, West S | acramento, CA 95695 | | | | | |
| Telephone: (916) 373-1995 | En | nail: agilani@miyamoto | international.com | | | | |
| | | | | | | | |
| Certification Method | | | | | | | |
| GR-63-Core X ICC-E | S AC156 | IEEE 344 | IEEE 693 | NEBS 3 | | | |
| Other (Please Specify): | | | | | | | |
| | (5.0 | OR CODE CO. | | | | | |
| Testing Laboratory | | | | | | | |
| Company Name: UNIVERSITY OF CAL | I <mark>FORNI</mark> A, BE | RKELEY (PEER) | | | | | |
| Contact Person: Amarnath Kasalanati | 27 | \.\\\\\\\\\\\\\\\\\\\\\\\\\\\\\\\\\\\\ | 2 | | | | |
| Mailing Address: 325 Davis Hall, Berkel | ey CA 94720- | -1729 -1729 | 11/61 | | | | |
| Telephone: (510) 642-3437 | BYEN | nail: amarnath1@berke | eley.edu | | | | |
| | | | | | | | |
| C | DAT | E: 04/23/2025 | 1/2/ | | | | |
| | | | TAYA O A I | | | | |

PNIA BUTTOS

VIII



STATE OF CALIFORNIA - HEALTH AND HUMAN SERVICES AGENCY



DEPARTMENT OF HEALTH CARE ACCESS AND INFORMATION OFFICE OF STATEWIDE HOSPITAL PLANNING AND DEVELOPMENT

| Seismic Parameters | Seismic Parameters | | | | | | |
|--|------------------------------------|--|--|--|--|--|--|
| Design Basis of Equipment or Components (F _p /W _p) = 1.80 | | | | | | | |
| SDS (Design spectral response accele | eration at short period, g) = 2.50 | | | | | | |
| ap (Amplification factor) = | 1.0 | | | | | | |
| R _P (Response modification factor) = | 2.5 | | | | | | |
| Ω_0 (System overstrength factor) = | 2.0 | | | | | | |
| Ip (Importance factor) = | 1.5 | | | | | | |
| z/h (Height ratio factor) = | 1 | | | | | | |
| Natural frequencies (Hz) = | See Attachment | | | | | | |
| Overall dimensions and weight = | See Attachment | | | | | | |

| HCAI Approval (For Office Use Only) - Approval Expires on 04/23/2031 | | | | | | |
|--|--|------------------------------------|----|--|--|--|
| Date: | 4/23/2025 OSP-0208 | 3 (2) | | | | |
| Name: | Mohammad Karim | Title: Supervisor, Health Faciliti | es | | | |
| Special S | Seismic Certification Valid Up to: SDS (g) = 2.5 | z/h = 1 | | | | |
| Conditio | on of Approval (if applicable): DATE: 04/23/20 | 025 | _ | | | |



"A healthier California where all receive equitable, affordable, and quality health care"

STATE OF CALIFORNIA - HEALTH AND HUMAN SERVICES AGENCY

Seismic Certification Product Listing

| Manufacturer: | Lescure Manufacturing LLC |
|---------------|-----------------------------------|
| Product Name | Lescure Fuel Oil Control System |
| Product Type: | Automated Fuel Oil Control System |
| Model Number | 248204 |



| UUT | Ttom ())()()()()()()()()()()()()()()()()()(| Model Tested | Din | Weight, | | |
|------|---|---------------|-------|---------|--------|-------|
| UUI | Item BY: | Mohammad Ka | Width | Depth | Height | (lbs) |
| UUT1 | Master Control Panel (MCP) | 248204-MCP001 | 48 | 16 | 72 | 650 |
| UUT2 | Return Pump Console (RPC) | 248204-RPC001 | 34 | 16 | 60 | 455 |
| UUT3 | Filtration Pump Console (FPC) | 248204-FPC001 | 25 60 | (30) | 71 | 1,085 |

Product Construction Summary

UUT1, Master Control Panel:

(Manufacturer Hoffman)

Dripshield F/NEMA12 Enclosure

48"x72"x16"

Material: Carbon steel

UUT2, Return Pump Console:

(Manufacturer Hoffman)

A48R3616HCR NEMA3R HNG CVR BO Enclosure

34"x60"x16"

Material: Carbon steel

UUT3, Filtration Pump Console:

(Manufacturer Lescure Manufacturing LLC.)

NEMA 3R GA12 Galv. Enclosure

60"x71"x30"

Material: Code Gauge Galvanized carbon steel

Miyamoto International, Inc.

| UUT | Manufacturer | Part No. | Description | Material | |
|-----|---------------------------|------------------------|---------------------------------|----------------------------------|--|
| 1 | Hoffman | T200216G100 | AC SIDE MTG 115V 50/60HZ TYPE 4 | Carbon steel/Copper/Plastic | |
| 1 | | TS-5000 | Fuel Management System Console, | | |
| | Incon | TS-EXP | FMS Expansion Module Console, | Carbon steel/Plastic | |
| | | STP-SCI | Smart Controller | | |
| 1 | | B14.0 | NEMA, Thermal Unit, | | |
| | Square D | 8501X020V02 | Relay, | Carbon steel/Plastic | |
| | | 8502SBO1V02S | Manual Switch | | |
| 1 | Cutler | TRN1P120V | Time Delay Relay, | Dlastic/Code or steel | |
| | Hammer | TRNP D3PA2 | 8 Pin Base for TRN1P120V | Plastic/Carbon steel | |
| | | | | | |
| 2 | g D | 2510FG1 | Manual Starter | G 1 1701 d | |
| _ | Square D | A14.8 | Thermal Unit | Carbon steel/Plastic | |
| 2 | Haight | 10U-10 GPM | Universal Pump | Cast Iron | |
| 2 | S56C Frame | | | | |
| _ | Leeson | Rigid "C" | Electric Motor | Carbon steel/Copper/Plastic | |
| | | Face- TEFC | FOR COL | | |
| 2 | Versa-Mount | 4263142 | Flowmeter | Brass/Plastic/Carbon steel | |
| 2 | AZCO | 82100054 | Solenoid Valve N/C | Brass/Plastic/Carbon steel | |
| 2 | Crouse Hinds | RE21 | Reducer Bushing | Carbon steel | |
| | Condulets | TCD2/ | OSD 0208 | Carbon steer | |
| | | | USP-U2U0 | | |
| 3 | Square D | 25 <mark>10KG</mark> 1 | Manual Switch | Carbon steel/Plastic | |
| 3 | Haight | SOUR - | Universal Relief Valve Pump | Cast Iron | |
| | | 30GPM | | / | |
| 3 | Leeson | 110910 | Electric Pump Motor | Carbon steel/Copper/Plastic | |
| 3 | RACOR | FBO-10-DPL | Fuel Purifier /23/2025 | Carbon steel | |
| 3 | AZCO | 82100054 | N/C Solenoid Valve | Brass,/Plastic/Carbon steel | |
| 3 | Franklyn Fueling | TSP-ULS | Leak Sensor | Stainless steel/Plastic/Aluminum | |
| 3 | Crouse Hinds Condulets | RE21 | Reducer Bushing | Carbon steel | |

Summary Sheet for Unit Under Test UUT1: Master Control Panel

| Product Description | | | | |
|---------------------|----------------------------|--|--|--|
| Manufacturer: | Lescure Manufacturing LLC | | | |
| Product Name: | Master Control Panel (MCP) | | | |
| Model Number: | 248204-MCP001 | | | |


| Construction |
|---|
| Dripshield F/NEMA12 Enclosure; (manufacturer Hoffman) |

| Product Subcomponents | | | | | | |
|-----------------------|--------------|---------------------------------|-----------------------------|--|--|--|
| Manufacturer | Part No. | Description | Material | | | |
| Hoffman | T200216G100 | AC SIDE MTG 115V 50/60HZ TYPE 4 | Carbon steel/Copper/Plastic | | | |
| | TS-5000 | Fuel Management System Console, | | | | |
| Incon | TS-EXP | FMS Expansion Module Console, | Carbon steel/Plastic | | | |
| | STP-SCI | Smart Controller | | | | |
| | B14.0 | NEMA, Thermal Unit, | | | | |
| Square D | 8501X020V02 | Relay, | Carbon steel/Plastic | | | |
| | 8502SBO1V02S | Manual Switch | | | | |
| Cutler Hammer | TRN1P120V | Time Delay Relay, | Plastic/Carbon steel | | | |
| Cutter nammer | TRNP D3PA2 | 8 Pin Base for TRN1P120V | Plastic/Carbon steel | | | |

| Properties | of UUT | 4/ | OSP- | 0208 | 3 | |
|-------------------|------------|------------|-------------|-------------|-------|------|
| | | Lowes | st natural | frequencies | | |
| Weigh, lbs | Width, in. | Depth, in. | Height, in. | X- | Y- | Z- |
| 650 | 48 | 16 B | ∕: M∂2hamr | 15.4 K | a12.7 | 10.1 |

| Highest Passed Seismic Certification Level for UUT | | | | | | | | | | |
|--|------------------|------|------|-----|--------------------|--------------------|---------|--------------------|--------------------|---------|
| Building | Test | SDS, | DA | I E | 04/2 | Horizont | al | | Vertical | |
| Code | criteria | g g | z/h | Ip | A _{FLX} , | A _{RIG} , | AFLX, / | A _{FLX} , | A _{RIG} , | AFLX, / |
| | | 1.7. | MXXX | | g | g | A RIG, | 8 | g | A RIG, |
| CBC 2022 | ICC-ES AC 156 | 2.50 | 1.0 | 1.5 | 4.00 | 3.00 | 1.33 | 1.67 | 0.67 | 2.5 |


UUT1 was full of content during the seismic tests. It maintained structural stability and was functional following the seismic tests.





Attached to support platform using ten (10) 1/2 in. A307 bolts. Support platform bolted to ground using four (4) 1/2 in. A307 bolts (one per support leg) B-line FW-1/2" 17/32 thick, Carbon steel Electro Galvanized Flat Washer. Base Plate B200-Square Washer 1-5/8 Sq. by 1/4" Thick

Support platform: Four $2x^2x^{1/4}$ in. ASTM A500 square tube legs; $2x^2x^{1/4}$ in. ASTM A36 angles for platform, Four $4x^6$ ASTM A36 support feet $4x^6$ AS



Miyamoto International, Inc.

Summary Sheet for Unit Under Test UUT2: Return Pump Console

| Product Description | | | | |
|----------------------------|---------------------------|--|--|--|
| Manufacturer: | Lescure Manufacturing LLC | | | |
| Product Name: | Return Pump Console (RPC) | | | |
| Model Number: | 248204-RPC001 | | | |

| Construction |
|---|
| A48R3616HCR: NEMA3R HNG CVR BO Enclosure (manufacturer Hoffman) |

| Manufacturer | Part No. | Description | Material | | |
|------------------------|----------------------|--------------------|-----------------------------|--|--|
| Saucra D | 2510FG1 | Manual Starter | Carbon steel/Plastic | | |
| Square D | A14.8 | Thermal Unit | Carbon steel/Plastic | | |
| Haight | 10U-10 GPM | Universal Pump | Cast Iron | | |
| T | S56C Frame Rigid "C" | Electric Motor | Corbon stool/Conner/Diostio | | |
| Leeson | Face- TEFC | Electric Motor | Carbon steel/Copper/Plastic | | |
| Versa-Mount | 4263142 | Flowmeter | Brass/Plastic/Carbon steel | | |
| AZCO | 82100054 | Solenoid Valve N/C | Brass/Plastic/Carbon steel | | |
| Crouse Hinds Condulets | RE21 | Reducer Bushing | Carbon steel | | |

| Properties of UUT | | | | | | | | | | |
|------------------------|------------|------------|-------------|-------|------------|-------------|--|--|--|--|
| | Weight and | dimensions | OSP- | Lowes | st natural | frequencies | | | | |
| Weigh, lbs | Width, in. | Depth, in. | Height, in. | X- | Y- | Z- | | | | |
| 455 | 34 | 16 | 60 | 14.3 | 13.7 | 10.1 | | | | |
| O BY: Mohammad Karim O | | | | | | | | | | |

| Highest Passed Seismic Certification Level for UUT | | | | | | | | | | |
|--|------------------|-------------------|-----------|-----|--------------------|--------------------|----------------------|--------------------|--------------------|----------------------|
| Building | Test | S _{DS} , | \square | TE | 04/2 | Horizont | al | | Vertical | |
| Code | criteria | g g | z/h | Ip | A _{FLX} , | A _{RIG} , | A _{FLX} , / | A _{FLX} , | A _{RIG} , | A _{FLX} , / |
| | | 151 | | MM | g | g | A RIG, | g | g | A RIG, |
| CBC 2022 | ICC-ES AC 156 | 2.50 | 1.0 | 1.5 | 4.00 | 3.00 | 1.33 | 1.67 | 0.67 | 2.5 |

UUT2 was full of content during the seismic tests. It maintained structural stability and was functional following the seismic tests.

Test mounting detail for UUT2






Attached to support platform using ten (10) 1/2 in. A307 bolts. Support platform bolted to ground using four (4) 1/2 in. A307 bolts (one per support leg) B-line FW-1/2" 17/32 thick, Carbon steel Electro Galvanized Flat Washer. Base Plate B200-Square Washer 1-5/8 Sq. by 1/4" Thick

Support platform: Four 2x2x1/4 in. ASTM A500 square tube legs; 2x2x1/4 in. ASTM A536 angles for platform, Four 4x6 ASTM A36 support feet

DATE: 04/23/2025



Miyamoto International, Inc.

Summary Sheet for Unit Under Test UUT3: Filtration Pump Console

| Product Description | | | | | | |
|----------------------------|-------------------------------|--|--|--|--|--|
| Manufacturer: | Lescure Manufacturing LLC | | | | | |
| Product Name: | Filtration Pump Console (FPC) | | | | | |
| Model Number: | 248204-FPC001 | | | | | |

| Construction | |
|--|---|
| BOX607130: 60"x71"x30" GA12 Galv Enclosure (manufacturer Lescure Manufacturing LLC.) | _ |

| Product Subcomponents | | | | | | | | | |
|------------------------|--------------|-----------------------------|----------------------------------|--|--|--|--|--|--|
| Manufacturer | Part No. | Description | Material | | | | | | |
| Square D | 2510KG1 | Manual Switch | Carbon steel/Plastic | | | | | | |
| Haight | SOUR - 30GPM | Universal Relief Valve Pump | Cast Iron | | | | | | |
| Leeson | 110910 | Electric Pump Motor | Carbon steel/Copper/Plastic | | | | | | |
| RACOR | FBO-10-DPL | Fuel Purifier | Carbon steel | | | | | | |
| AZCO | 82100054 | N/C Solenoid Valve | Brass, /Plastic/Carbon steel | | | | | | |
| Franklyn Fueling | TSP-ULS | Leak Sensor | Stainless steel/Plastic/Aluminum | | | | | | |
| Crouse Hinds Condulets | RE21 | Reducer Bushing | Carbon steel | | | | | | |


| Properties | of UUT | 2/ | OSP- | 0208 | 3 | |
|-------------------|------------|------------|---------------|-------------|------|------|
| | Weight and | Lowe | st natural | frequencies | | |
| Weigh, lbs | Width, in. | Depth, in. | Height, in. | X_{T} | Y- | Z- |
| 1,085 | 60 | 30 | • 1V1911a1111 | 14.3 | 13.7 | 10.1 |

| Highest Passed Seismic Certification Level for UUT | | | | | | | | | | |
|--|----------|------|-------|------------|------------|----------|--------------------|--------|---------|--------------------|
| Building Test Sps, | | | | Horizontal | | Vertical | | | | |
| Code | | z/h | I_p | AFLX, | A RIG, | AFLX, | A _{FLX} , | A RIG, | AFLX, / | |
| | 01100110 | 0 | | | g | g | A _{RIG} , | g | g | A _{RIG} , |
| CBC 2022 | ICC-ES | 2.50 | 1.0 | 1.5 | 4.00 | 3.00 | 1.33 | 1.67 | 0.67 | 2.5 |
| | AC 156 | | (V) | 1 | 7 17 18 18 | MAL | | | | |

UUT3 was full of content during the seismic tests. It maintained structural stability and was functional following the seismic tests.

Test mounting detail for UUT3






Attached to support platform using ten (10) 1/2 in. A307 bolts. Support platform bolted to ground using four (4) 1/2 in. A307 bolts (one per support leg) B-line FW-1/2" 17/32 thick, Steel Electro Galvanized Flat Washer. Base Plate B200-Square Washer 1-5/8 Sq. by 1/4" Thick

Support platform: Four 2x2x1/4 in. ASTM A500 square tube legs; 2x2x1/4 in ASTM A36 angles for platform, Four 4x6 ASTM A36 support feet





Miyamoto International, Inc.

