



**OFFICE OF STATEWIDE HEALTH PLANNING AND DEVELOPMENT
FACILITIES DEVELOPMENT DIVISION**

**APPLICATION FOR OSHPD SPECIAL SEISMIC
CERTIFICATION PREAPPROVAL (OSP)**

OFFICE USE ONLY

APPLICATION #: **OSP – 0233-10**

OSHPD Special Seismic Certification Preapproval (OSP)

Type: New Renewal

Manufacturer Information

Manufacturer: **Hochiki America Corporation**

Manufacturer's Technical Representative: **Bill Denney**

Mailing Address: **7051 Village Drive, Suite 100, Buena Park, CA 90621**

Telephone: **559.490.7972** Email: **bdenney@hochiki.com**

Product Information

Product Name: **FireNET Alarm Control Panels**

Product Type: **Fire Alarm Control Panel**

Product Model Number: **See Attachment 1**

(List all unique product identification numbers and/or part numbers)

General Description: **Analog addressable fire alarm control panels and battery cabinets.**

Mounting Description: **Rigid wall mounted.**

Applicant Information

Applicant Company Name: **Manwill Engineering LLC**

Contact Person: **Derek Manwill, SE**

Mailing Address: **PO Box 1194, Bend, OR 97709**


Telephone: **541.241.2102** Email: **derek@manwillSE.com**

I hereby agree to reimburse the Office of Statewide Health Planning and Development review fees in accordance with the California Administrative Code, 2016.

Signature of Applicant:  Date: **3/15/2017**

Title: **President** Company Name: **Manwill Engineering LLC**

"Access to Safe, Quality Healthcare Environments that Meet California's Diverse and Dynamic Needs"





**OFFICE OF STATEWIDE HEALTH PLANNING AND DEVELOPMENT
FACILITIES DEVELOPMENT DIVISION**

California Licensed Structural Engineer Responsible for the Engineering and Test Report(s)

Company Name: Manwill Engineering LLC

Name: Derek Manwill, SE California License Number: S6266

Mailing Address: PO Box 1194, Bend, OR 97709

Telephone: 541.241.2102 Email: derek@manwillSE.com

Supports and Attachments Preapproval

- Supports and attachments are preapproved under OPM- _____
(Separate application for OSHPD Preapproval of Manufacturer's Certification (OPM) of Supports and attachments is required)
- Supports and attachments are not preapproved

Certification Method

- Testing in accordance with: ICC-ES AC156
- Other (Please Specify): _____


Testing Laboratory

Company Name: National Technical Systems (NTS)

Contact Name: Ratish Rao

Mailing Address: 1536 East Valencia Drive, Fullerton, CA 92831

Telephone: 714.879.6110 Email: ratish.rao@nts.com





**OFFICE OF STATEWIDE HEALTH PLANNING AND DEVELOPMENT
FACILITIES DEVELOPMENT DIVISION**

Seismic Parameters

Design in accordance with ASCE 7-10 Chapter 13: Yes No

Design Basis of Equipment or Components (F_p/W_p) = 1.88

S_{DS} (Design spectral response acceleration at short period, g) = 2.5

a_p (In-structure equipment or component amplification factor) = 2.5

R_p (Equipment or component response modification factor) = 6.0

Ω_0 (System overstrength factor) = 2.0

I_p (Importance factor) = 1.5

z/h (Height factor ratio) = 1

Equipment or Component Natural Frequencies (Hz) = N/A (wall mounted)

Overall dimensions and weight (or range thereof) = See Attachments 1 & 2

Equipment or Components @ grade designed in accordance with ASCE 7-10 Chapter 15: Yes No

Design Basis of Equipment or Components (V/W) = _____

S_{DS} (Design spectral response acceleration at short period, g) = _____

S_{D1} (Design spectral response acceleration at 1 second period, g) = _____

R (Response modification coefficient) = _____

Ω_0 (System overstrength factor) = _____

C_d (Deflection amplification factor) = _____

I_p (Importance factor) = 1.5

Height to Center of Gravity above base = _____

Equipment or Component Natural Frequencies (Hz) = _____

Overall dimensions and weight (or range thereof) = _____

Tank(s) designed in accordance with ASME BPVC, 2015: Yes No

List of Attachments Supporting Special Seismic Certification

Test Report(s) Drawings Calculations Manufacturer's Catalog

Other(s) (Please Specify): Attachments 1 & 2


OSHPD Approval (For Office Use Only) – Approval Expires on December 31, 2022

Signature:  Date: 3/15/2017

Print Name: M. R. Karim Title: SHFR

Special Seismic Certification Valid Up to : S_{DS} (g) = 2.5 z/h = 1.0

Condition of Approval (if applicable): _____



ATTACHMENT 1: CERTIFIED COMPONENTS

SEISMIC COMPLIANCE REPORT

TABLE 1

DOCUMENT NO.: 17021CR1.0

| MANUFACTURER: | | HOCHIKI AMERICA CORPORATION | | | | |
|---|---|--|--------|----------------------|---|---------|
| PRODUCT FAMILY: | | FireNET ALARM CONTROL PANELS & BATTERY ENCLOSURE | | | | |
| MODEL NUMBER | DIMENSIONS (in) | | | MAX. WT. (lb) | DESCRIPTION / NOTES | BASIS |
| | DEPTH | WIDTH | HEIGHT | | | |
| FireNET Analog Addressable Fire Alarm Control Panels | | | | | | |
| FN-4127N | 5.0 | 14.5 | 24.0 | 29 | | UUT 1 |
| FN-4127-DDWN | 5.0 | 14.5 | 24.0 | 28 | | UUT 2 |
| Plus-1127 | 3.5 | 14.5 | 19.0 | 20 | | UUT 3 |
| FN-ACC | 5.8 | 17.8 | 14.9 | 62 | UUT 4 weighed 27-lb | UUT 4,5 |
| MOUNTING: | Rigid wall mounted. | | | SEISMIC LEVEL | $S_{DS} = 2.5g$ for $z/h = 1$ $I_p = 1.5$ | |
| NOTES: | Product Construction: Carbon steel enclosure. Options/Subcomponents: Model number uniquely identifies subcomponents except for FN-ACC. FN-ACC can have a range of battery sizes as shown in Table 2. | | | | | |

TABLE 2 - SUBCOMPONENTS

| MANUFACTURER: | | HOCHIKI AMERICA CORPORATION | | | | |
|-----------------------------------|---|--|--------|-------------------------|---|--------|
| PRODUCT FAMILY: | | FireNET ALARM CONTROL PANELS & BATTERY ENCLOSURE | | | | |
| MODEL NUMBER | DIMENSIONS (in) | | | MAX. WT. (lb) | DESCRIPTION / NOTES | BASIS |
| | DEPTH | WIDTH | HEIGHT | | | |
| MK Battery - 12V Batteries | | | | | | |
| ES7-12 | 5.9 | 2.6 | 3.7 | 5.3 | | UUT 4 |
| ES9-12 | 5.9 | 2.6 | 3.7 | 5.9 | | INTERP |
| ES10-12 | 5.9 | 2.6 | 4.4 | 7.3 | | INTERP |
| ES12-12 | 5.9 | 3.9 | 3.7 | 9.0 | | INTERP |
| ES14-12 | 5.9 | 3.9 | 3.7 | 9.4 | | INTERP |
| ES17-12 | 7.1 | 3.0 | 6.6 | 13 | | INTERP |
| ES20-12 | 7.1 | 3.0 | 6.6 | 13 | | INTERP |
| ES26-12 | 6.5 | 6.9 | 4.9 | 21 | | INTERP |
| ES33-12 | 7.8 | 5.2 | 6.3 | 23 | | UUT 5 |
| MOUNTING: | Mounted within unit. | | | SEISMIC LEVEL(S) | $S_{DS} = 2.5g$ for $z/h = 1$ $I_p = 1.5$ | |
| NOTES: | Product Construction/Options: Model number uniquely identifies manufacturer, materials and configuration of subcomponents. | | | | | |

ATTACHMENT 2: UNIT UNDER TEST SUMMARIES

SEISMIC COMPLIANCE REPORT

UUT 1

DOCUMENT NO.: 17021CR1.0

| | | | | | | |
|---|--------------|---|------------------------------|------------------------------|------------------------------|----------|
| MANUFACTURER: | | HOCHIKI AMERICA CORPORATION | | | | |
| MODEL NUMBER: | | FireNET FN-4127N | | | | |
| UNIT FUNCTION: | | Alarm Control Panel | | | | |
| SERIAL NUMBER: | | N/A | | | | |
| DIMENSIONS (in) | | | WEIGHT (lb) | RES. FREQ. (Hz) | | |
| DEPTH | WIDTH | HEIGHT | | F-B | S-S | V |
| 5.0 | 14.5 | 24.0 | 29 | N/A | N/A | N/A |
| BUILDING CODE | | TEST CRITERIA | | LAB REPORT NO. | | |
| 2016 CBC | | ICC-ES AC156 | | NTS 113-2355 | | |
| S_{DS} (g) | z/h | A_{FLX-H} (g) | A_{RIG-H} (g) | A_{FLX-V} (g) | A_{RIG-V} (g) | |
| 2.5 | 1 | 4.00 | 3.00 | 1.68 | 0.68 | |
| IMPORTANCE FACTOR, I_p = 1.5 | | | | | | |
| Unit was full of operating content during the shake table test. Unit maintained structural integrity and remained functional per manufacturer requirement after shake table test. | | | | | | |
| MOUNTING: | | Rigid wall mounted using (4) #10 screws. | | | | |
| CONSTRUCTION: | | Carbon steel enclosure | | | | |
| SUBCOMPONENTS: | | Model number uniquely identifies subcomponents. | | | | |
| TESTING NOTES: | | N/A | | | | |



UUT 2

| | | | | | | |
|---|--------------|---|------------------------------|------------------------------|------------------------------|----------|
| MANUFACTURER: | | HOCHIKI AMERICA CORPORATION | | | | |
| MODEL NUMBER: | | FireNET FN-4127-DDWN | | | | |
| UNIT FUNCTION: | | Alarm Control Panel | | | | |
| SERIAL NUMBER: | | N/A | | | | |
| DIMENSIONS (in) | | | WEIGHT (lb) | RES. FREQ. (Hz) | | |
| DEPTH | WIDTH | HEIGHT | | F-B | S-S | V |
| 5.0 | 14.5 | 24.0 | 28 | N/A | N/A | N/A |
| BUILDING CODE | | TEST CRITERIA | | LAB REPORT NO. | | |
| 2016 CBC | | ICC-ES AC156 | | NTS 113-2355 | | |
| S_{DS} (g) | z/h | A_{FLX-H} (g) | A_{RIG-H} (g) | A_{FLX-V} (g) | A_{RIG-V} (g) | |
| 2.5 | 1 | 4.00 | 3.00 | 1.68 | 0.68 | |
| IMPORTANCE FACTOR, I_p = 1.5 | | | | | | |
| Unit was full of operating content during the shake table test. Unit maintained structural integrity and remained functional per manufacturer requirement after shake table test. | | | | | | |
| MOUNTING: | | Rigid wall mounted using (4) #10 screws. | | | | |
| CONSTRUCTION: | | Carbon steel enclosure | | | | |
| SUBCOMPONENTS: | | Model number uniquely identifies subcomponents. | | | | |
| TESTING NOTES: | | N/A | | | | |



ATTACHMENT 2: UNIT UNDER TEST SUMMARIES

SEISMIC COMPLIANCE REPORT

UUT 3

DOCUMENT NO.: 17021CR1.0

| | | | | | | |
|---|--------------|---|------------------------------|------------------------------|------------------------------|----------|
| MANUFACTURER: | | HOCHIKI AMERICA CORPORATION | | | | |
| MODEL NUMBER: | | FireNET Plus-1127 | | | | |
| UNIT FUNCTION: | | Alarm Control Panel | | | | |
| SERIAL NUMBER: | | N/A | | | | |
| DIMENSIONS (in) | | | WEIGHT (lb) | RES. FREQ. (Hz) | | |
| DEPTH | WIDTH | HEIGHT | | F-B | S-S | V |
| 3.5 | 14.5 | 19.0 | 20 | N/A | N/A | N/A |
| BUILDING CODE | | TEST CRITERIA | | LAB REPORT NO. | | |
| 2016 CBC | | ICC-ES AC156 | | NTS 113-2355 | | |
| S_{DS} (g) | z/h | A_{FLX-H} (g) | A_{RIG-H} (g) | A_{FLX-V} (g) | A_{RIG-V} (g) | |
| 2.5 | 1 | 4.00 | 3.00 | 1.68 | 0.68 | |
| IMPORTANCE FACTOR, I_p = 1.5 | | | | | | |
| Unit was full of operating content during the shake table test. Unit maintained structural integrity and remained functional per manufacturer requirement after shake table test. | | | | | | |
| MOUNTING: | | Rigid wall mounted using (4) #10 screws. | | | | |
| CONSTRUCTION: | | Carbon steel enclosure | | | | |
| SUBCOMPONENTS: | | Model number uniquely identifies subcomponents. | | | | |
| TESTING NOTES: | | N/A | | | | |



UUT 4

| | | | | | | |
|---|--------------|--|------------------------------|------------------------------|------------------------------|----------|
| MANUFACTURER: | | HOCHIKI AMERICA CORPORATION | | | | |
| MODEL NUMBER: | | FN-ACC | | | | |
| UNIT FUNCTION: | | Alarm Battery Panel | | | | |
| SERIAL NUMBER: | | N/A | | | | |
| DIMENSIONS (in) | | | WEIGHT (lb) | RES. FREQ. (Hz) | | |
| DEPTH | WIDTH | HEIGHT | | F-B | S-S | V |
| 5.8 | 17.8 | 14.9 | 27 | N/A | N/A | N/A |
| BUILDING CODE | | TEST CRITERIA | | LAB REPORT NO. | | |
| 2016 CBC | | ICC-ES AC156 | | NTS 113-2355 | | |
| S_{DS} (g) | z/h | A_{FLX-H} (g) | A_{RIG-H} (g) | A_{FLX-V} (g) | A_{RIG-V} (g) | |
| 2.5 | 1 | 4.00 | 3.00 | 1.68 | 0.68 | |
| IMPORTANCE FACTOR, I_p = 1.5 | | | | | | |
| Unit was full of operating content during the shake table test. Unit maintained structural integrity and remained functional per manufacturer requirement after shake table test. | | | | | | |
| MOUNTING: | | Rigid wall mounted using (4) #10 screws. | | | | |
| CONSTRUCTION: | | Carbon steel enclosure | | | | |
| SUBCOMPONENTS: | | MK Battery - battery (two ES7-12) | | | | |
| TESTING NOTES: | | N/A | | | | |



ATTACHMENT 2: UNIT UNDER TEST SUMMARIES

SEISMIC COMPLIANCE REPORT

UUT 5

DOCUMENT NO.: 17021CR1.0

| | | | | | | | |
|---|--------------|--|------------------------------|------------------------------|------------------------------|----------|--|
| MANUFACTURER: | | HOCHIKI AMERICA CORPORATION | | | | | |
| MODEL NUMBER: | | FN-ACC | | | | | |
| UNIT FUNCTION: | | Alarm Battery Panel | | | | | |
| SERIAL NUMBER: | | N/A | | | | | |
| DIMENSIONS (in) | | | WEIGHT (lb) | RES. FREQ. (Hz) | | | |
| DEPTH | WIDTH | HEIGHT | | F-B | S-S | V | |
| 5.8 | 17.8 | 14.9 | 62 | N/A | N/A | N/A | |
| BUILDING CODE | | TEST CRITERIA | | LAB REPORT NO. | | | |
| 2016 CBC | | ICC-ES AC156 | | NTS 113-2355 | | | |
| S_{DS} (g) | z/h | A_{FLX-H} (g) | A_{RIG-H} (g) | A_{FLX-V} (g) | A_{RIG-V} (g) | | |
| 2.5 | 1 | 4.00 | 3.00 | 1.68 | 0.68 | | |
| IMPORTANCE FACTOR, I_p = 1.5 | | | | | | | |
| Unit was full of operating content during the shake table test. Unit maintained structural integrity and remained functional per manufacturer requirement after shake table test. | | | | | | | |
| MOUNTING: | | Rigid wall mounted using (4) #10 screws. | | | | | |
| CONSTRUCTION: | | Carbon steel enclosure | | | | | |
| SUBCOMPONENTS: | | MK Battery - battery (two ES33-12) | | | | | |
| TESTING NOTES: | | N/A | | | | | |

