| 0 | | "Equitable Healthcare Accessibility for California" |
|----------------------|---|---|
| Off | fice of Statewide Health Pla | anning and Development |
| Faci 400 F | ilities Development Division R Street. Suite 200, Sacramento, California 95 | www.oshpd.ca.gov/fdd 811-6213 Phone (916) 440-8300 Fax (916) 654-2973 |
| | | ON FOR PREAPPROVAL IFICATION OF EQUIPMENT AND COMPONENTS |
| | APPLICATION NO. | Check whether application is: NEW X RENEWAL |
| | OSP - 0244 - 10 | |
| 1.0 | Ameridex Plate Exchangers | Mark R. Hilkman |
| | Manufacturer 145 County Road 309 | Manufacturer's Technical Representative |
| | | Bryant, Alabama 35958 Mailing Address |
| | | |
| | 256-597-3360 Tolophono | ameridexplateexchangers@ameridex.net E-mail Address |
| | Telephone | E-mail Address |
| 2.0 | Ameridex Plate Exchangers | Plate Heat Exchangers |
| | Product Name | Product Type |
| | Ameride | x X-5-IND to X-30 (See Table-1) |
| | Product model No (List a | ll unique product identification numbers and/or serial numbers) |
| | General Description: Rigid Floor Mo | unted Vertical Plate Heat Exchangers. |
| 3.0 | Panache Engineering Inc | Ahmed Haider, Ph.D., P.E. |
| | Applicant Company Name | Contact Person |
| | 150 N Santa Anita Ave, Suit | |
| | (626)698-0784 | Mailing Address Ahmed.haider@panacheg.com |
| | Telephone | E-mail Address |
| | reby agree to reimburse the Office s incurred by the department for re A. Hourd Signature of Applicant | of Statewide Health Planning and Development for the actual eview. |
| | c | |
| | Engineering Manager <i>Title</i> | Panache Engineering Inc Company Name |
| OSH Page | I-FD e 1 of 3 | State of California – Health and Human Services Agency Edmund G. Brown Jr., Governor |



Office of Statewide Health Planning and Development



 \checkmark

"Equitable Healthcare Accessibility for California"

Office of Statewide Health Planning and Development



| Δnr | nnval | Para | meters |
|-----|---------|------|--------|
| Αρμ | Ji Ovai | raia | meters |

bd

| - | - |
|-----|---|
| α | n |
| . 3 | υ |

0

| Design in accordance with ASCE 7-05 Chapter 13: 🔀 Yes 🗌 No |
|--|
| Design Basis of Equipment or Components $(F_p/W_p) = 1.44 @ S_{DS} = 2.0$ = 0.60 @ $S_{DS} = 2.5$ |
| S_{DS} (Spectral response acceleration at short period) = See Table 1 |
| a_p (In-structure equipment or component amplification factor) =1 |
| R_p (Equipment or component response modification factor) =2.5 |
| I_{p} (Importance factor) = 1.5 |
| z/h (Height factor ratio) = See Table 1 |
| Equipment or Component fundamental period(s) = See Table 2 |
| Building period limits (if any) =N/A |
| Overall dimensions and weight (or range thereof) = See Table 2 |
| Equipment or Components @ grade designed in accordance with ASCE 7-05 Chapter 15: 🗌 Yes 🔀 No |
| Design Basis of Equipment or Components (V/W) = |
| S_{DS} (Spectral response acceleration at short period) = |
| S_1 (Spectral response acceleration at 1 second period) = |
| R (Response modification coefficient)=1.0 |
| Ω_0 (System overstrength factor) =1.0 |
| C_d (Deflection amplification factor) =1.0 |
| I_p (Importance factor) =1.5 |
| Height to Center of Gravity above base = |
| Equipment or Component fundamental period(s) = Sec |
| Overall dimensions and weight (or range thereof) = |
| Tank(s) designed in accordance with ASME BPVC, 2007: Yes No |
| 10.0 List of attachments supporting the special seismic certification of equipment or components: |
| 🛛 Test Report 🖾 Drawings 🗌 Manufacturer's Catalog |
| Calculations Others (Please Specify): |
| 11.0 OSHPD Approval (For Office Use Only) 11.0 12/06/2012 Signature & Date Approval Expiration Date |
| Timothy J. Piland, SSESDS (g) =See Section 9.0z/h =See Section 9.0 |
| Name & Title Special Seismic Certification Valid Up to Condition of Approval (if any): Special Seismic Certification Valid Up to |

| Table 1 | CHE A |
|--|---|
| Special Seismic Certification Approved Units | Ameridex Plate Exchangers |
| Product Type: Vertical Plate Heat Exchangers | Manufacturer: Ameridex Plate Exchangers |
| Product Function Fluid Heat Exchange | |
| Certified Product Construction: | Certified Mounting Descriptions: |
| Stainless Steel SA-240 316 exchanger plates, SA-516 Grade 70 Header Plates, SA-193 B7 Rods and SA-194 2H Nuts | Rigid Floor Mounted |

| MODEL | Max Length (inches) | Width (inches) | Height (inches) | Max Wet Weight (Lbs) | Port Size | z/h | Sds (G) | UUT |
|-------|---------------------------|-------------------|--------------------|----------------------------|-----------|--------|------------|--------------|
| X-5 | 13 | 8 | 19.5 | 125 | 1 | 0 1 | 2.5 2.0 | UUT-2 |
| X-10 | 19 | 8 | 31.5 | 200 | 1 | 0 1 | 2.5 2.0 | Interpolated |
| X-15 | 38 | 13.25 | 27.3 | 260 | 2 | 0 1 | 2.5 2.0 | Interpolated |
| X-18 | 38 | 16.5 | 26 | 400 | 2.5 | 0 1 | 2.5 2.0 | Interpolated |
| X-20 | 38 | 13.25 | 39.1 | 400 | 2 | 0 1 | 2.5 2.0 | Interpolated |
| X-25 | 38 | 13.25 | 47 | 550 | 2 | 0 1 | 2.5 2.0 | Interpolated |
| X-28 | 38 | 16.5 | 38.5 | 600 | 2.5 | 0 1 | 2.5 2.0 | Interpolated |
| X-30 | 42 | 20 | 44 | 1520 | 4 | 0 1 | 2.5 2.0 | UUT-1 |
| X-30 | 50 | 20 | 44 | 1800 | 4 | 0 1 | 2.5 2.0 | Extrapolated |

Panache Engineering Inc., 150 N. Santa Anita Ave Ste 300, Arcadia, CA 91006, Phone: 626-698-0784, Fax: 267-948-5441, www.panacheg.com

| <text></text> | | | Table 2 | | | | | | | |
|--|-----------------|--------------------|---------------|----------------|-------------------|-------------------|---------------------------------|-----------------|----------------------|-----------|
| windfurg: | | Unit Und | | mmary Sheet | | Ameridex | Plate Exch | angers | SEISMIC WWW.Panad | VIBRATION |
| eritied Configuration: Tested Configuration: | | | | | | | | | | 0 |
| | | | at Exchangers | | | | | - | | |
| exhe Runctionality Test Result Pasted Pasted Pasted Runctionality Test Result Pasted Image: Construction of the State Structure Totesension Image: Constructure Totesension | Stainless Steel | SA-240 316 exch | | | Full of water and | | Rigid Floor m of (5) 5/8" fo | ounted. Attac | hed to the test | |
| <image/> UI Propring mining from back hutter frequency (bit) for side to sid | Pre-Shake Fund | ctionality Test Re | sults | Passed | Post-Shake Functi | onality Test Resu | | Passed | | |
| UT Image: Constrained frequency (Hz) Dimensione (Incher) Operating (Methylik) UUT 2.3.3 2.6.17 2.9.15 8.4.3 2.9.2 1.9.5 | | | | | Post-Shake Struct | ural Observation | s | No Anomaly/ | Passed | |
| UT Image: Constrained frequency (Hz) Dimensione (Incher) Operating (Methylik) UUT 2.3.3 2.6.17 2.9.15 8.4.3 2.9.2 1.9.5 | | | | | UUT Properti | ies | | | | |
| UnitNoteNumberFrom:BackSide to SideVerticalLengthWidthHeightWeight(h)U1123.330.310.3 <t< td=""><td></td><td></td><td></td><td>Lowest Natural</td><td>-</td><td></td><td>Di</td><td>imensions (Inch</td><td>es)</td><td>Operating</td></t<> | | | | Lowest Natural | - | | Di | imensions (Inch | es) | Operating |
| UUT2 X.5 Q.4.7 Q.3.5 NA 1.3 8 19.5 1.2.5 Selsmic Test Parameters Main Arie-H Arie-H Arie-K | UUT | Model Number | Front | -Back | Side to Side | Vertical | Length | Width | Height | |
| UUT2 X.5 Q.4.7 Q.3.5 NA 1.3 8 19.5 1.2.5 Selsmic Test Parameters Main Arie-H Arie-H Arie-K | UUT1 | X-30 | 33 | 3.3 | 33.3 | 6.3 | 43 | 20 | 44 | 1520 |
| Building Code Test Criteria Sds L/h up After H Arige H After V Arige V CBC 2010 ICC ES AC156 (2010) 2.5 0 1.5 2.50 1.00 1.68 0.68 2.0 1 1.5 3.20 2.40 1.34 0.54 UTI S 100 | | | | | | | | | | |
| Building Code Test Criteria Sds L/h up After H Arige H After V Arige V CBC 2010 ICC ES AC156 (2010) 2.5 0 1.5 2.50 1.00 1.68 0.68 2.0 1 1.5 3.20 2.40 1.34 0.54 UTI S 100 | | | | | | | | | | |
| ICC_ES_ACISS (200) 2.5 0 1.5 2.0 1.00 1.68 0.68 CC 2010 ICC_ES_ACISS (200) 2.0 1 1.5 3.20 2.40 1.44 0.54 UNIT OF COLSPANE SUBJECT SU | Buildi | ng Code | Test Criteria | Sds | 1 | 1 | Aflx-H | Arig-H | Aflx-V | Arig-V |
| <image/> CC 2010 1 1 3.0 2.40 1.4 0.41 Colspan="4">Colspan="4">Colspan="4">Colspan="4">Colspan="4">Colspan="4">Colspan="4">Colspan="4">Colspan="4"Colspan="4">Colspan="4"Colspan="4"Colspan="4">Colspan="4"Colspan="4"Colspan="4"Colspan="4"Colspan="4">Colspan="4"Colspan="4"Colspan="4"Colspan="4"Colspan="4"Colspan="4"Colspan="4"Colspan="4"Colspan="4"Colspan="4"Colspan="4"Colspan="4">Colspan="4"C | Dailai | | . cot enteriu | | Ì | | | | | |
| <image/> <caption><image/><image/><image/></caption> | CBC | 2010 | | | | | | | | |
| UUT1 (5) 5/8" ASTM A325 UUT1 (5) 5/8" ASTM A325 UUT2 (4) 1/2" ASTM A325 Bolts UUT1 & UUT2 Attachment To Test Fixture | | | | | UUT2 | ayout on Shake Ta | able | Sr. | | |
| UUT1 (5) 5/8" ASTM A325 UUT1 (5) 5/8" ASTM A325 UUT2 (4) 1/2" ASTM A325 Bolts UUT1 & UUT2 Attachment To Test Fixture | | | | | | | | | | |
| | | | | UUT1 (5) 5/8" | | | | UUT2 (4) 1/2" | ASTM A325 Bol | ts |
| | | | | 00 4 | | | | | | |

| Tabl | e 3 | CHED | | | |
|--|------------------|---------------------------------------|--|--------------------------------|--|
| Unit Under Test (UUT) N | ents | Intervidex Plate Exchangers | | | |
| Product Type: Vertical Plate Heat Exchange | rs | | Manufactu | rer: Ameridex Plate Exchangers | |
| Certified Product Construction: | | Tested Configurat | ions: | Test Mounting Descriptions: | |
| Stainless Steel SA-240 316 exchanger plates, SA-516 Grade 70 Header Plates, SA-193 B7 Rods and SA-194 2H Nuts | | Full of water and Mounted to floor | Rigid Floor mounted. Attached to the test fixture by means of (5) 5/8" for UUT1 and (3) 1/2" for UUT2 AST A325 Bolts | | |
| Pre-Shake Functionality Test Results | Post-Shake Funct | onality Test | t Results Passed | | |

UUT-1 Major Sub Components

- (2) Vertical ASTM SA-516 Grade 70 Header Frame Plates manufactured by Ameridex
- (96) Stainless Steel -SA-240 316 Exchanger Plates manufactured by Ameridex
- (6) SA-193 B7 Bolts
- (12) SA-194 2H Nuts
- (4) 4" Port

UUT-2 Major Sub Components

(2) Vertical ASTM SA-516 Grade 70 Header Frame Plates manufactured by Ameridex
(27) Stainless Steel -SA-240 316 Exchanger Plates manufactured by Ameridex
(6) SA-193 B7 Bolts
(12) SA-194 2H Nuts
(4) 1" Port

Additional Sub-Components for UUT1 and UUT-2

- Victaulic Couplings Schedule 40 Style A07 Carbon Steel manufactured by Victaulic Corporation
- Bars & Stanchions ASTM A36 carbon steel except upper guide bars are made from SS 316 (manufactured by Ameridex)
- NPT Nozzles Schedule 40 Type 316 SS
- Gaskets Nitrile Butyl Rubber manufactured Blaylock Gasket
- Flanges ANSI B16.5 150# manufactured by Texas Flange

Panache Engineering Inc., 150 N. Santa Anita Ave Ste 300, Arcadia, CA 91006, Phone: 626-698-0784, Fax: 267-948-5441, www.panacheg.com