



OFFICE OF STATEWIDE HEALTH PLANNING AND DEVELOPMENT
FACILITIES DEVELOPMENT DIVISION

APPLICATION FOR OSHPD SPECIAL SEISMIC
CERTIFICATION PREAPPROVAL (OSP)

OFFICE USE ONLY
APPLICATION #: OSP - 0250

OSHPD Special Seismic Certification Preapproval (OSP)

Type: [ ] New [X] Renewal

Manufacturer Information

Manufacturer: Johnson Controls, Inc.

Manufacturer's Technical Representative: Devin Du

Mailing Address: 5000 Renaissance Drive, New Freedom, PA 17349

Telephone: 717.771.6376 Email: devin.du@jci.com

Product Information

Product Name: YCAL/QTC2 & YCUL Air-Cooled Scroll Chillers

Product Type: Air-Cooled Chillers

Product Model Number: See Attachment 1
(List all unique product identification numbers and/or part numbers)

General Description: Carbon steel air-cooled scroll chillers.

Seismic enhancements made to the test units shall be incorporated into the production units.

Mounting Description: Isolated floor mounted with captive mount neoprene isolators.

Applicant Information

Applicant Company Name: Manwill Engineering LLC

Contact Person: Derek Manwill, SE

Mailing Address: PO Box 1194, Bend, OR 97709


Telephone: 541.241.2102 Email: derek@manwillSE.com

I hereby agree to reimburse the Office of Statewide Health Planning and Development review fees in accordance with the California Administrative Code, 2016.

Signature of Applicant: [Signature] Date: 4/24/2019

Title: President Company Name: Manwill Engineering LLC

\*Access to Safe, Quality Healthcare Environments that Meet California's Diverse and Dynamic Needs\*





**OFFICE OF STATEWIDE HEALTH PLANNING AND DEVELOPMENT  
FACILITIES DEVELOPMENT DIVISION**

**California Licensed Structural Engineer Responsible for the Engineering and Test Report(s)**

Company Name: Manwill Engineering LLC

Name: Derek Manwill, SE California License Number: S6266

Mailing Address: PO Box 1194, Bend, OR 97709

Telephone: 541.241.2102 Email: derek@manwillSE.com

**Supports and Attachments Preapproval**

- Supports and attachments are preapproved under OPM- \_\_\_\_\_  
(Separate application for OSHPD Preapproval of Manufacturer's Certification (OPM) of Supports and attachments is required)
- Supports and attachments are not preapproved

**Certification Method**

- Testing in accordance with:  ICC-ES AC156
- Other (Please Specify): \_\_\_\_\_


**Testing Laboratory**

Company Name: Clark Dynamic Test Laboratory, Inc.

Contact Name: Patrick Wetherill

Mailing Address: 1801 51 South, Jefferson Hills, PA 15025

Telephone: 412.387.1676 Email: pwetherill@clarktesting.com





OFFICE OF STATEWIDE HEALTH PLANNING AND DEVELOPMENT
FACILITIES DEVELOPMENT DIVISION

Seismic Parameters

Design in accordance with ASCE 7-10 Chapter 13: [X] Yes [ ] No

Design Basis of Equipment or Components (Fp/Wp) = 3.60

Sds (Design spectral response acceleration at short period, g) = 2.00

ap (In-structure equipment or component amplification factor) = 2.5

Rp (Equipment or component response modification factor) = 2.5

Omega\_0 (System overstrength factor) = 2.0

Ip (Importance factor) = 1.5

z/h (Height factor ratio) = 1.0

Equipment or Component Natural Frequencies (Hz) = See Attachment 2

Overall dimensions and weight (or range thereof) = See Attachments 1 & 2

Equipment or Components @ grade designed in accordance with ASCE 7-10 Chapter 15: [ ] Yes [X] No

Design Basis of Equipment or Components (V/W) =

Sds (Design spectral response acceleration at short period, g) =

Sd1 (Design spectral response acceleration at 1 second period, g) =

R (Response modification coefficient) =

Omega\_0 (System overstrength factor) =

Cd (Deflection amplification factor) =

Ip (Importance factor) = 1.5

Height to Center of Gravity above base =

Equipment or Component Natural Frequencies (Hz) =

Overall dimensions and weight (or range thereof) =

Tank(s) designed in accordance with ASME BPVC, 2015: [ ] Yes [X] No

List of Attachments Supporting Special Seismic Certification

[X] Test Report(s) [ ] Drawings [ ] Calculations [X] Manufacturer's Catalog

[X] Other(s) (Please Specify): Attachments 1, 2, & 3


OSHPD Approval (For Office Use Only) - Approval Expires on December 31, 2025

Signature: [Signature] Date: July 23, 2020

Print Name: Timothy J. Piland Title: SSE

Special Seismic Certification Valid Up to: Sds (g) = 2.00 z/h = 1

Condition of Approval (if applicable):



## ATTACHMENT 1: CERTIFIED COMPONENTS

## SEISMIC COMPLIANCE REPORT

### TABLE 1

DOCUMENT NO.: 19042CR1.0

<b>MANUFACTURER:</b> JOHNSON CONTROLS, INC.						
<b>PRODUCT FAMILY:</b> YCAL/QTC2 & YCUL AIR-COOLED SCROLL CHILLERS						
MODEL NUMBER	DIMENSIONS (in)			MAX. WT. (lb)	DESCRIPTION / NOTES	BASIS
	DEPTH	WIDTH	HEIGHT			
<b>YCAL/QTC2 &amp; YCUL Air-Cooled Scroll Chillers</b>						
YCUL0020EE**XE	109.8	44.7	46.1	1502		EXTRAP
QTC2015TEE**XEB	109.8	44.7	46.1	1597		EXTRAP
YCAL0019EE**XE	109.8	44.7	46.1	1597		EXTRAP
YCUL0024EE**XE	109.8	44.7	46.1	1502		EXTRAP
QTC2020TEE**XEB	109.8	44.7	46.1	1597		EXTRAP
YCAL0022EE46XE	109.8	44.7	46.1	1597	460V	UUT 1
YCAL0022EE**XE	109.8	44.7	46.1	1597		INTERP
YCUL0031EE**XE	118.6	44.7	50.0	1734		INTERP
QTC2025TEE**XEB	118.6	44.7	50.0	1829		INTERP
YCAL0028EE**XE	118.6	44.7	50.0	1829		INTERP
YCUL0035EE**XE	118.6	44.7	50.0	1982		INTERP
QTC2030TEE**XEB	118.6	44.7	50.0	2077		INTERP
YCAL0033EE**XE	118.6	44.7	50.0	2077		INTERP
YCUL0045EE**XE	144.8	90.6	47.8	2856		INTERP
QTC2035TEE**XEB	144.8	90.6	47.8	2967		INTERP
YCAL0043EE**XE	144.8	90.6	47.8	2967		INTERP
YCUL0051EE**XE	144.8	90.6	47.8	2890		INTERP
QTC2040TEE**XEB	144.8	90.6	47.8	3001		INTERP
YCAL0046EE**XE	144.8	90.6	47.8	3001		INTERP
YCUL0055EE**XE	148.8	90.6	62.6	3104		INTERP
QTC2045TEE**XEB	148.6	90.6	62.6	3233		INTERP
YCAL0052EE**XE	148.8	90.6	62.6	3233		INTERP
YCUL0065EE**XE	148.8	90.6	62.6	3116		INTERP
YCAL0056EE**XE	148.8	90.6	62.6	3245		INTERP
YCUL0072EE**XE	153.6	90.6	62.6	3973		INTERP
YCAL0066EE**XE	153.6	90.6	62.6	4142		INTERP
YCAL0066EE17XE	153.6	90.6	62.6	4142	200/208V	UUT 2
<b>MOUNTING:</b>	Isolated floor mounted on captive mount neoprene isolators.			<b>SEISMIC LEVEL:</b>	$S_{DS} = 2.00g$ for $z/h = 1$	$I_p = 1.5$
<b>NOTES:</b>	<p><b>Product Construction:</b> Painted carbon steel construction.</p> <p><b>Options/Subcomponents:</b> Available subcomponents are listed in Table 2. Voltage: 200-575V, 60Hz.</p> <p><b>Nomenclature:</b> See Attachment 3 for full nomenclature.</p> <p>-QTC2 is identical to YCAL except for branding.</p> <p>-YCUL is identical to YCAL except that they do not have an evaporator.</p> <p>-'**' indicates voltage (see Attachment 3).</p>					

## ATTACHMENT 1: CERTIFIED SUBCOMPONENTS

## SEISMIC COMPLIANCE REPORT

### TABLE 2 - SUBCOMPONENTS

DOCUMENT NO.: 19042CR1.0

<b>MANUFACTURER: JOHNSON CONTROLS, INC.</b>						
<b>PRODUCT FAMILY: YCAL/QTC2 &amp; YCUL AIR-COOLED SCROLL CHILLERS</b>						
MODEL NUMBER	DIMENSIONS (in)			MAX. WT. (lb)	DESCRIPTION / NOTES	BASIS
	DEPTH	WIDTH	HEIGHT			
<b>Copeland - Scroll Compressors</b>						
ZP103	10.4	11.2	21.0	134		EXTRAP
ZP120	10.4	11.2	21.0	135		UUT 1
ZP137	10.4	11.2	21.0	138		INTERP
ZP154	12.9	11.7	22.2	146		INTERP
ZP182	12.9	11.7	21.7	146		UUT 2
ZP235	16.8	14.8	28.5	310		UUT 2
<b>SWEP - Brazed Plate Heat Exchanger Evaporators (Stainless Steel)</b>						
P120T-82	7.8	9.6	20.7	95	Single circuit	UUT 1
Dp300x122	9.6	9.6	20.7	111	Dual circuit	INTERP
Dp300x146	11.4	9.6	20.7	129	Dual circuit	INTERP
Dp300x198	15.3	9.6	20.7	169	Dual circuit	UUT 2
<b>Johnson Controls - Condensers (Copper Tube, Aluminum Fin)</b>						
375-58294-024	5.0	78.0	32.0			UUT 1
375-58294-022	5.0	81.0	32.0			INTERP
375-58294-023	5.0	90.0	36.0			INTERP
375-59426-200	5.0	90.0	36.3			INTERP
375-58487-200	5.0	90.0	48.0			INTERP
375-58276-200	5.0	99.0	48.0			UUT 2
<b>AO Smith - Condenser Fan Motor</b>						
024-35427-xxx	5.0	5.0	9.1	19	0.5HP	UUT 1
024-34980-xxx	6.4	6.4	15.7	51	2HP	UUT 2
<b>Baldor - Condenser Fan Motor</b>						
024-27322-xxx	6.6	6.6	16.9	44	2HP	UUT 2
<b>MultiWing - Condenser Fan Impeller</b>						
026-43008-000	30.0	30.0			30in, 21deg, 3 blade, low sound	UUT 1
026-41592-000	30.0	30.0			30in, 29deg, 3 blade, low sound	INTERP
026-41593-000	30.0	30.0			30in, 29deg, 4 blade, ultra quiet	UUT 2
026-41942-000	35.0	35.0			35in, 34deg, 3 blade, low sound	INTERP
026-41594-000	35.0	35.0			35in, 26deg, 3 blade, ultra quiet	UUT 2
<b>Danfoss - Thermal Expansion Valve</b>						
025-40900-001	2.0	4.5	4.6	1		EXTRAP
025-40900-002	2.0	4.8	4.6	1		UUT 1
025-40900-003	2.0	5.1	5.7	2		INTERP
025-40900-006	2.0	5.1	5.7	2		UUT 2
025-40900-007	2.0	5.1	5.7	2		UUT 2
<b>Johnson Controls - Power Panel (Carbon Steel, NEMA 3R)</b>						
371-05161-xxx	9.0	38.1	25.4	150		UUT 1
371-05162-xxx	9.0	38.1	25.4	150		INTERP
371-05163-xxx	9.0	38.1	25.4	150		UUT 2
<b>MOUNTING:</b>	Mounted within unit.			<b>SEISMIC LEVEL:</b>	S <sub>DS</sub> = 2.00g for z/h = 1      I <sub>p</sub> = 1.5	
<b>NOTES:</b>	Construction/Options: Model number uniquely identifies manufacturer, materials, and configuration of subcomponents.					



## ATTACHMENT 2: UNIT UNDER TEST SUMMARIES

## SEISMIC COMPLIANCE REPORT

### UUT 1

DOCUMENT NO.: 19042CR1.0

<b>MANUFACTURER:</b>		JOHNSON CONTROLS, INC.				
<b>MODEL NUMBER:</b>		YCAL0022EE46XE				
<b>UNIT FUNCTION:</b>		AIR-COOLED CHILLER				
<b>SERIAL NUMBER:</b>		2EXM011678				
DIMENSIONS (in)			WEIGHT (lb)	RES. FREQ. (Hz)		
DEPTH	WIDTH	HEIGHT		F-B	S-S	V
109.8	44.7	46.1	1597	16.1	8.1	13.1
<b>CODE &amp; CRITERIA:</b>		2016 CBC		ICC-ES AC156		
<b>TEST LABORATORY:</b>		CLARK DYNAMIC TEST LABORATORY, INC.				
<b>REPORT &amp; DATE:</b>		EL:9911		November 28, 2011		
S <sub>DS</sub> (g)	z/h	A <sub>FLX-H</sub> (g)	A <sub>RIG-H</sub> (g)	A <sub>FLX-V</sub> (g)	A <sub>RIG-V</sub> (g)	
2.50	1	4.00	3.00	1.68	0.68	
<b>IMPORTANCE FACTOR, I<sub>p</sub> = 1.5</b>						
Unit was full of operating content during the shake table test. Unit maintained structural integrity and remained functional per manufacturer requirement after shake table test.						
<b>MOUNTING:</b>		Floor mounted on (4) VMC RSM 3-700 neoprene isolators. Unit bolted to each isolator with (1) 1/2" Grade 8 bolt (4 total). Each isolator bolted to fixture with (2) 5/8" Grade 5 bolts (8 total).				
<b>CONSTRUCTION:</b>		Painted carbon steel construction. Voltage: 460V.				
<b>SUBCOMPONENTS:</b>		Copeland - scroll compressor (ZP103), SWEP - brazed plate heat exchanger (P120T-82), Johnson Controls - condenser (375-58294-024), AO Smith - condenser fan motor (024-35427-xxx), MultiWing - condenser fan impeller (026-43008-000), Danfoss - thermal expansion valve (025-40900-002), Johnson Controls - power panel (371-05161-xxx).				



### UUT 2

DATE: 07/23/2020

<b>MANUFACTURER:</b>		JOHNSON CONTROLS, INC.				
<b>MODEL NUMBER:</b>		YCAL0066EE17XE				
<b>UNIT FUNCTION:</b>		AIR-COOLED CHILLER				
<b>SERIAL NUMBER:</b>		2KXM3489				
DIMENSIONS (in)			WEIGHT (lb)	RES. FREQ. (Hz)		
DEPTH	WIDTH	HEIGHT		F-B	S-S	V
153.6	90.6	62.6	4142	4.5	6.1	6.1
<b>CODE &amp; CRITERIA:</b>		2016 CBC		ICC-ES AC156		
<b>TEST LABORATORY:</b>		CLARK DYNAMIC TEST LABORATORY, INC.				
<b>REPORT &amp; DATE:</b>		EL:9911		November 29, 2011		
S <sub>DS</sub> (g)	z/h	A <sub>FLX-H</sub> (g)	A <sub>RIG-H</sub> (g)	A <sub>FLX-V</sub> (g)	A <sub>RIG-V</sub> (g)	
2.00	1	3.20	2.40	1.34	0.54	
<b>IMPORTANCE FACTOR, I<sub>p</sub> = 1.5</b>						
Unit was full of operating content during the shake table test. Unit maintained structural integrity and remained functional per manufacturer requirement after shake table test.						
<b>MOUNTING:</b>		Floor mounted on (2) VMC RSM 3-1000 and (2) VMC RSM 3-1300 neoprene isolators. Unit bolted to each isolator with (1) 1/2" Grade 8 bolt (4 total). Each isolator bolted to fixture with (2) 5/8" Grade 5 bolts (8 total).				
<b>CONSTRUCTION:</b>		Painted carbon steel construction. Voltage: 200/208V.				
<b>SUBCOMPONENTS:</b>		Copeland - scroll compressors (ZP182, ZP235), SWEP - brazed plate heat exchanger (Dp300x198), Johnson Controls - condenser (375-58276-200), AO Smith - condenser fan motor (024-34980-xxx), Baldor - condenser fan motor (024-27322-xxx), MultiWing - condenser fan impellers (026-41593-000, 026-41594-000), Danfoss - thermal expansion valves (025-40900-006, 025-40900-007), Johnson Controls - power panel (371-05163-xxx).				





