

Title: President

## DEPARTMENT OF HEALTH CARE ACCESS AND INFORMATION **FACILITIES DEVELOPMENT DIVISION**

## OFFICE USE ONLY APPLICATION FOR HCAI SPECIAL SEISMIC CERTIFICATION PREAPPROVAL (OSP) APPLICATION #: OSP-0257 **HCAI Special Seismic Certification Preapproval (OSP)** Type: New Renewal **Manufacturer Information** Manufacturer: Legrand Manufacturer's Technical Representative: Sarah Turner Mailing Address: 2234 Rutherford Road, Carlsbad, CA 92008 Telephone: (760) 804-2814 Email: sarah.turner@legrand.com **Product Information** Product Name: Electrical Control Panels on Life Safety/Critical Branch Product Type: Lighting Control Panels Product Model Number: WattStopper LI & LMCP Lighting Control Panels General Description: Wall-mounted relay-based automatic lighting control panels containing circuit boards, relays, communication cards, contactors, and power supplies. Mounting Description: Rigid, Wall Mounted None Tested Seismic Enhancements: **Applicant Information** Applicant Company Name: Manwill Engineering LLC Contact Person: Derek Manwill Mailing Address: PO Box 1194, Bend, OR 97709 Telephone: (541) 241-2102 Email: derek@manwillse.com





"A healthíer Calífornía where all receive equitable, affordable, and quality health care"

STATE OF CALIFORNIA – HEALTH AND HUMAN SERVICES AGENCY



# DEPARTMENT OF HEALTH CARE ACCESS AND INFORMATION FACILITIES DEVELOPMENT DIVISION

California Licensed Structural Engineer Responsible	for the Engineering and Test Report(s)
Company Name: MANWILL ENGINEERING LLC	
Name: Derek Manwill	California License Number: S6266
Mailing Address: PO Box 1194, Bend, OR 97709	
Telephone: (541) 241-2102 Email: der	ek@manwillse.com
Certification Method	
GR-63-Core X ICC-ES AC156	IEEE 344
Other (Please Specify):	
EOR CO	DDE CO
Testing Laboratory	····· Mp.
Company Name: NATIONAL TECHNICAL SYSTEMS (NTS)	
Contact Person: Anuj Kumar	2
Mailing Address: 38995 Cherry Street, Newark CA 94560	-0257 m
Telephone: (510) 578-3500 Email: An	uj.Kumar@nts.com
DATE: 08	/10/2023





STATE OF CALIFORNIA - HEALTH AND HUMAN SERVICES AGENCY



# DEPARTMENT OF HEALTH CARE ACCESS AND INFORMATION FACILITIES DEVELOPMENT DIVISION

Seismic Parameters						
Design Basis of Equipment or Components	$(F_p/W_p) = 1.88$					
Sps (Design spectral response accele	eration at short period, g) = 2.50					
a <sub>p</sub> (Amplification factor) =	2.5					
R <sub>P</sub> (Response modification factor) =	6.0					
$\Omega_0$ (System overstrength factor) =	2.0					
Ip (Importance factor) =	1.5					
z/h (Height ratio factor) =	1					
Natural frequencies (Hz) =	See Attachment					
Overall dimensions and weight =	See Attachment ODE					

HCAI Approval (For Office Use Only) - Approval Expires on 08/10/2029							
Date:	8/10/2023 OSP-0257	12					
Name:	Mohammad Karim	Title:	Supervisor, Health Facilities				
Special	Seismic Certification Valid Up to: SDS (g) = 2.50	z/h =	1				
Conditio	n of Approval (if applicable): DATF 08/10/2023						



"A healthier California where all receive equitable, affordable, and quality health care"

STATE OF CALIFORNIA – HEALTH AND HUMAN SERVICES AGENCY





ATTACHMENT 1: CERTIFIED COMPONENTS

#### SPECIAL SEISMIC CERTIFICATION

## LEGRAND WattStopper LI & LMCP Lighting Control Panels

TABLE 1							
Model Number		Dimensions (i	n)	Max. Wt.	Description / Notes	Basis	
Model Number	Depth	Width	Height	(lb)	Description / Notes	Dasis	
WattStopper LI & LMCP Lighting Co.	ntrol Panels						
LMCP-8-F	5.0	17.0	16.0	26	8-relay, switching, flush mount	UUT 4	
LI-8	5.0	17.0	16.0	27	8-relay	UUT 1, 7	
LI-8-F	5.0	17.0	16.0	27	8-relay, flush mount	INTERP	
LMCP-8	5.0	17.0	16.0	27	8-relay, switching	8 TUU	
LMCP-8-10V	5.0	17.0	16.0	27	8-relay, dimming	INTERP	
LMCP-8-10V-F	5.0	17.0	16.0	27	8-relay, dimming, flush mount	INTERP	
LI-24	5.0	24.0	32.0	67	24-relay	UUT 2,10	
LI-24-F	5.0	24.0	32.0	67	24-relay, flush mount	INTERP	
LMCP-24	5.0	24.0	32.0	60	24-relay, switching	UUT 5, 11	
LMCP-24-F	5.0	24.0	32.0	60	24-relay, switching, flush mount	INTERP	
LMCP-24-10V	5.0	24.0	32.0	60	24-relay, dimming	INTERP	
LMCP-24-10V-F	5.0	24.0	32.0	60	24-relay, dimming, flush mount	INTERP	
LI-48	5.0	24.0	P45.025	7 85	48-relay	UUT 3, 9	
LI-48-F	5.0	24.0	45.0	85	48-relay, flush mount	INTERP	
LMCP-48-F	5.0	24.0	45.0	89	48-relay, switching, flush mount	UUT 6	
LMCP-48-10V	5.0	3 Y 24.00h	am45.0ad	Karam	48- <mark>relay,</mark> dimming	INTERP	
LMCP-48-10V-F	5.0	24.0	45.0	97	48-relay, dimming, flush mount	INTERP	
LMCP-48	5.0	24.0	45.0	97	48-relay, switching	UUT 12	
Mounting: Rigid wall mounted.	S	DATE:	U8/1U/2	Seismic Levels:	$S_{DS} = 2.50g$ for z/h = 1 $S_{DS} = 2.50g$ for z/h = 0	I <sub>P</sub> = 1.5	

Product Construction: NEMA 1 enclosures as listed in Table 2.

**Options/Subcomponents:** Enclosure may contain any combination of the subcomponents listed in Table 2 so long as the maximum weights of Table 1 are not exceeded.

Page 4 of 19





ATTACHMENT 1: CERTIFIED SUBCOMPONENTS

## SPECIAL SEISMIC CERTIFICATION

## LEGRAND WattStopper LI & LMCP Lighting Control Panels

		TABLE 2.	SUBCOM	IPONENTS		
Model Number	D	imensions (i	in)	Max. Wt.	Description / Notes	Basis
MODEL MULLIDEL	Depth	Width	Height	(lb)	Description / Notes	Dasis
Subcomponent: Enclosures - Manuf	acturer: Legr	and				
LENC8S	4.7	16.6	15.8	18	8 relay capacity, surface mount	UUT 1,4,7,8
LENC8F	4.7	18.5	17.1	20	8 relay capacity, flush mount	INTERP
LENC8-24S	4.7	24.0	32.0	45	8 relay w/ 24 size tub, surface m.	INTERP
LENC24S	4.7	24.0	32.0	45	24 relay capacity, surface mount	2,5,10,11
LENC24F	4.7	25.9	33.4	50	24 relay capacity, flush mount	INTERP
LENC24-48S	4.7	24.0	44.5	62	24 relay capacity with 48 size tub	INTERP
LENC48S	4.7	24.0	44.5	62	48 relay capacity, surface mount	UUT 3,9,12
LENC48F	4.7	25.9	45.9	66	48 relay capacity, flush mount	UUT 6
Subcomponent: Power Supply Modu	ule - Manufac	<mark>ture</mark> r: Ohga I	nc.			
437D535G06	1:5		YMYAV	<1		UUT 1-6
579B373G02		NYMMY <del>1</del> _M_1		<1	7	UUT 1-6
Subcomponent: Power Supply Modu	ule - Manufac	turer: Shang	hai Legrand	Electric Co.	15	
437D535G06	~ (A)	- 08	SP-025	) / <1		UUT 7-12
579B373G02		XXXXXXXX		<1	- 1111	UUT 7-12
Subcomponent: Power Supply Asse	<mark>mbly - Manu</mark> f	acturer: Ohg	a Inc.	17 :		
579B410G01			ammad			UUT 1-6
Subcomponent: Power Supply Asse	mbly Card - N	/lanufacturer	: Shanghai l	Legrand Electi	ric Co <mark>.</mark>	
579B410G01		A TE	0014011	<1		UUT 7-12
Subcomponent: Power Supply (DAL	IPS) Assemb	ly - Manufac	turer: Ohga	1nc.23		
579B442G01	Z W			<1	7-0/	UUT 2 & 3
Subcomponent: Power Supply (DAL	I PS) Assemb	ly - Manufac	turer: Shan	ghai Legrand E	Electric Co.	
579B442G01				<1	· - ·	UUT 7-12
Subcomponent: Power Supply (PS)	Assembly - M	anufacturer:	Ohga Inc.		<b>~</b> //	
579B410G01	-	VI		<10	<u> </u>	UUT 3 & 6
Subcomponent: Power Supply (PS)	Assembly Ca	rd - Manufac	turer: Shan	ghai Legrand E	Electric Co.	
579B410G01	-	30	ILLUIN	<1	-	UUT 7-12
Subcomponent: Transformer - Manu	ıfacturer: Bas	ler				
BE31820001	-	-	-	2.2	115V/277V, 50Hz/60Hz	1,4,7-12
BE31820003	-	-	-	2.2	115V/277V, 50Hz/60Hz	2,3,5-12
Subcomponent: Transformer - Manu	ıfacturer: MC	l Transforme	r			
2-51-0305	-	-	-	<1	28V, 50Hz/60Hz	UUT 1-12
Subcomponent: User Inferface Cons	sole (LM-U) - I	Manufacture	r: Ohga Inc.			
77-0299-132	-	-	-	<1	-	UUT 1
Subcomponent: User Inferface Cons	sole (LM-U) - I	Manufacture	r: Shanghai	Legrand Elect	ric Co.	
77-0299-132	-	-	-	<1	-	UUT 7
Subcomponent: User console interfa	ace board (LN	/I-I) - Manufad	cturer: Ohga	a Inc.		
77-0303-102	-	-	-	<1	-	UUT 1
Subcomponent: User console interfa	ace board (LN	/I-I) - Manufad	cturer: Shar	ighai Legrand	Electric Co.	
77-0303-102	-	-	-	<1	-	UUT 7
Subcomponent: Relay Driver Board	(RD) - Manufa	acturer: Ohga	a Inc.			
483C417G01	-	-	-	<1	-	UUT 1-3
483C417G01	-	-	-	<1	_	UUT 7,9,10

Notes: Table continues on the next page. Additional notes, information, and seismic parameters are shown at the end of the table.





ATTACHMENT 1: CERTIFIED SUBCOMPONENTS

## SPECIAL SEISMIC CERTIFICATION

## LEGRAND WattStopper LI & LMCP Lighting Control Panels

	TABLE	2. SUBCOM	PONEN	ITS (CONTI	NUED)	
Model Number	D Depth	imensions (in) Width	Height	Max. Wt. (lb)	Description / Notes	Basis
Subcomponent: Relays - Manufa	cturer: Gruner					
HDR	=	-	-	<1	-	UUT 1-3
HDR-9	=	-	-	<1	-	UUT 4-6
Subcomponent: Relays - Manufa	cturer: Rocom					
HDR-11	-	-	-	<1	-	UUT 7-12
Subcomponent: Main Interface B	Board - Manufacti	urer: Ohga Inc.		-1		UUT 1
437D884G01  Subcomponent: Main Interface B	- Roard - Manufacti	urer: Shanghai I	ogrand !	<1	-	0011
437D884G01	oaru - Mariuracti	urer. Snangnari	-egranu i	Liectric Co.		UUT 7
Subcomponent: Group Card - Ma	nufacturer: Ohe	alne	\\\ <del>\</del> \\		_	0017
437D884G01	andracturer. Ong	a IIIC.				UUT 1
Subcomponent: Group Card - Ma	nufacturor, Sha	nghai Lagrand F	loctric C	<1		0011
437D884G01	anulactules. Sha	ngnai Legianu L	lectric C	<1	7	UUT 7
Subcomponent: Lighting Control	I - Manufacturer:	Shanghai Legra	and Flad			0017
ELCU-100	i - Watturacturer.	Silangilai Legia	and Fied	<1	l im l	2,3,9,10
Subcomponent: Contactor - Man	ufacturer: ARR	XXXXXX <del>X</del> XXXXXXXXXXXXXXXXXXXXXXXXXXXXX		<u> </u>		2,3,3,10
A16-04-00	diacturer. ABB	3Y: Mohar	nmad	Karim		2,3,9,10
Subcomponent: Interface/Comm	unication Card -			· · · · · · · · · · · · · · · · · · ·		2,0,0,10
579B449G01	dilloation Gard	-	- -	<1		UUT 2
Subcomponent: Interface/Comm	unication Card -	Manufacturer: S	Shanghai		ric Co.	33
579B449G01	T I		KIO-14000	<1000	7.0	UUT 10
Subcomponent: Communication	Card - Manufact	urer: Ohga Inc.	+ 333		0	
579B404G01				<1		UUT 3
579B404G02	100			<1	<u> </u>	UUT 3
Subcomponent: Lonworks LW/L	C Communicatio	n Card - Manufa	cturer: C	hga Inc.		
579B404G01	_	A DITT	- TA	15 31	-	UUT 2 & 3
579B404G02	_	POI	-DIL	<1	-	UUT 2 & 3
579B404G03	-	-	-	<1	-	UUT 2 & 3
Subcomponent: Lonworks LW/L	C Communicatio	n Card - Manufa	cturer: S	hanghai Legra	and Electric Co.	
579B404G01	=	-	-	<1	-	UUT 9 & 10
579B404G02	-	-	-	<1	-	UUT 9 & 10
579B404G03	-	-	-	<1	-	UUT 9 & 10
Subcomponent: Group Card - Ma	anufacturer: Ohg	a Inc.				
437D884G01	-	-	-	<1	-	UUT 2
Subcomponent: Group Card - Ma	anufacturer: Sha	nghai Legrand E	Electric C	ю.		
437D884G01	-	<u>-</u>	-	<1	-	<b>UUT 10</b>
Subcomponent: Programming M	odule - Manufac	turer: WattStopp	oer			
HCLK8SS	<u>-</u>			<1	<del>-</del>	UUT 2 & 10

Notes: Table continues on the next page. Additional notes, information, and seismic parameters are shown at the end of the table.





#### ATTACHMENT 1: CERTIFIED SUBCOMPONENTS

## SPECIAL SEISMIC CERTIFICATION

## LEGRAND WattStopper LI & LMCP Lighting Control Panels

TABLE 2. SUBCOMPONENTS (CONTINUED)							
Model Number	Depth	imensions (i Width	n) Height	Max. Wt. (lb)	Description / Notes	Basis	
Subcomponent: Circuit Board - Man	ufacturer: Sh	anghai Legra	and Electric	Co.			
16615	-	-	-	<1	LMPI	4-6,8,11-12	
29851-02	-	-	-	<1	LMRD-8-10V	INTERP	
16916	-	-	-	<1	LMRD-8	UUT 4 & 8	
29851-01	-	-	-	<1	LMRD-12-10V	INTERP	
16694	-	-	-	<1	LMRD-12	5,6,11,12	
Mounting: Mounted within unit.		OR	CODE	Seismic Levels:	$S_{DS} = 2.50g$ for z/h = 1 $S_{DS} = 2.50g$ for z/h = 0	I <sub>P</sub> = 1.5	

Construction/Options: Model number uniquely identifies manufacturer, materials, and configuration of subcomponents.



Page 7 of 19





#### SPECIAL SEISMIC CERTIFICATION

TEST UNITS								
UUT	Model Number	Test Report	Report Date	Test Laboratory	Test Date			
UUT 1	LI-8	R86371	2-8-12	NTS-Newark	1-23-12			
UUT 2	LI-24	R86371	2-8-12	NTS-Newark	1-23-12			
UUT 3	LI-48	R86371	2-8-12	NTS-Newark	1-23-12			
UUT 4	LMCP-8-F	R94679	2-27-14	NTS-Newark	2-13-14			
UUT 5	LMCP-24	R94679	2-27-14	NTS-Newark	2-13-14			
UUT 6	LMCP-48-F	R94679	2-27-14	NTS-Newark	2-13-14			
UUT 7	LI-8	PR052797.01 Rev 1	1-10-17	NTS-Newark	11-16-16			
UUT 8	LMCP-8-F	PR052797.01 Rev 1	1-10-17	NTS-Newark	11-16-16			
UUT 9	LI-48	PR052797.01 Rev 1	1-10-17	NTS-Newark	11-16-16			
<b>UUT 10</b>	LI-24	PR052797.01 Rev 1	1-10-17	NTS-Newark	11-17-16			
UUT 11	LMPC-24	PR052797.01 Rev 1	1-10-17	NTS-Newark	11-17-16			
UUT 12	LMPC-48	PR052797.01 Rev 1	1-10-17	NTS-Newark	11-17-16			

**UUT 1** 

Manufacturer: LEGRAND Model number: LI-8

Unit function: LIGHTING CONTROL PANELS

Serial number: N/A

Dimensions (in)			Weight	Res	OFreq. (	(Hz)ad
Depth	Width	Height	(lb)	F-B	S-S	V
5.0	17.0	16.0	27	N/A	N/A	N/A

Code & criteria: 2022 CBC, ICC-ES AC156

Test laboratory: NTS-Newark

Report: R86371 (dated 2-8-12), tested on 1-23-12

S <sub>DS</sub> (g)	z/h	A <sub>FLX-H</sub> (g)	A <sub>RIG-H</sub> (g)	A <sub>FLX-V</sub> (g)	A <sub>RIG-V</sub> (g)
2.50	1	4.00	3.00	1.68	0.68
2.50	0	4.00	3.00	//	0.00

Importance Factor,  $I_P = 1.5$ : Unit was full of operating content during the shake table test. Unit maintained structural integrity and remained functional per manufacturer requirement after shake table test.

Mounting: Unit was rigid wall mounted to fixture using (4) 3/8" lag bolts. The fixture was rigid mounted to table.

Construction: 16 ga carbon steel NEMA-1 enclosures with 14 ga carbon steel covers.

Subcomponents: Legrand - Enclosures (LENC8S), Ohga Inc. - Power Supply Module (437D535G06), Ohga Inc. - Power Supply Module

(579B373G02), Ohga Inc. - Power Supply Assembly (579B410G01), Basler - Transformer (BE31820001), MCI Transformer - Transformer (2-51-0305), Ohga Inc. - User Inferface Console (LM-U) (77-0299-132), Ohga Inc. - User console interface board (LM-I) (77-0303-102), Ohga Inc. - Relay Driver Board (RD) (483C417G01), Gruner - Relays (HDR), Ohga Inc. - Main

Interface Board (437D884G01), Ohga Inc. - Group Card (437D884G01)

Testing notes: UUT 1 is called NTS-ENV-1 in the test report. Testing was performed on a uniaxial table in all 4 directions (X, Y, Z, and 45-

deg to X &Y).







### SPECIAL SEISMIC CERTIFICATION

## **UUT 2**

Manufacturer: LEGRAND Model number: LI-24

Unit function: LIGHTING CONTROL PANELS

Serial number: N/A

Dimensions (in)			Weight	Res	s. Freq.	(Hz)
Depth	Width	Height	(lb)	F-B	S-S	V
5.0	24.0	32.0	67	N/A	N/A	N/A

Code & criteria: 2022 CBC, ICC-ES AC156

Test laboratory: NTS-Newark

Report: R86371 (dated 2-8-12), tested on 1-23-12

$S_{DS}(g)$	z/h	A <sub>FLX-H</sub> (g)	A <sub>RIG-H</sub> (g)	$A_{FLX-V}(g)$	$A_{RIG-V}(g)$
2.50	1	4.00	3.00	1.68	(0.69)
2.50	0	4.00	3.00	1.00	$\bigcirc 0.68$

Importance Factor,  $I_P = 1.5$ : Unit was full of operating content during the shake table test. Unit maintained structural integrity and remained functional per manufacturer requirement after shake table test.

Mounting: Unit was rigid wall mounted to fixture using (4) 3/8" lag bolts. The fixture was rigid mounted to table.

Construction: 16 ga carbon steel NEMA-1 enclosures with 14 ga carbon steel covers.

Subcomponents: Legrand - Enclosures (LENC24S), Ohga Inc. - Power Supply Module (437D535G06), Ohga Inc. - Power Supply Module

(579B373G02), Ohga Inc. - Power Supply Assembly (579B410G01), Ohga Inc. - Power Supply (DALI PS) Assembly (579B442G01), Basler - Transformer (BE31820003), MCI Transformer - Transformer (2-51-0305), Ohga Inc. - Relay Driver Board (RD) (483C417G01), Gruner - Relays (HDR), Shanghai Legrand Electric Co. - Lighting Control (ELCU-100), ABB - Contactor (A16-04-00), Ohga Inc. - Interface/Communication Card (579B449G01), Ohga Inc. - Lonworks LW/LC Communication Card (579B404G01), Ohga Inc. - Lonworks LW/LC Communication Card (579B404G02), Ohga Inc. - Lonworks LW/LC Communication Card (579B404G03), Ohga Inc. - Group Card (437D884G01), WattStopper -

Programming Module (HCLK8SS)

Testing notes: UUT 2 is called NTS-ENV-2 in the test report. Testing was performed on a uniaxial table in all 4 directions (X, Y, Z, and 45-

OPVIA BUILDING CODY

deg to X &Y).







### SPECIAL SEISMIC CERTIFICATION

## **UUT 3**

Manufacturer: LEGRAND Model number: LI-48

Unit function: LIGHTING CONTROL PANELS

Serial number: N/A

D	imensions (i	n)	Weight	Res	s. Freq.	(Hz)
Depth	Width	Height	(lb)	F-B	S-S	V
5.0	24.0	45.0	85	N/A	N/A	N/A

Code & criteria: 2022 CBC, ICC-ES AC156

Test laboratory: NTS-Newark

Report: R86371 (dated 2-8-12), tested on 1-23-12

$S_{DS}(g)$	z/h	$A_{FLX-H}(g)$	$A_{RIG-H}(g)$	$A_{FLX-V}(g)$	A <sub>RIG-V</sub> (g)
2.50	1	4.00	3.00	1.68	(0.69)
2.50	0	4.00	3.00	1.00	0.68

Importance Factor,  $I_P = 1.5$ : Unit was full of operating content during the shake table test. Unit maintained structural integrity and remained functional per manufacturer requirement after shake table test.

Mounting: Unit was rigid wall mounted to fixture using (4) 3/8" lag bolts. The fixture was rigid mounted to table.

Construction: 16 ga carbon steel NEMA-1 enclosures with 14 ga carbon steel covers.

Subcomponents: Legrand - Enclosures (LENC48S), Ohga Inc. - Power Supply Module (437D535G06), Ohga Inc. - Power Supply Module

(579B373G02), Ohga Inc. - Power Supply Assembly (579B410G01), Ohga Inc. - Power Supply (DALI PS) Assembly (579B442G01), Ohga Inc. - Power Supply (DALI PS) Assembly (579B442G01), Basler - Transformer (BE31820003) MCI Transformer - Transformer (2-51-0305), Ohga Inc. - Relay Driver Board (RD) (483C417G01), Gruner - Relays (HDR), Shanghai Legrand Electric Co. - Lighting Control (ELCU-100), ABB - Contactor (A16-04-00), Ohga Inc. - Communication Card (579B404G01), Ohga Inc. - Communication Card (579B404G01), Ohga Inc. - Communication Card

(579B404G01), Ohga Inc. - Lonworks LW/LC Communication Card (579B404G02), Ohga Inc. - Lonworks LW/LC

Communication Card (579B404G03)

Testing notes: UUT 3 is called NTS-ENV-3 in the test report. Testing was performed on a uniaxial table in all 4 directions (X, Y, Z, and 45-

PIVIA BUILDING CODY

deg to X &Y).



Page 10 of 19





### SPECIAL SEISMIC CERTIFICATION

## **UUT 4**

Manufacturer: LEGRAND Model number: LMCP-8-F

Unit function: LIGHTING CONTROL PANELS

Serial number: N/A

Dimensions (in)			Weight	Res	. Freq.	(Hz)
Depth	Width	Height	(lb)	F-B	S-S	V
5.0	17.0	16.0	26	N/A	N/A	N/A

Code & criteria: 2022 CBC, ICC-ES AC156

Test laboratory: NTS-Newark

Report: R94679 (dated 2-27-14), tested on 2-13-14

$S_{DS}(g)$	z/h	$A_{FLX-H}(g)$	A <sub>RIG-H</sub> (g)	$A_{FLX-V}(g)$	$A_{RIG-V}(g)$
2.50	1	4.00	3.00	1.68	(069)
2.50	0	4.00	3.00	1.00	$\bigcirc 0.68$

Importance Factor,  $I_P = 1.5$ : Unit was full of operating content during the shake table test. Unit maintained structural integrity and remained functional per manufacturer requirement after shake table test.

Mounting: Unit was rigid wall mounted to fixture using (4) 3/8" lag bolts. The fixture was rigid mounted to table.

Construction: 16 ga carbon steel NEMA-1 enclosures with 14 ga carbon steel covers.

Subcomponents: Legrand - Enclosures (LENC8S), Ohga Inc. - Power Supply Module (437D535G06), Ohga Inc. - Power Supply Module

(579B373G02), Ohga Inc. - Power Supply Assembly (579B410G01), Basler - Transformer (BE31820001), MCI Transformer - Transformer (2-51-0305), Gruner - Relays (HDR-9), Shanghai Legrand Electric Co. - Circuit Board (16615), Shanghai

Legrand Electric Co. - Circuit Board (16916) ammad Karim

Testing notes: UUT 4 is called LMCP-8-F in the test report. Testing was performed on a uniaxial table in all 4 directions (X, Y, Z, and 45-

deg to X &Y).



08/10/2023

OSP-0257

Page 11 of 19





#### SPECIAL SEISMIC CERTIFICATION

## **UUT 5**

Manufacturer: LEGRAND Model number: LMCP-24

Unit function: LIGHTING CONTROL PANELS

Serial number: N/A

Dimensions (in)			Weight	Res	s. Freq.	(Hz)
Depth	Width	Height	(lb)	F-B	S-S	V
5.0	24.0	32.0	60	N/A	N/A	N/A

Code & criteria: 2022 CBC, ICC-ES AC156

Test laboratory: NTS-Newark

Report: R94679 (dated 2-27-14), tested on 2-13-14

$S_{DS}(g)$	z/h	$A_{FLX-H}(g)$	A <sub>RIG-H</sub> (g)	$A_{FLX-V}(g)$	A <sub>RIG-V</sub> (g)
2.50	1	4.00	3.00	1.68	(0.69)
2.50	0	4.00	3.00	1.00	$\bigcirc 0.68$

Importance Factor, I<sub>P</sub> = 1.5: Unit was full of operating content during the shake table test. Unit maintained structural integrity and remained functional per manufacturer requirement after shake table test.

Mounting: Unit was rigid wall mounted to fixture using (4) 3/8" lag bolts. The fixture was rigid mounted to table.

Construction: 16 ga carbon steel NEMA-1 enclosures with 14 ga carbon steel covers.

Subcomponents: Legrand - Enclosures (LENC24S), Ohga Inc. - Power Supply Module (437D535G06), Ohga Inc. - Power Supply Module

(579B373G02), Ohga Inc. - Power Supply Assembly (579B410G01), Basler - Transformer (BE31820003), MCI Transformer -

Transformer (2-51-0305), Gruner - Relays (HDR-9), Shanghai Legrand Electric Co. - Circuit Board (16615), Shanghai

Legrand Electric Co. - Circuit Board (16694) ammad Karim

Testing notes: UUT 5 is called LMCP-24-S in the test report. Testing was performed on a uniaxial table in all 4 directions (X, Y, Z, and 45-

deg to X &Y).







### SPECIAL SEISMIC CERTIFICATION

## **UUT 6**

Manufacturer: LEGRAND Model number: LMCP-48-F

Unit function: LIGHTING CONTROL PANELS

Serial number: N/A

D	imensions (i	n)	Weight	Res	s. Freq.	(Hz)
Depth	Width	Height	(lb)	F-B	S-S	V
5.0	24.0	45.0	89	N/A	N/A	N/A

Code & criteria: 2022 CBC, ICC-ES AC156

Test laboratory: NTS-Newark

Report: R94679 (dated 2-27-14), tested on 2-13-14

$S_{DS}(g)$	z/h	$A_{FLX-H}(g)$	A <sub>RIG-H</sub> (g)	$A_{FLX-V}(g)$	$A_{RIG-V}(g)$
2.50	1	4.00	3.00	1.68	(069)
2.50	0	4.00	3.00	1.00	$\bigcirc 0.68$

Importance Factor,  $I_P = 1.5$ : Unit was full of operating content during the shake table test. Unit maintained structural integrity and remained functional per manufacturer requirement after shake table test.

Mounting: Unit was rigid wall mounted to fixture using (4) 3/8" lag bolts. The fixture was rigid mounted to table.

Construction: 16 ga carbon steel NEMA-1 enclosures with 14 ga carbon steel covers.

Subcomponents: Legrand - Enclosures (LENC24S), Ohga Inc. - Power Supply Module (437D535G06), Ohga Inc. - Power Supply Module

(579B373G02), Ohga Inc. - Power Supply Assembly (579B410G01), Ohga Inc. - Power Supply (DALI PS) Assembly (579B442G01), Basler - Transformer (BE31820003), MCI Transformer - Transformer (2-51-0305), Gruner - Relays (HDR-9),

Shanghai Legrand Electric Co. - Circuit Board (16615), Shanghai Legrand Electric Co. - Circuit Board (16694)

Testing notes: UUT 6 is called LMCP-48-F in the test report. Testing was performed on a uniaxial table in all 4 directions (X, Y, Z, and 45-

deg to X &Y).



Page 13 of 19

OSP-0257

08/10/2023





#### SPECIAL SEISMIC CERTIFICATION

## **UUT 7**

Manufacturer: LEGRAND Model number: LI-8

Unit function: LIGHTING CONTROL PANELS

Serial number: N/A

Dimensions (in)			Weight	Res	s. Freq. (	(Hz)
Depth	Width	Height	(lb)	F-B	S-S	V
5.0	17.0	16.0	25	N/A	N/A	N/A

Code & criteria: 2022 CBC, ICC-ES AC156

Test laboratory: NTS-Newark

Report: PR052797.01 Rev 1 (dated 1-10-17), tested on 11-16-16

$S_{DS}(g)$	z/h	$A_{FLX-H}(g)$	A <sub>RIG-H</sub> (g)	$A_{FLX-V}(g)$	A <sub>RIG-V</sub> (g)
2.50	1	4.00	3.00	1.68	(0.69)
2.50	0	4.00	3.00	1.00	$\bigcirc 0.68$

Importance Factor,  $I_P$  = 1.5: Unit was full of operating content during the shake table test. Unit maintained structural integrity and remained functional per manufacturer requirement after shake table test.

Mounting: Unit was rigid wall mounted to fixture using (4) 3/8" lag bolts. The fixture was rigid mounted to table.

Construction: 16 ga carbon steel NEMA-1 enclosures with 14 ga carbon steel covers.

Subcomponents: Legrand - Enclosures (LENC8S), Shanghai Legrand Electric Co. - Power Supply Module (437D535G06), Shanghai Legrand

Electric Co. - Power Supply Module (579B373G02), Shanghai Legrand Electric Co. - Power Supply Assembly Card (579B410G01), Shanghai Legrand Electric Co. - Power Supply (DALI PS) Assembly (579B410G01), Shanghai Legrand Electric Co. - Power Supply (PS) Assembly Card (579B410G01), Basler - Transformer (BE31820001), Basler - Transformer (BE31820003), MCI Transformer - Transformer (2-51-0305), Shanghai Legrand Electric Co. - User Inferface Console (LM-U) (77-0299-132), Shanghai Legrand Electric Co. - User console interface board (LM-I) (77-0303-102), Ohga Inc. - Relay Driver Board (RD) (483C417G01), Rocom - Relays (HDR-11), Shanghai Legrand Electric Co. - Main Interface Board

(437D884G01), Shanghai Legrand Electric Co. - Group Card (437D884G01)

Testing notes: UUT 7 is called EUT-1 in the test report. Testing was performed on a uniaxial table in all 4 directions (X, Y, Z, and 45-deg to

X &Y).



08/10/2023

Page 14 of 19

OSP-0257





#### SPECIAL SEISMIC CERTIFICATION

## **UUT 8**

Manufacturer: LEGRAND Model number: LMCP-8-F

Unit function: LIGHTING CONTROL PANELS

Serial number: N/A

D	imensions (i	n)	Weight	Res	s. Freq.	(Hz)
Depth	Width	Height	(lb)	F-B	S-S	V
5.0	17.0	16.0	27	N/A	N/A	N/A

Code & criteria: 2022 CBC, ICC-ES AC156

Test laboratory: NTS-Newark

Report: PR052797.01 Rev 1 (dated 1-10-17), tested on 11-16-16

$S_{DS}(g)$	z/h	A <sub>FLX-H</sub> (g)	A <sub>RIG-H</sub> (g)	$A_{FLX-V}(g)$	A <sub>RIG-V</sub> (g)
2.50	1	4.00	3.00	1.68	(0.69)
2.50	0	4.00	3.00	1.00	$\bigcirc 0.68$

Importance Factor,  $I_P$  = 1.5: Unit was full of operating content during the shake table test. Unit maintained structural integrity and remained functional per manufacturer requirement after shake table test.

Mounting: Unit was rigid wall mounted to fixture using (4) 3/8" lag bolts. The fixture was rigid mounted to table.

Construction: 16 ga carbon steel NEMA-1 enclosures with 14 ga carbon steel covers.

Subcomponents: Legrand - Enclosures (LENC8S), Shanghai Legrand Electric Co. - Power Supply Module (437D535G06), Shanghai Legrand

Electric Co. - Power Supply Module (579B373G02), Shanghai Legrand Electric Co. - Power Supply Assembly Card (579B410G01), Shanghai Legrand Electric Co. - Power Supply (DALI PS) Assembly (579B410G01), Shanghai Legrand Electric Co. - Power Supply (PS) Assembly Card (579B410G01), Basler - Transformer (BE31820001), Basler - Transformer (BE31820003), MCI Transformer - Transformer (2-51-0305), Rocom - Relays (HDR-11), Shanghai Legrand Electric Co. -

Circuit Board (16615), Shanghai Legrand Electric Co. - Circuit Board (16916)

Testing notes: UUT 8 is called EUT-2 in the test report. Testing was performed on a uniaxial table in all 4 directions (X, Y, Z, and 45-deg to

X &Y).



Page 15 of 19





### SPECIAL SEISMIC CERTIFICATION

### **UUT 9**

Manufacturer: LEGRAND Model number: LI-48

Unit function: LIGHTING CONTROL PANELS

Serial number: N/A

Dimensions (in)			Weight	Res	s. Freq.	(Hz)
Depth	Width	Height	(lb)	F-B	S-S	V
5.0	24.0	45.0	72	N/A	N/A	N/A

Code & criteria: 2022 CBC, ICC-ES AC156

Test laboratory: NTS-Newark

Report: PR052797.01 Rev 1 (dated 1-10-17), tested on 11-16-16

$S_{DS}(g)$	z/h	A <sub>FLX-H</sub> (g)	A <sub>RIG-H</sub> (g)	$A_{FLX-V}(g)$	$A_{RIG-V}(g)$
2.50	1	4.00	3.00	1.68	(069)
2.50	0	4.00	3.00	1.00	$\bigcirc 0.68 \mid$

Importance Factor,  $I_P = 1.5$ : Unit was full of operating content during the shake table test. Unit maintained structural integrity and remained functional per manufacturer requirement after shake table test.

Mounting: Unit was rigid wall mounted to fixture using (4) 3/8" Grade 5 bolts. Fixture was rigid mounted to table.

Construction: 16 ga carbon steel NEMA-1 enclosures with 14 ga carbon steel covers.

Subcomponents: Legrand - Enclosures (LENC48S), Shanghai Legrand Electric Co. - Power Supply Module (437D535G06), Shanghai

Legrand Electric Co. - Power Supply Module (579B373G02), Shanghai Legrand Electric Co. - Power Supply Assembly Card (579B410G01), Shanghai Legrand Electric Co. - Power Supply (DALI PS) Assembly (579B410G01), Shanghai Legrand Electric Co. - Power Supply (PS) Assembly Card (579B410G01), Basler - Transformer (BE31820001), Basler - Transformer (BE31820003), MCI Transformer - Transformer (2-51-0305), Ohga Inc. - Relay Driver Board (RD) (483C417G01), Rocom - Relays (HDR-11), Shanghai Legrand Electric Co. - Lighting Control (ELCU-100), ABB - Contactor (A16-04-00), Shanghai Legrand Electric Co. - Lonworks LW/LC Communication Card (579B404G01), Shanghai Legrand Electric Co. - Lonworks LW/LC Communication Card

(579B404G03)

Testing notes: UUT 9 is called EUT-3 in the test report. Testing was performed on a uniaxial table in all 4 directions (X, Y, Z, and 45-deg to

PNIA BUILDING CO

X &Y).



08/10/2023 OSP-0257 Page 16 of 19





### SPECIAL SEISMIC CERTIFICATION

## **UUT 10**

Manufacturer: LEGRAND Model number: LI-24

Unit function: LIGHTING CONTROL PANELS

Serial number: N/A

Dimensions (in)			Weight	Res	s. Freq.	(Hz)
Depth	Width	Height	(lb)	F-B	S-S	V
5.0	24.0	32.0	49	N/A	N/A	N/A

Code & criteria: 2022 CBC, ICC-ES AC156

Test laboratory: NTS-Newark

Report: PR052797.01 Rev 1 (dated 1-10-17), tested on 11-17-16

$S_{DS}(g)$	z/h	$A_{FLX-H}(g)$	A <sub>RIG-H</sub> (g)	$A_{FLX-V}(g)$	$A_{RIG-V}(g)$
2.50	1	4.00	3.00	1.68	(069)
2.50	0	4.00	3.00	1.00	0.68

Importance Factor,  $I_P = 1.5$ : Unit was full of operating content during the shake table test. Unit maintained structural integrity and remained functional per manufacturer requirement after shake table test.

Mounting: Unit was rigid wall mounted to fixture using (4) 3/8" lag bolts. The fixture was rigid mounted to table.

Construction: 16 ga carbon steel NEMA-1 enclosures with 14 ga carbon steel covers.

Subcomponents: Legrand - Enclosures (LENC24S), Shanghai Legrand Electric Co. - Power Supply Module (437D535G06), Shanghai

Legrand Electric Co. - Power Supply Module (579B373G02), Shanghai Legrand Electric Co. - Power Supply Assembly Card (579B410G01), Shanghai Legrand Electric Co. - Power Supply (DALI PS) Assembly (579B410G01), Shanghai Legrand Electric Co. - Power Supply (PS) Assembly Card (579B410G01), Basler - Transformer (BE31820001), Basler - Transformer (BE31820003), MCI Transformer - Transformer (2-51-0305), Ohga Inc. - Relay Driver Board (RD) (483C417G01), Rocom - Relays (HDR-11), Shanghai Legrand Electric Co. - Lighting Control (ELCU-100), ABB - Contactor (A16-04-00), Shanghai Legrand Electric Co. - Interface/Communication Card (579B449G01), Shanghai Legrand Electric Co. - Lonworks LW/LC

Communication Card (579B404G01), Shanghai Legrand Electric Co. - Lonworks LW/LC Communication Card

(579B404G02), Shanghai Legrand Electric Co. - Lonworks LW/LC Communication Card (579B404G03), Shanghai Legrand Electric Co. - Group Card (437D884G01), WattStopper - Programming Module (HCLK8SS)

ANIA BUILDING C

Testing notes: UUT 10 is called EUT-4 in the test report. Testing was performed on a uniaxial table in all 4 directions (X, Y, Z, and 45-deg

to X &Y).







### SPECIAL SEISMIC CERTIFICATION

## **UUT 11**

Manufacturer: LEGRAND Model number: LMPC-24

Unit function: LIGHTING CONTROL PANELS

Serial number: N/A

Dimensions (in)			Weight	Res	s. Freq.	(Hz)
Depth	Width	Height	(lb)	F-B	S-S	V
5.0	24.0	32.0	50	N/A	N/A	N/A

Code & criteria: 2022 CBC, ICC-ES AC156

Test laboratory: NTS-Newark

Report: PR052797.01 Rev 1 (dated 1-10-17), tested on 11-17-16

$S_{DS}(g)$	z/h	A <sub>FLX-H</sub> (g)	A <sub>RIG-H</sub> (g)	$A_{FLX-V}(g)$	$A_{RIG-V}(g)$
2.50	1	4.00	3.00	1.68	(069)
2.50	0	4.00	3.00	1.00	$\bigcirc 0.68 \mid$

Importance Factor,  $I_P = 1.5$ : Unit was full of operating content during the shake table test. Unit maintained structural integrity and remained functional per manufacturer requirement after shake table test.

Mounting: Unit was rigid wall mounted to fixture using (4) 3/8" lag bolts. The fixture was rigid mounted to table.

Construction: 16 ga carbon steel NEMA-1 enclosures with 14 ga carbon steel covers.

Subcomponents: Legrand - Enclosures (LENC24S), Shanghai Legrand Electric Co. - Power Supply Module (437D535G06), Shanghai

Legrand Electric Co. - Power Supply Module (579B373G02), Shanghai Legrand Electric Co. - Power Supply Assembly Card (579B410G01), Shanghai Legrand Electric Co. - Power Supply (DALI PS) Assembly (579B410G01), Shanghai Legrand Electric Co. - Power Supply (PS) Assembly Card (579B410G01), Basler - Transformer (BE31820001), Basler - Transformer (BE31820003), MCI Transformer - Transformer (2-51-0305), Rocom - Relays (HDR-11), Shanghai Legrand Electric Co. -

Circuit Board (16615), Shanghai Legrand Electric Co. - Circuit Board (16694)

Testing notes: UUT 11 is called EUT-5 in the test report. Testing was performed on a uniaxial table in all 4 directions (X, Y, Z, and 45-deg

to X &Y).



Page 18 of 19





#### SPECIAL SEISMIC CERTIFICATION

## **UUT 12**

Manufacturer: LEGRAND Model number: LMPC-48

Unit function: LIGHTING CONTROL PANELS

Serial number: N/A

Dimensions (in)			Weight	Res	s. Freq.	(Hz)
Depth	Width	Height	(lb)	F-B	S-S	V
5.0	24.0	45.0	97	N/A	N/A	N/A

Code & criteria: 2022 CBC, ICC-ES AC156

Test laboratory: NTS-Newark

Report: PR052797.01 Rev 1 (dated 1-10-17), tested on 11-17-16

$S_{DS}(g)$	z/h	A <sub>FLX-H</sub> (g)	$A_{RIG-H}(g)$	$A_{FLX-V}(g)$	$A_{RIG-V}(g)$
2.50	1	4.00	3.00	1.68	(069)
2.50	0	4.00	3.00	1.00	0.68

Importance Factor, I<sub>P</sub> = 1.5: Unit was full of operating content during the shake table test. Unit maintained structural integrity and remained functional per manufacturer requirement after shake table test.

Mounting: Unit was rigid wall mounted to fixture using (4) 3/8" Grade 5 bolts. Fixture was rigid mounted to table.

Construction: 16 ga carbon steel NEMA-1 enclosures with 14 ga carbon steel covers.

Subcomponents: Legrand - Enclosures (LENC48S), Shanghai Legrand Electric Co. - Power Supply Module (437D535G06), Shanghai

Legrand Electric Co. - Power Supply Module (579B373G02), Shanghai Legrand Electric Co. - Power Supply Assembly Card (579B410G01), Shanghai Legrand Electric Co. - Power Supply (DALI PS) Assembly (579B410G01), Shanghai Legrand Electric Co. - Power Supply (PS) Assembly Card (579B410G01), Basler - Transformer (BE31820001), Basler - Transformer (BE31820003), MCI Transformer - Transformer (2-51-0305), Rocom - Relays (HDR-11), Shanghai Legrand Electric Co. -

Circuit Board (16615), Shanghai Legrand Electric Co. - Circuit Board (16694)

Testing notes: UUT 12 is called EUT-6 in the test report. Testing was performed on a uniaxial table in all 4 directions (X, Y, Z, and 45-deg

to X &Y).

