



**DEPARTMENT OF HEALTH CARE ACCESS AND INFORMATION  
FACILITIES DEVELOPMENT DIVISION**

**APPLICATION FOR HCAI SPECIAL SEISMIC  
CERTIFICATION PREAPPROVAL (OSP)**

OFFICE USE ONLY

**APPLICATION #: OSP-0269**

**HCAI Special Seismic Certification Preapproval (OSP)**

Type:  New  Renewal

**Manufacturer Information**

Manufacturer: Dynamic Air Quality Solutions

Manufacturer's Technical Representative: Joseph Kramer

Mailing Address: P.O. Box 1258, Princeton, NJ 08542

Telephone: (800) 578-7873

Email: jkramer@dynamicaqs.com

**Product Information**

Product Name: Air Conditioning Units

Product Type: Air Filters

Product Model Number: See table 1 of attachment

General Description: The filter pads of the air cleaner are a patented combination of medias, bonded together in a frame that seals securely between the hinged aluminum frames of the module. Used in rigid base mounted HVAC applications.

Mounting Description: Units were stacked in the test structure. Top and bottom of stack were fastened to horizontal frames, each unit's flanges were fastened to vertical support frame on both sides.

Tested Seismic Enhancements: None

**Applicant Information**

Applicant Company Name: VMC Group


Contact Person: John Giuliano

Mailing Address: 113 Main Street, Bloomingdale, NJ 07403

Telephone: (973) 838-1780

Email: john.giuliano@thvmcgroup.com

Title: President





**DEPARTMENT OF HEALTH CARE ACCESS AND INFORMATION  
FACILITIES DEVELOPMENT DIVISION**

**California Licensed Structural Engineer Responsible for the Engineering and Test Report(s)**


Company Name: THE VMC GROUP  
Name: Kenneth Tarlow California License Number: S2851  
Mailing Address: 980 9th Street, 16th Floor, Sacramento, CA 95814  
Telephone: (832) 627-2214 Email: ken.tarlow@thevmcgroup.com

**Certification Method**

GR-63-Core     ICC-ES AC156     IEEE 344     IEEE 693     NEBS 3  
 Other (Please Specify): \_\_\_\_\_

**Testing Laboratory**

Company Name: Versatile Measuring Instruments  
Contact Person: Sherwin Jamisola  
Mailing Address: 165 Pony Drive, Newmarket ON L3Y7B5  
Telephone: (905) 954-0841 Email: cwnc@curtisswright.com





**DEPARTMENT OF HEALTH CARE ACCESS AND INFORMATION  
FACILITIES DEVELOPMENT DIVISION**

**Seismic Parameters**

Design Basis of Equipment or Components ( $F_p/W_p$ ) = 1.87

SDS (Design spectral response acceleration at short period, g) = 2.49

$a_p$  (Amplification factor) = 2.5

$R_p$  (Response modification factor) = 6.0

$\Omega_0$  (System overstrength factor) = 2.0

$I_p$  (Importance factor) = 1.5

$z/h$  (Height ratio factor) = 1

Natural frequencies (Hz) = See Attachment

Overall dimensions and weight = See Attachment


**HCAI Approval (For Office Use Only) - Approval Expires on 09/26/2028**

Date: 9/26/2022

Name: Timothy Piland Title: Senior Structural Engineer

Special Seismic Certification Valid Up to: SDS (g) = 2.49  $z/h$  = 1

Condition of Approval (if applicable): DATE: 09/26/2022



### Table 1 - Certified Components - Air Cleaners

Model Number	Dimensional Data [ in ]			MERV Rating	Weight [ lbs ]	UUT
	Depth	Width	Height			
1V8-2612-24-X-XX	24	26	12	13 & 14	39	Extrapolated
1V8-2612-29.5-F	29.5	26	12	13	47	UUT-1
1V8-2612-29.5-X-XX	29.5	26	12	13 & 14	47	Interpolated
1V8-3012-24-X-XX	24	30	12	13 & 14	42	Interpolated
1V8-3012-29.5-X-XX	29.5	30	12	13 & 14	50	Interpolated
1V8-3412-24-X-XX	24	34	12	13 & 14	47	Interpolated
1V8-3412-29.5-X-XX	29.5	34	12	13 & 14	55	Interpolated
1V8-3812-24-X-XX	24	38	12	13 & 14	47	Interpolated
1V8-3812-29.5-X-XX	29.5	38	12	13 & 14	55	Interpolated
1V8-3912-24-X-XX	24	39	12	13 & 14	50	Interpolated
1V8-3912-29.5-X-XX	29.5	39	12	13 & 14	58	Interpolated
1V8-4312-24-X-XX	24	43	12	13 & 14	57	Interpolated
1V8-4312-29.5-X-XX	29.5	43	12	13 & 14	65	Interpolated
1V8-4812-24-X-XX	24	48	12	13 & 14	59	Interpolated
1V8-4812-29.5-X-XX	29.5	48	12	13 & 14	67	Interpolated
1V8-2618-24-X-XX	24	26	18	13 & 14	58	Interpolated
1V8-2618-29.5-X-XX	29.5	26	18	13 & 14	70	Interpolated
1V8-3018-24-X-XX	24	30	18	13 & 14	63	Interpolated
1V8-3018-29.5-X-XX	29.5	30	18	13 & 14	75	Interpolated
1V8-3418-24-X-XX	24	34	18	13 & 14	69	Interpolated
1V8-3418-29.5-X-XX	29.5	34	18	13 & 14	81	Interpolated
1V8-3818-24-X-XX	24	38	18	13 & 14	71	Interpolated
1V8-3818-29.5-X-XX	29.5	38	18	13 & 14	83	Interpolated
1V8-3918-24-X-XX	24	39	18	13 & 14	75	Interpolated
1V8-3918-29.5-X-XX	29.5	39	18	13 & 14	87	Interpolated
1V8-4318-24-X-XX	24	43	18	13 & 14	81	Interpolated
1V8-4318-29.5-X-XX	29.5	43	18	13 & 14	93	Interpolated
1V8-4818-24-X-XX	24	48	18	13 & 14	87	Interpolated
1V8-4818-29.5-F	29.5	48	18	13	99	UUT-2
1V8-4818-29.5-X-XX	29.5	48	18	13 & 14	99	Interpolated


**Notes:**

X- Indicates downstream or upstream side for service access; XX- Indicates filter media

**Table 2 - Certified Subcomponents - Control Panel**

Model Number <sup>1</sup>	Dimensional Data [ in ]			Input Voltage	Rating	Weight	UUT
	Depth	Width	Height	[ V ]	[ VA ]	[ lbs ]	
CP-75-X	6.3	15.7	11.7	120	75	15	UUT-3

<sup>1</sup> X is defined by input voltage (options: 120, 208, 240, 277, and 480), tested input voltage was 120V, only difference between input voltage options is wiring





# UNIT UNDER TEST (UUT) Summary Sheet

UUT-1

Test Report: REPT-33300-01

Model Line	Model Number	Manufacturer
V8 High Efficiency Air Cleaner	1V8-2612-29.5-F	Dynamic Air Quality Solutions

### Product Construction Summary

Filter pads of the air cleaner are a patented combination of medias, bonded together in a frame that seals securely between the hinged aluminum frame of the module. Galvanized steel screens cover each filter pad and filter pads are connected with a galvanized steel frame. The unit has (4) pads per nominal 12" of height. 24VAC is used to polarize fibers in the media and airborne contaminants.

### Options / Subcomponent Summary

Control Panel

### UUT Properties



Weight [ lbs ]	Dimensions [ in ]			Lowest Nat. Freq. [ Hz ]		
	Length	Width	Height	F-B	S-S	V
47	29.5	26.0	12.0	N/A	N/A	N/A

### UUT Highest Passed Seismic Run Information

Building Code	Test Criteria	$S_{DS}$	$z/h$	$I_p$	$A_{FLX-H}$	$A_{RIG-H}$	$A_{FLX-V}$	$A_{RIG-V}$
CBC 2019	ICC-ES AC156	2.49	1.0	1.5	3.98	2.99	2.66	1.99

### Test Mounting Details

UUT-1 consisted of (3) units stacked. Each unit was fastened to a vertical support framing member with (4) #8x1/2" self tapping screws per unit with a minimum of 2 screws per vertical member (12 total). The multiple rows of air cleaners were fastened together on the backside through the horizontal mounting flanges using (2) #10 x 1" self tapping screws (4 total).



All units were filled with contents and maintained structural integrity and functionality after AC-156 test.



# UNIT UNDER TEST (UUT) Summary Sheet

UUT-2

Test Report: REPT-33300-01

Model Line	Model Number	Manufacturer
V8 High Efficiency Air Cleaner	1V8-4818-29.5-F	Dynamic Air Quality Solutions

### Product Construction Summary

Filter pads of the air cleaner are a patented combination of medias, bonded together in a frame that seals securely between the hinged aluminum frame of the module. Galvanized steel screens cover each filter pad and filter pads are connected with a galvanized steel frame. The unit has (4) pads per nominal 12" of height. 24VAC is used to polarize fibers in the media and airborne contaminants.

### Options / Subcomponent Summary

Control Panel

### UUT Properties



Weight [ lbs ]	Dimensions [ in ]			Lowest Nat. Freq. [ Hz ]		
	Length	Width	Height	F-B	S-S	V
99	29.5	48.0	18.0	N/A	N/A	N/A

### UUT Highest Passed Seismic Run Information

Building Code	Test Criteria	S <sub>DS</sub>	z/h	I <sub>p</sub>	A <sub>FLX-H</sub>	A <sub>RIG-H</sub>	A <sub>FLX-V</sub>	A <sub>RIG-V</sub>
CBC 2019	ICC-ES AC156	2.49	1.0	1.5	3.98	2.99	2.66	1.99
		-	-	-	-	-	-	-

### Test Mounting Details

UUT-2 consisted of (2) units stacked. Each unit was fastened to a vertical support framing member (6) #8x1/2" self tapping screws per unit with a minimum of 3 screws per vertical member (12 total). The multiple rows of air cleaners were fastened together on the backside through the horizontal mounting flanges using (2) #10 x 1" self tapping screws (2 total).



All units were filled with contents and maintained structural integrity and functionality after AC-156 test.



# UNIT UNDER TEST (UUT) Summary Sheet

UUT-3

Test Report: REPT-33300-01

Model Line	Model Number	Manufacturer
V8 High Efficiency Air Cleaner	CP 75-120	Dynamic Air Quality Solutions

**Product Construction Summary**

Plastic enclosure

**Options / Subcomponent Summary**

N/A

UUT Properties						
Weight [ lbs ]	Dimensions [ in ]			Lowest Nat. Freq. [ Hz ]		
	Length	Width	Height	F-B	S-S	V
15	6.3	15.7	11.7	N/A	N/A	N/A


UUT Highest Passed Seismic Run Information									
Building Code	Test Criteria	S <sub>DS</sub>	z/h	I <sub>p</sub>	A <sub>FLX-H</sub>	A <sub>RIG-H</sub>	A <sub>FLX-V</sub>	A <sub>RIG-V</sub>	
CBC 2019	ICC-ES AC156	2.49	1.0	1.5	3.98	2.99	2.66	1.99	

**Test Mounting Details**

UUT-3 was mounted directly to the framing member using (2) #8x1/2" self tapping screws on each corner (8 total).



UUT-3  
(Backside)



All units were filled with contents and maintained structural integrity and functionality after AC-156 test.