



**OFFICE OF STATEWIDE HEALTH PLANNING AND DEVELOPMENT  
FACILITIES DEVELOPMENT DIVISION**

**APPLICATION FOR OSHPD SPECIAL SEISMIC  
CERTIFICATION PREAPPROVAL (OSP)**

OFFICE USE ONLY

APPLICATION #: **OSP – 0279 – 10**

**OSHPD Special Seismic Certification Preapproval (OSP)**

Type:  New  Renewal

**Manufacturer Information**

Manufacturer: **HASKRIS**

Manufacturer's Technical Representative: Allen Dreyer

Mailing Address: 100 Kelly Street, Elk Grove, IL. 60007

Telephone: On File Email: On File

**Product Information**

Product Name: **R1200; OPC-SERIES & WW-SERIES**

Product Type: **OUTRDOOR CHILLERS & HEAT EXCHANGERS**

Product Model Number: SEE ATTACHMENT 1

(List all unique product identification numbers and/or part numbers)

General Description: Self-contained air-cooled process fluid chiller systems, and fluid-to-fluid heat exchangers. All enclosures are powder-coated carbon steel. Seismic enhancements incorporated into the test units and modifications required to address anomalies observed during tests shall be incorporated into the certified units.

Mounting Description: Rigid base mounted.

**Applicant Information**

Applicant Company Name: **EASE LLC.**

Contact Person: JONATHAN ROBERSON, S.E.


Mailing Address: 5877 Pine Ave, Suite 210, Chino Hills, CA. 91709

Telephone: (909) 606-7622 Email: (909) 606-7622

I hereby agree to reimburse the Office of Statewide Health Planning and Development review fees in accordance with the California Administrative Code, 2016.

Signature of Applicant:  Date: 11/17/16

Title: PRINCIPAL ENGINEER Company Name: **EASE LLC.**





### California Licensed Structural Engineer Responsible for the Engineering and Test Report(s)

Company Name: EASE LLC.  
Name: Jonathan Roberson, S.E. California License Number: S4197  
Mailing Address: 5877 Pine Ave, Suite 210, Chino Hills, CA. 91709  
Telephone: 909-606-7622 Email: [jon@easeco.com](mailto:jon@easeco.com)

### Supports and Attachments Preapproval


- Supports and attachments are preapproved under OPM- \_\_\_\_\_  
(Separate application for OSHPD Preapproval of Manufacturer's Certification (OPM) of Supports and attachments is required)
- Supports and attachments are not preapproved

### Certification Method

- Testing in accordance with:  ICC-ES AC156
- Other (Please Specify): \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

### Testing Laboratory

Company Name: Environmental Testing Laboratory, Inc.  
Contact Name: Brady Richard  
Mailing Address: 11034 Indian Trail, Dallas, TX 75229-3513  
Telephone: 972-247-9657 Email: [brady@etldallas.com](mailto:brady@etldallas.com)





**Seismic Parameters**

Design in accordance with ASCE 7-10 Chapter 13:  Yes  No

Design Basis of Equipment or Components ( $F_p/W_p$ ) = 1.872

$S_{DS}$  (Design spectral response acceleration at short period, g) = 2.6

$a_p$  (In-structure equipment or component amplification factor) = 1.0

$R_p$  (Equipment or component response modification factor) = 2.5

$\Omega_0$  (System overstrength factor) = 2.0

$I_p$  (Importance factor) = 1.5

$z/h$  (Height factor ratio) = 1.0

Equipment or Component Natural Frequencies (Hz) = SEE ATTACHMENT 2

Overall dimensions and weight (or range thereof) = SEE ATTACHMENT 1

Equipment or Components @ grade designed in accordance with ASCE 7-10 Chapter 15:  Yes  No

Design Basis of Equipment or Components ( $V/W$ ) = \_\_\_\_\_

$S_{DS}$  (Design spectral response acceleration at short period, g) = \_\_\_\_\_

$S_{D1}$  (Design spectral response acceleration at 1 second period, g) = \_\_\_\_\_

$R$  (Response modification coefficient) = 1.0

$\Omega_0$  (System overstrength factor) = 2.0

$C_d$  (Deflection amplification factor) = 1.0

$I_p$  (Importance factor) = 1.5

Height to Center of Gravity above base = \_\_\_\_\_

Equipment or Component Natural Frequencies (Hz) = \_\_\_\_\_

Overall dimensions and weight (or range thereof) = \_\_\_\_\_

Tank(s) designed in accordance with ASME BPVC, 2015:  Yes  No

**List of Attachments Supporting Special Seismic Certification**

Test Report(s)  Drawings  Calculations  Manufacturer's Catalog

Other(s) (Please Specify): Attachments 1 & 2

**OSHPD Approval (For Office Use Only) – Approval Expires on December 31, 2022**

Signature:  Date: 12/21/16


Print Name: M. R. Karim Title: SHFR

Special Seismic Certification Valid Up to :  $S_{DS}$  (g) = 2.6  $z/h$  = 1.0

Condition of Approval (if applicable): \_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_



**ATTACHMENT 1: SEISMIC CERTIFIED COMPONENTS**

ATTACHMENT PAGE | 1 OF 3

**TABLE 1: SEISMIC CERTIFIED SYSTEMS & COMPONENTS**

<i>Manufacturer</i>	<b>HASKRIS</b>						
<i>Product Line</i>	<b>OUTDOOR CHILLERS AND RECIRCULATING WATER SYSTEMS</b>						
COMPONENT	PART NO.	DIMENSIONS (IN.)			MAX. WT. (LB.)	MOUNTING	BASIS <sup>[1]</sup>
		W	D	H			
<b>Chiller</b>							
R1200 Outdoor Chiller	R1200- Seismic -006	49	36	75	1460	Rigid Base	UUT1
OPC10 Outdoor Process	OPC 10-460 V-3-Seismic	49	36	75	1460	Rigid Base	INT
OPC8 Outdoor Process Chiller	OPC 8-460 V- 3-Seismic	49	36	75	1430	Rigid Base	UUT2
WW3 Platform Non-Refrigerated Water Recirculating Systems (Water- to-Water)	WW3- Seismic -001	30	25	34	300	Rigid Base	UUT3
WW4 Platform Non-Refrigerated Water Recirculating Systems (Water- to-Water)	WW4- Seismic -001	30	25	34	315	Rigid Base	UUT4
<i>Mount</i>	Rigid Base: a free-standing, base mounted condition with the component rigidly attached to a supporting structure and no lateral support above the base (i.e. Floor Mounted).						
<i>Notes</i>	<ol style="list-style-type: none"> <li>BASIS: <ul style="list-style-type: none"> <li>UUT#: Indicates that a test specimen matching these characteristics was tested.</li> <li>INT (Interpolate): indicates a model that was not specifically tested, and by which seismic qualification was established through evaluation of testing of other, similar models in the product line.</li> </ul> </li> <li>Seismic Certification is limited to units which include the major subassemblies identified in Table 2: Seismic Qualified Internal Subassemblies. <ol style="list-style-type: none"> <li>Tabulated Weights are dry weights</li> </ol> </li> </ol>						

**ATTACHMENT 1: SEISMIC CERTIFIED COMPONENTS**

ATTACHMENT PAGE | 2 OF 3

**TABLE 2: SEISMIC QUALIFIED INTERNAL SUBASSEMBLIES**

MANUFACTURER	PRODUCT SERIES	MODEL	NOTES
<b>COMPRESSORS</b>			
Copeland	Scroll™ ZR compressors	ZR108KCE-TFD-265	UUT 1
Copeland	Scroll™ ZR compressors	ZR125KCE-TFD-265	
Copeland	Scroll™ ZR compressors	ZR144KCE-TFD-265	UUT 2
<b>PUMP</b>			
MTH	Regenerative Turbine	T41M-AB, 2HP	UUT 1
MTH	Regenerative Turbine	T51M-AB, 5HP	UUT 2
MTH	Regenerative Turbine	T41P-AB, 2HP	UUT 3
MTH	Regenerative Turbine	T51P-AB, 5HP	UUT 4
<b>FAN MOTOR/BLADE</b>			
Continental Fan Manufacturing	Direct Drive	AFK180	UUT 1, UUT 2
<b>EVAPORATOR</b>			
GEA PHE SYSTEMS North America, Inc.	Brazed Plate Heat Exchanger	WP5-30	UUT 1, UUT 2
<b>VARIABLE FREQUENCY DRIVE (VFD)</b>			
Yaskawa	AC Drive	CIMR-VU4A0005GAAA	UUT 1, UUT 2
<b>HEAT EXCHANGER</b>			
GEA PHE SYSTEMS North America, Inc.	Brazed Plate Heat Exchanger	WP4-40	UUT 3
GEA PHE SYSTEMS North America, Inc.	Brazed Plate Heat Exchanger	(2) WP4-40	UUT 4
<b>EXPANSION VALVE</b>			
Sporlan	Balanced Port TXV	EBSVE-11-CP100	UUT 1, UUT 2
<b>CONDENSER</b>			
LUVATA	Copper tube aluminum fin	T071025B	UUT 1, UUT 2
<b>FLOW SWITCH</b>			
JOHNSON CONTROLS	Paddle Flow Switch	F61LB-1C	UUT 1, UUT 2
<b>LIQUID FILTER DRIER</b>			
Emerson Climate Technologies	EK Liquid Line Filter Drier	EK-415S	UUT 1, UUT 2
<b>LOW FLUID TANK LEVEL INDICATOR</b>			
Gems Sensors	LS-7	605147	UUT1
Madison Company	Side-Mounted Switches with Slosh Shield	M8705	UUT2
Gems Sensors	LS-7	602969	UUT3, UUT4

Table continues next page


**ATTACHMENT 1: SEISMIC CERTIFIED COMPONENTS**


ATTACHMENT PAGE | 3 OF 3

MANUFACTURER	PRODUCT SERIES	MODEL	NOTES
<b>PRESSURE RELIEF BYPASS VALVE</b>			
Fulflo Speciality Valves	SVB	SFVB-5105R-SS-WS	UUT 1, UUT 2, UUT 3, UUT 4
<b>CONTROLLER</b>			
Future Design Controls	4300	51301100	UUT 1, UUT 2
Future Design Controls	9300	513810	UUT 1, UUT 2
Future Design Controls	4300	5150000	UUT 3, UUT 4
<b>RESERVOIR (CLOSED SYSTEM)</b>			
Haskris	30 gal non-sealed stainless steel tank	4589	UUT 1
Haskris	25 gal sealed stainless steel tank	5110	UUT 2
Haskris	14 gal. non-sealed stainless steel tank	4924	UUT 3; UUT 4

**ATTACHMENT 2: TEST SPECIMEN SUMMARY**


ATTACHMENT PAGE | 1 OF 2


<b>UUT- 1 R1200 Outdoor Chiller</b>								
<i>Manufacturer:</i> Haskris Company								
<i>Identification:</i> Model No.: R1200								
Serial No. HB22170								
<i>Description:</i> Powder-coated carbon steel enclosure with the major internal subassemblies identified in Attachment 1/Table 2 and other elements necessary to form a complete chiller system. UUT was tested with reservoir full of fluid.  Test specimen included structural enhancements corresponding to Model No. R1200-SEISMIC-006.								
<i>Mounting:</i> Rigid Base								
<i>Properties:</i>								
DIMENSIONS (in.)				Weight (lb.)	LOWEST RESONANT FREQUENCY (Hz.)			
Width	Depth	Height	FRONT-AXIS		SIDE-AXIS	VERTICAL-AXIS		
48.875	36	75.75	1452		12.39	13.29	11.61	
<i>Shake Table Test Parameters</i>								
CODE	TEST CRITERIA	S <sub>DS</sub> (g)	z/h	I <sub>P</sub>	A <sub>FLX-H</sub> (g)	A <sub>RIG-H</sub> (g)	A <sub>FLX-V</sub> (g)	A <sub>RIG-V</sub> (g)
CBC 2016	ICC-ES AC156-15	2.6	1	1.5	4.16	3.12	1.74	0.70
Unit maintained structural integrity and functionality after the ICC-ES AC 156 test in accordance with manufacturer requirements.								

<b>UUT- 2 OPC8 Outdoor Process Chiller</b>								
<i>Manufacturer:</i> Haskris Company								
<i>Identification:</i> Model No.: OPC 8								
Serial No. HB22635								
<i>Description:</i> Powder-coated carbon steel enclosure with the major internal subassemblies identified in Attachment 1/Table 2 and other elements necessary to form a complete chiller system. UUT was tested with reservoir full of fluid.  Test specimen included structural enhancements corresponding to Model No. OPC 8-460V-3-SEISMIC.								
<i>Mounting:</i> Rigid Base								
<i>Properties:</i>								
DIMENSIONS (in.)				Weight (lb.)	LOWEST RESONANT FREQUENCY (Hz.)			
Width	Depth	Height	FRONT-AXIS		SIDE-AXIS	VERTICAL-AXIS		
48.875	36	75.75	1424		12.71	13.77	12.03	
<i>Shake Table Test Parameters</i>								
CODE	TEST CRITERIA	S <sub>DS</sub> (g)	z/h	I <sub>P</sub>	A <sub>FLX-H</sub> (g)	A <sub>RIG-H</sub> (g)	A <sub>FLX-V</sub> (g)	A <sub>RIG-V</sub> (g)
CBC 2016	ICC-ES AC156-15	2.6	1	1.5	4.16	3.12	1.74	0.70
Unit maintained structural integrity and functionality after the ICC-ES AC 156 test in accordance with manufacturer requirements.								

**ATTACHMENT 2: TEST SPECIMEN SUMMARY**

ATTACHMENT PAGE | 2 OF 2

<b>UUT- 3 WW3 Platform Non-Refrigerated Water Recirculating Systems (Water-to-Water)</b>								
<i>Manufacturer:</i> Haskris Company								
<i>Identification:</i> Model No.: WW3								
Serial No. HB24458								
<i>Description:</i> Powder-coated carbon steel enclosure with the major internal subassemblies identified in Attachment 1/Table 2 and other elements necessary to form a complete fluid-fluid heat exchange system. UUT was tested with reservoir full of fluid.  Test specimen included structural enhancements corresponding to Model No. WW3-SEISMIC-001.								
<i>Mounting:</i> Rigid Base								
<i>Properties:</i>								
DIMENSIONS (in.)				Weight (lb.)	LOWEST RESONANT FREQUENCY (Hz.)			
Width	Depth	Height	FRONT-AXIS		SIDE-AXIS	VERTICAL-AXIS		
29.5	24.5	32	25.86		27.91	25.75		
<i>Shake Table Test Parameters</i>								
CODE	TEST CRITERIA	S <sub>DS</sub> (g)	z/h	I <sub>P</sub>	A <sub>FLX-H</sub> (g)	A <sub>RIG-H</sub> (g)	A <sub>FLX-V</sub> (g)	A <sub>RIG-V</sub> (g)
CBC 2016	ICC-ES AC156-15	2.6	1	1.5	4.16	3.12	1.74	0.70
Unit maintained structural integrity and functionality after the ICC-ES AC 156 test in accordance with manufacturer requirements.								

<b>UUT- 4 WW4 Platform Non-Refrigerated Water Recirculating Systems (Water-to-Water)</b>								
<i>Manufacturer:</i> Haskris Company								
<i>Identification:</i> Model No.: WW4								
Serial No. HB24430								
<i>Description:</i> Powder-coated carbon steel enclosure with the major internal subassemblies identified in Attachment 1/Table 2 and other elements necessary to form a complete fluid-fluid heat exchange system. UUT was tested with reservoir full of fluid.  Test specimen included structural enhancements corresponding to Model No. WW4-SEISMIC-001.								
<i>Mounting:</i> Rigid Base								
<i>Properties:</i>								
DIMENSIONS (in.)				Weight (lb.)	LOWEST RESONANT FREQUENCY (Hz.)			
Width	Depth	Height	FRONT-AXIS		SIDE-AXIS	VERTICAL-AXIS		
29.5	24.5	32	19.09		27.47	>50		
<i>Shake Table Test Parameters</i>								
CODE	TEST CRITERIA	S <sub>DS</sub> (g)	z/h	I <sub>P</sub>	A <sub>FLX-H</sub> (g)	A <sub>RIG-H</sub> (g)	A <sub>FLX-V</sub> (g)	A <sub>RIG-V</sub> (g)
CBC 2016	ICC-ES AC156-15	2.6	1	1.5	4.16	3.12	1.74	0.70
Unit maintained structural integrity and functionality after the ICC-ES AC 156 test in accordance with manufacturer requirements.								