

## DEPARTMENT OF HEALTH CARE ACCESS AND INFORMATION FACILITIES DEVELOPMENT DIVISION

APPLICATION FOR HCAI SPECIAL SEISMIC	OFFICE USE ONLY
CERTIFICATION PREAPPROVAL (OSP)	APPLICATION #: OSP-0338
HCAI Special Seismic Certification Preapproval (OSP)	
Type: New X Renewal	
Manufacturer Information	
Manufacturer: Eaton	
Manufacturer's Technical Representative: Art Jur	
Mailing Address: 3990 Old Tasso Road NE, Cleveland, TN 37312	
Telephone: (423) 478-0201 Email: ArtJJur@eaton.c	com
Product Information	MA
Product Name: Switchgear/Switchboards	
Product Type: Switchboards	2
Product Model Number: Enclosed Circuit Breakers	
General Description: Enclosed molded case circuit breakers, 100-1200/ and 12 enclosures.	A. NEMA Type 1, 3R, 4X
Mounting Description: Rigid, Wall Mounted	
Tested Seismic Enhancements: None	22
Applicant Information	
Applicant Company Name: WE Gundy & Associates, Inc	Or
Contact Person: Travis Soppe	
Mailing Address: PO Box 9121, Boise, ID 83707	
Telephone:       (208) 342-5989       Email:       tsoppe@wegai.com	com
Title: President	



"A healthier California where all receive equitable, affordable, and quality health care" STATE OF CALIFORNIA – HEALTH AND HUMAN SERVICES AGENCY

OSP-0338

All Ju



# DEPARTMENT OF HEALTH CARE ACCESS AND INFORMATION FACILITIES DEVELOPMENT DIVISION

lifornia Licensed Structural Engineer Responsible for the Engineering and Test Report(s)	
mpany Name: W.E. GUNDY & ASOCIATES INC.	
me: Travis Soppe California License Number: S6115	
iling Address: P.O. Box 9121, Boise, ID 83707	
ephone: (208) 342-5989 Email: tsoppe@wegai.com	
ertification Method	
GR-63-Core         X         ICC-ES AC156         IEEE 344         IEEE 693         NEBS	3
Other (Please Specify):	
FOR CODE CO.	
sting Laboratory	
mpany Name: NATIONAL TECHNICAL SYSTEMS (NTS)	
ntact Person: Tom Boonarkat	
iling Address: 7800 Highway 20 West, Huntsville AL 35806	
lephone: (256) 716-4520 Email: tom.boonarkat@element.com	
DATE: 02-28-2024	
TOP I I I I I I I I I I I I I I I I I I I	
A BUILDING CO	



"A healthier California where all receive equitable, affordable, and quality health care" STATE OF CALIFORNIA – HEALTH AND HUMAN SERVICES AGENCY

OSP-0338

Alla



# DEPARTMENT OF HEALTH CARE ACCESS AND INFORMATION FACILITIES DEVELOPMENT DIVISION

Seismic	Parameters

Design Basis of Equipment or Components	(Fp/Wp) = 1.88								
SDS (Design spectral response accele	eration at short period, g) = $2.50$								
ap (Amplification factor) = 2.5									
$R_p$ (Response modification factor) = $6.0$									
$\Omega_0$ (System overstrength factor) =									
$ Ω_0 (System overstrength factor) = 2.0 $ Ip (Importance factor) = 1.5									
z/h (Height ratio factor) =	1								
Natural frequencies (Hz) =	See Attachment								
Overall dimensions and weight =	See Attachment	2							
HCAI Approval (For Office Use Only)	Approval Expires on 02/28/203	0 7							
Date: 2/28/2024	OSP-0338	I'A							
Name: Timothy Piland		Title:	Senior Structural Engineer						
Special Seismic Certification Valid Up to: St	os (g) = 2.50	z/h =	1						
Condition of Approval (if applicable):	DATE: 02-28-2024								
	PRIVIA BUILDING CO	202							



"A healthier California where all receive equitable, affordable, and quality health care"

Alla

TABLE 1		FON EN MIC CE	WE	EGAI				
	Seismic	c Certificatio	W.E. GUNDY & ASSOCIATES, INC. STRUCTURAL & EARTHQUAKE ENGINEERING					
	A	Breaker	Encl	osure Type an	d Dimensior	ns (in)	Weight	Representative
Identification <sup>1</sup>	Amperage	Frame	NEMA <sup>2</sup>	Width	Depth	Height	(lbs)	UUT <sup>3</sup>
SGDN100	100	G	1	8.6	6.3	17.5	12	extrapolated
FFDN100	100	F	1	9.7	6.3	18.8	12	extrapolated
SFDN100	100	F	1	9.1	5.2	19.1	13	extrapolated
SFD100E	100	F (ELCB)	1	8.6	6.3	23.3	15	extrapolated
FFD100E	100	F (ELCB)	1	9.7	6.3	24.6	15	extrapolated
SFDN225	225	F	1	8.6	6.3	23.3	15	extrapolated
FFDN225	225	F	1	9.7	6.3	24.6	15	extrapolated
RGDN100	100	G	3R	9.2	9.3	19.9	16	extrapolated
JGDN100	100	G	12	9.2	9.3	19.9	16	extrapolated
JFDN100	100	F	12	9.2 DE	9.3	19.9	16	extrapolated
WFDN100	100	F	4X-0	8.8	9.3	19.9	16	extrapolated
WGDN100	100	G	4X	8.8	9.3	19.9	16	extrapolated
FPD1K0125	125	1/0	1		5.1	18.4	18	UUT <sub>v</sub> - 4
SPD2J0225	225	2	1	8.0	5.2	22.8	18	interpolated
SPD2K0225	225	24	1	DSP- <b>8.0</b> 638	5.2	22.8	18	interpolated
FPD2J0225	225	2		8.0	5.2	22.8	18	interpolated
FPD2K0225	225	2	BV· ⊤	imot <sup>8,0</sup>   Pi	and 5.2	22.8	18	interpolated
SPD1K0125	125	1	1	8.0	5.1	<b>18.4</b>	19	UUT <sub>y</sub> - 2
RFDN100	100	F	_3R	9.2	9.3	25.7	19	interpolated
RFDN100E	100	F (ELCB)	3R	9.2	9.3	19.9	19	interpolated
JFDN100E	100	F (ELCB)	12	9.2	9.3	19.9	19	interpolated
RFDN225	225	F	3R	9.2	9.3	25.7	19	interpolated
JFDN225	225	F	12	9.2	9.3	25.7	19	interpolated
RPD1J0125	125	1	3R	8.0	5.6	18.5	20	interpolated
DPD1K0125	125	1	12	018.0	5.6	18.5	20	interpolated
DPD1J0125	125	1	12	8.0	5.6	18.5	20	interpolated
WFDN100E	100	F (ELCB)	4X	8.8	9.3	19.9	20	interpolated
WFDN225	225	F	4X	8.8	9.3	25.7	20	interpolated
RPD1K0125	125	1	3R	8.0	5.6	18.5	21	UUT <sub>y</sub> - 6
WPD1K0125	125	1	4X	8.0	5.6	18.5	21	UUT <sub>y</sub> - 8
WPD1J0125	125	1	4X	8.0	5.6	18.5	21	interpolated
XPD1J0125	125	1	4X	8.0	5.6	18.5	21	interpolated
XPD1K0125	125	1	4X	8.0	5.6	18.5	21	interpolated
RPD2K0225	225	2	3R	8.5	6.5	22.8	25	interpolated

<sup>1</sup> All components are manufactured by Eaton and the part numbers listed uniquely identify the type of component, manufacturer, and material of construction for each sub-component within the tested and interpolated units.

<sup>2</sup> Enclosures are manufactured by Eaton with the NEMA 1/12/3R enclosures constructed of carbon steel and NEMA 4X enclosures constructed of stainless steel.

<sup>3</sup> The units were tested at different times and the subscripts on the UUT's reference the following lab test reports:

x - 70961R13 / y - PR154605-TR-22

TABLE 1		FON ENG MIC CE	WE	EGAI				
	Seismic	c Certificatio	W.E. GUNDY & ASSOCIATES, INC. STRUCTURAL & EARTHQUAKE ENGINEERING					
	A	Breaker	Encle	osure Type an	d Dimensior	ns (in)	Weight	Representative
Identification <sup>1</sup>	Amperage	Frame	NEMA <sup>2</sup>	Width	Depth	Height	(lbs)	UUT <sup>3</sup>
RPD2J0225	225	2	3R	8.5	6.5	22.8	25	interpolated
DPD2K0225	225	2	12	8.5	6.5	22.8	25	interpolated
DPD2J0225	225	2	12	8.5	6.5	22.8	25	interpolated
WPD2J0225	225	2	4X	8.5	6.5	22.8	25	interpolated
WPD2K0225	225	2	4X	8.5	6.5	22.8	25	interpolated
XPD2J0225	225	2	4X	8.5	6.5	22.8	25	interpolated
XPD2K0225	225	2	4X	8.5	6.5	22.8	25	interpolated
SJDN250	250	J	1	10.9	7.2	34.7	31	interpolated
FJDN250	250	J	1	12.2	7.2	36.0	32	interpolated
RJDN250	250	J	3R	11.9	10.2	37.5	37	interpolated
JJDN250	250	J	12-0	11.9	10.2	37.5	37	interpolated
WJDN250	250	J	4X	11.6	10.2	37.5	39	interpolated
FPD3K0400	400	3 2	1	10.6	9.7	38.1	52	UUT <sub>v</sub> - 5
SKDN400	400	K	1	Nev. 11.1.1.	10.9	38.8	53	interpolated
FKDN400	400	K	1	DSP <u>12</u> .438	10.9	40.1	53	interpolated
RKDN400	400	K	3R	12.3	14.1	41.7	58	interpolated
JKDN400	400	K	BI2. T	imot <sup>12,3</sup> Pi	land <sup>14.1</sup>	41.7	58	interpolated
SPD3K0400	400	3	1	10.6	9.7	38.1	63	interpolated
RPD3K0400	400	3	_3R	10.5	9.6	38.1	73	interpolated
DPD3K0400	400	3-		10.5	9.6	38.1	73	interpolated
WPD3K0400	400	3	4X	10.5	9.6	38.1	73	interpolated
XPD3K0400	400	3	4X	10.5	9.6	38.1	73	interpolated
WKDN400	400	K	4X	12.4	14.1	41.7	74	UUT <sub>x</sub> - 1
SLDN600	600	L	IAL	14.3	12.4	45.9	81	interpolated
RLDN600	600	L	3R	0115.6	15.5	48.3	84	interpolated
JLDN600	600	L	12	15.6	15.5	48.3	84	interpolated
WLDN600	600	L	4X	14.9	15.5	48.3	88	interpolated
SLG630E	600	LG (ELCB)	1	21.9	10.0	51.1	90	interpolated
SPD3K0600	600	3	1	21.3	8.4	49.9	93	interpolated
RLG630	600	LG	3R	23.1	14.1	53.4	94	interpolated
RLG630	600	LG (ELCB)	3R	23.1	14.1	53.4	94	interpolated
JLG630	600	LG	12	23.1	14.1	53.4	94	interpolated
JLG630	600	LG (ELCB)	12	23.1	14.1	53.4	94	interpolated
WLG630	600	LG	4X	23.1	14.1	53.4	96	interpolated

<sup>1</sup> All components are manufactured by Eaton and the part numbers listed uniquely identify the type of component, manufacturer, and material of construction for each sub-component within the tested and interpolated units.

<sup>2</sup> Enclosures are manufactured by Eaton with the NEMA 1/12/3R enclosures constructed of carbon steel and NEMA 4X enclosures constructed of stainless steel.

<sup>3</sup> The units were tested at different times and the subscripts on the UUT's reference the following lab test reports: x - 70961R13 / y - PR154605-TR-22

TABLE 1		FON EN MIC CE	WEGAI					
	Seismic	c Certificatio		& Associates, Inc. Arthquake engineering				
<b>T</b> 1 1 1 1 1		Breaker	Weight	Representative				
Identification <sup>1</sup>	Amperage	Frame	NEMA <sup>2</sup>	Width	Depth	Height	(lbs)	UUT <sup>3</sup>
RPD3K0600	600	3	3R	21.3	8.5	49.9	105	interpolated
DPD3K0600	600	3	12	21.3	8.5	49.9	105	interpolated
WPD3K0600	600	3	4X	21.3	8.5	49.9	105	interpolated
XPD3K0600	600	3	4X	21.3	8.5	49.9	105	interpolated
<b>SLG630</b>	600	LG	1	21.9	10.0	53.8	108	UUT <sub>x</sub> - 3
SPD4K0800	800	4	1	20.8	13.0	60.0	139	interpolated
JNDN1200	1200	M,N	12	22.6	17.6	63.6	175	interpolated
SPD5K1200	1200	5	1	20.8	13.0	60.0	178	UUT <sub>y</sub> - 3
SNDN1200	1200	M,N	1	21.4	15.4	61.2	178	interpolated
RPD4K0800	800	4	3R	20.8	13.1	59.9	190	interpolated
DPD4K0800	800	4	12-0	20.8	13.1	59.9	190	interpolated
WPD4K0800	800	4	4X	20.8	13.1	59.9	190	interpolated
XPD4K0800	800	4 1	4X	20.8	13.1	59.9	190	interpolated
<b>RNDN1200</b>	1200	M,N	3R	22.6	17.6	63.8	240	UUT <sub>x</sub> - 2
XPD5K1200	1200	54	4X (	DSP27838	13.1	60.0	254	interpolated
WPD5K1200	1200	5	4X	27.8	13.1	60.0	254	UUT <sub>y</sub> - 9
DPD5K1200	1200	5	BI2 T	imot <sup>27,8</sup> . Pi	and <sup>13.1</sup>	60.0	258	interpolated
RPD5K1200	1200	5	3R	27.8	13.1	60.0	258	UUT <sub>v</sub> - 7

<sup>1</sup>All components are manufactured by Eaton and the part numbers listed uniquely identify the type of component, manufacturer, and material of construction for each sub-component within the tested and interpolated units.

<sup>2</sup> Enclosures are manufactured by Eaton with the NEMA 1/12/3R enclosures constructed of carbon steel and NEMA 4X enclosures constructed of stainless steel.

<sup>3</sup> The units were tested at different times and the subscripts on the UUT's reference the following lab test reports:

x - 70961R13 / y - PR154605-TR-22

TABLE 2	EATON ENCLOSI CERTIFIED SUB	WEGAI W.E. GUNDY & ASSOCIATES, INC. STRUCTURAL & EARTHQUAKE ENGINEERING		
ID/Catalog Number	Manufacturer	Description	Weight (lbs)	Representative UUT
	Series G / C Molded Cas	e Circuit Breakers: 1 - 3 Poles (3 Pole	e Data)	•
EG - Frame	Eaton	15A-125A	2	extrapolated
G - Frame	Eaton	15A-100A	2	extrapolated
F - Frame	Eaton	10A-225A	5	extrapolated
K - Frame	Eaton	70A-400A	12	extrapolated
HKD3400F	Eaton	400A	12	UUT <sub>x</sub> - 1
JG - Frame	Eaton	63A-250A	14	interpolated
J - Frame	Eaton	70A-250A	14	interpolated
LG - Frame	Eaton	250A-630A	20	interpolated
LGE3630NN	Eaton	R CODE 600A	20	UUT <sub>x</sub> - 3
L - Frame	Eaton	125A-600A	20	interpolated
M - Frame	Eaton	300A-800A	30	interpolated
NG - Frame	Eaton	320A-1200A	45	interpolated
N - Frame	Eaton	400A-1200A	45	interpolated
NG31000WX04Y02	Eaton	1200A	45	UUT <sub>x</sub> - 2
	Power D <mark>efens</mark> e Molded Ca	<mark>se Circuit Breakers: 1 - 3 Poles (3</mark> Po	le Data)	
PDG-1	Eaton BY:	Fimothy J Piland	3	interpolated
PDG13M0125	Eaton	15A-125A	3	UUT <sub>v</sub> - 2/4/6/8
PDG-2	Eaton DAT	02-28-215A-225A	4	interpolated
PDG-3	Eaton	45A-400A	11	interpolated
PDG33M0400	Eaton	400A	11	UUT <sub>y</sub> - 5
PDG-3	Eaton	45A-600A	12	interpolated
PDG-4	Eaton	300A-800A	30	interpolated
PDG-5	Eaton	320A-1200A	47	interpolated
PDG53M1200	Eaton	1200A	47	UUT <sub>y</sub> - 3/7/9

#### UNIT UNDER TEST (UUT) SUMMARY SHEET



Mounting Details: Rigid wall mounted with (6) 5/16" grade 5 bolts



#### UNIT UNDER TEST (UUT) SUMMARY SHEET



**Mounting Details:** Rigid wall mounted with (6) 5/16" grade 5 bolts



### UNIT UNDER TEST (UUT) SUMMARY SHEET



Mounting Details: Rigid wall mounted with (6) 5/16" grade 5 bolts



 $UUT_y - 2$ 

#### UNIT UNDER TEST (UUT) SUMMARY SHEET



Mounting Details: Rigid wall mounted with (4) 1/4" grade 5 bolts



maintained structural integrity during and after the ICC-ES AC156 test.

UUT <sub>y</sub> -	- 3			ER TE ARY SI	ST (UUT HEET	)	W.E. GUNDY & STRUCTURAL & EAR	EGAI ASSOCIATES, INC. ITHOUAKE ENGINEERING				
Mounting Det	Mounting Details: Rigid wall mounted with (6) 5/16" grade 5 bolts											
		RED FO BY: DAT	R CO HC OSP-C Timoth E: 02									
Manufacturer		P			ocation: NT		ille, AL					
Product: Enc		Breakers	RIIT	- TAILA	ate: March 2							
Section ID: S	PD5K1200		JUIL	-	Number: P							
UUT Descript	inni	NEMA 1 carbon reaker PDG53M	1200.			ize 5 Power	r Defense	Molded				
		U	UT PR	OPERTI	ES							
Weight (lb)		Dimensions (inc	hes)		N	latural Free	quency (Hz	z)				
	Width	Depth	H	leight	FB	S	S	V				
178	20.8	13.0		60.0	NA	N.	A	NA				
		SEISMI	C TES	T PARA	METERS							
Building Code	/ Test Criter	ia $S_{DS}(g)$	z / h	IP	$A_{FLX-H}(g)$	A <sub>RIG-H</sub> (g)	A <sub>FLX-V</sub> (g	$A_{RIG-V}(g)$				
CBC 2022 / IC	CC-ES AC15		1.0	1.5	4.00	3.00	1.68	0.68				
Note: The unit w maintained struct	as full of conter ural integrity du	nts during testing and uring and after the IC	l remaine CC-ES A	ed functiona C156 test.	al before and aff	ter the ICC-E	S AC156 tes	st. The unit				

UUT <sub>y</sub> -	- 4		JNDE MMAI		ST (UUT HEET	)	W.E. GUNDY & STRUCTURAL & EA	EGAI Associates, Inc. RTHQUAKE ENGINEERING			
Mounting Details: Rigid wall mounted with (4) 1/4" grade 5 bolts											
Manufacturer:       East    Test Locatior: NTS - Huntsville, AL											
Manufacturer		100 Million					lle, AL				
Product: Enc		reakers		-116	ate: March 2						
Section ID: F	PD1K0125		DIL	Report	Number: P	R154605-T	R-22				
UUT Descript	inni	MA 1 carbon st DG13M0125.				e 1 Power 1	Defense N	Aolded Case			
		U	UT PRO	PERTI	ES						
Waight (1h)	Di	imensions (inch	les)		N	latural Freq	uency (H	z)			
Weight (lb)	Width	Depth	Hei	ght	FB	SS	S	V			
18	8.0	5.1	18	.4	NA	Nz	A	NA			
		SEISMI	C TEST	PARA	METERS						
Building Code	/ Test Criteria	$S_{DS}(g)$	z / h	I <sub>P</sub>	A <sub>FLX-H</sub> (g)	A <sub>RIG-H</sub> (g)	A <sub>FLX-V</sub> (§	g) $A_{RIG-V}(g)$			
	Building Code / Test Criteria $S_{DS}(g)$ $z / h$ $I_P$ $A_{FLX-H}(g)$ $A_{FLX-V}(g)$ $A_{RIG-V}(g)$ CBC 2022 / ICC-ES AC156         2.50         1.0         1.5         4.00         3.00         1.68         0.68										
		during testing and ng and after the IC			l before and aft	er the ICC-ES	S AC156 te	st. The unit			

UUTy -	- 5		UNDE MMAI		ST (UUT HEET	)	W.E. GUNDY & STRUCTURAL & EA	EGAI ASSOCIATES, INC. RTHOUAKE ENGINEERING
Mounting Deta	ils: Rigid wall	mounted with	(4) 5/16	" grade	5 bolts			
UUT		BY:		8-202	4			
Manufacturer:		Op 1			ocation: NT		ille, AL	
Product: Encl		reakers	21.1-1-	-116	ate: March 2			
Section ID: Fl					Number: P			
UUT Description	on•	MA 1 carbon st DG33M0400.	teel enclo	sure wi	th Frame Siz	e 3 Power	Defense N	Iolded Case
		U	UT PRO	PERTI	ES			
W.: 1 ( (1)	Di	mensions (inch	nes)		N	atural Freq	luency (H	z)
Weight (lb)	Width	Depth	Hei	ght	FB	S	S	V
52	10.6	9.7	38	.1	NA	N	A	NA
		SEISMI	C TEST	PARA	METERS		·	
Building Code	/ Test Criteria	$S_{DS}(g)$	z / h	I <sub>P</sub>	$A_{FLX-H}(g)$	$A_{RIG-H}(g)$	A <sub>FLX-V</sub> (§	g) $A_{RIG-V}(g)$
CBC 2022 / IC		2.50	1.0	1.5	4.00	3.00	1.68	0.68
Note: The unit wa maintained structu					l before and aft	er the ICC-E	S AC156 te	st. The unit

02/28/2024

~

UUT <sub>y</sub> -	- 7				ST (UUT HEET	)	W.E. GUNDY & STRUCTURAL & EAR	GAI ASSOCIATES, INC.
Mounting Det	ails: Rigid wal	l mounted with	(6) 5/16	" grade	5 bolts			
		ED FO	JT – 7 	J Pilan 28-202	4			
Manufacturer Product: Enc		rankara		and the	ocation: NT ate: March 2			
Section ID: F		ICANCIS A	BUTIE	-116	Number: P			
UUT Descript	1200A NI	EMA 3R carbor aker PDG53M1	n steel en	-				e Molded
		U	UT PRO	PERTI	ES			
Weight (lb)	Di	imensions (inch	es)		Ν	latural Freq	uency (H	z)
	Width	Depth	Hei	ght	FB	SS	S	V
258	27.8	13.1	60	0.0	NA	N	A	NA
		SEISMIC	C TEST	PARA	METERS			
Building Code	/ Test Criteria	$S_{DS}(g)$	z / h	IP	A <sub>FLX-H</sub> (g)	$A_{RIG-H}\left(g ight)$	A <sub>FLX-V</sub> (g	g) $A_{RIG-V}(g)$
CBC 2022 / IC	CC-ES AC156	2.50	1.0	1.5	4.00	3.00	1.68	0.68
		during testing and ng and after the IC			l before and af	ter the ICC-E	S AC156 tes	st. The unit

 $UUT_y - 8$ 

### UNIT UNDER TEST (UUT) SUMMARY SHEET



Mounting Details: Rigid wall mounted with (4) 1/4" grade 5 bolts



UUT <sub>y</sub> – 9		UNIT UNDER TEST (UUT) SUMMARY SHEET					W.E. GUNDY & STRUCTURAL & EA	EGAI ASSOCIATES, INC. RTHOUAKE ENGINEERING	
Mounting Details: Rigid wall mounted with (6) 5/16" grade 5 bolts									
		TRACE TRACE TRACE TRACE TRACE TRACE TRACE TRACE TRACE TRACE TRACE TRACE TRACE TRACE TRACE TRACE TRACE	DR CO HC OSP-03 Timothy E: 02-2				9		
					Test Location: NTS - Huntsville, AL				
Product: Enclosed Circuit Breakers Test Date: March 2022									
Section ID: V	WPD5K1200			-	Number: P				
UUT Descript	1001	EMA 4X stainl ker PDG53M1		enclosu	re with Fram	e Size 5 Po	wer Defe	nse Molded	
		U	UT PRO	PERTI	ES				
Weight (lb)	Di	mensions (incl	hes)		N	latural Freq	luency (H	z)	
	Width	Depth	Hei	ght	FB	SS	S	V	
254	27.8	13.1	60	.0	NA	NA	A	NA	
		SEISMI	C TEST	PARA	METERS				
Building Code / Test Criteria S		$S_{DS}(g)$	z / h	IP	$A_{FLX-H}(g)$	A <sub>RIG-H</sub> (g)	A <sub>FLX-V</sub> (§	g) $A_{RIG-V}(g)$	
CBC 2022 / ICC-ES AC156		2.50	1.0	1.5	4.00	3.00	1.68	0.68	
	as full of contents rural integrity durin				l before and aft	ter the ICC-E	S AC156 te	st. The unit	