



**OFFICE OF STATEWIDE HEALTH PLANNING AND DEVELOPMENT  
FACILITIES DEVELOPMENT DIVISION**

**APPLICATION FOR OSHPD SPECIAL SEISMIC  
CERTIFICATION PREAPPROVAL (OSP)**

OFFICE USE ONLY

APPLICATION #: **OSP – 0362 – 10**

**OSHPD Special Seismic Certification Preapproval (OSP)**

Type:  New  Renewal

**Manufacturer Information**

Manufacturer: Rauland-Borg Corporation

Manufacturer's Technical Representative: Vernon Morris

Mailing Address: 1802 West Central Road, Mt. Prospect, IL 60056

Telephone: (847) 590-7100

Email: [vernon.morris@ametek.com](mailto:vernon.morris@ametek.com)

**Product Information**

Product Name: Responder Call Stations

Product Type: System Cabinets

Product Model Number: See Certified Product Table attached

(List all unique product identification numbers and/or part numbers)

General Description: Responder Nurse Call Stations consist of terminal cabinets containing the control and termination modules, network equipment, & power required to operate the stations. Seismic enhancements made to the test units and modifications required to address anomalies observed during the tests shall be incorporated into product units.

Mounting Description: Rigidly wall mounted

**Applicant Information**

Applicant Company Name: Rauland-Borg Corporation

Contact Person: Vernon Morris

Mailing Address: 1802 West Central Road, Mt. Prospect, IL 60056

Telephone: (847) 590-7100

Email: [vernon.morris@ametek.com](mailto:vernon.morris@ametek.com)


I hereby agree to reimburse the Office of Statewide Health Planning and Development review fees in accordance with the California Administrative Code, 2016.

Signature of Applicant: 

Date: 10/11/2017

Title: Regulatory Compliance Engineer Company Name: Rauland-Borg Corporation

"Access to Safe, Quality Healthcare Environments that Meet California's Diverse and Dynamic Needs"





**OFFICE OF STATEWIDE HEALTH PLANNING AND DEVELOPMENT  
FACILITIES DEVELOPMENT DIVISION**

**California Licensed Structural Engineer Responsible for the Engineering and Test Report(s)**

Company Name: Forell/Elsesser Engineers, Inc.

Name: Marco Scanu, SE California License Number: S4454

Mailing Address: 160 Pine St., 6<sup>th</sup> Flr., San Francisco, CA 94111

Telephone: (415) 837-0700 Email: [m.scanu@forell.com](mailto:m.scanu@forell.com)

**Supports and Attachments Preapproval**

- Supports and attachments are preapproved under OPM- \_\_\_\_\_  
(Separate application for OSHPD Preapproval of Manufacturer's Certification (OPM) of Supports and attachments is required)
- Supports and attachments are not preapproved

**Certification Method**

- Testing in accordance with:  ICC-ES AC156
- Other (Please Specify): \_\_\_\_\_


**Testing Laboratory**

Company Name: National Technical Systems

Contact Name: Ray Chavez

Mailing Address: 38995 Cherry Street, Newark, CA 94560

Telephone: (510) 578-3500 Email: \_\_\_\_\_





**OFFICE OF STATEWIDE HEALTH PLANNING AND DEVELOPMENT  
FACILITIES DEVELOPMENT DIVISION**

**Seismic Parameters**

Design in accordance with ASCE 7-10 Chapter 13:  Yes  No

Design Basis of Equipment or Components ( $F_p/W_p$ ) = 1.94

$S_{DS}$  (Design spectral response acceleration at short period, g) = 2.58

$a_p$  (In-structure equipment or component amplification factor) = 2.5

$R_p$  (Equipment or component response modification factor) = 6.0

$\Omega_0$  (System overstrength factor) = 2.0

$I_p$  (Importance factor) = 1.5

$z/h$  (Height factor ratio) = 1

Equipment or Component Natural Frequencies (Hz) = See attachment, UUT Summary Sheets

Overall dimensions and weight (or range thereof) = See attachment, Certified Products Table

Equipment or Components @ grade designed in accordance with ASCE 7-10 Chapter 15:  Yes  No

Design Basis of Equipment or Components ( $V/W$ ) = \_\_\_\_\_

$S_{DS}$  (Design spectral response acceleration at short period, g) = \_\_\_\_\_

$S_{D1}$  (Design spectral response acceleration at 1 second period, g) = \_\_\_\_\_

$R$  (Response modification coefficient) = \_\_\_\_\_

$\Omega_0$  (System overstrength factor) = \_\_\_\_\_

$C_d$  (Deflection amplification factor) = \_\_\_\_\_

$I_p$  (Importance factor) = 1.5

Height to Center of Gravity above base = \_\_\_\_\_

Equipment or Component Natural Frequencies (Hz) = \_\_\_\_\_

Overall dimensions and weight (or range thereof) = \_\_\_\_\_


Tank(s) designed in accordance with ASME BPVC, 2015:  Yes  No

**List of Attachments Supporting Special Seismic Certification**

Test Report(s)  Drawings  Calculations  Manufacturer's Catalog

Other(s) (Please Specify): Certified Products Table, Certified Subcomponents Table, UUT Summary Sheets

**OSHPD Approval (For Office Use Only) – Approval Expires on December 31, 2022**


Signature:  Date: November 21, 2017

Print Name: Timothy J. Piland Title: SSE

Special Seismic Certification Valid Up to :  $S_{DS}$  (g) = 2.58  $z/h$  = 1

Condition of Approval (if applicable): \_\_\_\_\_

\_\_\_\_\_  
\_\_\_\_\_



## Rauland-Borg Corporation - Responder Call Stations

### I. Certified Product Table

Unit	Width	Depth	Height	Max. Weight	Construction Material <sup>1,2</sup>	Test Status
<b>Responder 4000</b>						
351102 Cabinet	14.375 in	4.75 in	28.0 in	42 lbs	16 ga CFS	PR054947.01 EUT-2
351102 Cabinet	14.375 in	4.75 in	28.0 in	50 lbs	16 ga CFS	PR064966.01 UUT-9
NC2828 Cabinet	28.0 in	5.50 in	28.0 in	67 lbs	16 ga CFS	PR054947.01 EUT-1
NC2828 Cabinet	28.0 in	5.50 in	28.0 in	101 lbs	16 ga CFS	PR064966.01 UUT-10
<b>Responder 5 &amp; 5000</b>						
351102 Cabinet	14.375 in	4.75 in	28.0 in	36 lbs	16 ga CFS	PR054947.01 EUT-4
351102 Cabinet	14.375 in	4.75 in	28.0 in	41 lbs	16 ga CFS	R93329 UUT-2
351102 Cabinet	14.375 in	4.75 in	28.0 in	51 lbs	16 ga CFS	PR064966.01 UUT-7
NC2828 Cabinet	28.0 in	5.50 in	28.0 in	66 lbs	16 ga CFS	PR054947.01 EUT-3
NC2828 Cabinet	28.0 in	5.50 in	28.0 in	67 lbs	16 ga CFS	R93329 UUT-1
NC2828 Cabinet	28.0 in	5.50 in	28.0 in	92 lbs	16 ga CFS	PR064966.01 UUT-8
<b>Notes</b>						
<ol style="list-style-type: none"> <li>1. All enclosures are NEMA 1 rated.</li> <li>2. CFS = cold-formed carbon steel.</li> <li>3. All enclosures are rigid wall-mounted.</li> <li>4. Responder 4000 panels can be configured to a maximum weight of 101 lbs.</li> <li>5. Responder 5 &amp; 5000 panels can be configured to a maximum weight of 92 lbs.</li> </ol>						

**Rauland-Borg Corporation - Responder Call Stations**  
**II. Certified Subcomponents Table**

**Responder 4000**

Components	Manufacturer	Part #	Testing Status
<b>Cabinets</b>			
28"Wx28"Hx5.5"D	Rauland-Borg	NC2828	PR054947.01 EUT-1 and PR064966.01 UUT-10
14.375"Wx28"Hx4.75"D	Rauland-Borg	351102	PR054947.01 EUT-2 and PR064966.01 UUT-9
<b>Subcomponents</b>			
Network Interface Module	Rauland-Borg	R4KNIM	PR054947.01 EUT-1 & EUT-2
Power Supply	Rauland-Borg	R4KPR400	PR054947.01 EUT-1 & EUT-2 and PR064966.01 UUT-9 & UUT-10
Battery Backup Kit	Rauland-Borg	R4KBK400	PR054947.01 EUT-1 & EUT-2 and PR064966.01 UUT-9 & UUT-10
Termination PCB	Rauland-Borg	R4KTMB	PR054947.01 EUT-1 & EUT-2
Paging Amplifier	Rauland-Borg	R4KPA25	PR054947.01 EUT-1 & EUT-2 and PR064966.01 UUT-10
X-Bus Adapter	Rauland-Borg	R4KXBA	PR054947.01 EUT-1

**Rauland-Borg Corporation - Responder Call Stations**  
**II. Certified Subcomponents Table**

**Responder 5 & 5000**

Components	Manufacturer	Part #	Testing Status
<b>Cabinets</b>			
28"Wx28"Hx5.5"D	Rauland-Borg	NC2828	R93329 UUT-1 and PR064966.01 UUT-8 and PR054947.01 EUT-3
14.375"Wx28"Hx4.75"D	Rauland-Borg	351102	R93329 UUT-2 and PR064966.01 UUT-7 and PR054947.01 EUT-4
<b>Subcomponents</b>			
Branch Regional Controller	Rauland-Borg	351000	R93329 UUT-2
Branch Regional Controller v2	Rauland-Borg	351001	Interpolated <sup>1</sup>
Responder Network Concentrator	Rauland-Borg	351010	R93329 UUT-1
Power Supply and Battery	Rauland-Borg	351003	R93329 UUT-1 & UUT-2 and PR064966.01 UUT-7 & UUT-8
8 Port Ethernet Switch	Rauland-Borg	351004	R93329 UUT-2 and PR064966.01 UUT-8
Fiber Optic Adapter	Rauland-Borg	351006	R93329 UUT-1, UUT-2
Main System Controller	Rauland-Borg	R5KMSC	PR054947.01 EUT-3 & EUT-4
Adapter	Rauland-Borg	R5KL2KA	PR054947.01 EUT-3 & EUT-4
Power Supply (15V) w/Battery Backup	Rauland-Borg	R5KMMPR15	PR054947.01 EUT-3 & EUT-4
Power Supply (36V) w/Battery Backup	Rauland-Borg	R5KMMPR36	PR054947.01 EUT-3 & EUT-4
Ethernet Switch	Rauland-Borg	R5KM8PRT	PR054947.01 EUT-3
Termination PCB	Rauland-Borg	R5KMTRM	PR054947.01 EUT-3 & EUT-4

**Notes:**

- The Branch Regional Controllers and Responder Network Concentrator are of similar construction, material, and configuration.

Rauland-Borg Corporation – Responder Call Stations

III. UUT Summary Sheets

**Test Report R93329 – UUT 1**

Responder 5000 Cabinet

16 ga. Cold Formed Carbon Steel

28"W x 5.5"D x 28"H, 67 lbs

Wall mounted using: (4) - 3/8" A307 Grade A bolts

Building Code	Test Criteria	S <sub>DS</sub> (g)	z/h	Horizontal		Vertical	
				A <sub>FLX-H</sub>	A <sub>RIG-H</sub>	A <sub>FLX-V</sub>	A <sub>RIG-H</sub>
CBC 2016	ICC-ES AC 156	2.81	1	4.50	3.37	1.88	0.75
Natural Frequencies			Test Results				
F-B	S-S	V	The UUT maintained structural integrity and functionality after the AC156 test. UUT full of contents during testing.				
n/a	n/a	n/a					



Subcomponents	Manufacturer	Part #
Cabinet	Rauland-Borg	NC2828
Power Supply with Battery Backup	Rauland-Borg	351003
Fiber Optic Adapter Module	Rauland-Borg	351006
Responder Network Concentrator	Rauland-Borg	351010

**Test Report R93329 – UUT 2**

Responder 5000 Cabinet  
 16 ga. Cold Formed Carbon Steel  
 14.375"W x 4.75"D x 28"H, 41 lbs  
 Wall mounted using: (4) - 3/8" A307 Grade A bolts

**Box-2**



Building Code	Test Criteria	S <sub>DS</sub> (g)	z/h	Horizontal		Vertical	
				A <sub>FLX-H</sub>	A <sub>RIG-H</sub>	A <sub>FLX-V</sub>	A <sub>RIG-H</sub>
CBC 2016	ICC-ES AC 156	2.81	1	4.50	3.37	1.88	0.75
Natural Frequencies			Test Results				
F-B	S-S	V	The UUT maintained structural integrity and functionality after the AC156 test. UUT full of contents during testing.				
n/a	n/a	n/a					

Subcomponents	Manufacturer	Part #
Cabinet	Rauland-Borg	351102
Branch Regional Controller	Rauland-Borg	351000
Power Supply with Battery Backup	Rauland-Borg	351003
8 Port Ethernet Switch	Rauland-Borg	351004
Fiber Optic Adapter Module	Rauland-Borg	351006




OSP APPLICATION  
 Rauland-Borg Corporation – Responder Call Stations  
 III. UUT Summary Sheets

Date: 9/19/2017

**Test Report PR054947.01 – EUT 1**

Responder 4000 Cabinet  
 16 ga. Cold Formed Carbon Steel  
 28"W x 5.5"D x 28"H, 67 lbs  
 Wall mounted using: (4) - 3/8" A307  
 Grade A bolts



Building Code	Test Criteria	S <sub>DS</sub> (g)	z/h	Horizontal		Vertical	
				A <sub>FLX-H</sub>	A <sub>RIG-H</sub>	A <sub>FLX-V</sub>	A <sub>RIG-H</sub>
CBC 2016	ICC-ES AC 156	3.00	1	4.80	3.60	2.01	0.80
<b>Natural Frequencies</b>			<b>Test Results</b>				
<b>F-B</b>	<b>S-S</b>	<b>V</b>	The UUT maintained structural integrity and functionality after the AC156 test. UUT full of contents during testing.				
n/a	n/a	n/a					


Subcomponents	Manufacturer	Part #
Network Interface Module	Rauland-Borg	R4KNIM
Power Supply	Rauland-Borg	R4KPR400
Battery Backup Kit	Rauland-Borg	R4KBK400
Termination PCB	Rauland-Borg	R4KTMB
Paging Amplifier	Rauland-Borg	R4KPA25
X-Bus Adapter	Rauland-Borg	R4KXBA

OSP APPLICATION  
 Rauland-Borg Corporation – Responder Call Stations  
 III. UUT Summary Sheets

Date: 9/19/2017

**Test Report PR054947.01 – EUT 2**

Responder 4000 Cabinet  
 16 ga. Cold Formed Carbon Steel  
 14.375"W x 4.75"D x 28"H, 42 lbs  
 Wall mounted using: (4) - 3/8" A307  
 Grade A bolts  
 EUT-2 shown on the right




Building Code	Test Criteria	S <sub>DS</sub> (g)	z/h	Horizontal		Vertical	
				A <sub>FLX-H</sub>	A <sub>RIG-H</sub>	A <sub>FLX-V</sub>	A <sub>RIG-H</sub>
CBC 2016	ICC-ES AC 156	3.00	1	4.80	3.60	2.01	0.80
<b>Natural Frequencies</b>			<b>Test Results</b>				
<b>F-B</b>	<b>S-S</b>	<b>V</b>	The UUT maintained structural integrity and functionality after the AC156 test. UUT full of contents during testing.				
n/a	n/a	n/a					

Subcomponents	Manufacturer	Part #
Network Interface Module	Rauland-Borg	R4KNIM
Power Supply	Rauland-Borg	R4KPR400
Battery Backup Kit	Rauland-Borg	R4KBK400
Termination PCB	Rauland-Borg	R4KTMB
Paging Amplifier	Rauland-Borg	R4KPA25

Rauland-Borg Corporation – Responder Call Stations  
 III. UUT Summary Sheets

**Test Report PR054947.01 – EUT 3**

Responder 5000 Cabinet  
 16 ga. Cold Formed Carbon Steel  
 28”W x 5.5”D x 28”H, 66 lbs  
 Wall mounted using: (4) - 3/8” A307  
 Grade A bolts  
 EUT-3 shown on the Left




Building Code	Test Criteria	S <sub>Ds</sub> (g)	z/h	Horizontal		Vertical	
				A <sub>FLX-H</sub>	A <sub>RIG-H</sub>	A <sub>FLX-V</sub>	A <sub>RIG-H</sub>
CBC 2016	ICC-ES AC 156	3.00	1	4.80	3.60	2.01	0.80
<b>Natural Frequencies</b>			<b>Test Results</b>				
<b>F-B</b>	<b>S-S</b>	<b>V</b>	The UUT maintained structural integrity and functionality after the AC156 test. UUT full of contents during testing.				
n/a	n/a	n/a					

Subcomponents	Manufacturer	Part #
Main System Controller	Rauland-Borg	R5KMSC
Adapter	Rauland-Borg	R5KL2KA
Power Supply (15V) w/Battery Backup	Rauland-Borg	R5KMPR15
Power Supply (36V) w/Battery Backup	Rauland-Borg	R5KMPR36
Ethernet Switch	Rauland-Borg	R5KM8PRT
Termination PCB	Rauland-Borg	R5KMTRM

Rauland-Borg Corporation – Responder Call Stations  
 III. UUT Summary Sheets

**Test Report PR054947.01 – EUT 4**  
 Responder 5000 Cabinet  
 16 ga. Cold Formed Carbon Steel  
 14.375”W x 4.75”D x 28”H, 36 lbs  
 Wall mounted using: (4) - 3/8” A307  
 Grade A bolts  
 EUT-4 shown on the right



Building Code	Test Criteria	S <sub>Ds</sub> (g)	z/h	Horizontal		Vertical	
				A <sub>FLX-H</sub>	A <sub>RIG-H</sub>	A <sub>FLX-V</sub>	A <sub>RIG-H</sub>
CBC 2016	ICC-ES AC 156	3.00	1	4.80	3.60	2.01	0.80
<b>Natural Frequencies</b>			<b>Test Results</b>				
<b>F-B</b>	<b>S-S</b>	<b>V</b>	The UUT maintained structural integrity and functionality after the AC156 test. UUT full of contents during testing.				
n/a	n/a	n/a					


Subcomponents	Manufacturer	Part #
Main System Controller	Rauland-Borg	R5KMSC
Adapter	Rauland-Borg	R5KL2KA
Power Supply (15V) w/Battery Backup	Rauland-Borg	R5KMPR15
Power Supply (36V) w/Battery Backup	Rauland-Borg	R5KMPR36
Termination PCB	Rauland-Borg	R5KMTRM

OSP APPLICATION  
 Rauland-Borg Corporation – Responder Call Stations  
 III. UUT Summary Sheets

Date: 9/19/2017

**Test Report PR064966.01 – UUT 7**

Responder 5 Cabinet  
 16 ga. Cold Formed Carbon Steel  
 14.375"W x 4.75"D x 28"H, 51 lbs  
 Wall mounted using: (4) -#10 Pan Head 1" long Screw



Building Code	Test Criteria	S <sub>Ds</sub> (g)	z/h	I <sub>p</sub>	Horizontal		Vertical	
					A <sub>FLX-H</sub> (g)	A <sub>RIG-H</sub> (g)	A <sub>FLX-V</sub> (g)	A <sub>RIG-V</sub> (g)
CBC 2016	ICC-ES AC 156	2.58	1.0	1.5	4.13	3.10	1.73	0.69
<b>Natural Frequencies (Hz)</b>			<b>Test Results</b>					
<b>F-B</b>	<b>S-S</b>	<b>V</b>	The UUT maintained structural integrity and functionality after the AC156 test. UUT full of contents during testing.					
n/a	n/a	n/a						

Subcomponents	Manufacturer	Part #
Cabinet	Rauland-Borg	351102
Power Supply and Battery	Rauland-Borg	351003

OSP APPLICATION  
 Rauland-Borg Corporation – Responder Call Stations  
 III. UUT Summary Sheets

Date: 9/19/2017

**Test Report PR064966.01 – UUT 8**

Responder 5 Cabinet  
 16 ga. Cold Formed Carbon Steel  
 28"W x 5.5"D x 28"H, 92 lbs  
 Wall mounted using: (4) -#10 Pan Head 1" long Screw



Building Code	Test Criteria	S <sub>Ds</sub> (g)	z/h	I <sub>p</sub>	Horizontal		Vertical	
					A <sub>FLX-H</sub> (g)	A <sub>RIG-H</sub> (g)	A <sub>FLX-V</sub> (g)	A <sub>RIG-V</sub> (g)
CBC 2016	ICC-ES AC 156	2.58	1.0	1.5	4.13	3.10	1.73	0.69
Natural Frequencies (Hz)			Test Results					
F-B	S-S	V	The UUT maintained structural integrity and functionality after the AC156 test. UUT full of contents during testing.					
n/a	n/a	n/a						

Subcomponents	Manufacturer	Part #
Cabinet	Rauland-Borg	NC2828
Power Supply and Battery	Rauland-Borg	351003
8 Port Ethernet Switch	Rauland-Borg	351004

OSP APPLICATION  
 Rauland-Borg Corporation – Responder Call Stations  
 III. UUT Summary Sheets

Date: 9/19/2017

**Test Report PR064966.01 – UUT 9**

Responder 4000 Cabinet  
 16 ga. Cold Formed Carbon Steel  
 14.375"W x 4.75"D x 28"H, 50 lbs  
 Wall mounted using: (4) -#10 Pan Head 1" long Screw



Building Code	Test Criteria	S <sub>Ds</sub> (g)	z/h	I <sub>p</sub>	Horizontal		Vertical	
					A <sub>FLX-H</sub> (g)	A <sub>RIG-H</sub> (g)	A <sub>FLX-V</sub> (g)	A <sub>RIG-V</sub> (g)
CBC 2016	ICC-ES AC 156	2.58	1.0	1.5	4.13	3.10	1.73	0.69
<b>Natural Frequencies (Hz)</b>			<b>Test Results</b>					
<b>F-B</b>	<b>S-S</b>	<b>V</b>	The UUT maintained structural integrity and functionality after the AC156 test. UUT full of contents during testing.					
n/a	n/a	n/a						

Subcomponents	Manufacturer	Part #
Cabinet	Rauland-Borg	351102
Power Supply	Rauland-Borg	R4KPR400
Battery Backup Kit	Rauland-Borg	R4KBK400

Rauland-Borg Corporation – Responder Call Stations

III. UUT Summary Sheets

**Test Report PR064966.01 – UUT 10**

Responder 4000 Cabinet

16 ga. Cold Formed Carbon Steel

28"W x 5.5"D x 28"H, 101 lbs

Wall mounted using: (4) -#10 Pan Head 1" Screws



Building Code	Test Criteria	S <sub>Ds</sub> (g)	z/h	I <sub>p</sub>	Horizontal		Vertical	
					A <sub>FLX-H</sub> (g)	A <sub>RIG-H</sub> (g)	A <sub>FLX-V</sub> (g)	A <sub>RIG-V</sub> (g)
CBC 2016	ICC-ES AC 156	2.58	1.0	1.5	4.13	3.10	1.73	0.69
<b>Natural Frequencies (Hz)</b>			<b>Test Results</b>					
<b>F-B</b>	<b>S-S</b>	<b>V</b>	The UUT maintained structural integrity and functionality after the AC156 test. UUT full of contents during testing.					
n/a	n/a	n/a						

Subcomponents	Manufacturer	Part #
Cabinet	Rauland-Borg	NC2828
Power Supply	Rauland-Borg	R4KPR400
Battery Backup Kit	Rauland-Borg	R4KBK400
Paging Amplifier	Rauland-Borg	R4KPA25