

| | OFFICE USE ONLY | | | | | |
|---|--|--|--|--|--|--|
| CERTIFICATION PREAPPROVAL (OSP) | APPLICATION #: OSP-0364-10 | | | | | |
| OSHPD Special Seismic Certification Preapproval (OSP) | | | | | | |
| Type: 🛛 New 🗌 Renewal | | | | | | |
| Manufacturer Information | | | | | | |
| Manufacturer:Tecogen, Inc. | | | | | | |
| Manufacturer's Technical Representative: Jean P. Roy, Manager of E | ngineering | | | | | |
| Mailing Address: 45 First Avenue, Waltham, MA 02451 | | | | | | |
| Telephone: (781) 466-6431 Email: jean. | roy@tecogen.com | | | | | |
| Product Information | | | | | | |
| Product Name: TECOCHILL water-cooled natural gas engine driven | chillers | | | | | |
| Product Type: Mechanical Equipment | | | | | | |
| Product Model Number: <u>SEE ATTACHMENT</u> (List all unique product identification numbers and/or part numbers) General Description: <u>The certified units are from the STx and DTx series, and include compressors, heat exchangers, natural gas engine,</u> pressure vessel, control cabinet, expansion valve, coolant pump and acoustic enclosure. Seismic enhancement made to the test units and | | | | | | |
| Mounting Description: The units are certified for a flexible base mount condition, mounted to neoprene or s | spring isolators, to cover both installation conditions. | | | | | |
| Applicant Information | | | | | | |
| Applicant Company Name: DYNAMIC CERTIFICATION LABORATO | RIES | | | | | |
| Contact Person: JOSEPH L. LA BRIE, S.E., MANAGING PARTNER | | | | | | |
| Mailing Address: 1315 GREG STREET, SUITE 109, SPARKS, NV 89 | 9431 | | | | | |
| Telephone: (775) 358-5085 Email: LAB | RIE@MAKEITRIGHT.NET | | | | | |
| I hereby agree to reimburse the Office of Statewide Health Planning and Development review fees in accordance with the California Administrative Code, 2013. Signature of Applicant: Date: | | | | | | |
| Title: MANAGING PARTNER Company Name: DYN | AMIC CERTIFICATION LABORATORIES | | | | | |
| "Access to Safe. Quality Healthcare Environments that Meet California's Diverse and Dvnamic Needs" STATE OF CALIFORNIA – HEALTH AND HUMAN SERVICES AGENCY OSH-FD-759 (REV 1/24/13) | Page 1 of 3 | | | | | |



| California Licensed Structural Engineer Responsible for the Engineering and Test Report(s) | | | | | | | |
|--|--|--|--|--|--|--|--|
| Company Name: DYNAMIC CERTIFICATION LABORATORIES | | | | | | | |
| Name: DR. AHMAD ITANI, S.E. California License Number: SE-5220 | | | | | | | |
| Mailing Address: 1315 GREG STREET, SUITE 109, SPARKS, NV 89431 | | | | | | | |
| Telephone: (775) 358-5085 Email: ITANI@SHAKETEST.COM | | | | | | | |
| Supports and Attachments Preapproval | | | | | | | |
| Supports and attachments are preapproved under OPM- (Separate application for OSHPD Preapproval of Manufacturer's Certification (OPM) of Supports and attachments is required) Supports and attachments are not preapproved | | | | | | | |
| Certification Method | | | | | | | |
| Testing in accordance with: ICC-ES AC156 Other (Please Specify): | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| Testing Laboratory | | | | | | | |
| Company Name: DYNAMIC CERTIFICATION LABORATORIES | | | | | | | |
| Contact Name: AUSTIN BROWN, P.E., LABORATORY MANAGER | | | | | | | |
| Mailing Address: | | | | | | | |
| Telephone: (775) 358-5085 Email: AUSTIN@SHAKETEST.COM | | | | | | | |

"Access to Safe, Quality Healthcare Environments that Meet California's Diverse and Dynamic Needs"

os Dpd



OFFICE OF STATEWIDE HEALTH PLANNING AND DEVELOPMENT FACILITIES DEVELOPMENT DIVISION

| Seismic Parameters | | | | | | | | | |
|---|--|--|--|--|--|--|--|--|--|
| Design in accordance with ASCE 7-10 Chapter 13: 🛛 Yes 🗌 No | | | | | | | | | |
| Design Basis of Equipment or Components (F_p/W_p) =3.6 (using neoprene isolators); 4.5 (using spring isolators) | | | | | | | | | |
| S_{DS} (Design spectral response acceleration at short period, g) = _2.0 | | | | | | | | | |
| a _p (In-structure equipment or component amplification factor) = 2.5 | | | | | | | | | |
| R_p (Equipment or component response modification factor) = <u>2.5 (neoprene isolators)</u> ; 2.0 (spring isolators) | | | | | | | | | |
| Ω_0 (System overstrength factor) = 2.5 | | | | | | | | | |
| I_p (Importance factor) = 1.5 | | | | | | | | | |
| z/h (Height factor ratio) = _1.0 | | | | | | | | | |
| Equipment or Component Natural Frequencies (Hz) = <u>SEE ATTACHMENT</u> | | | | | | | | | |
| Overall dimensions and weight (or range thereof) = <u>SEE ATTACHMENT</u> | | | | | | | | | |
| Equipment or Components @ grade designed in accordance with ASCE 7-10 Chapter 15: \Box Yes \boxtimes No Design Basis of Equipment or Components (V/W) = | | | | | | | | | |
| S_{PS} (Design spectral response acceleration at short period, g) = | | | | | | | | | |
| S_{P1} (Design spectral response acceleration at 1 second period, g) = | | | | | | | | | |
| R (Response modification coefficient) = | | | | | | | | | |
| Ω_0 (System overstrength factor) = | | | | | | | | | |
| C_{d} (Deflection amplification factor) = | | | | | | | | | |
| $\int_{a} (\text{Importance factor}) = 1.5$ | | | | | | | | | |
| Height to Center of Gravity above base = | | | | | | | | | |
| Equipment or Component Natural Frequencies (Hz) = | | | | | | | | | |
| Overall dimensions and weight (or range thereof) = | | | | | | | | | |
| Tank(s) designed in accordance with ASME BPVC. 2010: Yes 🕅 No | | | | | | | | | |
| List of Attachments Supporting Special Sciencia Contification | | | | | | | | | |
| List of Attachments Supporting Special Seismic Certification | | | | | | | | | |
| Test Report(s) Drawings Calculations Manufacturer's Catalog Other(s) (Please Specify): | | | | | | | | | |
| OSHPD Approval (For Office Use Only) – Approval Expires on December 31, 2019 | | | | | | | | | |
| Signature: Date: 11/5/2013 | | | | | | | | | |
| Print Name: M. R. Karim Title: SHFR | | | | | | | | | |
| Special Seismic Certification Valid Up to : $S_{DS}(g) = 2.0$ $z/h = 1.0$ | | | | | | | | | |
| Condition of Approval (if applicable): | | | | | | | | | |
| | | | | | | | | | |
| | | | | | | | | | |
| "Access to Safe, Quality Healthcare Environments that Meet California's Diverse and Dvnamic Needs" | | | | | | | | | |
| STATE OF CALIFORNIA - HEALTH AND HUMAN SERVICES AGENCY | | | | | | | | | |

Special Seismic Certification

Tested Units



Manufacturer: Tecogen

Product Line: TECOCHILL Natural Gas Engine Driven Chillers (Water Cooled Models)

Tested Product Construction:

Carbon steel vessels and support structure, Cast iron engine block and compressor

Tested Options:

Compressors, heat exchangers, natural gas engine, pressure vessel, control cabinet, expansion valve, coolant pump and acoustic enclosure

Tested Mounting Description:

Flexible (neoprene pads or spring isolators)

Tested Units

| | | Dimensions | | | | | | |
|--------------|-----------------|------------|---------|----------|--------------------------|------------------------------------|-------------------|-------|
| Product Line | Model Number | Depth | Width | Height | Operating Weight (lb) | Mount | Sds (g), z/h=1 | Unit |
| TECOCHILL | CH-150x | 4' 4" | 13' 10" | 7' 1" | 11,750 | Base Mounted (Neoprene) | 2.0 | UUT1a |
| | | | | | | Base Mounted (Spring Isolators) | | UUT1b |
| | СН-400х 6' | 6' 11" 14 | 141.21 | 7' 10.5" | 23,650 | Base Mounted (Neoprene) | 2.0 | UUT2a |
| | | | 14 5 | | | Base Mounted (Spring Isolators) | 2.0 | UUT2b |

Special Seismic Certification Certified Units



Manufacturer: Tecogen

Product Line: TECOCHILL Natural Gas Engine Driven Chillers (Water Cooled Models)

Certified Product Construction:

Carbon steel vessels and support structure, Cast iron engine block and compressor

Certified Options:

Compressors, heat exchangers, natural gas engine, pressure vessel, control cabinet, expansion valve, coolant pump and acoustic enclosure

Certified Mounting Description:

Flexible (neoprene pads or spring isolators)

Certified Units

| | | Dimensions | | | Maximum | | | | | |
|--------------|--|------------|---------|-------------------|---------|--|--------|--------------|--|--------------|
| Product Line | duct Line Model Number Depth Width Height Weight (Ib) | | Mount | Sds (g), z/h=1 | Unit | | | | | |
| | CH-150x | a' a'' | 12' 10" | 7' 1" | 71.41 | 7' 1" | 11 750 | | | UUT1a, UUT1b |
| TECOCHILL | CH-200x | 44 | 13 10 | | 11,750 | Base Mounted (Neoprene and Spring Isolators) | 2.0 | Interpolated | | |
| | CH-300x | 6' 11" | 14' 3" | 7' 10.5" | 23,650 | | | Interpolated | | |
| | CH-350x | | | | | | | Interpolated | | |
| | CH-400x | | | | | | | UUT2a, UUT2b | | |

| Special Seismic Certification (()) DCL Dynamic Certification Laboratories | | | | | | |
|--|---------------------------|--|-----------|--------------------------|-------------------------------|--|
| Manufacturer: Tecogen | | | | | | |
| Manujucturer. Tecogen, T | IIL. | was Chiller (Mater Cooles | Madala) | | | |
| | | Ven Chiller (Water-Cooleu | i Models) | | | |
| Components: Compressor | rs, Heat Exchangers an | | rc | | | |
| | Component | Compresso | 15 | Construction | | |
| Manufacturer Model Number | Manufacturer | Description | Size | Material | Test in UUT | |
| HS 2024 GED | J&E Hall | Compressor | N/A | Cast iron | UUT1a, UUT1b, UUT2a, UUT2b | |
| | | | | | | |
| | | Heat Exchang | gers | | | |
| Manufacturer Model Number | Component Manufacturer | Description | Size | Construction Material | Test in UUT | |
| FF-18144-200 | Henry | Francisco | Smallest | Carbon Steel | UUT1a, UUT1b | |
| FF-30144-200 | Technologies | Evaporator | Largest | Carbon Steel | UUT2a, UUT2b | |
| CC-18144-200 | Henry | Condoncor | Smallest | Carbon Steel | UUT1a, UUT1b | |
| CC-24144-200 | Technologies | Condenser | Largest | Carbon Steel | UUT2a, UUT2b | |
| B-1205-80380 | Thormal Transfor | Engine Dump Heat | Smallest | Carbon Steel | UUT1a, UUT1b | |
| B-1604-90280 | | Exchanger | Largest | Carbon Steel | UUT2a, UUT2b | |
| 9.6 x 13.88 | Tecogen | Exhaust Heat Exchanger | N/A | Stainless Steel | UUT1a, UUT1b, UUT2a, UUT2b | |
| | | | | | | |
| | | Natural Gas Er | ngine | | | |
| Manufacturer Model Number | Component Manufacturer | Description Size Construction Material | | | Test in UUT | |
| TecoDrive 7400 LE | Tecogen | Natual Gas Engine | N/A | Cast Iron | UUT1a, UUT1b, UUT2a, UUT2b | |
| | | | | | | |

| Special Seismic Certification | | | | | | | | |
|-------------------------------|---------------------------|----------------------------|----------------------|--------------------------|-------------------------------|--|--|--|
| | Certified Component List | | | | | | | |
| Manufacturer: Tecogen, Inc. | | | | | | | | |
| Product Line: TECOCHILL I | Natural Gas Engine Dr | riven Chiller (Water-Coole | ed Models) | | | | | |
| Components: Pressure Ve | ssels, Control Cabinet | ts, Expansion Valves, Cool | ant Pumps and Acoust | ic Enclosure | | | | |
| | | Pressure Ve | essel | | | | | |
| Manufacturer Model Number | Component Manufacturer | Test in UUT | | | | | | |
| C-TEC-OF-24055 | Henry | | Smallest | Carbon Steel | UUT1a, UUT1b | | | |
| COS-26105-500 | Technologies | Oil Separator | Largest | Carbon Steel | UUT2a, UUT2b | | | |
| | | • | • | | | | | |
| | | Control Cab | pinet | | | | | |
| Manufacturer Model Number | Component Manufacturer | Description | Size | Construction Material | Test in UUT | | | |
| 79351 | Tasagan | TecoNet Control | Smallest | Steel | UUT1a, UUT1b | | | |
| 79352 | recogen | Panel | Largest | Steel | UUT2a, UUT2b | | | |
| | | • | • | | | | | |
| | | Expansion \ | /alve | | | | | |
| Manufacturer Model Number | Component Manufacturer | Description | Size | Construction Material | Test in UUT | | | |
| 027H4012NA | | E | Smallest | Cast Iron | UUT1a, UUT1b | | | |
| 027H5010NA | Dantoss | Expansion valve | Largest | Cast Iron | UUT2a, UUT2b | | | |
| | | • | • | | | | | |
| | | Coolant Pu | Imp | | | | | |
| Manufacturer Model Number | Component Manufacturer | Description | Size | Construction Material | Test in UUT | | | |
| 15G5-1 1/4, 1 1/2 HP | Durkos | Coolant Dump | Smallest | Cast Iron | UUT1a, UUT1b | | | |
| 20G5-1 1/4, 1 1/2 HP | Burkes | Coolant Pump | Largest | Cast Iron | UUT2a, UUT2b | | | |
| | | | | | | | | |
| | | Acoustic Enc | losure | | | | | |
| Manufacturer Model Number | Component Manufacturer | Description | Size | Construction Material | Test in UUT | | | |
| n/a | Fiberglass Specialties | Acoustic Enclosure | 70.5"Lx46"Wx40"H | Epoxy-glass | UUT1a, UUT1b, UUT2a, UUT2b | | | |
| | | | | | | | | |

| 11 | 11 | D | 0 | Ē. |
|----|---------------|---|---|-----------|
| 11 | \mathcal{P} | υ | | ; |

UNIT UNDER TEST (UUT) Summary Sheet

Manufacturer: Tecogen

Product Line: TECOCHILL Natural Gas Engine Driven Chillers (Water Cooled Models)

Model Number: CH-150x

Product Construction Summary:

Carbon steel vessels and support structure; cast iron engine block and compressor

Options / Component Summary:

Base mounted using neoprene pads. Unit contained a compressor, heat exchangers, natural gas engine, pressure vessel, control cabinet, expansion valve, coolant pump and acoustic enclosure

Note: The UUT was operational before and after shaking and was full of operating content during the tests. The structural integrity of the component attachment system and force-resisting systems was maintained.

| UUT Properties | | | | | | | | | |
|-------------------------|-------------------------|------------|-------|---------|--------|------------|-------------------------------|----------|--|
| Operating Weight | | Dimensions | | | | | Lowest Natural Frequency (Hz) | | |
| (lb) | | | Depth | Width | Height | Front-Back | Side-Side | Vertical | |
| 11,750 | UUT1 | La | 4' 4" | 13' 10" | 7' 1" | 13.8 | 16.0 | 29.8 | |
| | Seismic Test Parameters | | | | | | | | |
| Building Code | Test Criteria | Sds | z/h | lp | Aflx-H | Arig-H | Aflx-V | Arig-V | |
| CBC 2013 | 2012 ICC-ES AC156 | 2.0 | 1.0 | 1.5 | 3.20 | 2.40 | 1.33 | 0.53 | |

Unit Mounting Description:



Unit 1a: Flexible Base Mount with Neoprene - The unit was mounted to the shake table interface frame with 8- ¾" grade 5 bolts on neoprene pads. The neoprene pads were Mason Industries "Super W Pads". Four neoprene pads were used in total, one under each foot. The bolts were torqued to 270 ft*lbs. The shake table interface frame was mounted to the shake table using 20- 1 ¼" threaded rod.

| 11 | DCI |
|------------------|-----|
| \boldsymbol{j} | DUL |

((

UNIT UNDER TEST (UUT) Summary Sheet

Manufacturer: Tecogen

Product Line: TECOCHILL Natural Gas Engine Driven Chillers (Water Cooled Models)

Model Number: CH-150x

Product Construction Summary:

Carbon steel vessels and support structure; cast iron engine block and compressor

Options / Component Summary:

Base mounted using spring isolators. Unit contained a compressor, heat exchangers, natural gas engine, pressure vessel, control cabinet, expansion valve, coolant pump and acoustic enclosure

Note: The UUT was operational before and after shaking and was full of operating content during the tests. The structural integrity of the component attachment system and force-resisting systems was maintained.

| UUT Properties | | | | | | | | | |
|------------------|-------------------------|------------|-------|---------|--------|------------|-------------------------------|----------|--|
| Operating Weight | | Dimensions | | | | | Lowest Natural Frequency (Hz) | | |
| (lb) | | | Depth | Width | Height | Front-Back | Side-Side | Vertical | |
| 11,750 | UUT1 | b | 4' 4" | 13' 10" | 7' 1" | 2.8 | 2.3 | 4.5 | |
| | Seismic Test Parameters | | | | | | | | |
| Building Code | Test Criteria | Sds | z/h | lp | Aflx-H | Arig-H | Aflx-V | Arig-V | |
| CBC 2013 | 2012 ICC-ES AC156 | 2.0 | 1.0 | 1.5 | 3.20 | 2.40 | 1.33 | 0.53 | |

Unit Mounting Description:



Unit 1b: Flexible Base Mount with Spring Isolators - Four Mason Industries Seismic Spring Mounts (two SLFADA 109's and two SLFADA 107's) were mounted to the shake table interface frame using 4- ¾" grade 5 bolts for each isolator. A riser HSS tube (10x4x5/8") was bolted to the two isolators situated under each respective side of the unit. The connection to the riser HSS tube from the isolators was 2- ¾" grade 5 bolts. The UUT was then bolted to the riser HSS tube using 2-3/4" grade 5 bolts. The shake table interface frame was mounted to the shake table using 20-1 ¼" threaded rod. (Note: acoustic enclosure cover was removed for the photograph.)

| 11 | | |
|----|---|--|
|)) | U | |

((

UNIT UNDER TEST (UUT) Summary Sheet

Manufacturer: Tecogen

Product Line: TECOCHILL Natural Gas Engine Driven Chillers (Water Cooled Models)

Model Number: CH-400x

Product Construction Summary:

Carbon steel vessels and support structure; cast iron engine block and compressor

Options / Component Summary:

Base mounted using neoprene pads. Unit contained a compressor, heat exchangers, natural gas engine, pressure vessel, control cabinet, expansion valve, coolant pump and acoustic enclosure

Note: The UUT was operational before and after shaking and was full of operating content during the tests. The structural integrity of the component attachment system and force-resisting systems was maintained.

| UUT Properties | | | | | | | | | |
|--------------------------|----------------------|-----|--------|--------|----------|-------------------------------|-----------|----------|--|
| Operating Weight (lb) | Dimensions | | | | | Lowest Natural Frequency (Hz) | | | |
| | | | Depth | Width | Height | Front-Back | Side-Side | Vertical | |
| 23,650 | UUT2a | | 6' 11" | 14' 3" | 7' 10.5" | 12.8 | 9.5 | 16.8 | |
| Seismic Test Parameters | | | | | | | | | |
| Building Code | Test Criteria | Sds | z/h | lp | Aflx-H | Arig-H | Aflx-V | Arig-V | |
| CBC 2013 | 2012 ICC-ES AC156 | 2.0 | 1.0 | 1.5 | 3.20 | 2.40 | 1.33 | 0.53 | |

Unit Mounting Description:



Unit 2a: Flexible Base Mount with Neoprene - The unit was mounted to the shake table interface frame with 8-7/8" grade 5 bolts on neoprene pads. The neoprene pads were Mason Industries "Super W Pads". Neoprene pads were used the full length of each foot. The bolts were torqued to 430 ft*lbs. The shake table interface frame was mounted to the shake table using 20-1 ¼" threaded rod.

UUT2b

| 11 | 11 | П | Ĕ. |
|----|---------------|---|----|
| 11 | \mathcal{P} | υ | |

UNIT UNDER TEST (UUT) Summary Sheet

Manufacturer: Tecogen

Product Line: TECOCHILL Natural Gas Engine Driven Chillers (Water Cooled Models)

Model Number: CH-400x

Product Construction Summary:

Carbon steel vessels and support structure; cast iron engine block and compressor

Options / Component Summary:

Base mounted using spring isolators. Unit contained a compressor, heat exchangers, natural gas engine, pressure vessel, control cabinet, expansion valve, coolant pump and acoustic enclosure

Note: The UUT was operational before and after shaking and was full of operating content during the tests. The structural integrity of the component attachment system and force-resisting systems was maintained.

| UUT Properties | | | | | | | | | |
|--------------------------|----------------------|-----|--------|--------|----------|-------------------------------|-----------|----------|--|
| Operating Weight (Ib) | Dimensions | | | | | Lowest Natural Frequency (Hz) | | | |
| | | | Depth | Width | Height | Front-Back | Side-Side | Vertical | |
| 23,650 | UUT2b | | 6' 11" | 14' 3" | 7' 10.5" | 3.0 | 2.5 | 4.5 | |
| Seismic Test Parameters | | | | | | | | | |
| Building Code | Test Criteria | Sds | z/h | lp | Aflx-H | Arig-H | Aflx-V | Arig-V | |
| CBC 2013 | 2012 ICC-ES AC156 | 2.0 | 1.0 | 1.5 | 3.20 | 2.40 | 1.33 | 0.53 | |

Unit Mounting Description:



Unit 2b: Flexible Base Mount with Spring Isolators - Four Mason Industries Seismic Spring Mount SLFADA 112's were mounted to the shake table interface frame using 4- ¾" grade 5 bolts for each isolator. A riser HSS tube (12x4x5/8") was bolted to the two isolators situated under each respective side of the unit. The connection to the riser HSS tube from the isolators was 4- ¾" grade 5 bolts. The UUT was then bolted to the riser HSS tube using 2 -7/8" grade 5 bolts. The shake table interface frame was mounted to the shake table using 20- 1 ¼" threaded rod.