

APPLICATION FOR OSHPD SPECIAL SEISMIC CERTIFICATION PREAPPROVAL (OSP)		
	APPLICATION #:	OSP – 0369
OSHPD Special Seismic Certification Preapproval (OSP)		
Type: New Renewal Manufacturer Information		
manufacturer information		
Manufacturer:		
Manufacturer's Technical Representative:Peter Hansel		
Mailing Address:15 Kit Street, Keene, NH 03431		
Telephone: (603) 352-5500	el@filtrine.com	
Product Information	MD,	
Product Name: PCP Closed Loop Process Liquid Chillers PD	T	
Product Type: Mechanical Equipment OSP-0369	- CFR	
Product Model Number: See attached (List all unique product identification numbers and/or part numbers) General Description: of Compressors, condenser, evaporator, pump, fan motor, and cooling test units and modifications required to address the anomalies observ productions units.	ooled models for outdoor	nancements made to the
Mounting Description: Units are rigid base mounted	20	
Op.	ODE	
Applicant Information		
Applicant Company Name: The VMC Group		
Contact Person: John Giuliano		
Mailing Address: 113 Main Street, Bloomingdale, NJ 07403		
Telephone: (973) 838-1780 Email: john.gi	uliano@thevmcgroup.co	m
I hereby agree to reimburse the Office of Statewide Health F accordance with the California Administrative Code, 2016. Signature of Applicant:	Date:	pment review fees in
Title: President Company Name: The VI	MC Group	
"Access to Safe, Quality Healthcare Environments that Meet California's Diverse and Dynamic Needs"	AMAMAMA	USHPD
STATE OF CALIFORNIA – HEALTH AND HUMAN SERVICES AGENCY	Leak hele the	Dere 1 of 2

Page 1 of 3

OSH-FD-759 (REV 12/16/15) 11/25/2020



California Licensed Structural Engineer Responsible for the Engineering and Test Report(s)
Company Name:The VMC Group
Name: Kenneth Tarlow California License Number: SE-2851
Mailing Address:113 Main Street, Bloomingdale, NJ 07403
Telephone: _(973) 838-1780 Email: <u>ken.tarlow@thevmcgroup.com</u>
Supports and Attachments Preapproval
 Supports and attachments are preapproved under OPM- (Separate application for OSHPD Preapproval of Manufacturer's Certification (OPM) of Supports and attachments is required) Supports and attachments are not preapproved
Certification Method
 Testing in accordance with: ICC-ES AC156 Other (Please Specify): OSP-0369
BY:Timothy J Piland
Testing Laboratory DATE: 11/25/2020
Company Name: DCL Labs
Contact Name: Josh Sailer, Laboratory Manager
Mailing Address:1315 Greg Street, Suite 109, Sparks, NV 89431
Telephone: (775) 358-5085 Email: josh@shaketest.com

"Access to Safe, Quality Healthcare Environments that Meet California's Diverse and Dynamic Needs"



Page 2 of 3

OFFICE OF STATEWIDE HEALTH PLANNING AND DEVELOPMENT FACILITIES DEVELOPMENT DIVISION

Seismic Parameters
Design in accordance with ASCE 7-10 Chapter 13: 🖂 Yes 🔲 No
Design Basis of Equipment or Components (Fp/Wp) = <u>1.15</u>
S_{DS} (Design spectral response acceleration at short period, g) = <u>1.60</u>
a _p (In-structure equipment or component amplification factor) = <u>1.0</u>
R _p (Equipment or component response modification factor) = <u>2.5</u>
Ω_0 (System overstrength factor) = _2
I _p (Importance factor) = 1.5
z/h (Height factor ratio) = _1
Equipment or Component Natural Frequencies (Hz) = <u>See attachment</u>
Overall dimensions and weight (or range thereof) = See attachment
Equipment or Components @ grade designed in accordance with ASCE 7-10 Chapter 15: 🗌 Yes 🛛 No
Design Basis of Equipment or Components (V/W) =
S _{DS} (Design spectral response acceleration at short period, g) =
S _{D1} (Design spectral response acceleration at 1 second period, g) =
R (Response modification coefficient) =
Ω₀ (System overstrength factor) =
C₄ (Deflection amplification factor) =
I _P (Importance factor) = 1.5 DATE: 11/25/2020
Height to Center of Gravit <mark>y above</mark> base =
Equipment or Component Natural Frequencies (Hz) =
Overall dimensions and weight (or range thereof) =
Tank(s) designed in accordance with ASME BPVC, 2015: 🔲 Yes 🖾 No
List of Attachments Supporting Special Seismic Certification
⊠ Test Report(s) ⊠ Drawings □ Calculations ⊠ Manufacturer's Catalog □ Other(s) (Please Specify):
OSHPD Approval (For Office Use Only) – Approval Expires on December 31, 2025
1.1.1.00
Signature: Date: Date: November 25, 2020
Print Name:Timothy J. Piland Title:SSE
Special Seismic Certification Valid Up to: S _{DS} (g) = <u>1.60</u> z/h = <u>1</u>
Condition of Approval (if applicable):
"Access to Safe, Quality Healthcare Environments that Meet California's Diverse and Dynamic Needs"
TATE OF CALIFORNIA – HEALTH AND HUMAN SERVICES AGENCY DSH-FD-759 (REV 12/16/15) Page 3 of 3

STATE OF CALIFORNIA - HEALTH AND HUMAN SERVICES AGENCY OSH-FD-759 (REV 12/16/15)

Table 1 - Certified Units

Manufacturer: Filtrine

Product Line: PCP Closed Loop Process Liquid Chillers

Certification Level: $S_{DS} = 1.60g$, z/h=1.0



	Di	Dimensions (in)		Maximum		
Model Number	Length	Depth	Height	Operating Weight (Ib)	Mount	Unit
PCP-200-33A-WP-OSP	62	27	66	1,170		UUT1
PCP-300G-36A-WP-OSP	72	32	75	1,400		Interpolated
PCP-300S-38A-WP-OSP	72	32	75	1,400		Interpolated
PCP-300G-40A-WP-OSP	72	32	75	1,400		Interpolated
PCP-300G-44A-WP-OSP	72	32	75	1,400		Interpolated
PCP-500G-48A-WP-OSP	82	35	77	1,800		Interpolated
PCP-500G-60A-WP-OSP	82	35	77	1,800		Interpolated
PCP-500S-62A-WP-OSP	82	35	R720	DF 1,800		Interpolated
PCP-500G-70A-WP-OSP	82	35	77	1,800		Interpolated
PCP-750G-80A-WP-OSP	119	39	77	2,200	Rigid base mount	Interpolated
PCP-750G-96A-WP-OSP	119	39	77	2,200	Rigid base mount	Interpolated
PCP-750S-98A-WP-OSP	119	39	77	2,200	10	Interpolated
PCP-1000G-122A-WP-OSP	119	49	DSP-(363,000	m	Interpolated
PCP-1000S-140A-WP-OSP	119	49	83	3,000		Interpolated
PCP-1500S-180A-WP-OSP	140	52	83	D 3,500		Interpolated
PCP-2000-230A-WP-OSP	140	52	85	4,000		Interpolated
PCP-2000S-230A-WP-OSP	<u>140</u>	52	85	4,600		Interpolated
PCP-2500-270A-WP-OSP	140	D ₅₂ TE:	118525	2024,800		Interpolated
PCP-2500S-270A-WP-OSP	140	52	85	4,800	5	Interpolated
PCP-3000-330A-WP-OSP	140	52	85	5,420	0	UUT2





Variable	Definition	Allowable Value	Allowable Value Description
А	Equipment type	PC	Process chiller
В	Pump type	Р	Circulating pump
С	Nominal compressor horsepower times 100	200 - 3000	2 to 30 nominal compressor horsepower
		G	Scroll compressor
D	Compressor type	S	Semi-hermetic compressor
		_	Combination of scroll and semi-hermetic compressors
E	Nominal MBTU/hr rating at 68°F discharge water temperature	33 - 330 FOR CI	33 to 330 nominal-MBTU/hr rating at 68°F discharge water temperature
F	Condenser type	A	Air cooled condenser
G	Enclosure type	WP	Weather resistant for outdoor use
Н	OSHPD unit	OSP	Designed specifically for OSHPD OSP certification



Table 3 - Certified Subcomponents



Manufacturer: Filtrine
Product Line: PCP Closed Loop Process Liquid Chillers

Components: Scroll compressors and semi-hermetic compressors

Certification Level: $S_{DS} = 1.60g$, z/h=1.0

Compressor - Scroll				
Model Number	Manufacturer	Description	Unit	
ZB21KCE-TFJ	Copeland	230V	UUT1	
ZB21KCE-TF(*)	Copeland		Interpolated	
ZB26KCE-TF(*)	Copeland		Interpolated	
ZB30KCE-TF(*)	Copeland		Interpolated	
ZB38KCE-TF(*)	Copeland		Interpolated	
ZB45KCE-TF(*)	Copeland	230V-460V	Interpolated	
ZB50KCE-TF(*)	Copeland		Interpolated	
ZB66KCE-TF(*)	Copeland		Interpolated	
ZB76KCE-TF(*)	Copeland ODF		Interpolated	
ZB76KCE-TFD	Copeland	460V	UUT2	

*insert voltage code J, V, D, 5, for 220-240, 200, 380-420, and 200-220 motor voltage

Compressor - Semi-Hermetic				
Old Model Number	New Model Number	Manufacturer	Description	Unit
2C0278SH	2HES-2	Bitzer P-030	208-230V/3Ph	UUT1
N/A	2EES- <mark>2</mark>	Bitzer		Interpolated
N/A	2HES <mark>-3</mark>	By TirBitzer NV J F	Piland	Interpolated
2C0484SH	2EES <mark>-3</mark>	Bitzer		Interpolated
4C0770SH	4FES- <mark>5</mark>	Bitzer		Interpolated
4C1145SH	4DES-7	DATE: Bitzer/25/20	208-230V/440-480V/3Ph	Interpolated
N/A	4PE-12	Bitzer		Interpolated
4C1761PH	4TE-12	Bitzer		Interpolated
4C2067PH	4PE-15	Bitzer		Interpolated
N/A	4JE-15	Bitzer	Dr	Interpolated
N/A	4HE-18	Bitzer	G CODE.	Interpolated
4C2397PH	4NE-20	Bitzer		Interpolated
4B2707PH	4JE-22	Bitzer		Interpolated
4B3139PH	4HE-25	Bitzer	440-480V/3Ph	UUT2

Table 4 - Certified Subcomponents



Manufacturer: Filtrine Product Line: PCP Closed Loop Process Liquid Chillers Components: Condensers, evaporators, pumps **Certification Level:** $S_{DS} = 1.60g$, z/h=1.0

Condenser				
Model Number	Manufacturer	Description	Unit	
KCM009A-T3A-A11H	Keeprite	208/230V	UUT1	
KCM009A-T(*)A-A11H	Keeprite		Interpolated	
KCM010A-T(*)A-A11H	Keeprite		Interpolated	
KCM011A-T(*)A-A11H	Keeprite		Interpolated	
KCM012A-T(*)A-A11H	Keeprite		Interpolated	
KCM013A-T(*)A-A12H	Keeprite		Interpolated	
KCM014A-T(*)A-A12H	Keeprite		Interpolated	
KCM016A-T(*)A-A12H	Keeprite	208/230V to 460V	Interpolated	
KCM017A-T(*)A-A12H	Keeprite ODF		Interpolated	
KCM018A-T(*)A-A12H	Keeprite		Interpolated	
KCM020A-T(*)A-A12H	Keeprite		Interpolated	
ксмо21а-т(*)а-а12н	Keeprite		Interpolated	
KCM022A-T(*)A-A12H	Keeprite	2	Interpolated	
KCM024A-T(*)A-A12H	Keeprite		Interpolated	
KCM028A-T(*)A-A13H	Keeprite	9	Interpolated	
KCM030A-T(*)A-A13H	Keeprite		Interpolated	
KCM032A-T(*)A-A13H	BY: Keeprite V J	Piland	Interpolated	
КСМ032А-Т4А-А13Н	Keeprite	460V	UUT2	
* insert voltage code 3 or 4, for 208/230V or 460V DATE: 11/25/2020				

C Evaporator			
Model Number	Component Manufacturer	Description	Unit
80' x 1" S/S tubing	Filtrine	4:	UUT1
< 80' and > 135' of 3/4" S/S tubing	Filtrine		Interpolated
< 80' and > 600' of 1" S/S tubing	Filtrine	Stainless steel tubing	Interpolated
600' x 1" S/S tubing	Filtrine		UUT2
CH5	Kelvion ¹	5"x20" brazed plate	UUT2 ²

1. Was GEA Heat Exchangers

2. Manufacturing process is ISO 9001 certified

Pump				
Manufacturer Model Number	Manufacturer	Description	Unit	
SSPC1, 1 hp	American Stainless Pump	6" stainless steel casing	UUT1	
SSPC1, 1.5 hp	American Stainless Pump	6" stainless steel casing	Interpolated	
SSPC1, 2 hp	American Stainless Pump	6" stainless steel casing	Interpolated	
7SP, 3 hp	American Stainless Pump	7" stainless steel casing	Interpolated	
7SP, 5 hp	American Stainless Pump	7" stainless steel casing	UUT2	

Table 5 - Certified Subcomponents



Manufacturer: Filtrine

Product Line: PCP Closed Loop Process Liquid Chillers

Components: Fan motors, control transformers

Certification Level: $S_{DS} = 1.60g$, z/h=1.0

Fan Motor			
Model Number	Manufacturer	Description	Unit
3/4 hp 208-230/60/3 1075 rpm	Marathon	3/4 hp	UUT1
3/4 hp 460/60/3 1075 rpm	Marathon	3/4 hp	UUT2

Control Transformer				
Manufacturer Model Number	Manufacturer	Description	Unit	
AE070150	Acme Transformer	208/230/460	UUT1	
AE070250	Acmo Transformor	Pri 120 sec 208/230/460	UUT2	
AE070250	Acme Transformer	Pri 120 sec	0012	



Table 6 - Tested Units

Manufacturer: Filtrine

Product Line: PCP Closed Loop Process Liquid Chillers



Model Number	Dimensions			Operating	Mount	Sds (g),	Unit
	Length	Depth	Height	Weight (lb)	Wount	z/h=1	Omit
PCP-200-33A-WP-OSP	62	27	66	1,170	Rigid base mounted	2.0	UUT1
PCP-3000-330A-WP-OSP	140	52	85	5,420	Rigiu base mounted	1.6	UUT2



UUT1

UNIT UNDER TEST (UUT) Summary Sheet



Manufacturer: Filtrine

Product Line: PCP Closed Loop Process Liquid Chillers

Model Number: PCP-200-33A-WP-OSP

Product Construction Summary:

Cabinet constructed of anodized aluminum panels with stainless steel corner legs and top on a welded angle iron frame. Welded stainless steel cooling tank shell and immersion coil evaporator. Stainless steel centrifugal pump mounted on rubber pads over a stainless steel condensation tray.

Options / Component Summary:

Rigid base mounted. The unit was a weather-resistant, air-cooled model for outdoor installation and contained compressors, condenser, evaporator, pump, fan, motor and control transformer.

Note: The UUT was operational before and after shaking and was full of operating content during the tests. The structural integrity of the component attachment system and force-resisting systems was maintained.

			UU	T Properties					
Operating Weight		Dimensions (inches)					Lowest Natural Frequency (Hz)		
(lb)			Length	Depth	Height	Front-Back	Side-Side	Vertical	
1,170	UUT	L	62	27	66	14.0	11.5	15.8	
Seismic Test Parameters									
Building Code	Test Criteria	Sds (g)	z/h	lp	Aflx-H (g)	Arig-H (g)	Aflx-V (g)	Arig-V (g)	
CBC 2016	ICC-ES AC156	2.0	1.0 🔘	SP1.536	9 3.20	2.40	1.33	0.53	
		(), (,),			<u>A FORTA A A A A A A A A A A A A A A A A A A </u>		-		

Unit Mounting Description:

BY:Timothy J Piland



The unit was rigid-base mounted to the shake table interface plate with six (6) 3/8-inch diameter Grade 5 bolts spaced at 25" in length and 29" in depth on center. For each mounting bolt, a 1-inch diameter carbon steel pipe was placed under the channel and the mounting bolt was passed through the pipe for support.

UNIT UNDER TEST (UUT) Summary Sheet



Manufacturer: Filtrine

Product Line: PCP Closed Loop Process Liquid Chillers

Model Number: PCP-3000-330A-WP-OSP

Product Construction Summary:

Cabinet constructed of anodized aluminum panels with stainless steel corner legs and top on a welded angle iron frame. Welded stainless steel cooling tank shell and immersion coil evaporator. Stainless steel centrifugal pump mounted on rubber pads over a stainless steel condensation tray.

Options / Component Summary:

Rigid base mounted. The unit was a weather-resistant, air-cooled model for outdoor installation and contained compressors, condenser, evaporator, pump, fan, motor and control transformer.

Note: The UUT was operational before and after shaking and was full of operating content during the tests. The structural integrity of the component attachment system and force-resisting systems was maintained.

			UUT	Properties					
Operating Weight (Ib)	Dimensions (inches)					Lowest Natural Frequency (Hz)			
			Length	Depth	Height	Front-Back	Side-Side	Vertical	
5,420	UUT2	2	140	52	85	4.8	3.8	6.3	
Seismic Test Parameters									
Building Code	Test Criteria	Sds (g)	z/h	lp	Aflx-H (g)	Arig-H (g)	Aflx-V (g)	Arig-V (g)	
CBC 2016	ICC-ES AC156	1.6	1.0 🔘	SP1.536	9 2.56	1.92	1.07	0.43	

Unit Mounting Description:

BY:Timothy J Piland



The unit was rigid-base mounted to the shake table interface plate with ten (10) 1/2-inch diameter Grade 5 bolts spaced at 32" in length and 54" in depth on center. For each mounting bolt, a 1-inch diameter carbon steel pipe was placed under the channel and the mounting bolt was passed through the pipe for support.