



OFFICE OF STATEWIDE HEALTH PLANNING AND DEVELOPMENT
FACILITIES DEVELOPMENT DIVISION

**APPLICATION FOR OSHPD SPECIAL SEISMIC
CERTIFICATION PREAPPROVAL (OSP)**

OFFICE USE ONLY

APPLICATION #: OSP – 0377 – 10

OSHPD Special Seismic Certification Preapproval (OSP)

Type: New Renewal

Manufacturer Information

Manufacturer: Eltek

Manufacturer's Technical Representative: Larry Lutz

Mailing Address: 2925 E. Plano Parkway, Plano, TX 75074

Telephone: (469) 330-9100 Email: Larry.Lutz@eltek.com

Product Information

Product Name: IBB-250WM and WME Battery Charger System

Product Type: Battery charger

Product Model Number: IBB-250WM and IBB-250WME (see Table 1 for specific model numbers)
(List all unique product identification numbers and/or part numbers)

General Description: Wall mounted battery charger system with 24VDC-140VDC output

Mounting Description: Rigid wall mounted

Applicant Information


Applicant Company Name: Tobolski Watkins Engineering, Inc.

Contact Person: Matthew Tobolski, PhD, SE

Mailing Address: 9246 Lightwave Ave, Suite 140, San Diego, CA 92123

Telephone: (858) 381-5843 Email: mtobolski@tobolskiwatkins.com


I hereby agree to reimburse the Office of Statewide Health Planning and Development review fees in accordance with the California Administrative Code, 2013.

Signature of Applicant:  Date: 12/24/13

Title: President and CEO Company Name: Tobolski Watkins Engineering, Inc.

"Access to Safe, Quality Healthcare Environments that Meet California's Diverse and Dynamic Needs"

STATE OF CALIFORNIA – HEALTH AND HUMAN SERVICES AGENCY
OSH-FD-759 (REV 1/24/13)



osHPD

Page 1 of 3



OFFICE OF STATEWIDE HEALTH PLANNING AND DEVELOPMENT FACILITIES DEVELOPMENT DIVISION

California Licensed Structural Engineer Responsible for the Engineering and Test Report(s)

Company Name: Tobolski Watkins Engineering, Inc.

Name: Matthew Tobolski, PhD, SE California License Number: S 5648

Mailing Address: 9246 Lightwave Avenue, Suite 140, San Diego, CA 92123

Telephone: (858) 381-5843 Email: mtobolski@tobolskiwatkins.com

Supports and Attachments Preapproval

- Supports and attachments are preapproved under OPM- _____
(Separate application for OSHPD Preapproval of Manufacturer's Certification (OPM) of Supports and attachments is required)
- Supports and attachments are not preapproved

Certification Method

- Testing in accordance with: ICC-ES AC156
- Other (Please Specify): _____

Testing Laboratory

Company Name: National Technical Systems (NTS)


Contact Name: Don Bennett

Mailing Address: 1536 E. Valencia, Fullerton, CA 92831

Telephone: (714) 879-6110 Email: Don.Bennett@nts.com

"Access to Safe, Quality Healthcare Environments that Meet California's Diverse and Dynamic Needs"

STATE OF CALIFORNIA – HEALTH AND HUMAN SERVICES AGENCY
OSH-FD-759 (REV 1/24/13)



osHPD

Page 2 of 3

Seismic Parameters

03/13/2014

OSP-0377-10

Page 2 of 7



OFFICE OF STATEWIDE HEALTH PLANNING AND DEVELOPMENT FACILITIES DEVELOPMENT DIVISION

Design in accordance with ASCE 7-10 Chapter 13: Yes No

Design Basis of Equipment or Components (F_p/W_p) = 1.88

S_{DS} (Design spectral response acceleration at short period, g) = 2.50

a_p (In-structure equipment or component amplification factor) = 2.5

R_p (Equipment or component response modification factor) = 6.0

Ω_0 (System overstrength factor) = 2.5

I_p (Importance factor) = 1.5

z/h (Height factor ratio) = 1.0

Equipment or Component Natural Frequencies (Hz) = See attachments

Overall dimensions and weight (or range thereof) = See attachments

Equipment or Components @ grade designed in accordance with ASCE 7-10 Chapter 15: Yes No

Design Basis of Equipment or Components (V/W) = _____

S_{DS} (Design spectral response acceleration at short period, g) = _____

S_{D1} (Design spectral response acceleration at 1 second period, g) = _____

R (Response modification coefficient) = _____

Ω_0 (System overstrength factor) = _____

C_d (Deflection amplification factor) = _____

I_p (Importance factor) = 1.5

Height to Center of Gravity above base = _____

Equipment or Component Natural Frequencies (Hz) = _____

Overall dimensions and weight (or range thereof) = _____

Tank(s) designed in accordance with ASME BPVC, 2010: Yes No

List of Attachments Supporting Special Seismic Certification

Test Report(s) Drawings Calculations Manufacturer's Catalog

Other(s) (Please Specify): Attachments

OSHPD Approval (For Office Use Only) – Approval Expires on December 31, 2019

Signature:  Date: 3/13/14

Print Name: M. R. Karim Title: SHFR

Special Seismic Certification Valid Up to : S_{DS} (g) = 2.5 z/h = 1.0

Condition of Approval (if applicable): _____






Table 1

Special Seismic Certification Certified Product Matrix

TWEI Project No.: 2013-0737-CO-001

Manufacturer: Eltek, Inc.

Model Line: IBB-250 WM and WME Battery Charger System

Certified Product Construction Summary:

Cabinet is constructed of painted galvanized steel. NEMA 1 rated.

Certified Options Summary:

Output voltage: shown in model number

Input voltage: 1 ϕ -120/208/240V, 3 ϕ -208/240V (phase shown in model number)

Internal component options are shown in Table 2

Certified Mounting Summary:

Rigid wall. SEOR to design anchorage.

Building Code: CBC 2013

Seismic Certification Limits:

$S_{DS} = 2.50g$

$z/h = 1.0$

$I_p = 1.5$

Model Line	Model	Dimension (in)			Weight (lb)	Notes	UUT
		Depth	Width	Height			
IBB-250WM	301300*: 1 ϕ /48V	18.0	16.8	22.6	151		1
	325058*: 1 ϕ /48V						
	301301*: 1 ϕ /24V						
	325059*: 1 ϕ /24V						
	301302*: 1 ϕ /140V						
	310118*: 1 ϕ /140V						
	311912*: 1 ϕ /140V						
	301303*: 3 ϕ /48V						
	325060*: 3 ϕ /48V						
	301304*: 3 ϕ /24V						
	325061*: 3 ϕ /24V						
	301305*: 3 ϕ /140V						
	320361*: 3 ϕ /140V						
IBB-250WME	301306*: 1 ϕ /140V	18.0	16.8	34.8	180		
	301307*: 3 ϕ /140V						2

* Model may contain additional nomenclature to reflect software configurations

© 2010 Tobolski Watkins Engineering, Inc.



Table 2

Special Seismic Certification Certified Product Matrix

TWEI Project No.: 2013-0737-CO-001

Manufacturer: Eltek, Inc.

Model Line: IBB-250 WM and WME Battery Charger System – Subcomponents

Certified Product Construction Summary:
N/A

Certified Options Summary:
Specific internal component options are listed herein.

Certified Mounting Summary:
Subcomponents are installed within charger cabinet.

Building Code: CBC 2013 **Seismic Certification Limits:** $S_{DS} = 2.50g$ $z/h = 1.0$ $I_p = 1.5$

Model Line	Model	Dimension (in)			Weight (lb)	Notes	UUT
		Depth	Width	Height			
Eaton Corporation Circuit Breakers	EGB3030FFG						
	EGB3050FFG						
	EGB2050FFG						
	EGB2080FFG						
	EGB3100FFG						
	EGB2100FFG						1,1
	JGE2150FAG						
	JGE3175FAG						2
	JGE2250FAG						2
Eltek, Inc. Smartpack2 I/O Monitor2	242100.500					Smartpack2 Master	1,2
	242100.501					Smartpack2 Basic	1
	242100.601					Smartpack2 Basic Industrial	2
	242100.502					I/O monitor	1,2
	242100.300					Battery monitor	1,2
	242100.301					Load monitor	1,2
Eltek, Inc. Flatpack2 Rectifiers	241115.205B						
	241115.205						
	241115.250						
	241115.705B						
	241115.705						1
	241115.805B						
	241115.805						
241119.805						2	

© 2010 Tobolski Watkins Engineering, Inc.



UUT – 1

UNIT UNDER TEST (UUT) Summary Sheet

TWEI Project No.: 2013-0737-CO-001

Manufacturer: Eltek, Inc.

Model Line: IBB-250 WM and WME Battery Charger System

Model Number: 301300 – IBB-250WM

Product Construction Summary:
Cabinet is constructed of painted galvanized steel. NEMA 1 rated.

Options/Subcomponent Summary:
1φ-48V output; 1φ-120/208/240V input; (2) Eaton Corporation Breakers: EBG2100FFG; (1) Eltek Smartpack2 Master (242100.500); (1) Eltek Smartpack2 Basic: 242100.501; (1) Eltek Smartpack2 I/O Monitor: 242100.502; (1) Eltek Smartpack2 Battery Monitor: 242100.300; (1) Eltek Smartpack2 Load Monitor: 242100.301; (6) Eltek Rectifiers: 241115.705

UUT Properties

Weight (lb)	Dimensions (in)			Lowest Natural Frequency (Hz)		
	Depth	Width	Height	Front-Back	Side-Side	Vertical
110	18.0	16.8	22.6	N/A	N/A	N/A

UUT Highest Passed Seismic Run Information

Building Code	Test Criteria	S _{DS}	z/h	I _p	A _{FLX-H}	A _{RIG-H}	A _{FLX-V}	A _{RIG-V}
CBC 2013	ICC-ES AC 156	2.50g	1.0	1.5	4.00g	3.00g	1.67g	0.67g

Test Mounting Details:



Mounted to test fixture using (4) 3/8" x 1" long lag bolts. Test fixture mounted to table using (16) 1/2" Grade 8 bolts. Unit maintained structural integrity and remained functional per manufacturer requirement. Contents were included in testing per operating conditions.

© 2010 Tobolski Watkins Engineering, Inc.



UUT – 2

UNIT UNDER TEST (UUT) Summary Sheet

TWEI Project No.: 2013-0737-CO-001

Manufacturer: Eltek, Inc.

Model Line: IBB-250 WM and WME Battery Charger System

Model Number: 301307 – IBB-250WME

Product Construction Summary:
Cabinet is constructed of painted galvanized steel. NEMA 1 rated.

Options/Subcomponent Summary:
1 ϕ -140V output; 3 ϕ -208/240V input; (2) Eaton Corporation Breakers: JGE3175FAG and JGE2250FAG; (1) Eltek Smartpack2 Master: 242100.500; (1) Eltek Smartpack2 Basic Industrial: 242100.601; (1) Eltek Smartpack2 I/O Monitor: 242100.502; (1) Eltek Smartpack2 Battery Monitor: 242100.300; (1) Eltek Smartpack2 Load Monitor: 242100.301; (10) Eltek Rectifiers: 241119.805

UUT Properties

Weight (lb)	Dimensions (in)			Lowest Natural Frequency (Hz)		
	Depth	Width	Height	Front-Back	Side-Side	Vertical
180	18.0	16.8	34.8	N/A	N/A	N/A

UUT Highest Passed Seismic Run Information

Building Code	Test Criteria	S _{DS}	z/h	I _p	A _{FLX-H}	A _{RIG-H}	A _{FLX-V}	A _{RIG-V}
CBC 2013	ICC-ES AC 156	2.50g	1.0	1.5	4.00g	3.00g	1.67g	0.67g

Test Mounting Details:



Mounted to test fixture using (6) 3/8" x 1" long lag bolts. Test fixture mounted to table using (16) 1/2" Grade 8 bolts. Unit maintained structural integrity and remained functional per manufacturer requirement. Contents were included in testing per operating conditions.

© 2010 Tobolski Watkins Engineering, Inc.