



DEPARTMENT OF HEALTH CARE ACCESS AND INFORMATION  
OFFICE OF STATEWIDE HOSPITAL PLANNING AND DEVELOPMENT

APPLICATION FOR HCAI SPECIAL SEISMIC  
CERTIFICATION PREAPPROVAL (OSP)

OFFICE USE ONLY

APPLICATION #: OSP-0405

HCAI Special Seismic Certification Preapproval (OSP)

Type: ☐ New ☒ Renewal

Manufacturer Information

Manufacturer: Eaton Corporation

Manufacturer's Technical Representative: Steven Solloway

Mailing Address: 3301 Spring Forest Road, Raleigh, NC 27616

Telephone: (919) 561-3137

Email: stevensolloway@eaton.com

Product Information

Product Name: 93PM and 93PM-L

Product Model Number(s): Varies (see attachment)

Product Category: UPS and Batteries

Product Sub-Category: UPS

General Description: 50-400 kVA UPS

Mounting Description: Base Mounted Rigid -

Tested Seismic Enhancements: Seismic enhancements made to the test units and/or modifications required to address anomalies during the tests shall be incorporated into the production units.

Applicant Information

Applicant Company Name: TRU Compliance, by Structural Integrity Associates

Contact Person: Daniel Zentner

Mailing Address: 233 SW Wilson Ave, Suite 101, Bend, OR 97702

Telephone: (541) 292-5839

Email: dzentner@structint.com

Title: Program Manager



**DEPARTMENT OF HEALTH CARE ACCESS AND INFORMATION  
OFFICE OF STATEWIDE HOSPITAL PLANNING AND DEVELOPMENT**

**California Licensed Structural Engineer Responsible for the Engineering and Test Report(s)**

Company Name: STRUCTURAL INTEGRITY ASSOCIATES, INC.

Name: LACHEZAR HANDZHIYSKI

California License Number: S6515

Mailing Address: 5215 Hellyer Avenue, Suite 210, San Jose, CA 95138

Telephone: (669) 437-0200

Email: Lhandzhiyski@StructInt.com

**Certification Method**

☐ GR-63-Core

☒ ICC-ES AC156

☐ IEEE 344

☐ IEEE 693

☐ NEBS 3

☐ Other (Please Specify): \_\_\_\_\_

**Testing Laboratory**

Company Name: AREVA TECHNICAL CENTER

Contact Person: Daniel Fort

Mailing Address: 1724 Mount Athos Road, Lynchburg VA 24504

Telephone: (434) 832-3816

Email: Daniel.Fort@AREVA.com

Company Name: CLARK TESTING LABORATORY, INC.

Contact Person: Devon Lohr

Mailing Address: 1801 Route 51, Jefferson Hills PA 15025

Telephone: (412) 387-1001

Email: dlohr@clarktesting.com

Company Name: ELEMENT (ELMT)

Contact Person: Greg Mason

Mailing Address: 7800 Highway 20 W, West, Huntsville AL 35806

Telephone: (256) 721-0144

Email: greg.mason@element.com




DEPARTMENT OF HEALTH CARE ACCESS AND INFORMATION  
OFFICE OF STATEWIDE HOSPITAL PLANNING AND DEVELOPMENT

Seismic Parameters


Design Basis of Equipment or Components ( $F_p/W_p$ ) =	1.32 ( $z/h = 1$ ); 0.82 ( $z/h = 0$ )
Sds (Design spectral response acceleration at short period, g) =	1.83 ( $z/h = 1$ ); 1.83 ( $z/h = 0$ )
$a_p$ (Amplification factor) =	1.0
$R_p$ (Response modification factor) =	2.5
$\Omega_0$ (System overstrength factor) =	2.0
$I_p$ (Importance factor) =	1.5
$z/h$ (Height ratio factor) =	1 and 0
Natural frequencies (Hz) =	See Attachment
Overall dimensions and weight =	See Attachment

HCAI Approval (For Office Use Only) - Approval Expires on 07/15/2031

Date:	7/15/2025		
Name:	Timothy Piland	Title:	Senior Structural Engineer
Special Seismic Certification Valid Up to:	Sds (g) = See Above	$z/h$ =	See Above
Condition of Approval (if applicable):			



**1800524-CR-001-R6**



# SPECIAL SEISMIC CERTIFICATION CERTIFIED COMPONENT MATRIX

1800524-CR-001-R6



<b>Manufacturer:</b> Eaton Corporation						<b>TABLE 1</b>		
<b>Model Line:</b> 93PM & 93PM-L Uninterruptible Power Supply								
<b>Certified Product Construction Summary:</b> 50kVA - 400 kVA, Carbon Steel Frame and Enclosure.								
<b>Certified Options Summary:</b> See model line numbering pages for the significance of "X"; Dimensions are Maximum Without Seismic Mounting/Bracing Kit; Weights are maximum.								
<b>Mounting Configuration:</b> Base mounted - rigid Note: Installed mounting must be of similar configuration and equivalent strength and stiffness to those tested.								
<b>Building Code: CBC 2022</b>		<b>Seismic Certification Limits:</b>				$S_{DS}= 1.83\text{ g}\quad z/h=1.0$ $S_{DS}= 1.83\text{ g}\quad z/h=0.0$ $I_P= 1.5$		
Model Line	Model	Dimensions (in)			Weight (lbs.)	Vertical C.G. (in)		UUT
		Depth	Width	Height				
93PM - L UPS	9GCXXXXXX XXXXX	42.0	22.0	74.0	570	38.3		Interp.
	9GCXXXXXX XXXXX	...	...	...	...	...		Interp.
	9GC312A700A02R0	42.0	22.0	74.0	1,604	43.5		16
	9GCXXXXXX XXXXX	42.0	30.0	74.0	742	37.1		Interp.
	9GCXXXXXX XXXXX	...	...	...	...	...		Interp.
	9GCXXXXXX XXXXX	42.0	30.0	74.0	1,765	42.5		Interp.
	9GCXXXXXX XXXXX	42.0	34.5	74.0	892	37.0		Interp.
	9GCXXXXXX XXXXX	...	...	...	...	...		Interp.
	9GCXXXXXX XXXXX	42.0	34.5	74.0	1,992	41.9		Interp.
	9GFXXXXXXX XXXXX	42.0	22.0	74.0	702	37.4		Interp.
	9GFXXXXXXX XXXXX	...	...	...	...	...		Interp.
	9GFXXXXXXX XXXXX	42.0	22.0	74.0	1,047	43.9		Interp.
	9GFXXXXXXX XXXXX	42.0	34.5	74.0	940	36.9		Interp.
	9GFXXXXXXX XXXXX	...	...	...	...	...		Interp.
	9GFXXXXXXX XXXXX	42.0	34.5	74.0	1,577	40.6		Interp.
	9GHXXXXXX AXXXX	42.0	34.5	74.0	933	36.4		Interp.
	9GHXXXXXX AXXXX	...	...	...	...	...		Interp.
	9GHXXXXXX AXXXX	42.0	34.5	74.0	1,416	40.7		Interp.
	9GKXXXXXX AXXXX	42.0	43.3	74.0	1,064	35.7		Interp.
	9GKXXXXXX AXXXX	...	...	...	...	...		Interp.
	9GK040A000A02R0	42.0	43.3	74.0	1,722	38.1		17

TRU Compliance, by Structural Integrity Associates, Inc.

844-TRU-0200 | info@trucompliance.com

# SPECIAL SEISMIC CERTIFICATION CERTIFIED COMPONENT MATRIX

1800524-CR-001-R6



<b>Manufacturer:</b> Eaton Corporation		<b>TABLE 1.1</b>
<b>Model Line:</b> 93PM & 93PM-L Uninterruptible Power Supply		
Columns 1 & 2	Model Line	9M = 93PM 0.8 pf
		9N = 93PM 0.9 pf
		9P = 93PM 1.0 pf
		9H = 9PHD 1.0 pf
		9L = 93PM 0.95 pf 59kVA
		9J = 93PM 0.9 pf 62.5kVA
Column 3	Base Model	A = 93PM-50 Capacity Frame
		B = 93PM-50 Redundant Frame, 1 UPM
		C = 93PM-50 Redundant Frame, 2 UPM
		D = 93PM-100 Capacity Frame, 1 UPM
		E = 93PM-100 Capacity Frame, 2 UPM
		F = 93PM-100 Redundant Frame, 1 UPM
		G = 93PM-100 Redundant Frame, 2 UPM
		H = 93PM-100 Redundant Frame, 3 UPM
		J = 93PM-150 Capacity Frame, 1 UPM
		K = 93PM-150 Capacity Frame, 2 UPM
		L = 93PM-150 Capacity Frame, 3 UPM
		M = 93PM-150 Redundant Frame, 1 UPM
		N = 93PM-150 Redundant Frame, 2 UPM
		P = 93PM-150 Redundant Frame, 3 UPM
		R = 93PM-150 Redundant Frame, 4 UPM
		S = 93PM-200 Capacity Frame, 1 UPM
		T = 93PM-200 Capacity Frame, 2 UPM
		U = 93PM-200 Capacity Frame, 3 UPM
		V = 93PM-200 Capacity Frame, 4 UPM
		Z = N/A, Used on P-110000112 93PM Accessories CTO
		0 = 93PM-400 Capacity Frame, 2 UPM
		1 = 93PM-400 Capacity Frame, 3 UPM
		2 = 93PM-400 Capacity Frame, 4 UPM
		3 = 93PM-400 Capacity Frame, 5 UPM
		4 = 93PM-400 Capacity Frame, 6 UPM
		5 = 93PM-400 Capacity Frame, 7 UPM
		6 = 93PM-400 Capacity Frame, 8 UPM
		9 = No UPS (SideCar Only)
Columns 4 & 5	UPS kVA Rating	02 = 20 kVA
		03 = 30 kVA
		04 = 40 kVA
		05 = 50 kVA
		06 = 60 kVA

TRU Compliance, by Structural Integrity Associates, Inc.

844-TRU-0200 | info@trucompliance.com



# SPECIAL SEISMIC CERTIFICATION CERTIFIED COMPONENT MATRIX

1800524-CR-001-R6



<b>Manufacturer:</b> Eaton Corporation <b>Model Line:</b> 93PM & 93PM-L Uninterruptible Power Supply		<b>TABLE 1.1</b>
Columns 4 & 5 (continued)	UPS kVA Rating	07 = 70 kVA
		08 = 80 kVA
		09 = 90 kVA
		10 = 100 kVA
		11 = 110 kVA
		12 = 120 kVA
		13 = 130 kVA
		14 = 140 kVA
		15 = 150 kVA
		16 = 160 kVA
		17 = 170 kVA
		18 = 180 kVA
		19 = 190 kVA
		20 = 200 kVA
		25 = 250 kVA
		30 = 300 kVA
		35 = 350 kVA
		40 = 400 kVA
		45 = 450 kVA
		50 = 500 kVA
Column 6	Voltage Configuration	A = 400V, 4 wire
		B = 400V, 3 wire
		C = 480V, 4 wire
		D = 480V, 3 wire
		E = 380V, 4 wire
		F = 380V, 3 wire
		G = 360V, 4 wire
		H = 360V, 3 wire
		J = 415V, 4 wire
		K = 415V, 3 wire
		L = 440V, 4 wire
		M = 440V, 3 wire
		N = 480V 3-wire / 208V 4-wire (For use with IAC-D)
		P = 208V 3-wire / 208V 4-wire (For use with IAC-D)
		R = 400V 3-wire / 400V 4-wire (For use with IAC-D)
Column 7	Internal Batteries	0 = No Internal Batteries; No Battery Breaker
		2 = With Internal Batteries, 3 strings, type 9Ah
		4 = With Internal Batteries, 4 strings, type 9Ah
		6 = With Internal Batteries, 5 strings, type 9Ah

TRU Compliance, by Structural Integrity Associates, Inc.

844-TRU-0200 | info@trucompliance.com

# SPECIAL SEISMIC CERTIFICATION CERTIFIED COMPONENT MATRIX

1800524-CR-001-R6



<b>Manufacturer:</b> Eaton Corporation		<b>TABLE 1.1</b>
<b>Model Line:</b> 93PM & 93PM-L Uninterruptible Power Supply		
Column 7 (continued)	Internal Batteries	A = Optional DC Breaker (50kVA / 100kVA / 150kVA), No Internal Batteries
		B = With Internal Battery Trays (3 strings), type 9Ah (Batteries not Supplied)
		C = With Internal Battery Trays (4 strings), type 9Ah (Batteries not Supplied)
		D = With Internal Battery Trays (5 strings), type 9Ah (Batteries not Supplied)
		E = With External Separate Battery (per UPM)
		F = With Internal Batteries (4 strings), type 9Ah LL
		G = With Internal Batteries (5 strings), type 9Ah LL
		H = With Internal Batteries (6 strings), type 9Ah LL
		J = With Internal Batteries (4 strings), type 9Ah LL
		K = With Internal Batteries And Thermal Sensor (3 strings), type 9Ah
		L = With Internal Batteries And Thermal Sensor (4 strings), type 9Ah
		M = With Internal Batteries And Thermal Sensor (4 strings), type 9Ah
Column 8	Input Options	0 = Single Feed, no Internal MBS
		1 = Single Feed, with Internal MBS
		2 = Dual Feed, no Internal MBS
		3 = Dual Feed, with Internal MBS
Column 9	Efficiency Options	0 = No ESS, no VMMS
		1 = No ESS, with VMMS
		2 = With ESS, no VMMS
		3 = With ESS, with VMMS
Column 10	Communication Options	0 = None (Empty)
		1 = Network and EMP
		2 = MODBUS and EMP
		3 = Relay, Network and EMP
		4 = Relay
		5 = INDGW-M2
		6 = Network
		7 = INDGW-M2 and EMP gen 2
		8 = Industrial Relay
		9 = INDGW-M2, Industrial Relay and EMP gen 2
Column 11	Sidecar / Top Entry Options	A = No Sidecar
		B = No Breakers, Left Mount
		C = No Breakers, Right Mount
		D = 2 Breaker, Left Mount (MBS)
		E = 3 Breaker, Left Mount (MBS)
		F = 4 Breaker, Left Mount (MBS)
		G = 2 Breaker, Right Mount (MBS)
		H = 3 Breaker, Right Mount (MBS)
		J = 4 Breaker, Right Mount (MBS)

TRU Compliance, by Structural Integrity Associates, Inc.

844-TRU-0200 | info@trucompliance.com



# SPECIAL SEISMIC CERTIFICATION CERTIFIED COMPONENT MATRIX

1800524-CR-001-R6



<b>Manufacturer:</b> Eaton Corporation		<b>TABLE 1.1</b>
<b>Model Line:</b> 93PM & 93PM-L Uninterruptible Power Supply		
Column 11 (continued)	Sidecar / Top Entry Options	K = 3 Breaker, Left Mount (Tie, External Capacity)
		L = 4 Breaker, Left Mount (Tie w/ MBS, External Capacity)
		M = 3 Breaker, Right Mount (Tie, External Capacity)
		N = 4 Breaker, Right Mount (Tie, w/ MBS, External Capacity)
		P = 3 Breaker, Left Mount (Tie, External Redundant)
		R = 4 Breaker, Left Mount (Tie w/ MBS, External Redundant)
		S = 3 Breaker, Right Mount (Tie, External Redundant)
		T = 4 Breaker, Right Mount (Tie w/ MBS, External Redundant)
		U = 2 Breaker, Left Mount (Tie, External Capacity / Redundant)
		V = 2 Breaker, Right Mount (Tie, External Capacity / Redundant)
Column 12	Sidecar Breaker kAIC Rating	0 = no specification
		1 = STD kAIC, all Breakers Aux
		2 = STD kAIC, MBS Aux Only
		3 = High kAIC, all Breakers Aux
		4 = High kAIC, MBS Aux Only
Column 13	Cabinet Configuration <sup>1</sup>	0 = With Dress Skins, Top Air Exhaust
		1 = With Dress Skins, Rear Air Exhaust
		2 = No Dress Skins, Top Air Exhaust
		3 = No Dress Skins, Rear Air Exhaust
		4 = With Dress Skins, Top Air Exhaust, Sidecar Ship Separate
		5 = With Dress Skins, Rear Air Exhaust, Sidecar Ship Separate
Column 14	Factory Location <sup>2</sup>	H = HPO (Helsinki, Finland)
		R = RPO (Raleigh)
		B = BA1 (China)
		F = FAA
		M = Healthcare
		L = UL 924
		A = UL 924a
		P = Power Conditioner (RPO)
		E = Power Conditioner (HPO)
		C = Frequency Converter (RPO)
D = Frequency Converter (HPO)		
Column 15	Generation Code	0 = Initial Release
		1 = ESS
		2 = 50KW STS W/Contactors
		3-9 = Future Product Generation Codes
<b>Notes:</b>		
<b>1.</b> Option 4 and 5 denotes whether the unit is built on site or at factory. Sidecar is attached at site if building doors will not accommodate size of fully constructed unit. <b>2.</b> Based on runtime only		

# SPECIAL SEISMIC CERTIFICATION CERTIFIED COMPONENT MATRIX

1800524-CR-001-R6



<b>Manufacturer:</b> Eaton Corporation <b>Model Line:</b> 93PM & 93PM-L Uninterruptible Power Supply		<b>TABLE 1.2</b>
Columns 1 & 2	Model Line	9G = 93PM-L (208V)
Column 3 & 4	Model-UPM Count	C1= 93PM-L 60 Capacity Frame, 1UPM
		C2= 93PM-L 60 Capacity Frame, 2UPM
		C3= 93PM-L 60 Capacity Frame, 3UPM
		F1= 93PM-L 120 Capacity Frame, 1UPM
		F2= 93PM-L 120 Capacity Frame, 2UPM
		F3= 93PM-L 120 Capacity Frame, 3UPM
		F4= 93PM-L 120 Capacity Frame, 4UPM
		F5= 93PM-L 120 Capacity Frame, 5UPM
		F6= 93PM-L 120 Capacity Frame, 6UPM
		H1= 93PM-L 160 Capacity Frame, 1UPM
		H2= 93PM-L 160 Capacity Frame, 2UPM
		H3= 93PM-L 160 Capacity Frame, 3UPM
		H4= 93PM-L 160 Capacity Frame, 4UPM
		H5= 93PM-L 160 Capacity Frame, 5UPM
		H6= 93PM-L 160 Capacity Frame, 6UPM
		H7= 93PM-L 160 Capacity Frame, 7UPM
		H8= 93PM-L 160 Capacity Frame, 8UPM
		K1= 93PM-L 200 Capacity Frame, 1UPM
		K2= 93PM-L 200 Capacity Frame, 2UPM
		K3= 93PM-L 200 Capacity Frame, 3UPM
		K4= 93PM-L 200 Capacity Frame, 4UPM
		K5= 93PM-L 200 Capacity Frame, 5UPM
		K6= 93PM-L 200 Capacity Frame, 6UPM
		K7= 93PM-L 200 Capacity Frame, 7UPM
		K8= 93PM-L 200 Capacity Frame, 8UPM
		K9= 93PM-L 200 Capacity Frame, 9UPM
		K0= 93PM-L 200 Capacity Frame, 10UPM
		9C= No UPS(sidecar only) 60kVA frame, CTO5/6=12
		9K= No UPS(sidecar only) 120kVA frame, CTO5/6=24

# SPECIAL SEISMIC CERTIFICATION CERTIFIED COMPONENT MATRIX

1800524-CR-001-R6



<b>Manufacturer:</b> Eaton Corporation		<b>TABLE 1.2</b>
<b>Model Line:</b> 93PM & 93PM-L Uninterruptible Power Supply		
Columns 5 & 6	UPS kVA Rating	02 = 10 kVA
		03 = 15 kVA
		04 = 20 kVA
		05 = 25 kVA
		06 = 30 kVA
		07 = 35 kVA
		08 = 40 kVA
		09 = 45 kVA
		10 = 50 kVA
		11 = 55 kVA
		12 = 60 kVA
		13 = 65 kVA
		14 = 70 kVA
		15 = 75 kVA
		16 = 80 kVA
		17 = 85 kVA
		18 = 90kVA
		19 = 95 kVA
		20 = 100 kVA
		21 = 105 kVA
		22 = 110 kVA
		23 = 115 kVA
		24 = 120 kVA
		25 = 125 kVA
		26 = 130 kVA
		27 = 135 kVA
		28 = 140 kVA
		29 = 145 kVA
		30 = 150 kVA
		31 = 155 kVA
		32 = 160 kVA
		33 = 165 kVA
		34 = 170 kVA
		35 = 175 kVA
		36 = 180 kVA
		37 = 185 kVA
		38 = 190 kVA
		39 = 195 kVA
		40 = 200 kVA

# SPECIAL SEISMIC CERTIFICATION CERTIFIED COMPONENT MATRIX

1800524-CR-001-R6



<b>Manufacturer:</b> Eaton Corporation		<b>TABLE 1.2</b>
<b>Model Line:</b> 93PM & 93PM-L Uninterruptible Power Supply		
Column 7	Voltage Configuration	A = Single Input 208/220V, 50/60 Hz; Output 208/220V, 1.0 p.f., 50/60Hz B = Dual Input 208/220V, 50/60 Hz; Output 208/220V, 1.0 p.f., 50/60Hz
Column 8	Internal Batteries	0 = No Internal Batteries; No Battery Breaker
		2 = With Internal Batteries, 2 strings
		3 = With Internal Batteries, 3 strings
		4 = With Internal Batteries, 4 strings
		5 = 2 Strings & Thermal Sensors
		6 = 3 Strings & Thermal Sensors
		7 = 4 Strings & Thermal Sensors
		8 = 2 Strings (Batteries Not Supplied)
		9 = 3 Strings (Batteries Not Supplied)
		A= 4 Strings (Batteries Not Supplied)
Column 9	Efficiency Options	0= No ESS
		1=
		2 = ESS
Column 10	Connectivity Slots	0 = None
		1 = Environmental Monitoring Probe
		2 = INDGW-M2 and IRC
		3 = EMP and IRC
		4=
		5 = Eaton Industrial Gateway Card Minislot for UPS
		6=
		7 = INDGW-M2 and EMP gen 2
		8 = Industrial Relay Card (IRC)
9 = INDGW-M2, IRC and EMP gen 2		
Column 11	Sidecar/Wireway Options	A = None
		B = Left Top Entry Sidecar, No Breakers
		C = Right Top Entry Sidecar, No Breakers
		D = Left MBS, 2 Breakers, MIS/MBP
		E = Left MBS, 3 Breakers, BIB/MIS/MBP
		F = Left MBS, 4 Breakers, RIB/BIB/MIS/MBP
		G = Right MBS, 2 Breakers, MIS/MBP
		H = 3 Breaker, Right Mount (MBS)
		J = Right MBS, 4 Breakers, RIB/BIB/MIS/MBP
		L = Wireway Ship Separate
Column 12	Sidecar Breaker	0 = No Specification
		1 = STD kAIC, Enhanced Monitoring (all breakers monitored)
		2 = STD kAIC, MBP/BIB Terminal Block monitored

**1800524-CR-001-R6**



TRU Compliance, by Structural Integrity Associates, Inc.  
844-TRU-0200 | [info@trucompliance.com](mailto:info@trucompliance.com)

# SPECIAL SEISMIC CERTIFICATION CERTIFIED COMPONENT MATRIX

1800524-CR-001-R6



<b>Manufacturer:</b> Eaton Corporation						<b>TABLE 2</b>		
<b>Model Line:</b> 93PM IAC								
<b>Certified Product Construction Summary:</b> 50 kVA- 200 kVA; Carbon Steel Frame and Enclosure.								
<b>Certified Options Summary:</b> See model line numbering pages for the significance of 'X'; Dimensions are maximum without seismic mounting/bracket kit; weights are maximum.								
<b>Mounting Configuration:</b> Base mounted - rigid Note: Installed mounting must be of similar configuration and equivalent strength and stiffness to those tested.								
<b>Building Code: CBC 2022</b>		<b>Seismic Certification Limits:</b>				$S_{DS}= 1.83\text{ g}\quad z/h=1.0$ $S_{DS}= 1.83\text{ g}\quad z/h=0.0$ $I_P= 1.5$		
Model Line	Model	Dimensions (in)			Weight (lbs.)	Vertical C.G. (in)		UUT
		Depth	Width	Height				
93PM IAC	9PZMA A000000010	42.0	20.0	74.0	404	36.0		5
	9PZMX XXXXXXXX1X	...	...	...	...	...		Interp
	9PZMD F200000010	42.0	20.0	74.0	726	36.0		6
	9PZMX XXXXXXXX1X	...	...	...	...	...		Interp
	9PZRX XXXXXXXX1X	42.0	20.0	74.0	1,034	36.0		Interp
	9PZR-Custom-1	42.0	31.3	74.0	664	35.3		20b
	9PZR-Custom-2	42.0	31.3	74.0	694	35.3		21
	9PZSX XXXXXXXX1X	42.0	31.3	74.0	...	...		Interp
	9PZR-Custom-1	42.0	31.3	74.0	733	36.5		20a
	9PZD1 H000000011	42.0	31.3	74.0	1,105	34.0		10
	9PZDX XXXXXXXX1X	...	...	...	...	...		Interp
	9PZEX XXXXXXXX1X	...	...	...	...	...		Interp
	9PZFX XXXXXXXX1X	...	...	...	...	...		Interp
	9PZDG XXXXXXXX1X	...	...	...	...	...		Interp
	9PZR XXXXXXXX1X	...	...	...	...	...		Interp
	9PZ"X"X XXXXXXXX1X	42.0	31.3	74.0	...	...	"X" specifies IAC-PD	Interp
	9PZG4 SBC0001011	42.0	31.3	74.0	2,165	27.0		11
							1154 lbs	



**1800524-CR-001-R6**

[illegible]

# SPECIAL SEISMIC CERTIFICATION CERTIFIED COMPONENT MATRIX

1800524-CR-001-R6



<b>Manufacturer:</b> Eaton Corporation		IAC-D Model Line Numbering	<b>TABLE 2.2</b>
<b>Model Line:</b> 93PM Integrated Accessory Cabinet (IAC)			
Columns 1-3	Model line	9PZ = 93PM Accessories	
Column 4	Accessory	D = 50 kVA IAC-D, 480 V / 208 V	
		E = 100 kVA IAC-D, 480 V / 208 V	
		F = 150 kVA IAC-D, 480 V / 208 V	
		G = 200 kVA IAC-D, 480 V / 208 V	
		N = 50 kVA IAC-D, 208 V / 208 V	
		P = 100 kVA IAC-D, 208 V / 208 V	
		0 = 150 kVA IAC-D, 480V Input Copper XFMR	
Column 5	Output Transformer	1 = K1 Non TP1, 480 V / 208 V Delta / WYE	
		2 = K13 Non TP1, 480 V / 208 V Delta / WYE	
		3 = K1 TP1, 480 V / 208 V Delta / WYE	
		4 = K13 TP1 480 V / 208 V Delta / WYE	
		5 = K1 DOE 2016, 60 Hz, 400V Output, Delta / WYE	
		6 = K13 DOE 2016, 60 Hz, 400V Output, Delta / WYE	
		7 = K20 DOE 2016, 60 Hz, 400V Output, Delta / WYE	
		8 = K1 DOE 2016, 50/60 Hz, 400V Output, Delta / WYE	
		9 = K13 DOE 2016, 50/60 Hz, 400V Output, Delta / WYE	
		A = K20 DOE 2016, 50/60 Hz, 400V Output, Delta / WYE	
Column 6	Breaker kAIC Rating	S = STD kAIC	
		H = High kAIC	
Column 7	Distribution Top	0 = No Distribution	
		B = 225 A Panel Board Top	
		1 = 1 Subfeed Breaker	
		2 = 2 Subfeed Breakers	
		3 = 3 Subfeed Breakers	
		4 = 4 Subfeed Breakers	
		5 = 5 Subfeed Breakers	
		6 = 1 Subfeed Breaker + 4 Field Upgrades	
		7 = 2 Subfeed Breakers + 3 Field Upgrades	
		8 = 3 Subfeed Breakers + 2 Field Upgrades	
		9 = 4 Subfeed Breakers + 1 Field Upgrade	
Column 8	Distribution Bottom	0 = No Distribution	
		B = 225 A Panel Board Bottom	
		1 = 1 Subfeed Breaker	
		2 = 2 Subfeed Breakers	
		3 = 3 Subfeed Breakers	
		C = 400 A Panel Board Bottom	
		4 = 1 Subfeed Breaker + 2 Field Upgrades	
		5 = 2 Subfeed Breakers + 1 Field Upgrade	

TRU Compliance, by Structural Integrity Associates, Inc.

844-TRU-0200 | info@trucompliance.com

**1800524-CR-001-R6**

[illegible]

# SPECIAL SEISMIC CERTIFICATION CERTIFIED COMPONENT MATRIX

1800524-CR-001-R6



<b>Manufacturer:</b> Eaton Corporation		IAC-B Model Line Numbering	<b>TABLE 2.3</b>
<b>Model Line:</b> 93PM Integrated Accessory Cabinet (IAC)			
Columns 1-3	Model line	9PZ = 93PM Accessories	
Column 4	Accessory	R = IAC-B	
Column 5	Associated UPS Model	A = 60 kW - 4 wire, IAC-B, 208/208V	
		B = 120 kW - 4 wire, IAC-B, 208/208V	
		C = 160 kW - 4 wire, IAC-B, 208/208V	
		D = 200 kW - 4 wire, IAC-B, 208/208V	
		E = 400 kW - 3 wire, IAC-B, 480/480V	
		F = 50kW - 3 wire, IAC-B, 480/480V	
		G = 50kW - 4 wire, IAC-B, 480/480V	
		H = 100kW - 3 wire, IAC-B, 480/480V	
		J = 100kW - 4 wire, IAC-B, 480/480V	
		K = 150kW - 3 wire, IAC-B, 480/480V	
		L = 150kW - 4 wire, IAC-B, 480/480V	
		M = 200kW - 3 wire, IAC-B, 480/480V	
		N = 200kW - 4 wire, IAC-B, 480/480V	
		P = 250kW - 3 wire, IAC-B, 480/480V	
		R = 250kW - 4 wire, IAC-B, 480/480V	
Column 6	Breaker Configuration	A = 2-Breaker 65 KAIC (MBP/MIS)	
		B = 3-Breaker 65 KAIC (MBP/MIS/BIB)	
		C = 4-Breaker 65 KAIC (MBP/MIS/BIB/RIB) Single Input	
		D = 4-Breaker 65 KAIC (MBP/MIS/BIB/RIB) Dual Input	
Column 7	Key/Interlock	1 = Key Interlock	
		2 = Interlock Bracket	
Column 8	Open	0 = None	
Column 9	Open	0 = None	
Column 10	Exhaust Configuration	0 = Top Exhaust	
		1 = Rear Exhaust (208V only)	
Column 11	Installation Configuration	0 = N/A (400 kVA only)	
		1 = Right Side Install (208V only)	
		2 = Left Side Install (208V only)	
Column 12	Open	0 = None	
Column 13	Line & Match/Remote Installation	0 = Line and Match (Required for 160 & 200 kVA 208V)	
		1 = Remote	
Column 14	Structural Configuration	0 = Standard	
		1 = OSHPD	
Column 15	Generation Code	0 - 9 = Product Generation Codes	

TRU Compliance, by Structural Integrity Associates, Inc.

844-TRU-0200 | info@trucompliance.com

**1800524-CR-001-R6**

[illegible]

# SPECIAL SEISMIC CERTIFICATION CERTIFIED COMPONENT MATRIX

1800524-CR-001-R6




<b>Manufacturer:</b> Eaton Corporation		IAC-PD Model Line Numbering	<b>TABLE 2.5</b>
<b>Model Line:</b> 93PM Integrated Accessory Cabinet (IAC)			
Columns 1-3	Model line	9PZ = 93PM Accessories	
Column 4	Accessory	X = IAC-PD	
Column 5	Associated UPS Model or Distribution Cabinet	A = 60 kVA 93PM-L-60, 208V	
		B = 120 kVA 93PM-L-120, 208V	
		C = 160 kVA 93PM-L-160, 208V	
		D = 200 kVA 93PM-L-200, 208V	
		E = 50 kVA 93PM 50, 480V	
		F = 100 kVA 93PM 100, 480V	
		G = 150 kVA 93PM 150, 480V	
		H = 200 kVA 93PM 200, 480V	
		J = 400 kVA 93PM 400, 480V	
		K = 208V 250A IAC-D Subfeed Breaker	
		L = 50 kVA IAC-D (208V) W/no Distribution Option	
		M = 100 kVA IAC-D (208V) W/no Distribution Option	
		N = 150 kVA IAC-D (208V) W/no Distribution Option	
		P = 200 kVA IAC-D (208V) W/no Distribution Option	
		R = 480V 250A IAC-BD Subfeed Breaker	
Column 6	Input Voltage	2 = 208Y/120V 4-Wire	
		4 = 480Y/277V 4-Wire	
		5 = 480V 3-Wire	
Column 7	Distribution Top	0 = No Distribution	
		B = 225A Panel Board (208/120V)	
		C = 400A Panel Board (208/120V)	
		D = 225A Panel Board (480/277V)	
		1 = 1 Subfeed Breaker (250A)	
		2 = 2 Subfeed Breakers (250A)	
		3 = 3 Subfeed Breakers (250A)	
		4 = 1 Subfeed Breaker (400A)	
		5 = 2 Subfeed Breakers (400A)	
Column 8	Distribution Bottom	B = 225A Panel Board (208/120V)	
		C = 400A Panel Board (208/120V)	
		D = 225A Panel Board (480/277V)	
		4 = 1 Subfeed Breaker (400A)	
		5 = 2 Subfeed Breakers (400A)	
Column 9	Open	0 = None	
Column 10	Branch Metering	0 = None	
		1 = BCMS	
Column 11	Cabinet Configuration	0 = Top Exhaust	
		1 = Rear exhaust	

TRU Compliance, by Structural Integrity Associates, Inc.

844-TRU-0200 | info@trucompliance.com



**1800524-CR-001-R6**



# SPECIAL SEISMIC CERTIFICATION CERTIFIED COMPONENT MATRIX

1800524-CR-001-R6



<b>Manufacturer:</b> Eaton Corporation							<b>TABLE 3</b>	
<b>Model Line:</b> 93PM IBC								
<b>Certified Product Construction Summary:</b> 50 kVA- 200 kVA; Carbon Steel Frame and Enclosure.								
<b>Certified Options Summary:</b> See model line numbering pages for the significance of 'X'; Dimensions are maximum without seismic mounting/bracket kit; weights are maximum.								
<b>Mounting Configuration:</b> Base mounted - rigid Note: Installed mounting must be of similar configuration and equivalent strength and stiffness to those tested.								
<b>Building Code: CBC 2022</b>			<b>Seismic Certification Limits:</b>			$S_{DS}= 1.83\text{ g}\quad z/h=1.0$ $S_{DS}= 1.83\text{ g}\quad z/h=0.0$ $I_P= 1.5$		
Model Line	Model	Dimensions (in)			Weight (lbs.)	Vertical C.G. (in)		UUT
		Depth	Width	Height				
93PM IBC	9PZXXXXXX XXXXXX	42.0	16.9	74.0	...	...		Extrap.
	9PZWBAE20010010	42.0	16.9	74.0	1,997	32.4	432V	18
	9PZXXXXXX XXXXXX	42.0	16.9	74.0	...	...		Interp.
	9PZWBBE20010210	42.0	16.9	74.0	2,141	34.0	480V	19
	9PZXXXXXX XXXXXX	42.0	20.0	74.0	...	...		Interp.
	9PZBBAY08 013010	42.0	20.0	74.0	2,246	32.0		7
	9PZXXXXXX XXXXXX	42.0	20.0	74.0	...	...		Interp.
	9PZABAE28 010010	42.0	32.0	74.0	3,185	41.0		13
	9PZXXXXXX XXXXXX	42.0	32.0	74.0	...	...		Interp.
	9PZABAE50 110010	42.0	32.0	74.0	4,745	41.0		8
	9PZXXXXXX XXXXXX	42.0	40.0	74.0	...	...		Interp.
	9PZABAE50 L10010	42.0	40.0	74.0	4,841	41.0		9
	9PZXXXXXX XXXXXX	42.0	34.0	74.0	...	...		Interp.
	9PZUDBN54010010	42.0	34.0	74.0	5,082	39.0		14

# SPECIAL SEISMIC CERTIFICATION CERTIFIED COMPONENT MATRIX

1800524-CR-001-R6



<b>Manufacturer:</b> Eaton Corporation		IBC Model Line Numbering	<b>TABLE 3.1</b>
<b>Model Line:</b> 93PM IBC			
Columns 1-3	Model Line	9PZ = 93PM Accessories	
Column 4	Accessory	A = IBC-L	
		B = IBC-S	
		C = IBC-LH	
		T = IBC-LW (300A breaker)	
		U = IBC-LHW (500A breaker)	
		V = IBC-LW (400A breaker)	
		W = IBC-SW	
Column 5	Associated UPS Model	A = 50 kW (93PM)	
		B = 100 kW (93PM)	
		C = 150 kW (93PM)	
		D = 200 kW (93PM) (480V UPS)	
		E = 400 kW (93PM)	
		F = 60 kW (93PM-L)	
		G = 120 kW (93PM-L)	
		H = 160 kW (93PM-L)	
		J = 200 kW (93PM-L) (208V UPS)	
Column 6	DC Voltage	A = 432 V	
		B = 480 V	
Columns 7-9	Battery Type <sup>1</sup>	B37 = UPS12-400MR, 1/4 (M6) Lugs	
		E20 = HRL-12-200 1/4 (M6) Lugs	
		E28 = HRL 12-280, 1/4 (M6) Lugs	
		E39 = PWR 12-390, 1/4 (M6) Lugs	
		E50 = PWR 12-500, 1/4 (M6) Lugs	
		E54 = HRL 12-540, 1/4 (M6) Lugs	
		E57 = PWP 12-502, 1/4 (M6) Lugs	
		E62 = PWHR 12-620, 1/4 (M6) Lugs	
		H41 = ENERSYS XE95, 3/8 (M10) Lugs	
		N54 = NSB12-540, 1/4 (M6) Lugs	
		Y08 = NPX-80RFR, #10 (M5) Lugs	
		001 = Empty Tray Assembly IBC-L, IBC-LW, 1/4 (M6) Lugs	
		002 = Empty Tray Assembly IBC-S, IBC-SW	
		003 = Empty Tray Assembly IBC-LH, IBC-LW (N54), 1/4 (M6) Lugs	
		004 = Empty Tray Assembly IBC-LH, IBC-LW (H41), 3/8 (M10) Lugs	
		005 = Empty Tray Assembly IBC-LW (E54/B37/N54), 1/4 (M6) LUGS	
		006 = Empty Tray Assembly IBC-LW (H41), 3/8 (M10) Lugs	
007 = Empty Tray Assembly IBC-LH (B37/E54) 1/4 (M6) Lugs			
<b>Notes:</b>			
<b>1.</b> 001-007 means the unit is shipped without batteries and they are installed onsite.			

TRU Compliance, by Structural Integrity Associates, Inc.

844-TRU-0200 | info@trucompliance.com

**1800524-CR-001-R6**



<b>Manufacturer:</b>		Eaton Corporation	IBC Model Line Numbering	<b>TABLE 3.1</b>
<b>Model Line:</b>		93PM IBC		
Column 10	Remote/ Top Entry Sidecar	0 = Line and Match, no Sidecar		
		1 = Remote Installation, no Sidecar		
		L = Remote with Left Sidecar for Top Entry (IBC-L/LH only)		
		R = Remote with Right Sidecar for Top Entry (IBC-L/LH only)		
Column 11	Number of Battery Cabinets	1 = 1 Cabinet		
		2 = 2 Cabinets		
		3 = 3 Cabinets		
		4 = 4 Cabinets		
		5 = 5 Cabinets		
		6 = 6 Cabinets		
		7 = 7 Cabinets		
		8 = 8 Cabinets		
Column 12	Number of Battery Strings	0 = Single String		
		2 = 2 Battery Strings (IBC-S only)		
		3 = 3 Battery Strings (IBC-S only)		
Column 13	Battery Monitoring	0 = With Monitoring Tabs, Without Thermal Sensor, Without Comm Card		
		1 = Without Monitoring Tabs, Without Thermal Sensor, Without Comm Card		
		2 = With Monitoring Tabs, With Thermal Sensor, Without Comm Card		
		3 = Without Monitoring Tabs, With Thermal Sensor, Without Comm Card		
		4 = With Monitoring Tabs, Without Thermal Sensor, With Comm Card		
		5 = Without Monitoring Tabs, Without Thermal Sensor, With Comm Card		
		6 = With Monitoring Tabs, With Thermal Sensor, With Comm Card		
Column 14	Structural Configuration <sup>2</sup>	0 = Standard		
		1 = OSHPD		
		2 = UL924		
		3 = UL924/OSHPD		
Column 15	Generation Code	0 - 9 = Product Generation Codes		
<b>Notes:</b>				
1. 001-007 means the unit is shipped without batteries and they are installed onsite.				
2. UL certification was completed after first OSP, nothing has changed on the unit.				

# SPECIAL SEISMIC CERTIFICATION CERTIFIED SUBCOMPONENT MATRIX

1800524-CR-001-R6



<b>Manufacturer:</b> Eaton Corporation		<b>Table Description:</b> Enclosures					<b>TABLE 4</b>	
<b>Model Line:</b> 93PM Uninterruptible Power Supply (UPS)								
<b>Building Code:</b> CBC 2022		<b>Seismic Certification Limits:</b>			$S_{DS} = 1.83\text{ g} \quad z/h = 1.0$ $S_{DS} = 1.83\text{ g} \quad z/h = 0.0$		$I_P = 1.5$	
Model Line (Manufacturer)	Model	Dimension (in)			Weight (lbs.)	Material	Notes	UUT
		Depth	Width	Height				
93PM (Eaton)	93PM Enclosures	42.0	20.0	74.0	366	93PM SMALL IAC-T / IBC-S FRAME		5, 6, 7
		42.0	22.0	74.0	392	93PM STD UPS FRAME		1
		42.0	31.0	74.0	397	93PM IAC-D / LARGE IAC-T FRAME		10, 11
		42.0	32.0	74.0	435	93PM LARGE UPS FRAME		Interp.
		42.0	34.5	74.0	528	93PM-L IAC-B		20a/b, 21
		42.0	31.3	74.0	540	93PM IAC-PD		Interp.
		42.0	30.0	74.0	557	93PM STD UPS + SMALL SC FRAME		4
		42.0	37.0	74.0	679	93PM STD UPS + LARGE SC FRAME		Interp.
		42.0	47.0	74.0	722	93PM LARGE UPS + LARGE SC FRAME		2, 12
		42.0	32.0	74.0	856	93PM IBC-L FRAME		8, 13
		42.0	34.0	74.0	828	93PM Frame Asm, IBC-L Weld		Interp.
		42.0	40.0	74.0	1,021	93PM IBC-L + SMALL SC FRAME		9
		42.0	64.0	74.0	800	93PM 400 kVA capacity UPS (8UPM)		15
		42.0	34.0	74.0	993	93PM IBC-LHW Line & match		14
		42.0	22.0	74.0	495	93PM-L 60 kVA Frame		16
		42.0	30.0	74.0	667	93PM-L 60 kVA Frame w/ empty SC		Interp.
		42.0	34.5	74.0	744	93PM-L 60 kVA Frame w/ MBP SC		Interp.
		42.0	22.0	74.0	621	93PM-L 120 kVA Frame		Interp.
		42.0	34.5	74.0	859	93PM-L 120 kVA Frame w/ empty SC		Interp.
		42.0	34.5	74.0	870	93PM-L 120 kVA Frame w/ MBP SC		Interp.
		42.0	34.5	74.0	732	93PM-L 160k VA frame		Interp.
		42.0	43.3	74.0	859	93PM-L 200k VA frame		17
		42.0	16.9	74.0	443	93PM IBC-SW		18, 19

TRU Compliance, by Structural Integrity Associates, Inc.

844-TRU-0200 | info@trucompliance.com

# SPECIAL SEISMIC CERTIFICATION CERTIFIED SUBCOMPONENT MATRIX

1800524-CR-001-R6



<b>Manufacturer:</b> Eaton Corporation		<b>Table Description:</b> Electrical Components			<b>TABLE 5</b>
<b>Model Line:</b> 93PM Uninterruptible Power Supply (UPS)					
<b>Building Code: CBC 2022</b>		<b>Seismic Certification Limits:</b> $S_{DS} = 1.83\text{ g}$ $z/h = 1.0$ $S_{DS} = 1.83\text{ g}$ $z/h = 0.0$ $I_P = 1.5$			
Component Type	Manufacturer	Model	Description	Notes	UUT
Panel Board	Eaton	122950146	PDU PRL1 225A; Cu		11
		122950148	PDU PRL2A 225A; Cu		Interp.
		122950147	PDU PRL1 400A; Cu		11
Power Modules	Eaton	730-05211	208V-4 Wire 20kW UPM		16, 17
		733-D2072	208V-4 Wire 20kW UPM		Interp.
		730-80505	480V-3 Wire 50kW UPM	New PCB layout, no structural change	Interp.
		730-B1045	480V-3 Wire 50kW UPM		1, 2, 4
		733-82035	480V-3 Wire 50kW UPM		Interp.
		733-A2205	480V-4 Wire 50kW UPM		Interp.
		733-A2206	480V-4 Wire 50kW UPM	Substitute for 733-A2205	Interp.
		730-D0057	480V-4 Wire 50kW UPM		12
Contactors	Eaton	XTCE018C10WD	K5 Contactor (50KW); 1 lb	Same as DILM17-10 (RDC60); Eaton P/N	Interp.
		DILM17-10 (RDC60)	K5 Contactor (50KW); 1 lb	Moeller P/N	1, 4
		XTCE115G00WD	K5 Contactor (100KW); 5 lbs	Same as DILM115 (RDC60); Eaton P/N	Interp.
		DILM115 (RDC60)	K5 Contactor (100KW); 5 lbs	Moeller P/N	Interp.
		DILM185A/22 (RDC60)	K5 Contactor (150KW); 14 lbs	Moeller P/N	Interp.
		XTCE250L22TD	K5 Contactor, (200kW); 17 lbs	Same as DILM250/22 (RDC48); Eaton P/N	Interp.
		DILM250/22 (RDC48)	K5 Contactor, (200kW); 17 lbs		12
Kirk Key System	Eaton	P-116000097			20a
Control Transformers	Eaglerise	149502123	300 VA, 480V/400V		20a
	Eaton	C0025E2A	25 VA, MTE, 240V/480V		20a

TRU Compliance, by Structural Integrity Associates, Inc.

844-TRU-0200 | info@trucompliance.com



# SPECIAL SEISMIC CERTIFICATION CERTIFIED SUBCOMPONENT MATRIX

1800524-CR-001-R6



Manufacturer: Eaton Corporation		Table Description: Electrical Components			TABLE 5
Model Line: 93PM Uninterruptible Power Supply (UPS)					
Building Code: CBC 2022		Seismic Certification Limits:		$S_{DS} = 1.83\text{ g}$ $z/h = 1.0$	$I_P = 1.5$
		$S_{DS} = 1.83\text{ g}$ $z/h = 0.0$			
Component Type	Manufacturer	Model	Description	Notes	UUT
Transformers	Eaton	WPV50011	50 kVA, K1, 480 Delta-208Y, Al 150C, non-TP1	639 lbs	Interp.
		WPV50012	50 kVA, K1, 480 Delta-208Y, Al 150C, TP1	545 lbs	10
		WPN50131	50 kVA, K13, 480 Delta-208Y, Al 150C, non-TP1	603 lbs	Interp.
		WPN50132	50 kVA, K13, 480 Delta-208Y, Al 150C, TP1	631 lbs	Interp.
		WPV12011	100 kVA, K1, 480 Delta-208Y, Al 150C, non-TP1	675 lbs	Interp.
		WPV12012	100 kVA, K1, 480 Delta-208Y, Al 150C, TP1	655 lbs	Interp.
		WPN12131	100 kVA, K13, 480 Delta-208Y, Al 150C, non-TP1	835 lbs	Interp.
		WPN12132	100 kVA, K13, 480 Delta-208Y, Al 150C, TP1	700 lbs	Interp.
		WPV49011	150 kVA, K1, 480 Delta-208Y, Al 150C, non-TP1	874 lbs	Interp.
		WPV49012	150 kVA, K1, 480 Delta-208Y, Al 150C, TP1	787 lbs	Interp.
		WPN49131	150 kVA, K13, 480 Delta-208Y, Al 150C, non-TP1	1154 lbs	Interp.
		WPN49132	150 kVA, K13, 480 Delta-208Y, Al 150C, TP1	1,378 lbs	Interp.
		WPV19011	200 kVA, K1, 480 Delta-208Y, Al 150C, non-TP1	1,165 lbs	Interp.
		WPV19012	200 kVA, K1, 480 Delta-208Y, Al 150C, TP1	1,123 lbs	Interp.
		WPN19131	200 kVA, K13, 480 Delta-208Y, Al 150C, non-TP1	1,414 lbs	Interp.
		WPN19132	200 kVA, K13, 480 Delta-208Y, Al 150C, TP1	1,416 lbs	11
Static Switches	Eaton	730-D0039	50kW STS; CS Frame; Al heat sink		1, 4
		730-B1035	100kW STS; CS Frame; Al heat sink		Interp.
		730-D0021	150kW/200kW STS; CS Frame; Al heat sink		12
		730-05213	93PM-L 60 kW STS		16
		730-05212	93PM-L 120 kW STS		Interp.
		730-05214	93PM-L 200 kW STS		17

TRU Compliance, by Structural Integrity Associates, Inc.

844-TRU-0200 | info@trucompliance.com

# SPECIAL SEISMIC CERTIFICATION CERTIFIED SUBCOMPONENT MATRIX

1800524-CR-001-R6




<b>Manufacturer:</b> Eaton Corporation		<b>Table Description:</b> Batteries			<b>TABLE 6</b>
<b>Model Line:</b> 93PM Uninterruptible Power Supply (UPS)					
<b>Building Code: CBC 2022</b>		<b>Seismic Certification Limits:</b> $S_{DS} = 1.83\text{ g}$ $z/h = 1.0$ $S_{DS} = 1.83\text{ g}$ $z/h = 0.0$			$I_p = 1.5$
Component Type	Manufacturer	Model	Description	Notes	UUT
Batteries	CSB	HR1227WFR	12V, 27 Watt (5Ah), VRLA; ABS house.; 4.3 lbs.		16
		PWRH1227W2FR	12V, 27 Watt (5Ah), VRLA; ABS house.; 4.3 lbs.		Interp.
		HRL1234W2FR	12V, 34 Watt (9Ah), VRLA; ABS house.; 6 lbs.		Interp.
		PWHR1234W2FR	12V, 34 Watt (9Ah), VRLA; ABS house.; 6 lbs.		4
		HRL12200WFR	12V, 52 Ah; PP housing; 39 lbs.		Interp.
		PWHR12200W4FR	12V, 52 Ah; PP housing; 39 lbs.		18, 19
		HRL12280WFR	12V, 75 Ah; PP housing.; 60 lbs.		Interp.
		PWHR12280W4FR	12V, 75 Ah; PP housing.; 60 lbs.		13
		HRL12330FR	12V, 280W; PP housing; 65 lbs.		Interp.
		PWHR12330W4FR	12V, 280W; PP housing; 65 lbs.		Interp.
		HRL12390FR	12V, 390W; PP housing; 74 lbs.		Interp.
		PWHR12390W4FR	12 V, 100 Ah; PP housing; 74 lbs.		Interp.
		XPL5700FR	12V, 110 Ah, VRLA; PP housing; 82 lbs.		Interp.
		PWXP12502W4FR	12V, 110 Ah, VRLA; PP housing; 82 lbs.		Interp.
		HRL12540WFR	12 V, 161 Ah, VRLA; PP housing; 97 lbs.		Interp.
		PWHR12540WFR	12 V, 161 Ah, VRLA; PP housing; 97 lbs.		Interp.
		HRL12500W	12V, 120 Ah; PP housing; 101 lbs.		Interp.
		PWHR12500W4FR	12 V, 120 Ah; PP housing; 101 lbs.		8, 9
	C&D Dynasty	UPS12-300MR	12 V, 78 Ah; PP housing; 58 lbs		13
		UPS12-350MR	12 V, 93.2 Ah; PP housing; 67 lbs		Interp.
		UPS12-400MR	12 V, 100 Ah; PP housing; 80 lbs		Interp.
		UPS12-490MR	12 V, 134 Ah; PP housing; 100 lbs		13
	G.S. YUASA	NPX-80RFR	12 V, 20 Ah, VRLA; PP housing; 15 lbs		7

TRU Compliance, by Structural Integrity Associates, Inc.

844-TRU-0200 | info@trucompliance.com

**1800524-CR-001-R6**



# SPECIAL SEISMIC CERTIFICATION CERTIFIED SUBCOMPONENT MATRIX

1800524-CR-001-R6



<b>Manufacturer:</b> Eaton Corporation		<b>Table Description:</b> Breakers			<b>TABLE 7</b>
<b>Model Line:</b> 93PM Uninterruptible Power Supply (UPS)					
<b>Building Code:</b> CBC 2022		<b>Seismic Certification Limits:</b> $S_{DS} = 1.83\text{ g}$ $z/h = 1.0$ $S_{DS} = 1.83\text{ g}$ $z/h = 0.0$ $I_P = 1.5$			
Component Type	Manufacturer	Model	Description	Notes	UUT
Breakers (Thermal Magnetic)	Eaton (CH)	HFD3080L	FD-Frame, 3-pole, 80 A, 5 lbs.		4
		*FD*	FD-Frame, 3-pole, 80-225 A, 5 lbs.		Interp.
		HFD3110L	FD-Frame, 3-pole, 110 A, 5 lbs.		1, 4
		HFD4175ELA02S22	FD-Frame, 3-pole, 175 A, 5 lbs.		4
		*JG*	JG-Frame, 3-pole, 80-250 A, 6 lbs.		Interp.
		HJGE3125FAGC	JG-Frame, 3-pole, 125 A, 6 lbs.		4
		HKDDC3300WA07S49	KD-Frame, 3-pole, 300 A, 12 lbs.		13
		HKD3300W	KD-Frame, 3-pole, 300 A, 12 lbs.		12
		*KD*	KD-Frame, 3-pole, 175-400 A, 12 lbs.		Interp.
		HKD3400W	KD-Frame, 3-pole, 400 A, 12 lbs.		12
		HLGE3300FAW	LG-Frame, 3-pole, 300 A, 16 lbs.		6
		*LG*	LG-Frame, 3-pole, 300-600 A, 16 lbs.		Interp.
		*LD*	LD-Frame, 3-pole, 600 A, 20 lbs.		Interp.
		*MD*	MD-Frame, 3-pole, 700 A, 29 lbs.		Interp.
		*ND*	ND-Frame, 3-pole, 1200 A, 45 lbs.		Interp.
		*NG*	NG-Frame, 3-pole, 800-1200 A, 45 lbs.		Interp.
			HNGS312032MC	NG-Frame, 3-pole, 1200 A, 45 lbs.	
<b>Notes:</b> * Breakers listed here include part numbers which identify configuration, manufacturer, materials, and breaker rating. Interpolated items have the same manufacturer, materials, and have the same configuration and construction as the tested units.					

# SPECIAL SEISMIC CERTIFICATION CERTIFIED SUBCOMPONENT MATRIX

1800524-CR-001-R6



<b>Manufacturer:</b> Eaton Corporation		<b>Table Description:</b> Breakers			<b>TABLE 7</b>
<b>Model Line:</b> 93PM Uninterruptible Power Supply (UPS)					
<b>Building Code:</b> CBC 2022		<b>Seismic Certification Limits:</b> $S_{DS} = 1.83\text{ g}$ $z/h = 1.0$ $S_{DS} = 1.83\text{ g}$ $z/h = 0.0$			$I_P = 1.5$
Component Type	Manufacturer	Model	Description	Notes	UUT
AC Breakers <sup>1</sup> (Thermal Magnetic) (Frame 1-4)	Eaton	PDG13*	Frame 1, 3-pole, 2.3 lbs	Not Modular	Interp.
		PDG13G0125TFFJ	Frame 1, 3-pole, 125 A, 2.3 lbs	Not Modular	20b
		PDD23*	Frame 2, 3-pole, 240VAC, 4.7 lbs	Not Modular	Interp.
		PDG23*	Frame 2, 3-pole, 4.7 lbs	Not Modular	Interp.
		PDD33*	Frame 3, 3-pole, 240VAC, 14.8 lbs	Modular	Interp.
		PDF33*	Frame 3, 3-pole, 100% Rated, 14.8 lbs	Modular	Interp.
		PDG33*	Frame 3, 3-pole, 14.8 lbs	Modular	Interp.
		PDG33K0400TFAN	Frame 3, 3-pole, 400 A, 11.8 lbs	Modular	20a
		PDF43*	Frame 4, 3-pole, 100% Rated, 31.0 lbs	Modular	Interp.
		PDG43*	Frame 4, 3-pole, 31.0 lbs	Modular	Interp.
		PDG43M0600TFAN	Frame 4, 3-pole, 600 A, 31.0 lbs	Modular	20a, 20b
AC Breakers <sup>1</sup> (Electronic Trip) (Frame 2-6)	Eaton	PDF23*	Frame 2, 3-pole, 100% Rated, 4.7 lbs	Not Modular	Interp.
		PDG23*	Frame 2, 3-pole, 4.7 lbs	Not Modular	Interp.
		PDG23G0225B2NL	Frame 2, 3-pole, adjustable 225 A, 4.5 lbs	Not Modular	20a
		PDF33*	Frame 3, 3-pole, 100% Rated, 14.8 lbs	Modular	Interp.
		PDG33*	Frame 3, 3-pole, 14.8 lbs	Modular	Interp.
		PDF43*	Frame 4, 3-pole, 100% Rated, 33.0 lbs	Modular	Interp.
		PDG43*	Frame 4, 3-pole, 33.0 lbs	Modular	Interp.
		PDC53*	Frame 5, 3-pole, IEC/CCC Rated, 48.0 lbs	Modular	Interp.
		PDF53*	Frame 5, 3-pole, 100% Rated, 48.0 lbs	Modular	Interp.
<b>Notes:</b> <b>1.</b> Frame 3, 4, 5 and 6 breaker assemblies may be assembled from individual Eaton breaker components at time of incorporation into Eaton products. * Breakers listed here include part numbers which identify configuration, manufacturer, materials, and breaker rating. Interpolated items have the same manufacturer, materials, and have the same configuration and construction as the tested units.					

TRU Compliance, by Structural Integrity Associates, Inc.

844-TRU-0200 | info@trucompliance.com

**1800524-CR-001-R6**



TRU Compliance, by Structural Integrity Associates, Inc.  
844-TRU-0200 | info@trucompliance.com  
Page 32 of 55



# UNIT UNDER TEST (UUT) SUMMARY SHEET

1800524-CR-001-R6



**Manufacturer:** Eaton Corporation


**Model Line:** 93PM, 93PM-L, 93PM IAC, 93PM IBC Uninterruptible Power Supply (UPS)

UUT	Unit Description (mounting)	Report Number (UUT#)	Testing Lab	Year Tested	ISO 17025 Accredited?	S <sub>DS</sub>	z/h	I <sub>p</sub>
1	93PM 50kVA Capacity UPS (1 UPM)	71589 Rev.A (UUT1)	Element - Huntsville <sup>1</sup>	2014	Yes	2.39	1.0 0.0	1.5
2	93PM 200kVA Capacity UPS (4 UPM)	71589 Rev.A (UUT2)	Element - Huntsville <sup>1</sup>	2014	Yes	2.39	1.0 0.0	1.5
3	NOT USED							
4	93PM 50kVA Capacity UPS (1 UPM)	71589 Rev.A (UUT4)	Element - Huntsville <sup>1</sup>	2014	Yes	2.39	1.0 0.0	1.5
5	93PM 50kVA External Redundant IAC-T	71589 Rev.A (UUT5)	Element - Huntsville <sup>1</sup>	2014	Yes	1.83	1.0 0.0	1.5
6	93PM 200kVA External Capacity IAC-T	71589 Rev.A (UUT6)	Element - Huntsville <sup>1</sup>	2014	Yes	1.83	1.0 0.0	1.5
7	93PM 100kVA IBC-S (line & match)	71589 Rev.A (UUT7)	Element - Huntsville <sup>1</sup>	2014	Yes	1.83	1.0 0.0	1.5
8	93PM 100kVA IBC-L (line & match)	71589 Rev.A (UUT8)	Element - Huntsville <sup>1</sup>	2014	Yes	1.83	1.0 0.0	1.5
9	93PM 100kVA IBC-L (remote w/ left sidecar)	71589 Rev.A (UUT9)	Element - Huntsville <sup>1</sup>	2014	Yes	1.83	1.0 0.0	1.5
10	93PM 50kVA IAC-D	71589 Rev.A (UUT10)	Element - Huntsville <sup>1</sup>	2014	Yes	1.83	1.0 0.0	1.5
11	93PM 200kVA IAC-D	71589 Rev.A (UUT11)	Element - Huntsville <sup>1</sup>	2014	Yes	1.83	1.0 0.0	1.5
12	93PM 200kVA Capacity UPS (4 UPM)	174-9243708-000 (UUT12)	AREVA Inc.	2015	Yes	2.50	1.0 0.0	1.5
13	93PM 100kVA IBC-L	174-9243708-000 (UUT13)	AREVA Inc.	2015	Yes	2.29	1.0 0.0	1.5
14	93PM 200 kVA IBC-LHW	JID 16-00773 Rev.1 (UUT14)	Clark Testing	2016	Yes	2.00 3.20	1.0 0.0	1.5
15	93PM 400 kVA UPS (8 UPM)	JID 16-00773 Rev.1 (UUT15)	Clark Testing	2016	Yes	2.00 3.20	1.0 0.0	1.5
16	93PM-L-60kVA (3 UPM)	JID 19-00067 Rev.3 (UUT16)	Clark Testing	2019	Yes	1.83	1.0 0.0	1.5
17	93PM-L-200kVA (10 UPM)	JID 19-00067 Rev.3 (UUT17)	Clark Testing	2019	Yes	1.83	1.0 0.0	1.5

**Notes:**

1. Element - Huntsville was formerly Wyle Laboratories.

**1800524-CR-001-R6**



**Model Line:** 93PM, 93PM-L, 93PM IAC, 93PM IBC Uninterruptible Power Supply (UPS)

**Notes:**

# UNIT UNDER TEST (UUT) SUMMARY SHEET

1800524-CR-001-R6

EATON

TRU  
COMPLIANCE

**Manufacturer:** Eaton Corporation  
**Model Line:** 93PM Uninterruptible Power Supply (UPS)  
**Model Number:** 9PA05D0220A01R1

**Serial Number:** N/A

**UUT 1**

**Product Construction Summary:**

Powder Coated Carbon Steel Framing

**Options/Subcomponent Summary:**

50kVA Capacity UPS (1 UPM); No Batteries; No Sidecare; Frame (Eaton); MBS Switch (Eaton);

**Power Modules:** Eaton (730-B1045); **Static Switches:** Eaton (730-D0039); **Contactors:** Eaton (DILM17-10 (RDC60));

**Breakers:** Eaton (HFD3110L); **Seismic Kit:** Eaton (P-103000765)


**UUT Properties**

Weight (lbs.)	Dimension (in)			Lowest Natural Frequency (Hz)		
	Depth	Width	Height	Front-Back	Side-Side	Vertical
686	42.0	22.0	74.0	13.0	10.5	>33.3

**UUT Highest Passed Seismic Run Information**

Building Code	Test Criteria	S <sub>DS</sub> (g)	z/h	I <sub>P</sub>	A <sub>FLX-H</sub> (g)	A <sub>RIG-H</sub> (g)	A <sub>FLX-V</sub> (g)	A <sub>RIG-V</sub> (g)
CBC 2022	ICC-ES AC156	2.39	1.0	1.5	3.82	2.87	1.59	0.64
		2.39	0.0					

**Test Mounting Details:** (Test Report: 71589 Rev.A (UUT1))



The UUT1 was based mounted - rigid to steel floor members using eight (8) 1/2" Grade 5 bolts. The steel floor members were welded to the shake table. Mounting brackets were attached to the UUT using eight (8) M8x20 Class 8.8 bolts. Unit maintained structural integrity and remained functional per manufacturer requirement after shake table test. Contents were included in testing per operating conditions.

TRU Compliance, by Structural Integrity Associates, Inc.

844-TRU-0200 | info@trucompliance.com

# UNIT UNDER TEST (UUT) SUMMARY SHEET

1800524-CR-001-R6

EATON

**TRU**  
COMPLIANCE

**Manufacturer:** Eaton Corporation  
**Model Line:** 93PM Uninterruptible Power Supply (UPS)  
**Model Number:** 9PV20D0029F20R1

**Serial Number:** N/A

**UUT 2**

**Product Construction Summary:**

Powder Coated Carbon Steel Framing

**Options/Subcomponent Summary:**

200kVA Capacity UPS (4 UPM) + 4 Bkr MBS Sidecar; Frame (Eaton); Static Switch (Eaton); Contactor (Eaton);  
**Breakers:** Eaton (HKD3300W, HKD3400W); **Power Modules:** Eaton (730-B1045); **Seismic Kit:** Eaton (P-103000842);  
**Side Car Seismic Kit:** Eaton (P-103000844)


**UUT Properties**

Weight (lbs.)	Dimension (in)			Lowest Natural Frequency (Hz)		
	Depth	Width	Height	Front-Back	Side-Side	Vertical
1,774	42.0	46.7	74.0	14.0	12.2	32.0

**UUT Highest Passed Seismic Run Information**

Building Code	Test Criteria	S <sub>DS</sub> (g)	z/h	I <sub>P</sub>	A <sub>FLX-H</sub> (g)	A <sub>RIG-H</sub> (g)	A <sub>FLX-V</sub> (g)	A <sub>RIG-V</sub> (g)
CBC 2022	ICC-ES AC156	2.39	1.0	1.5	3.82	2.87	1.59	0.64
		2.39	0.0					

**Test Mounting Details:** (Test Report: 71589 Rev.A (UUT2))



The UUT2 was base mounted - rigid to steel floor members using twelve (12) 1/2" Grade 5 bolts. The steel floor members were welded to the shake table. Mounting brackets were attached to the UUT using twelve (12) M8x20 Class 8.8 bolts. Unit maintained structural integrity and remained functional per manufacturer requirement after shake table test. Contents were included in testing per operating conditions.



# UNIT UNDER TEST (UUT) SUMMARY SHEET



1800524-CR-001-R6


<b>Manufacturer:</b>	Eaton Corporation	<b>UUT 4</b>
<b>Model Line:</b>	93PM Uninterruptible Power Supply (UPS)	
<b>Model Number:</b>	9PA05D6029L00R1	
<b>Serial Number:</b>		N/A

**Product Construction Summary:**  
Powder Coated Carbon Steel Framing

**Options/Subcomponent Summary:**  
50kVA Capacity UPS (1 UPM) with Batteries + Tie / Bypass Sidecar; Frame (Eaton); MBS Switch (Sonthaimer);  
**Power Modules:** Eaton (730-B1045); **Static Switches:** Eaton (730-D0039); **Contactors:** Eaton (DILM17-10 (RDC60));  
**Batteries:** CSB (PWHR1234W2FR); **Breakers:** Eaton (HFD3080L, HFD3110L, HFD4175ELA02S22, HJGE3125FAGC);  
**Seismic Kit:** Eaton (P-103000765); **Side Car Seismic Kit:** Eaton (P-103000766)

UUT Properties										
Weight (lbs.)	Dimension (in)			Lowest Natural Frequency (Hz)						
	Depth	Width	Height	Front-Back	Side-Side	Vertical				
2,178	42.0	30.0	74.0	13.0	7.8	> 33.3				
UUT Highest Passed Seismic Run Information										
Building Code		Test Criteria		S <sub>DS</sub> (g)	z/h	I <sub>p</sub>	A <sub>FLX-H</sub> (g)	A <sub>RIG-H</sub> (g)	A <sub>FLX-V</sub> (g)	A <sub>RIG-V</sub> (g)
CBC 2022		ICC-ES AC156		2.39	1.0	1.5	3.82	2.87	1.59	0.64
				2.39	0.0					

**Test Mounting Details:** (Test Report: 71589 Rev.A (UUT4))



The UUT4 was base mounted - rigid to steel floor members using twelve (12) 1/2" Grade 5 bolts. The steel floor members were welded to the shake table. Mounting brackets were attached to the UUT using twelve (12) M8x20 Class 8.8 bolts. Unit maintained structural integrity and remained functional per manufacturer requirement after shake table test. Contents were included in testing per operating conditions.

# UNIT UNDER TEST (UUT) SUMMARY SHEET

1800524-CR-001-R6

**EATON**

**TRU**  
COMPLIANCE

**Manufacturer:** Eaton Corporation  
**Model Line:** 93PM IAC  
**Model Number:** 9PZMAA000000010

**Serial Number:** N/A

**UUT 5**

**Product Construction Summary:**

Powder Coated Carbon Steel Framing

**Options/Subcomponent Summary:**

50kVA External Redundant IAC-T, 2 Bkr. Frame (Eaton);

**Breakers:** Eaton (FD3080); **Seismic Kit:** Eaton (P-103000843)


**UUT Properties**

Weight (lbs.)	Dimension (in)			Lowest Natural Frequency (Hz)		
	Depth	Width	Height	Front-Back	Side-Side	Vertical
404	42.0	19.7	74.0	9.0	7.9	24.0

**UUT Highest Passed Seismic Run Information**

Building Code	Test Criteria	S <sub>DS</sub> (g)	z/h	I <sub>P</sub>	A <sub>FLX-H</sub> (g)	A <sub>RIG-H</sub> (g)	A <sub>FLX-V</sub> (g)	A <sub>RIG-V</sub> (g)
CBC 2022	ICC-ES AC156	1.83	1.0	1.5	2.93	2.20	1.22	0.49
		1.83	0.0					

**Test Mounting Details:** (Test Report: 71589 Rev.A (UUT5))



The UUT5 was base mounted - rigid to steel floor members using eight (8) 1/2" Grade 5 bolts. The steel floor members were welded to the shake table. Mounting brackets were attached to the UUT using eight (8) M8x20 Class 8.8 bolts. Unit maintained structural integrity and remained functional per manufacturer requirement after shake table test. Contents were included in testing per operating conditions.

TRU Compliance, by Structural Integrity Associates, Inc.

844-TRU-0200 | info@trucompliance.com



# UNIT UNDER TEST (UUT) SUMMARY SHEET

1800524-CR-001-R6

EATON

TRU  
COMPLIANCE

**Manufacturer:** Eaton Corporation  
**Model Line:** 93PM IAC  
**Model Number:** 9PZMDF200000010

**Serial Number:** N/A

**UUT 6**

**Product Construction Summary:**

Powder Coated Carbon Steel Framing

**Options/Subcomponent Summary:**

200kVA External Capacity IAC-T, 4 Bkr + MIS, MBP. Frame (Eaton);

**Breakers:** Eaton (HLGE3300FAW, HNGS312032MC); **Seismic Kit:** Eaton (P-103000843)


**UUT Properties**

Weight (lbs.)	Dimension (in)			Lowest Natural Frequency (Hz)		
	Depth	Width	Height	Front-Back	Side-Side	Vertical
726	42.0	19.7	74.0	9.5	5.5	> 33.3

**UUT Highest Passed Seismic Run Information**

Building Code	Test Criteria	S <sub>DS</sub> (g)	z/h	I <sub>P</sub>	A <sub>FLX-H</sub> (g)	A <sub>RIG-H</sub> (g)	A <sub>FLX-V</sub> (g)	A <sub>RIG-V</sub> (g)
CBC 2022	ICC-ES AC156	1.83	1.0	1.5	2.93	2.20	1.22	0.49
		1.83	0.0					

**Test Mounting Details:** (Test Report: 71589 Rev.A (UUT6))



The UUT6 was base mounted - rigid to steel floor members using eight (8) 1/2" Grade 5 bolts. The steel floor members were welded to the shake table. Mounting brackets were attached to the UUT using eight (8) M8x20 Class 8.8 bolts. Unit maintained structural integrity and remained functional per manufacturer requirement after shake table test. Contents were included in testing per operating conditions.

TRU Compliance, by Structural Integrity Associates, Inc.

844-TRU-0200 | info@trucompliance.com

# UNIT UNDER TEST (UUT) SUMMARY SHEET

1800524-CR-001-R6

EATON

TRU  
COMPLIANCE

**Manufacturer:** Eaton Corporation  
**Model Line:** 93PM IBC  
**Model Number:** 9PZBBAY08013010

**Serial Number:** N/A

**UUT 7**

**Product Construction Summary:**

Powder Coated Carbon Steel Framing

**Options/Subcomponent Summary:**

100kVA IBC-S, Line & Match. Frame (Eaton);

**Breakers:** Eaton (HKDC3300WA07S49); **Batteries:** G.S. YUASA (NPX-80RFR); **Seismic Kit:** Eaton (P-103000843)


**UUT Properties**

Weight (lbs.)	Dimension (in)			Lowest Natural Frequency (Hz)		
	Depth	Width	Height	Front-Back	Side-Side	Vertical
2,246	42.0	19.7	74.0	10.0	5.0	22.0

**UUT Highest Passed Seismic Run Information**

Building Code	Test Criteria	S <sub>DS</sub> (g)	z/h	I <sub>p</sub>	A <sub>FLX-H</sub> (g)	A <sub>RIG-H</sub> (g)	A <sub>FLX-V</sub> (g)	A <sub>RIG-V</sub> (g)
CBC 2022	ICC-ES AC156	1.83	1.0	1.5	2.93	2.20	1.22	0.49
		1.83	0.0					

**Test Mounting Details:** (Test Report: 71589 Rev.A (UUT7))



The UUT7 was rigid mounted to steel floor members using eight (8) 1/2" Grade 5 bolts. The steel floor members were welded to the shake table. Mounting brackets were attached to the UUT using eight (8) M8x20 Class 8.8 bolts.

Unit maintained structural integrity and remained functional per manufacturer requirement after shake table test. Contents were included in testing per operating conditions.

TRU Compliance, by Structural Integrity Associates, Inc.

844-TRU-0200 | info@trucompliance.com

# UNIT UNDER TEST (UUT) SUMMARY SHEET

1800524-CR-001-R6

EATON

TRU  
COMPLIANCE

**Manufacturer:** Eaton Corporation  
**Model Line:** 93PM IBC  
**Model Number:** 9PZABAE50010010

**Serial Number:** N/A

**UUT 8**

**Product Construction Summary:**

Powder Coated Carbon Steel Framing

**Options/Subcomponent Summary:**

100kVA IBC-L, Line & Match. Frame (Eaton);

**Breakers:** Eaton (HKDC3300WA07S49); **Batteries:** CSB (PWHR12500W4FR); **Seismic Kit:** Eaton (P-103000768)


**UUT Properties**

Weight (lbs.)	Dimension (in)			Lowest Natural Frequency (Hz)		
	Depth	Width	Height	Front-Back	Side-Side	Vertical
4,745	42.0	32.2	74.0	10.0	4.7	21.0

**UUT Highest Passed Seismic Run Information**

Building Code	Test Criteria	S <sub>DS</sub> (g)	z/h	I <sub>P</sub>	A <sub>FLX-H</sub> (g)	A <sub>RIG-H</sub> (g)	A <sub>FLX-V</sub> (g)	A <sub>RIG-V</sub> (g)
CBC 2022	ICC-ES AC156	1.83	1.0	1.5	2.93	2.20	1.22	0.49
		1.83	0.0					

**Test Mounting Details:** (Test Report: 71589 Rev.A (UUT8))



The UUT8 was base mounted - rigid to steel floor members using eight (8) 1/2" Grade 5 bolts. The steel floor members were welded to the shake table. Mounting brackets were attached to the UUT using eight (8) M12x25 Class 8.8 bolts. Unit maintained structural integrity and remained functional per manufacturer requirement after shake table test. Contents were included in testing per operating conditions.

TRU Compliance, by Structural Integrity Associates, Inc.

844-TRU-0200 | info@trucompliance.com

# UNIT UNDER TEST (UUT) SUMMARY SHEET

1800524-CR-001-R6

**EATON**

**TRU**  
COMPLIANCE

**Manufacturer:** Eaton Corporation  
**Model Line:** 93PM IBC  
**Model Number:** 9PZABAE50L10010

**Serial Number:** N/A

**UUT 9**

**Product Construction Summary:**

Powder Coated Carbon Steel Framing

**Options/Subcomponent Summary:**

100kVA IBC-L; Remote with Left Sidecar; Frame (Eaton);

**Breakers:** Eaton (HKDC3300WA07S49); **Seismic Kit:** Eaton (P-103000769);

**Batteries:** CSB (PWHR12500W4FR), ENERSYS (0790-6005-C0K00), NORTHSTAR (NSB12540)


**UUT Properties**

Weight (lbs.)	Dimension (in)			Lowest Natural Frequency (Hz)		
	Depth	Width	Height	Front-Back	Side-Side	Vertical
4,841	42.0	40.2	74.0	9.5	5.7	22.0

**UUT Highest Passed Seismic Run Information**

Building Code	Test Criteria	S <sub>DS</sub> (g)	z/h	I <sub>P</sub>	A <sub>FLX-H</sub> (g)	A <sub>RIG-H</sub> (g)	A <sub>FLX-V</sub> (g)	A <sub>RIG-V</sub> (g)
CBC 2022	ICC-ES AC156	1.83	1.0	1.5	2.93	2.20	1.22	0.49
		1.83	0.0					

**Test Mounting Details:** (Test Report: 71589 Rev.A (UUT9))



The UUT9 was base mounted - rigid to steel floor members using twelve (12) 1/2" Grade 5 bolts. The steel floor members were welded to the shake table. Mounting brackets were attached to the UUT using eight (8) M12x25 Class 8.8 bolts (IBC-L) and four (4) M8x20 Class 8.8 bolts (sidecar).

Unit maintained structural integrity and remained functional per manufacturer requirement after shake table test. Contents were included in testing per operating conditions.

TRU Compliance, by Structural Integrity Associates, Inc.

844-TRU-0200 | info@trucompliance.com



# UNIT UNDER TEST (UUT) SUMMARY SHEET

1800524-CR-001-R6

**EATON**

**TRU**  
COMPLIANCE

**Manufacturer:** Eaton Corporation  
**Model Line:** 93PM IAC  
**Model Number:** 9PZD1H000000011

**Serial Number:** N/A

**UUT 10**

**Product Construction Summary:**

Powder Coated Carbon Steel Framing

**Options/Subcomponent Summary:**

50kVA IAC-D; 480 Vin / 208 Vout. Frame (Eaton);

**Breakers:** Eaton (HFD3080L, HKD3175W); **Transformer:** Eaton (WPV50012); **Seismic Kit:** Eaton (P-103000767)


**UUT Properties**

Weight (lbs.)	Dimension (in)			Lowest Natural Frequency (Hz)		
	Depth	Width	Height	Front-Back	Side-Side	Vertical
1,105	42.0	31.3	74.0	11.0	7.9	22.0

**UUT Highest Passed Seismic Run Information**

Building Code	Test Criteria	S <sub>DS</sub> (g)	z/h	I <sub>p</sub>	A <sub>FLX-H</sub> (g)	A <sub>RIG-H</sub> (g)	A <sub>FLX-V</sub> (g)	A <sub>RIG-V</sub> (g)
CBC 2022	ICC-ES AC156	1.83	1.0	1.5	2.93	2.20	1.22	0.49
		1.83	0.0					

**Test Mounting Details:** (Test Report: 71589 Rev.A (UUT10))



The UUT10 was base mounted - rigid to steel floor members using eight (8) 1/2" Grade 5 bolts. The steel floor members were welded to the shake table. Mounting brackets were attached to the UUT using eight (8) M12x25 Class 8.8 bolts. Unit maintained structural integrity and remained functional per manufacturer requirement after shake table test. Contents were included in testing per operating conditions.

TRU Compliance, by Structural Integrity Associates, Inc.

844-TRU-0200 | info@trucompliance.com

# UNIT UNDER TEST (UUT) SUMMARY SHEET

1800524-CR-001-R6

**EATON**

**TRU**  
COMPLIANCE

**Manufacturer:** Eaton Corporation  
**Model Line:** 93PM IAC  
**Model Number:** 9PZG4SBC0001011

**Serial Number:** N/A

**UUT 11**

**Product Construction Summary:**

Powder Coated Carbon Steel Framing

**Options/Subcomponent Summary:**

200kVA IAC-D; 480 Vin / 208 Vout; Frame (Eaton);

**Breakers:** Eaton (FD3225, KD3400F); **Panel Board:** Eaton (122950146, 122950147); **Transformer:** Eaton (WPN19132);

**Seismic Kit:** Eaton (P-103000767)


**UUT Properties**

Weight (lbs.)	Dimension (in)			Lowest Natural Frequency (Hz)		
	Depth	Width	Height	Front-Back	Side-Side	Vertical
2,165	42.0	31.3	74.0	9.5	8.0	22.0

**UUT Highest Passed Seismic Run Information**

Building Code	Test Criteria	S <sub>DS</sub> (g)	z/h	I <sub>P</sub>	A <sub>FLX-H</sub> (g)	A <sub>RIG-H</sub> (g)	A <sub>FLX-V</sub> (g)	A <sub>RIG-V</sub> (g)
CBC 2022	ICC-ES AC156	1.83	1.0	1.5	2.93	2.20	1.22	0.49
		1.83	0.0					

**Test Mounting Details:** (Test Report: 71589 Rev.A (UUT11))



The UUT11 was base mounted - rigid to steel floor members using eight (8) 1/2" Grade 5 bolts. The steel floor members were welded to the shake table. Mounting brackets were attached to the UUT using eight (8) M12x25 Class 8.8 bolts. Unit maintained structural integrity and remained functional per manufacturer requirement after shake table test. Contents were included in testing per operating conditions.

TRU Compliance, by Structural Integrity Associates, Inc.

844-TRU-0200 | info@trucompliance.com



# UNIT UNDER TEST (UUT) SUMMARY SHEET

1800524-CR-001-R6

**EATON**

**TRU**  
COMPLIANCE

**Manufacturer:** Eaton Corporation

**Model Line:** 93PM Uninterruptible Power Supply (UPS)

**Model Number:** 9PV20C0029F20R2

**Serial Number:** N/A

**UUT 12**

**Product Construction Summary:**

Powder Coated Carbon Steel Framing

**Options/Subcomponent Summary:**

200kVA Capacity UPS (4 UPM) + 4 Bkr MBS Sidecar; Frame (Eaton);

**Power Modules:** Eaton (730-D0057); **Static Switches:** Eaton (730-D0021); **Contactors:** Eaton (DILM250/22 (RDC48));

**Breakers:** Eaton (HKD3300W, HKD3400W); **Seismic Kit:** Eaton (P-103000842); **Side Car Seismic Kit:** Eaton (P-103000844)


**UUT Properties**

Weight (lbs.)	Dimension (in)			Lowest Natural Frequency (Hz)		
	Depth	Width	Height	Front-Back	Side-Side	Vertical
1,795	42.0	46.7	74.0	6.4	5.2	6.2

**UUT Highest Passed Seismic Run Information**

Building Code	Test Criteria	S <sub>DS</sub> (g)	z/h	I <sub>P</sub>	A <sub>FLX-H</sub> (g)	A <sub>RIG-H</sub> (g)	A <sub>FLX-V</sub> (g)	A <sub>RIG-V</sub> (g)
CBC 2022	ICC-ES AC156	2.5	1.0	1.5	4.00	3.00	1.67	0.67
		2.5	0.0					

**Test Mounting Details:** (Test Report: 174-9243708-000 (UUT12))



The UUT12 was base mounted - rigid to an aluminum plate using twelve (12) 1/2" Grade 5 bolts and washers torqued to 63 ft./lbs. The aluminum plate was base mounted - rigid to the shake table. Mounting brackets were attached to the UUT using twelve (12) M8x20 Class 8.8 bolts.

Unit maintained structural integrity and remained functional per manufacturer requirement after shake table test. Contents were included in testing per operating conditions.

TRU Compliance, by Structural Integrity Associates, Inc.

844-TRU-0200 | info@trucompliance.com

# UNIT UNDER TEST (UUT) SUMMARY SHEET

1800524-CR-001-R6



**Manufacturer:** Eaton Corporation  
**Model Line:** 93PM IBC  
**Model Number:** 9PZABAE28010010

**UUT 13**

**Serial Number:** N/A

**Product Construction Summary:**

Powder Coated Carbon Steel Framing

**Options/Subcomponent Summary:**

100kVA IBC-L; Line and Match; No Sidecar; Frame (Eaton);

**Batteries:** CSB (PWHR12280W4FR), ENERSYS (12HX300, 12HX500), C&D Dynasty (UPS12-300MR, UPS12-490MR);

**Breakers:** Eaton (HKDDC3300WA07S49); **Seismic Kit:** Eaton (P-103000768)


**UUT Properties**

Weight (lbs.)	Dimension (in)			Lowest Natural Frequency (Hz)		
	Depth	Width	Height	Front-Back	Side-Side	Vertical
3,185	42.0	32.2	74.0	14.6	5.4	> 33.3

**UUT Highest Passed Seismic Run Information**

Building Code	Test Criteria	S <sub>DS</sub> (g)	z/h	I <sub>p</sub>	A <sub>FLX-H</sub> (g)	A <sub>RIG-H</sub> (g)	A <sub>FLX-V</sub> (g)	A <sub>RIG-V</sub> (g)
CBC 2022	ICC-ES AC156	2.29	1.0	1.5	3.66	2.75	1.53	0.61
		2.29	0.0					

**Test Mounting Details:** (Test Report: 174-9243708-000 (UUT13))



The UUT13 was base mounted - rigid to an aluminum plate using eight (8) 1/2" Grade 5 bolts and washers torqued to 63 ft./lbs. The aluminum plate was base mounted - rigid to the shake table. Mounting brackets were attached to the UUT using eight (8) M12x25 Class 8.8 bolts.

Unit maintained structural integrity and remained functional per manufacturer requirement after shake table test. Contents were included in testing per operating conditions.

TRU Compliance, by Structural Integrity Associates, Inc.

844-TRU-0200 | info@trucompliance.com

# UNIT UNDER TEST (UUT) SUMMARY SHEET

1800524-CR-001-R6

EATON

**TRU**  
COMPLIANCE

**Manufacturer:** Eaton Corporation  
**Model Line:** 93PM IBC  
**Model Number:** 9PZUDBN54010010

**Serial Number:** N/A

**UUT 14**

**Product Construction Summary:**

Powder Coated Carbon Steel Framing

**Options/Subcomponent Summary:**

93PM 200 kVA IBC-LHW; Line and Match;

**Batteries:** NORTHSTAR (NSB12540 x40); **Seismic Kit:** Eaton (P-103002072)


**UUT Properties**

Weight (lbs.)	Dimension (in)			Lowest Natural Frequency (Hz)		
	Depth	Width	Height	Front-Back	Side-Side	Vertical
5,082	42.0	34.2	74.0	10.57	9.86	>33.33

**UUT Highest Passed Seismic Run Information**

Building Code	Test Criteria	$S_{DS}$ (g)	$z/h$	$I_p$	$A_{FLX-H}$ (g)	$A_{RIG-H}$ (g)	$A_{FLX-V}$ (g)	$A_{RIG-V}$ (g)
CBC 2022	ICC-ES AC156	2.00	1.0	1.5	3.20	2.40	2.13	0.85
		3.20	0.0					

**Test Mounting Details:** (Test Report: JID 16-00773 Rev.1 (UUT14))



The UUT14 was base mounted - rigid to an aluminum plate using twelve (12) 1/2"-13 Grade 5 hex head bolts, washers, and lock washers torqued to 55 ft./lbs. The Aluminum plate was base mounted - rigid to the shake table. Mounting brackets were attached to the UUT using twelve (12) M8x25 Class 8.8 bolts.

Unit maintained structural integrity and remained functional per manufacturer requirement after shake table test. Contents were included in testing per operating conditions.

TRU Compliance, by Structural Integrity Associates, Inc.

844-TRU-0200 | info@trucompliance.com

# UNIT UNDER TEST (UUT) SUMMARY SHEET



1800524-CR-001-R6

<b>Manufacturer:</b>	Eaton Corporation	<b>UUT 15</b>
<b>Model Line:</b>	93PM Uninterruptible Power Supply (UPS)	
<b>Model Number:</b>	9P640D0029A00R2	
<b>Serial Number:</b>		N/A


**Product Construction Summary:**  
Powder Coated Carbon Steel Framing

**Options/Subcomponent Summary:**  
400 kVA UPS (8 UPM); Frame (Eaton);  
**Seismic Kit:** Eaton (P-103000842, QTY 2)

UUT Properties						
Weight (lbs.)	Dimension (in)			Lowest Natural Frequency (Hz)		
	Depth	Width	Height	Front-Back	Side-Side	Vertical
2,628	42.0	63.9	74.0	20.55	12.91	>33.33

UUT Highest Passed Seismic Run Information									
Building Code	Test Criteria	S <sub>DS</sub> (g)	z/h	I <sub>P</sub>	A <sub>FLX-H</sub> (g)	A <sub>RIG-H</sub> (g)	A <sub>FLX-V</sub> (g)	A <sub>RIG-V</sub> (g)	
CBC 2022	ICC-ES AC156	2.00	1.0	1.5	3.20	2.40	2.13	0.85	
		3.20	0.0						

**Test Mounting Details:** (Test Report: JID 16-00773 Rev.1 (UUT15))



UUT15 was base mounted - rigid to an aluminum plate using sixteen (16) 1/2"-13 Grade 5 hex head bolts, washers and lock washers torqued to 55 ft./lbs. The Aluminum plate was base mounted - rigid to the shake table. Mounting brackets were attached to the UUT using (16) M8x20 Class 8.8 bolts.  
Unit maintained structural integrity and remained functional per manufacturer requirement after shake table test. Contents were included in testing per operating conditions.



# UNIT UNDER TEST (UUT) SUMMARY SHEET

1800524-CR-001-R6

**EATON**

**TRU**  
COMPLIANCE

**Manufacturer:** Eaton Corporation  
**Model Line:** 93PM Uninterruptible Power Supply (UPS)  
**Model Number:** 9GC312A700A02R0

**Serial Number:** EN025UJJ02

**UUT 16**

**Product Construction Summary:**

Powder Coated Carbon Steel Framing

**Options/Subcomponent Summary:**

93PM-L-60kVA; Frame (Eaton);

**Power Modules:** Eaton (730-05211 x3); **Static Switches:** Eaton (730-05213); **Batteries:** CSB (HR1227WFR x160);

**Seismic Kit:** Eaton (P-103000765)


**UUT Properties**

Weight (lbs.)	Dimension (in)			Lowest Natural Frequency (Hz)		
	Depth	Width	Height	Front-Back	Side-Side	Vertical
1,604	42.0	22.0	74.0	10.5	6.6	12.2

**UUT Highest Passed Seismic Run Information**

Building Code	Test Criteria	S <sub>DS</sub> (g)	z/h	I <sub>P</sub>	A <sub>FLX-H</sub> (g)	A <sub>RIG-H</sub> (g)	A <sub>FLX-V</sub> (g)	A <sub>RIG-V</sub> (g)
CBC 2022	ICC-ES AC156	1.83	1.0	1.5	2.93	2.20	1.22	0.49
		1.83	0.0					

**Test Mounting Details:** (Test Report: JID 19-00067 Rev.3 (UUT16))



The UUT16 was base mounted - rigid to an aluminum plate using eight (8) 1/2"-13 Grade 5 bolts, washers, and lock washers torqued to 55 ft./lbs. The aluminum plate was base mounted - rigid to the shake table. Mounting brackets were attached to the UUT using eight (8) M8x20 Class 8.8 bolts.

Unit maintained structural integrity and remained functional per manufacturer requirement after shake table test. Contents were included in testing per operating conditions.

TRU Compliance, by Structural Integrity Associates, Inc.

844-TRU-0200 | info@trucompliance.com

# UNIT UNDER TEST (UUT) SUMMARY SHEET

1800524-CR-001-R6

**EATON**

**TRU**  
COMPLIANCE

**Manufacturer:** Eaton Corporation

**Model Line:** 93PM Uninterruptible Power Supply (UPS)

**Model Number:** 9GK040A000A02R0

**Serial Number:** EN021UJJ05

**UUT 17**

**Product Construction Summary:**

Powder Coated Carbon Steel Framing

**Options/Subcomponent Summary:**

93PM-L-200kVA; Frame (Eaton);

**Power Modules:** Eaton (730-05211 x10); **Static Switches:** Eaton (730-05214); **Seismic Kit:** Eaton (P-103003059)


**UUT Properties**

Weight (lbs.)	Dimension (in)			Lowest Natural Frequency (Hz)		
	Depth	Width	Height	Front-Back	Side-Side	Vertical
1,722	42.0	43.4	74.0	22.4	19.2	>33.3

**UUT Highest Passed Seismic Run Information**

Building Code	Test Criteria	S <sub>DS</sub> (g)	z/h	I <sub>P</sub>	A <sub>FLX-H</sub> (g)	A <sub>RIG-H</sub> (g)	A <sub>FLX-V</sub> (g)	A <sub>RIG-V</sub> (g)
CBC 2022	ICC-ES AC156	1.83	1.0	1.5	2.93	2.20	1.22	0.49
		1.83	0.0					

**Test Mounting Details:** (Test Report: JID 19-00067 Rev.3 (UUT17))



The UUT17 was base mounted - rigid to an aluminum plate using eight (8) 1/2"-13 Grade 5 bolts, washers, and lock washers torqued to 55 ft./lbs. The aluminum plate was base mounted - rigid to the shake table. Mounting brackets were attached to the UUT using (16) M8x20 Class 8.8 bolts.

Unit maintained structural integrity and remained functional per manufacturer requirement after shake table test. Contents were included in testing per operating conditions.

TRU Compliance, by Structural Integrity Associates, Inc.

844-TRU-0200 | info@trucompliance.com



# UNIT UNDER TEST (UUT) SUMMARY SHEET

1800524-CR-001-R6

**EATON**

**TRU**  
COMPLIANCE

**Manufacturer:** Eaton Corporation  
**Model Line:** 93PM IBC  
**Model Number:** 9PZWBAE20010010

**Serial Number:** FT082VXX09

**UUT 18**

**Product Construction Summary:**

Powder Coated Carbon Steel Framing

**Options/Subcomponent Summary:**

432V IBC-SW; No Sidecar; Frame (Eaton); With Monitoring Tabs; Without Thermal Sensor

**Batteries:** CSB (PWHR12200W4FR); **Breakers (DC - Thermal Trip):** Eaton (PDK33K0250TFAN);

**Seismic Kit:** Eaton (P-103005194 x2)



**UUT Properties**

Weight (lbs.)	Dimension (in)			Lowest Natural Frequency (Hz)		
	Depth	Width	Height	Front-Back	Side-Side	Vertical
1,997	42.0	16.9	74.0	12.54	10.04	>33.33

**UUT Highest Passed Seismic Run Information**

Building Code	Test Criteria	S <sub>DS</sub> (g)	z/h	I <sub>P</sub>	A <sub>FLX-H</sub> (g)	A <sub>RIG-H</sub> (g)	A <sub>FLX-V</sub> (g)	A <sub>RIG-V</sub> (g)
CBC 2022	ICC-ES AC156	2.0	1.0	1.5	3.20	2.40	1.67	0.67
		2.5	0.0					

**Test Mounting Details:** (Test Report: JID 24-00216 (UUT2b))



UUT18 was base mounted - rigid using eight (8) Grade 5 SAE 1/2-13 hex bolts, washers and lock washers, torqued to 60ft.-lbs. Mounting brackets were attached to the UUT using eight (8) M8 Class 8.8 bolts. Unit maintained structural integrity and remained functional per manufacturer requirement after shake table test. Contents were included in testing per operating conditions.

TRU Compliance, by Structural Integrity Associates, Inc.

844-TRU-0200 | info@trucompliance.com

# UNIT UNDER TEST (UUT) SUMMARY SHEET

1800524-CR-001-R6

**EATON**

**TRU**  
COMPLIANCE

**Manufacturer:** Eaton Corporation  
**Model Line:** 93PM IBC  
**Model Number:** 9PZWBBE20010210

**Serial Number:** FT082VXX11

**UUT 19**

**Product Construction Summary:**

Powder Coated Carbon Steel Framing

**Options/Subcomponent Summary:**

480V IBC-SW; No Sidecar; Frame (Eaton); With Monitoring Tabs and Thermal Sensor

**Batteries:** CSB (PWHR12200W4FR); **Breakers (DC - Thermal Trip):** Eaton (PDK33K0250TFAN);

**Seismic Kit:** Eaton (P-103005194)


**UUT Properties**

Weight (lbs.)	Dimension (in)			Lowest Natural Frequency (Hz)		
	Depth	Width	Height	Front-Back	Side-Side	Vertical
2,141	42.0	16.9	74.0	12.85	9.09	>33.33

**UUT Highest Passed Seismic Run Information**

Building Code	Test Criteria	S <sub>DS</sub> (g)	z/h	I <sub>p</sub>	A <sub>FLX-H</sub> (g)	A <sub>RIG-H</sub> (g)	A <sub>FLX-V</sub> (g)	A <sub>RIG-V</sub> (g)
CBC 2022	ICC-ES AC156	2.0	1.0	1.5	3.20	2.40	1.67	0.67
		2.5	0.0					

**Test Mounting Details:** (Test Report: JID 24-00216 (UUT3b))



UUT19 was base mounted - rigid using eight (8) Grade 5 SAE 1/2-13 hex bolts, washers and lock washers, torqued to 60ft.-lbs. Mounting brackets were attached to the UUT using eight (8) M8 Class 8.8 bolts. Unit maintained structural integrity and remained functional per manufacturer requirement after shake table test. Contents were included in testing per operating conditions.

TRU Compliance, by Structural Integrity Associates, Inc.

844-TRU-0200 | info@trucompliance.com

# UNIT UNDER TEST (UUT) SUMMARY SHEET

1800524-CR-001-R6

EATON

TRU  
COMPLIANCE

**Manufacturer:** Eaton Corporation

**Model Line:** 93PM IAC

**Model Number:** 9PZR-Custom-1 w/ Convenience Outlet

**Serial Number:** N/A

**UUT 20a**

**Product Construction Summary:**

Powder Coated Carbon Steel Framing. 120V AC Convenience Outlet

**Options/Subcomponent Summary:**

IAC-B; Frame (Eaton)

**Kirk Key System:** Eaton (P-116000097); **Breakers (AC - Thermal Magnetic):** Eaton (PDG33K0400TFAN, PDG43M0600TFAN);

**Breakers (AC - Electronic Trip):** Eaton (PDG23G0225B2NL, PDG53P1200E2NM); **Seismic Kit:** Eaton (P-10300767);

**Transformers:** Eaglerise (149502123), Eaton (C0025E2A);

120V AC Convenience Outlet


**UUT Properties**

Weight (lbs.)	Dimension (in)			Lowest Natural Frequency (Hz)		
	Depth	Width	Height	Front-Back	Side-Side	Vertical
733	42.0	31.5	73.5	16.07	17.52	>33.33

**UUT Highest Passed Seismic Run Information**

Building Code	Test Criteria	S <sub>DS</sub> (g)	z/h	I <sub>p</sub>	A <sub>FLX-H</sub> (g)	A <sub>RIG-H</sub> (g)	A <sub>FLX-V</sub> (g)	A <sub>RIG-V</sub> (g)
CBC 2022	ICC-ES AC156	2.0	1.0	1.5	3.20	2.40	1.67	0.67
		2.5	0.0					

**Test Mounting Details:** (Test Report: JID 24-00216 (UUT4a))



UUT20a was base mounted - rigid using eight (8) Grade 5 SAE 1/2-13 hex bolts, washers and lock washers, torqued to 60ft.-lbs.

Mounting brackets were attached to the UUT using eight (8) M12 Class 8.8 bolts.

Unit maintained structural integrity and remained functional per manufacturer requirement after shake table test. Contents were included in testing per operating conditions.

TRU Compliance, by Structural Integrity Associates, Inc.

844-TRU-0200 | info@trucompliance.com



# UNIT UNDER TEST (UUT) SUMMARY SHEET

1800524-CR-001-R6



**Manufacturer:** Eaton Corporation  
**Model Line:** 93PM IAC  
**Model Number:** 9PZR-Custom-1

**Serial Number:** N/A

**UUT 20b**

**Product Construction Summary:**

Powder Coated Carbon Steel Framing

**Options/Subcomponent Summary:**

IAC-B; Frame (Eaton)

**Breakers (AC - Thermal Magnetic):** Eaton (PDG13G0125TFFJ, PDG43M0600TFAN);

**Breakers (DC - Thermal Trip):** Eaton (PDK23M0175TFFJ, PDK33K0500TFAJ); **Seismic Kit:** Eaton (P-103000767)



**UUT Properties**

Weight (lbs.)	Dimension (in)			Lowest Natural Frequency (Hz)		
	Depth	Width	Height	Front-Back	Side-Side	Vertical
664	42.0	31.5	73.5	15.74	14.46	>33.33

**UUT Highest Passed Seismic Run Information**

Building Code	Test Criteria	S <sub>DS</sub> (g)	z/h	I <sub>P</sub>	A <sub>FLX-H</sub> (g)	A <sub>RIG-H</sub> (g)	A <sub>FLX-V</sub> (g)	A <sub>RIG-V</sub> (g)
CBC 2022	ICC-ES AC156	2.0	1.0	1.5	3.20	2.40	1.67	0.67
		2.5	0.0					

**Test Mounting Details:** (Test Report: JID 24-00216 (UUT4b))



UUT20b was base mounted - rigid using eight (8) Grade 5 SAE 1/2-13 hex bolts, washers and lock washers, torqued to 60ft.-lbs.

Mounting brackets were attached to the UUT using eight (8) M12 Class 8.8 bolts.

Unit maintained structural integrity and remained functional per manufacturer requirement after shake table test. Contents were included in testing per operating conditions.

TRU Compliance, by Structural Integrity Associates, Inc.

844-TRU-0200 | info@trucompliance.com

# UNIT UNDER TEST (UUT) SUMMARY SHEET

1800524-CR-001-R6

**EAT•N**

**TRU**  
COMPLIANCE

**Manufacturer:** Eaton Corporation

**Model Line:** 93PM IAC

**Model Number:** 9PZR-Custom-2

**Serial Number:** N/A

**UUT 21**

**Product Construction Summary:**

Powder Coated Carbon Steel Framing

**Options/Subcomponent Summary:**

IAC-B; Frame (Eaton)

**Breakers (AC- Electronic Trip):** Eaton (PDG63P2000E2NM); **Seismic Kit:** Eaton (P-103000767)


**UUT Properties**

Weight (lbs.)	Dimension (in)			Lowest Natural Frequency (Hz)		
	Depth	Width	Height	Front-Back	Side-Side	Vertical
694	42.0	31.5	73.5	14.89	17.52	24.67

**UUT Highest Passed Seismic Run Information**

Building Code	Test Criteria	S <sub>DS</sub> (g)	z/h	I <sub>P</sub>	A <sub>FLX-H</sub> (g)	A <sub>RIG-H</sub> (g)	A <sub>FLX-V</sub> (g)	A <sub>RIG-V</sub> (g)
CBC 2022	ICC-ES AC156	2.0	1.0	1.5	3.20	2.40	1.67	0.67
		2.5	0.0					

**Test Mounting Details:** (Test Report: JID 24-00216 (UUT5))



UUT21 was base mounted - rigid using eight (8) Grade 5 SAE 1/2-13 hex bolts, washers and lock washers, torqued to 60ft.-lbs.

Mounting brackets were attached to the UUT using eight (8) M12 Class 8.8 bolts.

Unit maintained structural integrity and remained functional per manufacturer requirement after shake table test. Contents were included in testing per operating conditions.

TRU Compliance, by Structural Integrity Associates, Inc.

844-TRU-0200 | info@trucompliance.com