



DEPARTMENT OF HEALTH CARE ACCESS AND INFORMATION
OFFICE OF STATEWIDE HOSPITAL PLANNING AND DEVELOPMENT

APPLICATION FOR HCAI SPECIAL SEISMIC
CERTIFICATION PREAPPROVAL (OSP)

OFFICE USE ONLY

APPLICATION #: OSP-0412

HCAI Special Seismic Certification Preapproval (OSP)

Type: ☐ New ☒ Renewal

Manufacturer Information

Manufacturer: Caterpillar (N.I.) Ltd.

Manufacturer's Technical Representative: Ciaran O'Flaherty

Mailing Address: Old Glenarm Road, Larne, Northern Ireland, United Kingdom BT401EJ

Telephone: +44-28-2826-5348 Email: oflaherty_ciaran@cat.com

Product Information

Product Name: Emergency and Standby Power Systems

Product Model Number(s): C27/C32/3512/3516/C175

Product Category: Emergency and Standby Power Systems

Product Sub-Category: Generators

General Description: Diesel Powered Generators & Control Panels

Mounting Description: See Certified Product Tables

Tested Seismic Enhancements: Seismic enhancements made to the test units and/or modifications required to address anomalies during the tests shall be incorporated into the production units.

Applicant Information

Applicant Company Name: TRU Compliance, by Structural Integrity Associates, Inc.

Contact Person: Victoria Ahrens

Mailing Address: 233 SW Wilson Ave, Suite 101, Bend, OR 97702

Telephone: (541) 292-5820 Email: vahrens@structint.com

Title: Certification Engineer



**DEPARTMENT OF HEALTH CARE ACCESS AND INFORMATION
OFFICE OF STATEWIDE HOSPITAL PLANNING AND DEVELOPMENT**

California Licensed Structural Engineer Responsible for the Engineering and Test Report(s)

Company Name: STRUCTURAL INTEGRITY ASSOCIATES, INC.

Name: LACHEZAR HANDZHIYSKI California License Number: S6515

Mailing Address: 5215 Hellyer Avenue, Suite 210, San Jose, CA 95138

Telephone: (669) 437-0200 Email: Lhandzhiyski@StructInt.com

Certification Method

☐ GR-63-Core ☒ ICC-ES AC156 ☐ IEEE 344 ☐ IEEE 693 ☐ NEBS 3
☐ Other (Please Specify): _____

Testing Laboratory

Company Name: U.S. ARMY ENGINEER RESEARCH AND DEVELOPMENT CENTER, CONSTRUCTION ENGINEERING RESEARCH LABORATORY (CERL)

Contact Person: James Wilcoski

Mailing Address: 2902 Newmark Dr., Champaign IL 61822-1076

Telephone: (217) 373-4565 Email: James.wilcoski@usace.army.mil

Company Name: ENVIRONMENTAL TESTING LABORATORIES, INC. (ETL)

Contact Person: Jeremy Lange

Mailing Address: 11034 Indian Trail, Dallas TX 75229-3513

Telephone: (972) 247-9657 Email: Jeremy@etldallas.com

Company Name: UNIVERSITY OF CALIFORNIA, BERKELEY (PEER)

Contact Person: Amarnath Kasalanati

Mailing Address: 325 Davis Hall, Berkeley CA 94720-1729

Telephone: (510) 642-3437 Email: Amarnath1@berkeley.edu

Company Name: UNIVERSITY OF NEVADA, RENO (UNR)

Contact Person: Patrick N Laplace

Mailing Address: 1664 N. Virginia Street, Reno NV 89557

Telephone: (775) 784-6937 Email: Laplace@unr.edu



DEPARTMENT OF HEALTH CARE ACCESS AND INFORMATION
OFFICE OF STATEWIDE HOSPITAL PLANNING AND DEVELOPMENT

Seismic Parameters

Design Basis of Equipment or Components (F_p/W_p) = 4.50 (Genset: $SDS=2.00$ @ $z/h=1$); 2.40 (Genset: $SDS=3.20$ @ $z/h=0$);
1.50 (Ctrl Panels: $SDS=2.00$ @ $z/h=1$); 1.44 (Ctrl Panel: $SDS=3.20$ @ $z/h=0$)

SDS (Design spectral response acceleration at short period, g) = 2.00 ($z/h = 1$); 3.20 ($z/h = 0$)

a_p (Amplification factor) = 2.5

R_p (Response modification factor) = 2.0 (Gensets Isolated); 6.0 (Control Panels)

Ω_0 (System overstrength factor) = 2.0

I_p (Importance factor) = 1.5

z/h (Height ratio factor) = 1 and 0

Natural frequencies (Hz) = See Attachment

Overall dimensions and weight = See Attachment

HCAI Approval (For Office Use Only) - Approval Expires on 07/01/2032

Date: 7/1/2025

Name: Mohammad Karim

BY: Mohammad Karim

Title: Supervisor, Health Facilities

Special Seismic Certification Valid Up to: SDS (g) = 2.0

z/h = 1

Condition of Approval (if applicable):

SPECIAL SEISMIC CERTIFICATION CERTIFIED COMPONENT MATRIX

TRU PROJECT NO. 2100427, Rev. 6



Manufacturer: Caterpillar Inc.						TABLE 1		
Model Line: C27/C32/3512/3516/C175 Generator Set								
Certified Product Construction Summary: Carbon Steel Base. Carbon Steel Enclosure (C27/C32). Carbon steel UL-142 fuel tank.								
Certified Options Summary: C27 & C32 available with and without fuel tank (1000 gal. or 2000 gal.) and enclosure. C175-16 available with and without radiator.								
Mounting Configuration: On fuel tank: base mounted - rigid with internal isolation. Off fuel tank: base mounted - isolated Note: Installed mounting must be of similar configuration and equivalent strength and stiffness to those tested.								
Building Code: CBC 2022						Seismic Certification Limits: $S_{DS}= 2.0 g \quad z/h=1.0$ $S_{DS}= 3.2 g \quad z/h=0.0$		$I_p = 1.5$
Model Line	Model	Dimensions (in)			Weight (lbs.)	Notes	UUT	
		Depth	Width	Height				
C27 (≤800 kW)	Open – Min. package	163.1	72.0	87.0	14,050		Extrap.	
	Open – Max. package	172.0	84.0	86.0	14,050		Extrap.	
	Enclosed – No tank	300.0	100.0	111.9	22,827		Extrap.	
	Enclosed – 1000 gal.	300.0	100.0	127.0	36,400		1	
	Enclosed - 2000 gal.	300.0	100.0	136.0	43,660		Interp.	
C32 (≤1250 kW)	Open – Min. package	166.7	79.1	85.0	18,200		Interp.	
	Open – Max. package	190.0	88.0	119.0	18,540		10	
	Enclosed – No tank	300.0	100.0	111.9	25,300		Interp.	
	Enclosed – 1000 gal.	300.0	100.0	127.0	38,806		Interp.	
	Enclosed - 2000 gal.	300.0	100.0	136.0	46,130		2	
C32B (≤1500 kW)	Open - Min. package	191.4	89.3	100.6	20,177		Interp.	
	Open - Max. package	200.0	96.0	100.6	21,750		20	
3512 (≤1250 kW)	Min. package	199.0	77.8	93.2	34,620		Interp.	
	Max. package	212.6	81.6	93.2	34,620		Interp.	
3512B (≤1500 kW)	Max. package	231.0	78.0	93.0	33,204		Interp.	
3512B-HD (≤1500 kW)	Max. package	231.0	78.0	93.0	33,689		Interp.	
3512C (≤1500 kW)	Max. package	233.1	89.8	110.0	38,688		Interp.	
3512C-HD (≤1750 kW)	Max. package	243.2	89.8	110.0	40,660		Interp.	
3516 (≤1600 kW)	Min. package	232.9	90.0	93.2	41,796		Interp.	
	Max. package	246.0	90.0	93.2	41,796		Interp.	
3516B (≤2250 kW)	Max. package	275.0	102.0	98.0	39,666		Interp.	
3516B-HD (≤2000 kW)	Max. package	272.0	90.0	98.0	39,913		Interp.	
3516C (≤2000 kW)	Min. package	253.3	93.7	116.5	44,708		Interp.	
	Max. package	271.9	93.7	116.5	44,708		Interp.	

TRU Compliance, by Structural Integrity Associates, Inc.

844-TRU-0200 | info@trucompliance.com

TRU PROJECT NO. 2100427, Rev. 6

[illegible]

TRU PROJECT NO. 2100427, Rev. 6

[illegible]

SPECIAL SEISMIC CERTIFICATION CERTIFIED SUBCOMPONENT MATRIX

TRU PROJECT NO. 2100427, Rev. 6



Manufacturer: Caterpillar Inc.		Table Description: Standard Components			TABLE 3
Model Line: C27/C32/3512/3516/C175 Generator Set					
Building Code: CBC 2022		Seismic Certification Limits:		$S_{DS} = 2.0 g \quad z/h = 1.0$ $S_{DS} = 3.2 g \quad z/h = 0.0$	$I_P = 1.5$
Component Type	Manufacturer	Model	Description	Notes	UUT
Radiator ¹	AKG	25.5SF		939 lbs.	1
		27.5SF		1,433 lbs.	2
		AB23	508-8112 / 508-8113	701 lbs. / 792 lbs.	Interp.
		AB24		1236 lbs.	15a
		AB26		1355 lbs.	15b
	Young Touchstone	44SF		6,356 lbs.	Extrap.
		50SF		7,535 lbs.	Extrap.
		56SF		8,008 lbs.	3
		64SF		8,645 lbs.	Interp.
		73SF		9,324 lbs.	Interp.
		84SF		12,400 lbs.	4
	Modine	25SF		1,774 lbs.	10
		A38AV		2,161 lbs.	20
	Caterpillar Inc.	A48	Caterpillar designed with Modine coolers	2,428 lbs.	14a
		A59 ²	Caterpillar designed with Yinlun coolers	4,150 lbs.	21
		A59	Caterpillar designed with Modine coolers	4,758 lbs.	Interp.
		A68 ²	Caterpillar designed with Yinlun coolers	4,800 lbs.	22
		A68	Caterpillar designed with Modine coolers	5,102 lbs.	12
		69SF	Caterpillar designed with Modine coolers	8,884 lbs.	Interp.
		81SF	Caterpillar designed with Modine coolers	9,965 lbs.	11

Notes:
1. Radiators are documented with dry weight.
2. Radiators shall not have any rigid connections to other components, except for the tested connections at the base.


Notes:

- Radiators are documented with dry weight.
- Radiators shall not have any rigid connections to other components, except for the tested connections at the base.


TRU Compliance, by Structural Integrity Associates, Inc.

844-TRU-0200 | info@trucompliance.com


TRU PROJECT NO. 2100427, Rev. 6



TRU PROJECT NO. 2100427, Rev. 6



TRU PROJECT NO. 2100427, Rev. 6



UNIT UNDER TEST (UUT) SUMMARY SHEET

TRU PROJECT NO. 2100427, Rev. 6



Manufacturer: Caterpillar Inc.								
Model Line: C27/C32/3512/3516/C175 Generator Set								
UUT	Unit Description (Mounting)	Report Number (UUT#)	Testing Lab	Year Tested	ISO 17025 Accredited?	S _{DS}	z/h	I _p
1	C27 Gen. Set - Enclosed w/ 1000 Gal. Tank (base mounted - rigid)	2013-0764-TR-001 (UUT1)	ERDC-CERL	2014	No ¹	2.00 3.20	1.0 0.0	1.5
2	C32 Gen. Set - Enclosed w/ 2000 Gal. Tank (base mounted - rigid)	2013-0764-TR-001 (UUT2)	ERDC-CERL	2014	No ¹	2.00 3.20	1.0 0.0	1.5
3	3516C HD Generator Set (base mounted - isolated)	2013-0764-TR-001 (UUT3)	ERDC-CERL	2014	No ¹	2.00 3.20	1.0 0.0	1.5
4	C175-16 Generator Set (base mounted - isolated)	2013-0764-TR-001 (UUT4)	ERDC-CERL	2014	No ¹	2.00 3.20	1.0 0.0	1.5
5	NOT USED							
6a	ICE Box - min (base mounted - rigid)	14175, Rev. 1 (UUT6 Rigid)	Environmental Testing Lab (ETL)	2016	Yes	2.00 3.20	1.0 0.0	1.5
6b	ICE Box - min (base mounted - isolated)	14175, Rev. 1 (UUT6 Isolated)	Environmental Testing Lab (ETL)	2016	Yes	2.00 3.20	1.0 0.0	1.5
7a	ICE Box - max (base mounted - rigid)	14175, Rev. 1 (UUT7 Rigid)	Environmental Testing Lab (ETL)	2016	Yes	2.00 3.20	1.0 0.0	1.5
7b	ICE Box - max (base mounted - isolated)	14175, Rev. 1 (UUT7 Isolated)	Environmental Testing Lab (ETL)	2016	Yes	2.00 3.20	1.0 0.0	1.5
8	ICE Box 1 (wall mounted - rigid)	14175, Rev. 1 (UUT8)	Environmental Testing Lab (ETL)	2016	Yes	2.00 3.20	1.0 0.0	1.5
9	ICE Box 2 (wall mounted - rigid)	14175, Rev. 1 (UUT9)	Environmental Testing Lab (ETL)	2016	Yes	2.00 3.20	1.0 0.0	1.5
Notes: 1. ERDC-CERL is not ISO 17025 accredited but has been reviewed by TRU Compliance and found to meet the requirements for ICC-ES AC156 testing. Review form is on file with TRU Compliance.								

TRU Compliance, by Structural Integrity Associates, Inc.

844-TRU-0200 | info@trucompliance.com

UNIT UNDER TEST (UUT) SUMMARY SHEET

TRU PROJECT NO. 2100427, Rev. 6



Manufacturer: Caterpillar Inc.								
Model Line: C27/C32/3512/3516/C175 Generator Set								
UUT	Unit Description (Mounting)	Report Number (UUT#)	Testing Lab	Year Tested	ISO 17025 Accredited?	S _{DS}	z/h	I _p
10	C32 - Generator Set (base mounted - isolated)	1700630-TR-001 (UUT10)	Pacific Earthquake (PEER)	2017	Yes	2.00 3.20	1.0 0.0	1.5
11	3516E - Generator Set (base mounted - isolated)	1700630-TR-001 (UUT11)	Pacific Earthquake (PEER)	2017	Yes	2.00 3.20	1.0 0.0	1.5
12	3516C - Generator Set (base mounted - isolated)	1900323-TR-001 (UUT1)	ERDC-CERL	2020	No ¹	2.00 3.20	1.0 0.0	1.5
13	NOT USED							
14a	3512 Opt Radiator (base mounted - isolated)	2100427-TR-001 (UUT1.1)	Environmental Testing Lab (ETL)	2022	Yes	2.00 3.20	1.0 0.0	1.5
14b	3512 Fresco Rad (base mounted - isolated)	2100427-TR-001 (UUT1.2)	Environmental Testing Lab (ETL)	2022	Yes	2.00 3.20	1.0 0.0	1.5
15a	C32 49CTD Rad. (base mounted - isolated)	2100427-TR-001 (UUT2.1)	Environmental Testing Lab (ETL)	2022	Yes	2.00 3.20	1.0 0.0	1.5
15b	C32 49CTD Rad. (base mounted - isolated)	2100427-TR-001 (UUT2.2)	Environmental Testing Lab (ETL)	2022	Yes	2.00 3.20	1.0 0.0	1.5
16	Doghouse w/ ECS 100, ECS 200 & GCCP1.2 (base mounted - isolated)	2300056-TR-001 (UUT1)	Environmental Testing Lab (ETL)	2023	Yes	2.00 3.20	1.0 0.0	1.5
17	Cat ECS 100 (622-3612 & 621-9888) (wall mounted - rigid)	2300056-TR-001 (UUT2)	Environmental Testing Lab (ETL)	2023	Yes	2.00 3.20	1.0 0.0	1.5
18	Cat GCCP1.2 (634-5258) (wall mounted - rigid)	2300056-TR-001 (UUT3)	Environmental Testing Lab (ETL)	2023	Yes	2.00 3.20	1.0 0.0	1.5

Notes:

1. ERDC-CERL is not ISO 17025 accredited but has been reviewed by TRU Compliance and found to meet the requirements for ICC-ES AC156 testing. Review form is on file with TRU Compliance.

UNIT UNDER TEST (UUT) SUMMARY SHEET

TRU PROJECT NO. 2100427, Rev. 6



Manufacturer: Caterpillar Inc. Model Line: C27/C32/3512/3516/C175 Generator Set								
UUT	Unit Description (Mounting)	Report Number (UUT#)	Testing Lab	Year Tested	ISO 17025 Accredited?	S _{DS}	z/h	I _p
19	Cat ECS 200 (631-2323) (wall mounted - rigid)	2300056-TR-001 (UUT4)	Environmental Testing Lab (ETL)	2023	Yes	2.00 3.20	1.0 0.0	1.5
20	C32B Gen. Set (base mounted - isolated)	2301377-TR-001 (UUT1)	ERDC-CERL	2024	No ¹	2.00 3.20	1.0 0.0	1.5
21	A59 Radiator (base mounted - isolated)	2400776-TR-001 (UUT1)	ERDC-CERL	2024	No ¹	2.00 3.20	1.0 0.0	1.5
22	A68 Radiator (base mounted - isolated)	2400776-TR-001 (UUT2)	ERDC-CERL	2024	No ¹	2.00 3.20	1.0 0.0	1.5
23	Doghouse w/ ECS 100 Panel with RS485 Module (base mounted - isolated)	2551830-TR-001 (UUT1)	University of Nevada, Reno (UNR)	2025	Yes	2.00 3.20	1.0 0.0	1.5
24	ECS100 Panel with RS485 Module (wall mounted - rigid)	2551830-TR-001 (UUT2)	University of Nevada, Reno (UNR)	2025	Yes	2.00 3.20	1.0 0.0	1.5

Notes:
 1. ERDC-CERL is not ISO 17025 accredited but has been reviewed by TRU Compliance and found to meet the requirements for ICC-ES AC156 testing. Review form is on file with TRU Compliance.

UNIT UNDER TEST (UUT) SUMMARY SHEET

TRU PROJECT NO. 2100427, Rev. 6



Manufacturer: Caterpillar Inc. Model Line: C27/C32/3512/3516/C175 Generator Set Model Number: C27 Generator Set – Enclosed w/ 1000 Gal. Tank Serial Number: N/A						<h2 style="text-align: center;">UUT 1</h2>			
Test Report: 2013-0764-TR-001 (UUT1)									
UUT Properties									
Weight (lbs.)	Dimension (in)			Lowest Natural Frequency (Hz)					
	Depth	Width	Height	Front-Back	Side-Side	Vertical			
36,400	300.0	100.0	127.0	4.6	4.0	8.0			
UUT Highest Passed Seismic Run Information									
Building Code	Test Criteria	S _{DS} (g)	z/h	I _P	A _{FLX-H} (g)	A _{RIG-H} (g)	A _{FLX-V} (g)	A _{RIG-V} (g)	
CBC 2022	ICC-ES AC156	2.0	1.0	1.5	3.20	2.40	2.13	0.85	
		3.2	0.0						
Product Construction Summary:					Test Mounting Details:				
Carbon steel enclosure, carbon steel base, carbon steel UL-142 fuel tank.									
Options/Subcomponent Summary:									
Description		Part Number							
C27 (≤800 kW)		Enclosed - 1000 gal							
Battery Charger (Stored Energy System)		NRG 24							
Electrical Panel (Square D)		QO Load Center							
Generator (Leroy-Somer)		1200 Frame							
Global Design Box w/ EMCP 4 Controller (Caterpillar)		Base and side extension box							
Jacket Water Heater (Hotstart)		CSM Hotflow - 9kW							
Louvers (Ruskin)		396-5818							
Molded Case Circuit Breaker (Schneider)		P Frame							
Radiator (AKG)		25.5 SF							
Silencer (Miratech)		3972005							
Spacer Heater (Berko)		HUHAA							
					UUT1 was base mounted - rigid to test fixture using sixteen (16) 3/4” Grade 8 bolts and is internally isolated with six (6) M4SSH-57K-400 spring isolators. Twenty-four (24) 5/8” Grade 8 bolts are used to mount the isolators to the fuel tank. Unit maintained structural integrity and remained functional per manufacturer requirement after shake table test. Contents were included in testing per operating conditions.				

TRU Compliance, by Structural Integrity Associates, Inc.

844-TRU-0200 | info@trucompliance.com

UNIT UNDER TEST (UUT) SUMMARY SHEET

TRU PROJECT NO. 2100427, Rev. 6



Manufacturer: Caterpillar Inc. Model Line: C27/C32/3512/3516/C175 Generator Set Model Number: C32 Generator Set – Enclosed w/ 2000 Gal. Tank Serial Number: N/A						UUT 2			
Test Report: 2013-0764-TR-001 (UUT2)									
UUT Properties									
Weight (lbs.)	Dimension (in)			Lowest Natural Frequency (Hz)					
	Depth	Width	Height	Front-Back	Side-Side	Vertical			
46,130	300.0	100.0	136.0	4.3	3.8	8.0			
UUT Highest Passed Seismic Run Information									
Building Code	Test Criteria	S _{DS} (g)	z/h	I _P	A _{FLX-H} (g)	A _{RIG-H} (g)	A _{FLX-V} (g)	A _{RIG-V} (g)	
CBC 2022	ICC-ES AC156	2.0	1.0	1.5	3.20	2.40	2.13	0.85	
		3.2	0.0						
Product Construction Summary:					Test Mounting Details:				
Carbon steel enclosure, carbon steel base, carbon steel UL-142 fuel tank.					 <p>UUT2 was base mounted - rigid to test fixture using sixteen (16) 3/4" Grade 8 bolts and is internally isolated with six (6) M4SSH-57K-400 spring isolators. Twenty-four (24) 5/8" Grade 8 bolts are used to mount the isolators to the fuel tank.</p> <p>Unit maintained structural integrity and remained functional per manufacturer requirement after shake table test. Contents were included in testing per operating conditions.</p>				
Options/Subcomponent Summary:									
Description		Part Number							
C32 (≤1250 kW)		Enclosed - 2000 gal.							
Battery Charger (Stored Energy System)		NRG 24							
Electrical Panel (Square D)		QO Load Center							
Generator (Leroy-Somer)		1400 Frame							
Global Design Box w/ EMCP 4 Controller (Caterpillar)		Base, side and rear extension box							
Jacket Water Heater (Hotstart)		CSM Hotflow - 9kW							
Louvers (Ruskin)		396-5818							
Molded Case Circuit Breaker (Schneider)		NT Frame							
Radiator (AKG)		27.5 SF							
Silencer (Silex)		3906968							
Spacer Heater (Berko)		HUHAA							

UNIT UNDER TEST (UUT) SUMMARY SHEET

TRU PROJECT NO. 2100427, Rev. 6



Manufacturer: Caterpillar Inc. Model Line: C27/C32/3512/3516/C175 Generator Set Model Number: 3516C HD Generator Set Serial Number: N/A						UUT 3			
Test Report: 2013-0764-TR-001 (UUT3)									
UUT Properties									
Weight (lbs.)	Dimension (in)			Lowest Natural Frequency (Hz)					
	Depth	Width	Height	Front-Back	Side-Side	Vertical			
44,175	277.0	120.0	109.0	3.7	3.9	8.2			
UUT Highest Passed Seismic Run Information									
Building Code	Test Criteria	S _{DS} (g)	z/h	I _P	A _{FLX-H} (g)	A _{RIG-H} (g)	A _{FLX-V} (g)	A _{RIG-V} (g)	
CBC 2022	ICC-ES AC156	2.0	1.0	1.5	3.20	2.40	2.13	0.85	
		3.2	0.0						
Product Construction Summary:					Test Mounting Details:				
Carbon Steel Base									
Options/Subcomponent Summary:									
Description		Part Number							
3516C-HD (≤2500 kW)		Max. Package							
Generator (Leroy-Somer)		3000 Frame							
Jacket Water Heater (Hotstart)		CSM Hotflow - 9kW							
Radiator (Young Touchstone)		56SF							
UUT3 was base mounted - isolated to test fixture using sixteen (16) VMC M2SSH-1E spring isolators. Sixty-four (64) 3/4" Grade 8 bolts are used to mount the isolators to the test fixture. Unit maintained structural integrity and remained functional per manufacturer requirement after shake table test. Contents were included in testing per operating conditions.									

UNIT UNDER TEST (UUT) SUMMARY SHEET

TRU PROJECT NO. 2100427, Rev. 6



Manufacturer: Caterpillar Inc. Model Line: C27/C32/3512/3516/C175 Generator Set Model Number: C175-16 Generator Set Serial Number: N/A						UUT 4			
Test Report: 2013-0764-TR-001 (UUT4)									
UUT Properties									
Weight (lbs.)	Dimension (in)			Lowest Natural Frequency (Hz)					
	Depth	Width	Height	Front-Back	Side-Side	Vertical			
61,192	307.0	114.0	134.0	3.5	3.3	7.7			
UUT Highest Passed Seismic Run Information									
Building Code	Test Criteria	S _{DS} (g)	z/h	I _P	A _{FLX-H} (g)	A _{RIG-H} (g)	A _{FLX-V} (g)	A _{RIG-V} (g)	
CBC 2022	ICC-ES AC156	2.0	1.0	1.5	3.20	2.40	2.13	0.85	
		3.2	0.0						
Product Construction Summary:					Test Mounting Details:				
Carbon Steel Base									
Options/Subcomponent Summary:									
Description		Part Number							
C175-16 (≤3100 kW)		Max. Package							
Generator (Leroy-Somer)		3000 Frame							
Jacket Water Heater (Hotstart)		CSM Hotflow - 12kW							
Radiator (Young Touchstone)		84SF							
UUT4 was base mounted - isolated to test fixture using eighteen (18) VMC M2SSH-1E spring isolators. Seventy-two (72) 3/4" Grade 8 bolts are used to mount the isolators to the test fixture. Unit maintained structural integrity and remained functional per manufacturer requirement after shake table test. Contents were included in testing per operating conditions.									

UNIT UNDER TEST (UUT) SUMMARY SHEET

TRU PROJECT NO. 2100427, Rev. 6



Manufacturer: Caterpillar Inc. Model Line: C27/C32/3512/3516/C175 Generator Set Model Number: ICE Box - Min Serial Number: N/A						UUT 6a			
Test Report: 14175 (UUT6 Rigid)									
UUT Properties									
Weight (lbs.) ¹	Dimension (in)			Lowest Natural Frequency (Hz)					
	Depth	Width	Height	Front-Back	Side-Side	Vertical			
3,270	45.0	37.0	66.0	8.26	13.93	14.83			
UUT Highest Passed Seismic Run Information									
Building Code	Test Criteria	S _{DS} (g)	z/h	I _P	A _{FLX-H} (g)	A _{RIG-H} (g)	A _{FLX-V} (g)	A _{RIG-V} (g)	
CBC 2022	ICC-ES AC156	2.0	1.0	1.5	3.20	2.40	2.13	0.85	
		3.2	0.0						
Product Construction Summary:					Test Mounting Details:				
Carbon Steel Enclosure									
Options/Subcomponent Summary:									
Description		Part Number							
ICE Box (Caterpillar)		Base controller, rear extension box, and small display							
ICE Control Panel w/ EMCP 4 Controller (Caterpillar)		Small Display							
Test Mounting Details:					<p>UUT6a was base mounted - rigid to the test fixture using six (6) 3/4" Grade 8 bolts.</p> <p>Unit maintained structural integrity and remained functional per manufacturer requirement after shake table test. Contents were included in testing per operating conditions.</p>				
¹ Weight is of UUT and the equipment mounting skid.									

UNIT UNDER TEST (UUT) SUMMARY SHEET

TRU PROJECT NO. 2100427, Rev. 6



Manufacturer: Caterpillar Inc. Model Line: C27/C32/3512/3516/C175 Generator Set Model Number: ICE Box - Min Serial Number: N/A						UUT 6b			
						Test Report: 14175 (UUT6 Isolated)			
UUT Properties									
Weight (lbs.) ¹	Dimension (in)			Lowest Natural Frequency (Hz)					
	Depth	Width	Height	Front-Back	Side-Side	Vertical			
3,270	45.0	37.0	66.0	3.15	4.00	7.74			
UUT Highest Passed Seismic Run Information									
Building Code	Test Criteria	S _{DS} (g)	z/h	I _P	A _{FLX-H} (g)	A _{RIG-H} (g)	A _{FLX-V} (g)	A _{RIG-V} (g)	
CBC 2022	ICC-ES AC156	2.0	1.0	1.5	3.20	2.40	2.13	0.85	
		3.2	0.0						
Product Construction Summary:					Test Mounting Details:				
Carbon Steel Enclosure									
Options/Subcomponent Summary:									
Description		Part Number							
ICE Box (Caterpillar)		Base controller, rear extension box, and small display							
ICE Control Panel w/ EMCP 4 Controller (Caterpillar)		Small Display							
Test Mounting Details:					<p>UUT6b was base mounted - isolated to the fixture using six (6) Mason SSLFH-C-1750 isolators using one (1) 5/8" Grade 8 bolt each. The isolators were mounted to the table using two (2) 5/8" Grade 8 bolts each.</p> <p>Unit maintained structural integrity and remained functional per manufacturer requirement after shake table test. Contents were included in testing per operating conditions.</p>				
<p>¹ Weight is of UUT and the equipment mounting skid.</p>									

UNIT UNDER TEST (UUT) SUMMARY SHEET

TRU PROJECT NO. 2100427, Rev. 6




Manufacturer: Caterpillar Inc. Model Line: C27/C32/3512/3516/C175 Generator Set Model Number: ICE Box - Max Serial Number: N/A						UUT 7a			
						Test Report: 14175 (UUT7 Rigid)			
UUT Properties									
Weight (lbs.) ¹	Dimension (in) ²			Lowest Natural Frequency (Hz)					
	Depth	Width	Height	Front-Back	Side-Side	Vertical			
3,270	45.0	84.0	66.0	5.99	7.62	31.02			
UUT Highest Passed Seismic Run Information									
Building Code	Test Criteria	S _{DS} (g)	z/h	I _P	A _{FLX-H} (g)	A _{RIG-H} (g)	A _{FLX-V} (g)	A _{RIG-V} (g)	
CBC 2022	ICC-ES AC156	2.0	1.0	1.5	3.20	2.40	2.13	0.85	
		3.2	0.0						
Product Construction Summary:					Test Mounting Details:				
Carbon Steel Enclosure									
Options/Subcomponent Summary:									
Description		Part Number							
Molded Case Circuit Breaker (Schneider)		R and NT Frame							
ICE Box (Caterpillar)		Base controller, side extension box, and large display							
ICE Control Panel w/ EMCP 4 Controller (Caterpillar)		Large Display							
Test Mounting Details:									
<p>¹ Weight is of UUT and the equipment mounting skid.</p> <p>² The width dimension is the combination of the Box and Panel.</p>					<p>UUT7a was base mounted - rigid to the test fixture using six (6) 3/4" Grade 8 bolts.</p> <p>Unit maintained structural integrity and remained functional per manufacturer requirement after shake table test. Contents were included in testing per operating conditions.</p>				

UNIT UNDER TEST (UUT) SUMMARY SHEET

TRU PROJECT NO. 2100427, Rev. 6



Manufacturer: Caterpillar Inc. Model Line: C27/C32/3512/3516/C175 Generator Set Model Number: ICE Box - Max Serial Number: N/A						UUT 7b			
						Test Report: 14175 (UUT7 Isolated)			
UUT Properties									
Weight (lbs.) ¹	Dimension (in) ²			Lowest Natural Frequency (Hz)					
	Depth	Width	Height	Front-Back	Side-Side	Vertical			
3,270	45.0	84.0	66.0	3.15	5.83	4.88			
UUT Highest Passed Seismic Run Information									
Building Code	Test Criteria	S _{DS} (g)	z/h	I _P	A _{FLX-H} (g)	A _{RIG-H} (g)	A _{FLX-V} (g)	A _{RIG-V} (g)	
CBC 2022	ICC-ES AC156	2.0	1.0	1.5	3.20	2.40	2.13	0.85	
		3.2	0.0						
Product Construction Summary:					Test Mounting Details:				
Carbon Steel Enclosure									
Options/Subcomponent Summary:									
Description		Part Number							
Molded Case Circuit Breaker (Schneider)		R and NT Frame							
ICE Box (Caterpillar)		Base controller, side extension box, and large display							
ICE Control Panel w/ EMCP 4 Controller (Caterpillar)		Large Display							
Test Mounting Details:									
¹ Weight is of UUT and the equipment mounting skid. ² The width dimension is the combination of the Box and Panel.					UUT7b was base mounted - isolated to the fixture using six (6) Mason SSLFH-C-1750 isolators using one (1) 5/8" Grade 8 bolt each. The isolators were mounted to the table using two (2) 5/8" Grade 8 bolts each. Unit maintained structural integrity and remained functional per manufacturer requirement after shake table test. Contents were included in testing per operating conditions.				

UNIT UNDER TEST (UUT) SUMMARY SHEET

TRU PROJECT NO. 2100427, Rev. 6



Manufacturer: Caterpillar Inc. Model Line: C27/C32/3512/3516/C175 Generator Set Model Number: ICE Box 1 Serial Number: N/A						UUT 8			
Test Report: 14175 (UUT8)									
UUT Properties									
Weight (lbs.)	Dimension (in)			Lowest Natural Frequency (Hz)					
	Depth	Width	Height	Front-Back	Side-Side	Vertical			
105	16.0	28.0	18.0	N/A	N/A	N/A			
UUT Highest Passed Seismic Run Information									
Building Code	Test Criteria	S _{DS} (g)	z/h	I _p	A _{FLX-H} (g)	A _{RIG-H} (g)	A _{FLX-V} (g)	A _{RIG-V} (g)	
CBC 2022	ICC-ES AC156	2.0	1.0	1.5	3.20	2.40	2.13	0.85	
		3.2	0.0						
Product Construction Summary:					Test Mounting Details:				
Carbon Steel Enclosure									
Options/Subcomponent Summary:									
Description		Part Number							
ICE Box (Caterpillar)		Small Display							
ICE Control Panel w/ EMCP 4 Controller (Caterpillar)		Small Display							
UUT8 was wall mounted - rigid using twelve (12) 1/4" lag screws. Unit maintained structural integrity and remained functional per manufacturer requirement after shake table test. Contents were included in testing per operating conditions.									

UNIT UNDER TEST (UUT) SUMMARY SHEET

TRU PROJECT NO. 2100427, Rev. 6



Manufacturer: Caterpillar Inc. Model Line: C27/C32/3512/3516/C175 Generator Set Model Number: ICE Box 2 Serial Number: N/A						UUT 9			
Test Report: 14175 (UUT9)									
UUT Properties									
Weight (lbs.)	Dimension (in)			Lowest Natural Frequency (Hz)					
	Depth	Width	Height	Front-Back	Side-Side	Vertical			
110	16.0	28.0	18.0	N/A	N/A	N/A			
UUT Highest Passed Seismic Run Information									
Building Code	Test Criteria	S _{DS} (g)	z/h	I _P	A _{FLX-H} (g)	A _{RIG-H} (g)	A _{FLX-V} (g)	A _{RIG-V} (g)	
CBC 2022	ICC-ES AC156	2.0	1.0	1.5	3.20	2.40	2.13	0.85	
		3.2	0.0						
Product Construction Summary: Carbon Steel Enclosure					Test Mounting Details:				
Options/Subcomponent Summary:									
Description	Part Number								
ICE Box (Caterpillar)	Large Display								
ICE Control Panel w/ EMCP 4 Controller (Caterpillar)	Large Display								
UUT9 was wall mounted - rigid using twelve (12) 1/4" lag screws. Unit maintained structural integrity and remained functional per manufacturer requirement after shake table test. Contents were included in testing per operating conditions.									

UNIT UNDER TEST (UUT) SUMMARY SHEET

TRU PROJECT NO. 2100427, Rev. 6



Manufacturer: Caterpillar Inc. Model Line: C27/C32/3512/3516/C175 Generator Set Model Number: C32 - Generator Set Serial Number: N/A						UUT 10			
Test Report: 1700630-TR-001 (UUT10)									
UUT Properties									
Weight (lbs.)	Dimension (in)			Lowest Natural Frequency (Hz)					
	Depth	Width	Height	Front-Back	Side-Side	Vertical			
18,540	190.0	88.0	119.0	2.9	2.0	4.5			
UUT Highest Passed Seismic Run Information									
Building Code	Test Criteria	S _{DS} (g)	z/h	I _P	A _{FLX-H} (g)	A _{RIG-H} (g)	A _{FLX-V} (g)	A _{RIG-V} (g)	
CBC 2022	ICC-ES AC156	2.0	1.0	1.5	3.20	2.40	2.13	0.85	
		3.2	0.0						
Product Construction Summary:					Test Mounting Details:				
Carbon Steel Base									
Options/Subcomponent Summary:									
Description		Part Number							
C32 (≤1250 kW)		Open - Max. Package							
Generator (Leroy-Somer)		1400 Frame							
ICE Box (Caterpillar)		Large Display							
Radiator (Modine)		25SF							
UUT10 was base mounted to test fixture using six (6) VMC M2SSH-1E 5150 spring isolators (and included hardware). Twelve (12) 3/4" Grade 8 bolts are used to mount the isolators to the test fixture. Unit maintained structural integrity and remained functional per manufacturer requirement after shake table test. Contents were included in testing per operating conditions.									

UNIT UNDER TEST (UUT) SUMMARY SHEET

TRU PROJECT NO. 2100427, Rev. 6




Manufacturer: Caterpillar Inc. Model Line: C27/C32/3512/3516/C175 Generator Set Model Number: 3516E - Generator Set Serial Number: N/A						UUT 11			
Test Report: 1700630-TR-001 (UUT11)									
UUT Properties									
Weight (lbs.)	Dimension (in)			Lowest Natural Frequency (Hz)					
	Depth	Width	Height	Front-Back	Side-Side	Vertical			
51,000	324.0	104.0	128.0	3.0	2.3	4.2			
UUT Highest Passed Seismic Run Information									
Building Code	Test Criteria	S _{DS} (g)	z/h	I _P	A _{FLX-H} (g)	A _{RIG-H} (g)	A _{FLX-V} (g)	A _{RIG-V} (g)	
CBC 2022	ICC-ES AC156	2.0	1.0	1.5	3.20	2.40	2.13	0.85	
		3.2	0.0						
Product Construction Summary:					Test Mounting Details:				
Carbon Steel Base									
Options/Subcomponent Summary:									
Description		Part Number							
C516E (≤2750 kW)		Max. Package							
Generator (Leroy-Somer)		3000 Frame							
Radiator (Caterpillar)		81SF							
UUT11 was base mounted to test fixture using fourteen (14) VMC M2SSH-1E 5150 spring isolators (and included hardware). The isolators were welded to the test fixture using three (3) 1" long 5/16" fillet welds along the long sides, and a 5/16" fillet weld along the entire length of the short sides. Unit maintained structural integrity and remained functional per manufacturer requirement after shake table test. Contents were included in testing per operating conditions.									

UNIT UNDER TEST (UUT) SUMMARY SHEET

TRU PROJECT NO. 2100427, Rev. 6



Manufacturer: Caterpillar Inc. Model Line: C27/C32/3512/3516/C175 Generator Set Model Number: 3516C - Generator Set Serial Number: N/A						UUT 12			
Test Report: 1900323-TR-001-R0 (UUT1)									
UUT Properties									
Weight (lbs.)	Dimension (in)			Lowest Natural Frequency (Hz)					
	Depth	Width	Height	Front-Back	Side-Side	Vertical			
43,139	257.3	100.9	123.2	3.3	3.3	5.6			
UUT Highest Passed Seismic Run Information									
Building Code	Test Criteria	S _{DS} (g)	z/h	I _P	A _{FLX-H} (g)	A _{RIG-H} (g)	A _{FLX-V} (g)	A _{RIG-V} (g)	
CBC 2022	ICC-ES AC156	2.0	1.0	1.5	3.20	2.40	2.13	0.85	
		3.2	0.0						
Product Construction Summary:					Test Mounting Details:				
Carbon Steel Base					 <p>UUT12 was base mounted to test fixture using ten (10) VMC M2SSH-1E 6500 spring isolators (with included hardware and added flat washer / under engine and alternator) and six (6) VMC M2SSH-1E 5150 spring isolators (with included hardware and added flat washer / under radiator). The isolators were welded to the test fixture using three (3) 2" long 5/16" fillet welds along the long sides, and a 5/16" fillet weld along the entire length of the short sides.</p> <p>Unit maintained structural integrity and remained functional per manufacturer requirement after shake table test. Contents were included in testing per operating conditions.</p>				
Options/Subcomponent Summary:									
Description		Part Number							
C516C-HD (≤2500 kW)		Min. Package							
Generator (Leroy-Somer)		3000 Frame							
Radiator (Caterpillar)		A68							

UNIT UNDER TEST (UUT) SUMMARY SHEET

TRU PROJECT NO. 2100427, Rev. 6



Manufacturer:	Caterpillar Inc.	UUT 14a
Model Line:	3512 Opt Radiator	
Model Number:	607-9886	
Serial Number:	2611476604	
		Test Report: 2100427-TR-001-R0 (UUT1.1)

UUT Properties						
Weight (lbs.)	Dimension (in)			Lowest Natural Frequency (Hz)		
	Depth	Width	Height	Front-Back	Side-Side	Vertical
2,428	89.0	27.0	100.0	8.41	9.72	7.99

UUT Highest Passed Seismic Run Information									
Building Code	Test Criteria	S _{DS} (g)	z/h	I _P	A _{FLX-H} (g)	A _{RIG-H} (g)	A _{FLX-V} (g)	A _{RIG-V} (g)	
CBC 2022	ICC-ES AC156	2.0	1.0	1.5	3.20	2.40	2.13	0.85	
		3.2	0.0						

Product Construction Summary: Test Mounting Details:

Carbon Steel Base

Options/Subcomponent Summary:

Description	Part Number
3512 Opt. Radiator (Caterpillar with Modine coolers)	A48

Test Mounting Details:



UUT14a was base mounted using six (6) CAT 353-9020 isolators were mounted to the bottom of the unit. See drawing below of isolator specs. Each isolator was mounted to the shake table with two (2) 3/4" Grade 5 Bolts and washers (12 total). Unit maintained structural integrity and remained functional per manufacturer requirement after shake table test. Contents were included in testing per operating conditions.


TRU PROJECT NO. 2100427, Rev. 6




UUT 14a

Test Report: 2100427-TR-001-R0 (UUT1.1)

Mounting Details:



Isolator 353-9020
6X qty used below opt
rad



SEISMICALLY RESTRAINED VIBRATION ISOLATOR 1" DEFLECTION				
RATED LOAD (LBS)	RATED DEFLECTION (IN)	SPRING RATE (LBS/IN)	SOLID LOAD (LBS)	COLOR CODE
5150	1.11	4626	7734	WHITE/ DK. PURPLE

UNIT UNDER TEST (UUT) SUMMARY SHEET

TRU PROJECT NO. 2100427, Rev. 6



Manufacturer:	Caterpillar Inc.	UUT 14b
Model Line:	3512 Fresco Rad	
Model Number:	572-8370	
Serial Number:	2202-1903000201	
		Test Report: 2100427-TR-001-R0 (UUT1.2)

UUT Properties						
Weight (lbs.)	Dimension (in)			Lowest Natural Frequency (Hz)		
	Depth	Width	Height	Front-Back	Side-Side	Vertical
3,380	98.0	25.0	108.0	5.84	9.49	9.57

UUT Highest Passed Seismic Run Information									
Building Code	Test Criteria	S _{DS} (g)	z/h	I _P	A _{FLX-H} (g)	A _{RIG-H} (g)	A _{FLX-V} (g)	A _{RIG-V} (g)	
CBC 2022	ICC-ES AC156	2.0	1.0	1.5	3.20	2.40	2.13	0.85	
		3.2	0.0						

Product Construction Summary: Test Mounting Details:

Carbon Steel Base

Options/Subcomponent Summary:

Description	Part Number
Fresco Radiator (Caterpillar with Modine coolers)	59CTD

Test Mounting Details:



UUT14b was base mounted using four (4) CAT 348-4785 isolators were mounted to the bottom of the unit. See drawing below of isolator specs. Each isolator was mounted to the shake table with two (2) 3/4" Grade 5 Bolts and washers (8 total). Unit maintained structural integrity and remained functional per manufacturer requirement after shake table test. Contents were included in testing per operating conditions.

UNIT UNDER TEST (UUT)
SUMMARY SHEET

TRU PROJECT NO. 2100427, Rev. 6





Manufacturer: Caterpillar Inc.
Model Line: 3512 Fresco Rad
Model Number: 572-8370
Serial Number: 2202-1903000201

UUT 14b

Test Report: 2100427-TR-001-R0 (UUT1.2)

Mounting Details:



SEISMICALLY RESTRAINED VIBRATION ISOLATOR 1" DEFLECTION				
RATED LOAD (LBS)	RATED DEFLECTION (IN)	SPRING RATE (LBS/IN)	SOLID LOAD (LBS)	COLOR CODE
5980	1.11	5364	8968	WHITE / DK. GREEN

UNIT UNDER TEST (UUT) SUMMARY SHEET

TRU PROJECT NO. 2100427, Rev. 6



Manufacturer:	Caterpillar Inc.	UUT 15a
Model Line:	C32 49CTD Rad.	
Model Number:	508-8110	
Serial Number:	N/A	
		Test Report: 2100427-TR-001-R0 (UUT2.1)

UUT Properties						
Weight (lbs.)	Dimension (in)			Lowest Natural Frequency (Hz)		
	Depth	Width	Height	Front-Back	Side-Side	Vertical
1,236	66.0	20.0	85.0	7.02	10.95	8.34

UUT Highest Passed Seismic Run Information									
Building Code	Test Criteria	S _{DS} (g)	z/h	I _P	A _{FLX-H} (g)	A _{RIG-H} (g)	A _{FLX-V} (g)	A _{RIG-V} (g)	
CBC 2022	ICC-ES AC156	2.0	1.0	1.5	3.20	2.40	2.13	0.85	
		3.2	0.0						

Product Construction Summary:	Test Mounting Details:
Carbon Steel Base	

Options/Subcomponent Summary:	
Description	Part Number
C32 Radiator (AKG)	AB24

Test Mounting Details:



UUT15a was base mounted using two (2) CAT 353-9020 isolators were mounted to the bottom of the unit. See drawing below of isolator specs. Each isolator was mounted to the shake table with two (2) 3/4" Grade 5 Bolts and washers (4 total). Unit maintained structural integrity and remained functional per manufacturer requirement after shake table test. Contents were included in testing per operating conditions.


UNIT UNDER TEST (UUT)
SUMMARY SHEET

TRU PROJECT NO. 2100427, Rev. 6



Manufacturer:	Caterpillar Inc.	UUT 15a
Model Line:	C32 49CTD Rad.	
Model Number:	508-8110	
Serial Number:	N/A	
Test Report:		2100427-TR-001-R0 (UUT2.1)

Mounting Details:



UNIT UNDER TEST (UUT) SUMMARY SHEET

TRU PROJECT NO. 2100427, Rev. 6



Manufacturer:	Caterpillar Inc.	UUT 15b
Model Line:	C32 49CTD Rad.	
Model Number:	508-8111	
Serial Number:	N/A	
		Test Report: 2100427-TR-001-R0 (UUT2.2)

UUT Properties						
Weight (lbs.)	Dimension (in)			Lowest Natural Frequency (Hz)		
	Depth	Width	Height	Front-Back	Side-Side	Vertical
1,355	72.0	21.0	85.0	7.02	8.73	25.75

UUT Highest Passed Seismic Run Information									
Building Code	Test Criteria	S _{DS} (g)	z/h	I _P	A _{FLX-H} (g)	A _{RIG-H} (g)	A _{FLX-V} (g)	A _{RIG-V} (g)	
CBC 2022	ICC-ES AC156	2.0	1.0	1.5	3.20	2.40	2.13	0.85	
		3.2	0.0						


Product Construction Summary: Test Mounting Details:


Carbon Steel Base

Options/Subcomponent Summary:

Description	Part Number
C32 Radiator (AKG)	AB26

Test Mounting Details:





UUT15b was base mounted using two (2) CAT 353-9020 isolators were mounted to the bottom of the unit. See drawing below of isolator specs. Each isolator was mounted to the shake table with two (2) 3/4" Grade 5 Bolts and washers (4 total). Unit maintained structural integrity and remained functional per manufacturer requirement after shake table test. Contents were included in testing per operating conditions.

TRU Compliance, by Structural Integrity Associates, Inc.

844-TRU-0200 | info@trucompliance.com

UNIT UNDER TEST (UUT)
SUMMARY SHEET

TRU PROJECT NO. 2100427, Rev. 6




Manufacturer: Caterpillar Inc.
Model Line: C32 49CTD Rad.
Model Number: 508-8111
Serial Number: N/A

UUT 15b

Test Report: 2100427-TR-001-R0 (UUT2.2)

Mounting Details:



SEISMICALLY RESTRAINED VIBRATION ISOLATOR 1" DEFLECTION				
RATED LOAD (LBS)	RATED DEFLECTION (IN)	SPRING RATE (LBS/IN)	SOLID LOAD (LBS)	COLOR CODE
5150	1.11	4626	7734	WHITE/DK. PURPLE

UNIT UNDER TEST (UUT) SUMMARY SHEET

TRU PROJECT NO. 2100427, Rev. 6



Manufacturer: Caterpillar Inc. Model Line: C27/C32/3512/3516/C175 Generator Set Model Number: Doghouse Serial Number: N/A						<h2 style="margin: 0;">UUT 16</h2>		
Test Report: 2300056-TR-001 (UUT1)								
UUT Properties								
Weight (lbs.)	Dimension (in)			Lowest Natural Frequency (Hz)				
	Depth	Width	Height	Front-Back	Side-Side	Vertical		
1,982	60.3	38.3	53.0	7.82	5.24	15.85		
UUT Highest Passed Seismic Run Information								
Building Code	Test Criteria	$S_{DS}(g)$	z/h	I_P	$A_{FLX-H}(g)$	$A_{RIG-H}(g)$	$A_{FLX-V}(g)$	$A_{RIG-V}(g)$
CBC 2022	ICC-ES AC156	2.0	1.0	1.5	3.20	2.40	2.13	0.85
		3.2	0.0					
Product Construction Summary:				Test Mounting Details:				
Carbon Steel Enclosure								
Options/Subcomponent Summary:								
Description		Part Number						
Cat ECS 100		622-3612 621-9888						
Cat ECS 200		631-2323						
Cat GCCP1.2		634-5258						
Test Mounting Details Continued:				<p>UUT16 was base mounted - isolated using six (6) VMC M2SSH-1E-5150 spring isolators (CAT: P/N 353-9020) to the equipment skid using one (1) 3/4" Grade 8 bolt each. The isolators were mounted to the table using four (4) 3/4" Grade 8 bolts and washers each (twenty-four (24) total)</p> <p>Unit maintained structural integrity and remained functional per manufacturer requirement after shake table test. Contents were included in testing per operating conditions.</p>				
<p>The doghouse is connected to slider rails, which will connect to the base rails. Between the slider rails and the doghouse are vibration isolators (Barry Controls Div, Barry Wright Corp: P/N 26275-2). A complete genset uses this mounting configuration (including the base rails).</p>								

UNIT UNDER TEST (UUT) SUMMARY SHEET

TRU PROJECT NO. 2100427, Rev. 6




Manufacturer: Caterpillar Inc.
Model Line: C27/C32/3512/3516/C175 Generator Set
Model Number: Doghouse
Serial Number: N/A


UUT 16

Test Report: 2300056-TR-001 (UUT1)

Mounting Details:



Isolator 353-9020
6X qty used below



SEISMICALLY RESTRAINED VIBRATION ISOLATOR 1" DEFLECTION						
RATED LOAD (LBS)	RATED DEFLECTION (IN)	SPRING RATE (LBS/IN)	SOLID LOAD (LBS)	RATED TENSILE LOAD (LBS)	RATED SHEAR LOAD (LBS)	COLOR CODE
5150	1.11	4626	7734	14000	10000	WHITE/DK PURPLE

UNIT UNDER TEST (UUT)
SUMMARY SHEET

TRU PROJECT NO. 2100427, Rev. 6




Manufacturer: Caterpillar Inc.
Model Line: C27/C32/3512/3516/C175 Generator Set
Model Number: Doghouse
Serial Number: N/A

UUT 16

Test Report: 2300056-TR-001 (UUT1)

Mounting Details:



UNIT UNDER TEST (UUT) SUMMARY SHEET

TRU PROJECT NO. 2100427, Rev. 6



Manufacturer: Caterpillar Inc. Model Line: C27/C32/3512/3516/C175 Generator Set Model Number: Cat ECS 100 (622-3612 & 621-9888) Serial Number: N/A						UUT 17			
Test Report: 2300056-TR-001 (UUT2)									
UUT Properties									
Weight (lbs.)	Dimension (in)			Lowest Natural Frequency (Hz)					
	Depth	Width	Height	Front-Back	Side-Side	Vertical			
95	8.5	28.0	18.5	N/A	N/A	N/A			
UUT Highest Passed Seismic Run Information									
Building Code	Test Criteria	S _{DS} (g)	z/h	I _p	A _{FLX-H} (g)	A _{RIG-H} (g)	A _{FLX-V} (g)	A _{RIG-V} (g)	
CBC 2022	ICC-ES AC156	2.0	1.0	1.5	3.20	2.40	2.13	0.85	
		3.2	0.0						
Product Construction Summary:					Test Mounting Details:				
Carbon Steel Enclosure									
Options/Subcomponent Summary:									
Description		Part Number							
N/A		N/A							
UUT17 was wall mounted - rigid to the fixture using nine (9) 5/16" lag screws and washers. Unit maintained structural integrity and remained functional per manufacturer requirement after shake table test. Contents were included in testing per operating conditions.									

TRU PROJECT NO. 2100427, Rev. 6



UNIT UNDER TEST (UUT) SUMMARY SHEET

TRU PROJECT NO. 2100427, Rev. 6



Manufacturer:	Caterpillar Inc.	UUT 19
Model Line:	C27/C32/3512/3516/C175 Generator Set	
Model Number:	Cat ECS 200 (631-2323)	
Serial Number:	N/A	
		Test Report: 2300056-TR-001 (UUT4)

UUT Properties						
Weight (lbs.) ¹	Dimension (in)			Lowest Natural Frequency (Hz)		
	Depth	Width	Height ¹	Front-Back	Side-Side	Vertical
154	8.5	28.0	53.0	N/A	N/A	N/A

UUT Highest Passed Seismic Run Information									
Building Code	Test Criteria	S _{DS} (g)	z/h	I _P	A _{FLX-H} (g)	A _{RIG-H} (g)	A _{FLX-V} (g)	A _{RIG-V} (g)	
CBC 2022	ICC-ES AC156	2.0	1.0	1.5	3.20	2.40	2.13	0.85	
		3.2	0.0						

Product Construction Summary:	Test Mounting Details:
Carbon Steel Enclosure	

Options/Subcomponent Summary:	
Description	Part Number
N/A	N/A

Test Mounting Details:
<p>¹ The weight and height are the combination of UUT2 and UUT4.</p> <p>UUT4 separately has a weight of 59 lbs. and height of 34.5".</p> <p>UUT4 cannot function without UUT2.</p>



UUT19 was wall mounted - rigid to the fixture using twenty-two (22) 5/16" lag screws and washers.

Unit maintained structural integrity and remained functional per manufacturer requirement after shake table test. Contents were included in testing per operating conditions.

UNIT UNDER TEST (UUT) SUMMARY SHEET

TRU PROJECT NO. 2100427, Rev. 6




Manufacturer:	Caterpillar Inc.	UUT 20
Model Line:	C27/C32/3512/3516/C175 Generator Set	
Model Number:	C32B Generator Set	
Serial Number:	N/A	
		Test Report: 2301377-TR-001 (UUT1)

UUT Properties						
Weight (lbs.)	Dimension (in)			Lowest Natural Frequency (Hz)		
	Depth	Width	Height	Front-Back	Side-Side	Vertical
21,750	200.0	96.0	100.6	3.75	4.05	7.81

UUT Highest Passed Seismic Run Information									
Building Code	Test Criteria	S _{DS} (g)	z/h	I _P	A _{FLX-H} (g)	A _{RIG-H} (g)	A _{FLX-V} (g)	A _{RIG-V} (g)	
CBC 2022	ICC-ES AC156	2.0	1.0	1.5	3.20	2.40	2.13	0.85	
		3.2	0.0						

Product Construction Summary:	Test Mounting Details:
Carbon Steel Base	

Options/Subcomponent Summary:	
Description	Part Number
C32B (≤1500 kW)	Max. Package
Generator (Leroy-Somer)	1646 Frame
Cat GCCP1.2 Controller (Caterpillar)	634-5258
Radiator (Modine)	A38AV



UUT20 was base mounted - isolated to test fixture using eight (8) VMC M2SSH-1E-6500 (CAT: P/N 348-5526) spring isolators and four (4) VMC M2SSH-1E-5150 (CAT: P/N 353-9020) spring isolators to the equipment skid using one (1) 3/4" Grade 8 bolt for each isolator. The isolators were welded to the test fixture using two (2) 1" long 5/16" continuous fillet welds along the long sides.

Unit maintained structural integrity and remained functional per manufacturer requirement after shake table test. Contents were included in testing per operating conditions.

UNIT UNDER TEST (UUT) SUMMARY SHEET

TRU PROJECT NO. 2100427, Rev. 6




Manufacturer: Caterpillar Inc.
Model Line: C27/C32/3512/3516/C175 Generator Set
Model Number: C32B Generator Set
Serial Number: N/A

UUT 20


Test Report: 2301377-TR-001 (UUT1)

Mounting Details:

Isolator CAT: 348-5526 x8 qty
used below (pink)



Isolator CAT: 353-9020 x4 qty
used below (purple)



Isolator CAT: 348-5526 (48 lbs.)

Isolator CAT: 353-9020 (48 lbs.)

SEISMICALLY RESTRAINED VIBRATION ISOLATOR 1" DEFLECTION						
RATED LOAD (LBS)	RATED DEFLECTION (IN)	SPRING RATE (LBS/IN)	SOLID LOAD (LBS)	RATED TENSILE LOAD (LBS)	RATED SHEAR LOAD (LBS)	COLOR CODE
6500	1.04	6250	9750	14000	10000	WHITE/GRAY

SEISMICALLY RESTRAINED VIBRATION ISOLATOR 1" DEFLECTION						
RATED LOAD (LBS)	RATED DEFLECTION (IN)	SPRING RATE (LBS/IN)	SOLID LOAD (LBS)	RATED TENSILE LOAD (LBS)	RATED SHEAR LOAD (LBS)	COLOR CODE
5150	1.11	4626	7734	14000	10000	WHITE/DK PURPLE

UNIT UNDER TEST (UUT) SUMMARY SHEET


TRU PROJECT NO. 2100427, Rev. 6




Manufacturer:	Caterpillar Inc.	UUT 21
Model Line:	A59 Rad.	
Model Number:	565-5542	
Serial Number:	N/A	
		Test Report: 2400776-TR-001-R0 (UUT1)

UUT Properties						
Weight (lbs.)	Dimension (in)			Lowest Natural Frequency (Hz)		
	Depth	Width	Height	Front-Back	Side-Side	Vertical
4,150	90.0	86.5	118.0	4.16	3.99	10.26

UUT Highest Passed Seismic Run Information									
Building Code	Test Criteria	S _{DS} (g)	z/h	I _P	A _{FLX-H} (g)	A _{RIG-H} (g)	A _{FLX-V} (g)	A _{RIG-V} (g)	
CBC 2022	ICC-ES AC156	2.0	1.0	1.5	3.20	2.40	2.13	0.85	
		3.2	0.0						

Product Construction Summary:		Test Mounting Details:	
Carbon Steel Base			
Options/Subcomponent Summary:			
Description	Part Number		
A59 Radiator (Caterpillar with Yinlun coolers)	A59		

Test Mounting Details:


UUT21 was base mounted - isolated to the test fixture using four (4) VMC M2SSH-1E-4000 (CAT: P/N 348-5526) spring isolators to the equipment skid using one (1) 3/4" Grade 8 bolt for each isolator. The isolators were mounted to the test fixture using four (4) 3/4" Grade 8 bolts for each isolator.

Unit maintained structural integrity and remained functional per manufacturer requirement after shake table test. Contents were included in testing per operating conditions.

UNIT UNDER TEST (UUT) SUMMARY SHEET

TRU PROJECT NO. 2100427, Rev. 6





Manufacturer: Caterpillar Inc.
Model Line: A59 Rad.
Model Number: 565-5542
Serial Number: N/A

UUT 21

Test Report: 2400776-TR-001-R0 (UUT1)

Mounting Details:

Isolator CAT: 348-5526 x4 qty
used below



MODEL M2SSH-1E SEISMICALLY RESTRAINED VIBRATION ISOLATOR FOR 1" DEFLECTION				
MODEL	STATIC LOAD (LBS)	STATIC DEFLECTION (IN)	STATIC SPRING RATE (LBS/IN)	SPRING COLOR CODE
M2SSH-1E-1650N	1650	1.07	1538	RED/DK. BLUE
M2SSH-1E-2000	2000	1.00	2000	TAN
M2SSH-1E-2400N	2400	1.04	2300	TAN/DK. BLUE
M2SSH-1E-2800	2800	1.00	2800	PINK
M2SSH-1E-3400N	3400	1.10	3100	PINK/DK. BLUE
M2SSH-1E-4000	4000	1.11	3600	WHITE
M2SSH-1E-5150N	5150	1.11	4626	WHITE/DK. PURPLE
M2SSH-1E-5980N	5980	1.11	5364	WHITE/DK. GREEN
M2SSH-1E-6500N	6500	1.04	6250	WHITE/GRAY

TRU Compliance, by Structural Integrity Associates, Inc.

844-TRU-0200 | info@trucompliance.com

UNIT UNDER TEST (UUT) SUMMARY SHEET


TRU PROJECT NO. 2100427, Rev. 6




Manufacturer:	Caterpillar Inc.	UUT 22
Model Line:	A68 Rad.	
Model Number:	564-1955	
Serial Number:	N/A	
		Test Report: 2400776-TR-001-R0 (UUT2)

UUT Properties						
Weight (lbs.)	Dimension (in)			Lowest Natural Frequency (Hz)		
	Depth	Width	Height	Front-Back	Side-Side	Vertical
4,800	101.0	72.0	139.0	4.16	3.94	10.25

UUT Highest Passed Seismic Run Information									
Building Code	Test Criteria	S _{DS} (g)	z/h	I _P	A _{FLX-H} (g)	A _{RIG-H} (g)	A _{FLX-V} (g)	A _{RIG-V} (g)	
CBC 2022	ICC-ES AC156	2.0	1.0	1.5	3.20	2.40	2.13	0.85	
		3.2	0.0						

Product Construction Summary:		Test Mounting Details:	
Carbon Steel Base			
Options/Subcomponent Summary:			
Description	Part Number		
A68 Radiator (Caterpillar with Yinlun coolers)	A68		

Test Mounting Details:	
	<p>UUT22 was base mounted - isolated to the test fixture using six (6) VMC M2SSH-1E-4000 (CAT: P/N 348-5526) spring isolators to the equipment skid using one (1) 3/4" Grade 8 bolt for each isolator. The isolators were mounted to the test fixture using four (4) 3/4" Grade 8 bolts for each isolator.</p> <p>Unit maintained structural integrity and remained functional per manufacturer requirement after shake table test. Contents were included in testing per operating conditions.</p>

TRU Compliance, by Structural Integrity Associates, Inc.
844-TRU-0200 | info@trucompliance.com

UNIT UNDER TEST (UUT) SUMMARY SHEET

TRU PROJECT NO. 2100427, Rev. 6




Manufacturer: Caterpillar Inc.
Model Line: A68 Rad.
Model Number: 564-1955
Serial Number: N/A

UUT 22

Test Report: 2400776-TR-001-R0 (UUT2)

Mounting Details:

Isolator CAT: 348-5526 x6 qty
used below



MODEL M2SSH-1E SEISMICALLY RESTRAINED VIBRATION ISOLATOR FOR 1" DEFLECTION				
MODEL	STATIC LOAD (LBS)	STATIC DEFLECTION (IN)	STATIC SPRING RATE (LBS/IN)	SPRING COLOR CODE
M2SSH-1E-1650N	1650	1.07	1538	RED/DK. BLUE
M2SSH-1E-2000	2000	1.00	2000	TAN
M2SSH-1E-2400N	2400	1.04	2300	TAN/DK. BLUE
M2SSH-1E-2800	2800	1.00	2800	PINK
M2SSH-1E-3400N	3400	1.10	3100	PINK/DK. BLUE
M2SSH-1E-4000	4000	1.11	3600	WHITE
M2SSH-1E-5150N	5150	1.11	4626	WHITE/DK. PURPLE
M2SSH-1E-5980N	5980	1.11	5364	WHITE/DK. GREEN
M2SSH-1E-6500N	6500	1.04	6250	WHITE/GRAY

TRU Compliance, by Structural Integrity Associates, Inc.

844-TRU-0200 | info@trucompliance.com

UNIT UNDER TEST (UUT) SUMMARY SHEET

TRU PROJECT NO. 2100427, Rev. 6



Manufacturer: Caterpillar Inc. Model Line: C27/C32/3512/3516/C175 Generator Set Model Number: Doghouse w/ ECS 100 Panel with RS485 Module Serial Number: N/A						UUT 23			
Test Report: 2551830-TR-001 (UUT1)									
UUT Properties									
Weight (lbs.)	Dimension (in)			Lowest Natural Frequency (Hz)					
	Depth	Width	Height	Front-Back	Side-Side	Vertical			
1,550	114.0	60.0	69.1	5.07	5.81	12.59			
UUT Highest Passed Seismic Run Information									
Building Code	Test Criteria	$S_{DS}(g)$	z/h	I_p	$A_{FLX-H}(g)$	$A_{RIG-H}(g)$	$A_{FLX-V}(g)$	$A_{RIG-V}(g)$	
CBC 2022	ICC-ES AC156	2.0	1.0	1.5	3.20	2.40	2.13	0.85	
		3.2	0.0						
Product Construction Summary:					Test Mounting Details:				
Carbon Steel Enclosure									
Options/Subcomponent Summary:									
Description		Part Number							
Cat ECS 100		622-3612 621-9888							
RS485 Module Converter		MGate MB3170I-T							
Test Mounting Details Continued:					<p>UUT23 was base mounted - isolated using six (6) VMC M2SSH-1E-5150 spring isolators (CAT: P/N 353-9020) to the equipment skid using one (1) 3/4" Grade 8 bolt each. The isolators were mounted to the table using four (4) 3/4" Grade 8 bolts and washers each (twenty-four (24) total)</p> <p>Unit maintained structural integrity and remained functional per manufacturer requirement after shake table test. Contents were included in testing per operating conditions.</p>				
<p>The doghouse is connected to slider rails, which will connect to the base rails. Between the slider rails and the doghouse are vibration isolators (Barry Controls Div, Barry Wright Corp: P/N 26275-2). A complete genset uses this mounting configuration (including the base rails).</p>									

UNIT UNDER TEST (UUT) SUMMARY SHEET

TRU PROJECT NO. 2100427, Rev. 6




Manufacturer: Caterpillar Inc.
Model Line: C27/C32/3512/3516/C175 Generator Set
Model Number: Doghouse w/ ECS 100 Panel with RS485 Module
Serial Number: N/A


UUT 23

Test Report: 2551830-TR-001 (UUT1)

Mounting Details:



Isolator 353-9020
6X qty used below



SEISMICALLY RESTRAINED VIBRATION ISOLATOR 1" DEFLECTION						
RATED LOAD (LBS)	RATED DEFLECTION (IN)	SPRING RATE (LBS/IN)	SOLID LOAD (LBS)	RATED TENSILE LOAD (LBS)	RATED SHEAR LOAD (LBS)	COLOR CODE
5150	1.11	4626	7734	14000	10000	WHITE/DK PURPLE

UNIT UNDER TEST (UUT)
SUMMARY SHEET

TRU PROJECT NO. 2100427, Rev. 6




Manufacturer: Caterpillar Inc.
Model Line: C27/C32/3512/3516/C175 Generator Set
Model Number: Doghouse w/ ECS 100 Panel with RS485 Module
Serial Number: N/A

UUT 23

Test Report: 2551830-TR-001 (UUT1)

Mounting Details:



UNIT UNDER TEST (UUT) SUMMARY SHEET

TRU PROJECT NO. 2100427, Rev. 6



Manufacturer: Caterpillar Inc. Model Line: C27/C32/3512/3516/C175 Generator Set Model Number: ECS100 Panel with RS485 Module Serial Number: N/A						UUT 24			
Test Report: 2551830-TR-001 (UUT2)									
UUT Properties									
Weight (lbs.)	Dimension (in)			Lowest Natural Frequency (Hz)					
	Depth	Width	Height	Front-Back	Side-Side	Vertical			
64	8.5	28.0	18.5	N/A	N/A	N/A			
UUT Highest Passed Seismic Run Information									
Building Code	Test Criteria	S _{DS} (g)	z/h	I _P	A _{FLX-H} (g)	A _{RIG-H} (g)	A _{FLX-V} (g)	A _{RIG-V} (g)	
CBC 2022	ICC-ES AC156	2.0	1.0	1.5	3.20	2.40	2.13	0.85	
		3.2	0.0						
Product Construction Summary:					Test Mounting Details:				
Carbon Steel Enclosure									
Options/Subcomponent Summary:									
Description		Part Number							
RS485 Module Converter		MGate MB3170I-T							
UUT24 was wall mounted - rigid to the fixture using seven (7) 5/16" lag screws and washers. Unit maintained structural integrity and remained functional per manufacturer requirement after shake table test. Contents were included in testing per operating conditions.									