

APPLICATION FOR OSHPD SPECIAL SEISMIC	OFFIC	CE USE ONLY
CERTIFICATION PREAPPROVAL (OSP)	APPLICATION #:	OSP – 0422
OSHPD Special Seismic Certification Preapproval (OSP)		
Type: 🗌 New 🛛 Renewal		
Manufacturer Information		
Manufacturer: Armstrong Fluid Technology		
Manufacturer's Technical Representative: On File		
Mailing Address: 23 Bertrand Ave, Toronto, Ontario, M1L2P3, Canada	a	
Telephone: On File	9	
Product Information	MD	
Product Name: Variable Frequency Drives OSHPD	TT.	
Product Type: Control Panel, Drives OSP-0422	R	
Product Model Number: See Attachment (List all unique product identification numbers and/or part numbers) hammad Alia Enclosures are cast aluminum body with plast General Description: aluminum	ari c cover or extruded alu	-
cover. Units contain controllers and disconnect switches. The certified Variable Frequency Drives. The listed drives are certified for any inter Armstrong Intelligent Variable Speed (or Design Envelope) Pumps ty 4382 IVS, DE 4312 IVS, DE 4392 IVS, DE 4030 IVS, DE 4280 IVS, D	<mark>rmed</mark> iate <mark>surfac</mark> e-mour pes DE <mark>4300</mark> IVS, DE 4	nted attachment, including 4380 IVS, DE4302 IVS, DE
Mounting Description: <u>Wall mount configuration (rigid and isolated)</u> .	ODE.	
ABUUDING		
Applicant Information		
Applicant Company Name: DCL Labs, LLC.		
Contact Person: Kelly Laplace		
Mailing Address:1315 Greg Street, Suite 109, Sparks, Nevada 89431		
Telephone: (775) 358-5085 Email: <u>kelly@</u>	shaketest.com	
I hereby agree to reimburse the Office of Statewide Health F accordance with the California Administrative Code, 2016.	Planning and Devel	lopment review fees in
Signature of Applicant:	Dat	te: <u>11/18/2020</u>
Title: Business Manager Company Name: DCL La	abs, LLC.	
"Access to Safe, Quality Healthcare Environments that Meet California's Diverse and Dynamic Needs"	AM.Am	OSHPD
STATE OF CALIFORNIA – HEALTH AND HUMAN SERVICES AGENCY OSH-FD-759 (REV 12/16/15)	Auth hela Aaa	Page 1 of 3



OFFICE OF STATEWIDE HEALTH PLANNING AND DEVELOPMENT FACILITIES DEVELOPMENT DIVISION

California Licensed Structural Engineer Responsible for the Engineering and Test Report(s)
Company Name: VMC Group
Name: Kenneth Tarlow California License Number: SE-2851
Mailing Address: <u>113 Main Street, Bloomingdale, NJ 07403</u>
Telephone: (973) 838-1780 Email: <u>ken.tarlow@thevmcgroup.com</u>
Supports and Attachments Preapproval
Supports and attachments are preapproved under OPM- (Separate application for OSHPD Preapproval of Manufacturer's Certification (OPM) of Supports and attachments is required)
Supports and attachments are not preapproved
Certification Method
 Testing in accordance with: Other (Please Specify):
OSP-0422
Testing Laboratory
Company Name: Dynamic Certification Laboratories 2/02/2020
Contact Name: Josh Sailer, Laboratory Manager
Mailing Address:1315 Greg Street, Suite 109, Sparks, NV 89431
Telephone: (775) 358-5085 Email: josh@shaketest.com

"Access to Safe, Quality Healthcare Environments that Meet California's Diverse and Dynamic Needs"

STATE OF CALIFORNIA – HEALTH AND HUMAN SERVICES AGENCY OSH-FD-759 (REV 12/16/15)



Page 2 of 3



OFFICE OF STATEWIDE HEALTH PLANNING AND DEVELOPMENT FACILITIES DEVELOPMENT DIVISION

Seismic Parameters

Design in accordance with ASCE 7-16 Chapter 13: 🛛 Yes 🗌 No
Design Basis of Equipment or Components $(F_p/W_p) = 1.88$ (Rigid Mount); 5.63 (Isolated Mount)
S_{DS} (Design spectral response acceleration at short period, g) = 2.50
a_p (In-structure equipment or component amplification factor) = <u>2.5</u>
R_{P} (Equipment or component response modification factor) = <u>6.0 (Rigid Mount)</u> ; 2.0 (Isolated Mount)
Ω_0 (System overstrength factor) = 2.0
I_p (Importance factor) = 1.5
z/h (Height factor ratio) = <u>1.0</u>
Equipment or Component Natural Frequencies (Hz) = <u>See attachment</u>
Overall dimensions and weight (or range thereof) =See attachment
Equipment or Components @ grade designed in accordance with ASCE 7-16 Chapter 15: 🗌 Yes 🛛 No
Design Basis of Equipment or Components (V/W) =
S _{DS} (Design spectral response acceleration at short period, g) =
S _{D1} (Design spectral response acceleration at 1 second period, g) =
R (Response modification coefficient) =
Ω₀ (System overstrength factor) =
C₄ (Deflection amplification factor) =
I_p (Importance factor) = 1.5 DATE: 12/02/2020
Height to Center of Gravity above base =
Equipment or Component Natural Frequencies (Hz) =
Overall dimensions and weight (or range thereof) =
Tank(s) designed in accordance with ASME BPVC, 2015: 🔲 Yes 🖾 No
List of Attachments Supporting Special Seismic Certification
☑ Test Report(s) □ Drawings □ Calculations ☑ Manufacturer's Catalog ☑ Other(s) (Discuss Specificity) Attachments
Other(s) (Please Specify): <u>Attachments</u>
OSHPD Approval (For Office Use Only) – Approval Expires on December 31, 2025
Signature: <u>M. Aliani</u> Date: <u>December 02, 2020</u>
Print Name: Mohammad Aliaari Title: Senior Structural Engineer
Special Seismic Certification Valid Up to : $S_{DS}(g) = \underline{See Above} z/h = \underline{1}$
Condition of Approval (if applicable):
"Access to Safe, Quality Healthcare Environments that Meet California's Diverse and Dynamic Needs"
STATE OF CALIFORNIA – HEALTH AND HUMAN SERVICES AGENCY
OSH-FD-759 (REV 12/16/15) Page 3 of 3

Certified Components

Manufacturer: Armstrong Fluid Technology

Product Line: Variable Frequency Drives

Certified Product Construction: Cast aluminum body with plastic cover or extruded aluminum body with aluminum cover

Certified Options: 208-230/480V , enclosures, controllers, disconnect switches

Mounting Description: Rigid or isolated wall mount

Seismic Levels: S_{DS} = 2.50g, z/h = 1.0

Variable Frequency Drives													
Model Number M		Ро	wer		Tested Enclosure	Certified D	Tested	Certified	Di	imensions, in.		Weight,	
Model Number	Manufacturer	ufacturer Voltage Material Enclosure NEMA	Enclosure NEMA NEM		NEMA Rating	Height Width		Depth	lb.	Unit			
751110-364		1.1	1.5		Cast aluminum body with plastic cover	OSHI	4 X	N.P.	16.5	9.5	9.3	27	UUT1a,b
755110-364/81/68		1.1	1.5		N/A	OSP-04	-2 _{N/A}		16.5	9.5	9.3	27	Interpolated
751121-364/81/68 to 77522B-H64/81/68		1.5-30	2-40		O N/A BY:	Mohamma	d Aliaa	ari	16.5 - 26.7	9.5 - 12.1	9.3 - 12.2	27 - 99	Interpolated
755230-364/81/68	Armstrong	37	50	208-230 /	N/A DAT	Cast aluminum body with plastic cover or extruded	2020 N/A	4, 4X, 12	26.7	12.1	12.2	99	Interpolated
751240-364/81/68		45	60	480V	N/A	aluminum body with aluminum cover	N/A	20	26.7	12.1	12.2	99	Interpolated
751251-381/68 to 77526B-H81/68		55-75	75-100		N/A	A BUILD	N/A C	00.	26.7 - 30.3	12.1 - 14.6	12.2 - 13.2	99 - 143	Interpolated
751271-381/68 to 77534B-H81/68		90-250	125-350		N/A	GILD	N/A		35.5 - 68.3	12.8 - 16.6	16.5	135 - 300	Interpolated
751355-381		315	450		Extruded aluminum body with aluminum cover		12		68.3	16.6	16.5	434	UUT2a,b



Certified Subcomponents

Manufacturer: Armstrong Fluid Technology

Product Line: Variable Frequency Drives

VFD Controller Model Number Manufacturer Description Voltage Material Unit												
Model Number Manufacturer Description Voltage Material DSDC Armstrong Description 24 //DC Aluminum UUUT1												
PSPC	Armstrong	Parallel Sensorless Pump Control	24 VDC	Aluminum	UUT1a,b, UUT2a							
		OSHPD OSP-0422 BY: Mohammad Aliaari DATE: 12/02/2020	m O									



Certified Subcomponents

Manufacturer: Armstrong Fluid Technology

Product Line: Variable Frequency Drives

Subcomponent: Fused Disconnect Switch Integrated into the VFD

Model Number*	Manufacturer	Description	Voltage	Material	
N/A	Armstrong	1.1 kW (1.5 Hp) VFD with integrated fused disconnect switch	200-240		
N/A	Armstrong	1.1-37 kW (1.5-50 Hp) VFD with integrated fused disconnect switch	200-240/380- 480	Stainless Steel and Plastic	
N/A	Armstrong	37 kW (50 Hp) VFD with integrated fused disconnect switch	480	-	
*Fused disconnect switc	h is integral to the VFD a	nd does not have a separate manufacturer's model number.			
		BY: Mohammad Aliaari			

DATE: 12/02/2020 FILTORNIA BUILDING CODE. 20

Fused Disconnect Switch



Unit

UUT1a,b

Interpolated

UUT2a,b

pecial Seismic ertified Subcon anufacturer: Armstron	mponents			DYNAMIC CERTIFICATION LABORATORIES,LLC							
roduct Line: Variable Fi											
u bcomponent: Non-Fu											
Non-Fusible Disconnect Switch											
Model Number	Manufacturer	Description	Material	Unit							
OT600U03	ABB	600VAC 600A 3PH DE CO.	Stainless Steel and Plastic	UUT2a,b*							
Иanufacturing process i	s iso soor certined.	OSHOD OSP-0422 Br. Mohammad Aliaari DATE: 12/02/2020	ACT O								



Tested Components

Manufacturer: Armstrong Fluid Technology

Product Line: Variable Frequency Drives

Tested Product Construction: Cast aluminum body with plastic cover and extruded aluminum body with aluminum cover

Tested Options: 208-230/480V , enclosures, controllers, disconnect switches

Tested Mounting Description: Rigid and isolated wall mount

Model Number	Manufacturer	Enclosure	NEMA	kW		Voltage	Overa	ll Dimensi	ons (in)	Weight	Mounting	Sds (g),	Unit	
nodel Number	Wanuacturer	Material	NEWIA	KUV	ПР	voltage	Depth	Width	Height	(lb)	wounting	z/h=1	Unit	
751110-364		Cast aluminum	4X	1.1	1.5	240	9.3	9.5	16.5	27	Rigid wall mount	2.50	UUT1a	
751110-364	Amotrong	body with plastic cover	4X	1.1 DV:	1.5 Mob	240	ZZ 11. 9.3 11 I Aliaa	9.5 ri	16.5	27	Isolated wall mount	2.50	UUT1b	
751355-381	Armstrong	Extruded aluminum	Extruded	12	315 DAT	450 E: 1	480 2/02/2	16.5 020	16.6	68.3	434	Rigid wall mount	2.50	UUT2a
751355-381		aluminum cover	12	315	450	480	16.5	16.6	68.3	434	Isolated wall mount	2.50	UUT2b	
				ORN	IA B	UILDI	NGC	opt						



UNIT UNDER TEST - Summary Sheet

UUT1 (a,b)

Manufacturer: Armstrong Fluid Technology

Product Line: Variable Frequency Drives

Model Number: 751110-364

Product Construction Summary: Cast aluminum body with plastic cover, NEMA 4X

Options / Subcomponent Summary: 240V with controller and disconnect switch

Unit Mounting Description:

UUT1a,b were mounted to the DCL wall fixture with four 1/4-inch diameter Grade 5 bolts spaced approximately 8.5-inches on-center widthwise and 15.8-inches on-center heightwise.

Rigid wall mount (UUT1a): The DCL wall fixture was rigidly attached to the shake table using M12 threaded rod spaced approximately 8inches on-center.

<u>Isolated wall mount (UUT1b)</u>: The DCL wall fixture was attached to (4) Mason Industries, Inc. SLFADA350-104 vibration spring isolators with two 3/4-inch diameter Grade 5 bolts per isolator. The isolators were welded to the DCL shake table interface plate which was attached to the shake table with M12 threaded rod spaced approximately 8-inches on-center.

			UUT P	roperties					
	Operating Wei	aht (lb)	FORC	Dimensions (in	1	Lowest Natural Frequency (Hz)			
UUT1 (a,b)			Depth	Width	Height	Front-Back	Side-Side	Vertical	
	27	L	9.3	9.5	16.5	N/A	N/A	N/A	
-			Seismic Te.	st Parameters	12				
Building Code	Test Criteria	Sds (g)	z/h CE	$-0/p_2$	Aflx-H (g)	Arig-H (g)	Aflx-V (g)	Arig-V (g)	
CBC 2019	ICC-ES AC156	2.50	1.0	1.5	4.00	3.00	1.67	0.67	



Rigid test setup (UUT1a)

Isolated test setup (UUT1b)

Note: The UUT was operational before and after shaking and was full of operating content during the tests. The structural integrity of the component and attachment system and force-resisting systems was maintained.

UNIT UNDER TEST - Summary Sheet



UUT2 (a,b)

Manufacturer: Armstrong Fluid Technology

Product Line: Variable Frequency Drives

Model Number: 751355-381

Product Construction Summary: Extruded aluminum body with aluminum cover, NEMA 12

Options / Subcomponent Summary: 480V with controller and disconnect switch

Unit Mounting Description:

UUT2a,b were mounted to the DCL wall fixture with a total of six 3/8-inch diameter Grade 5 bolts. Four 3/8-inch diameter Grade 5 bolts were located on the top of the unit with the outermost bolts spaced approximately 15-inches on-center widthwise and the innermost bolts spaced approximately 11-inches on-center widthwise. The bottom of the unit contained two 3/8-inch diameter Grade 5 bolts spaced approximately 11inches on-center widthwise. Overall, the bolts were spaced approximately 68-inches on-center heightwise.

<u>Rigid wall mount (UUT2a)</u>: The DCL wall fixture was rigidly attached to the shake table using M12 threaded rod spaced approximately 8-inches on-center.

<u>Isolated wall mount (UUT2b)</u>: The DCL wall fixture was attached to (4) Mason Industries, Inc. SLFADA350-104 vibration spring isolators with two 3/4-inch diameter Grade 5 bolts per isolator. The isolators were welded to the DCL shake table interface plate which was attached to the shake table with M12 threaded rod spaced approximately 8-inches on-center.

				Properties	MAD			
	Operating Wei	aht (lh)		Dimensions (in		Lowest	Natural Frequ	iency (Hz)
Operating Wo UUT2 (a,b)			Depth	Width	Height	Front-Back	Side-Side	Vertical
	434	Li /	16.5	16.6	68.3	N/A	N/A	N/A
		R	Seismic	Test Paramete	rs	m		
Building Code	Test Criteria	Sds (g)	z/h	lp	Aflx-H (g)	Arig-H (g)	Aflx-V (g)	Arig-V (g)
CBC 2019	ICC-ES AC156	2.50	v. 1.0	$mm^{1.5}$	4.00	<u>3.0</u> 0	1.67	0.67
I			зү; шиона	mmau A	наан т			



Rigid test setup (UUT2a)

Isolated test setup (UUT2b)

Note: The UUT was operational before and after shaking and was full of operating content during the tests. The structural integrity of the component and attachment system and force-resisting systems was maintained.