### OFFICE USE ONLY APPLICATION FOR OSHPD SPECIAL SEISMIC **CERTIFICATION PREAPPROVAL (OSP) APPLICATION #:** OSP - 0425 - 10 **OSHPD Special Seismic Certification Preapproval (OSP) Manufacturer Information** Manufacturer: Johnson Controls Inc. Manufacturer's Technical Representative: Tom Naughton Mailing Address: 6 Technology Park Drive, Westford, MA 01886 Telephone: (978) 577-4231 Email: Thomas.Naughton@JCI.com **Product Information** Product Name: iSTAR Controllers Access Controllers Product Type: Product Model Number: See attached (List all unique product identification numbers and/or part numbers) PCB iSTAR controllers and power supplies inside NEMA 1 enclosures General Description: Rigid wall mounted Mounting Description: **Applicant Information** Applicant Company Name: The VMC Group Contact Person: John Giuliano Mailing Address: 113 Main Street, Bloomingdale, NJ 07403 Email: john.giuliano@thevmcgroup.com Telephone: (973) 838-1780 I hereby agree to reimburse the Office of Statewide Health Planning and Development review fees in accordance with the California Administrative Code, 2016. Signature of Applicant: Date: 1/28/19 Title: President The VMC Group

"Access to Safe, Quality Healthcare Environments that Meet California's Diverse and Dynamic Needs'





Page 1 of 3

California Licensed Structural Engineer Responsible for the Engineering and Test Report(s)
Company Name: The VMC Group
Name: Kenneth Tarlow California License Number: SE-2851
Mailing Address: 113 Main Street, Bloomingdale, NJ 07403
Telephone: (973) 838-1780 Email: ken.tarlow@thevmcgroup.com
Supports and Attachments Preapproval
Supports and attachments are preapproved under OPM- (Separate application for OSHPD Preapproval of Manufacturer's Certification (OPM) of Supports and attachments is required)
Supports and attachments are not preapproved CODE
Certification Method
Testing in accordance with:
BY:Ali Sumer
Testing Laboratory  DATE: 05/07/2019
Company Name: National Technical Systems, Inc.
Contact Name: Michael Rowe
Mailing Address: 1146 Massachusetts Avenue, Boxborough, MA 01719
Telephone: (978) 266-1001 Email: michael.rowe@nts.com



"Access to Safe, Quality Healthcare Environments that Meet California's Diverse and Dynamic Needs"

05/07/2019 OSP-0425-10 Page 2 of 8



# OFFICE OF STATEWIDE HEALTH PLANNING AND DEVELOPMENT FACILITIES DEVELOPMENT DIVISION

STATE OF CALIFORNIA – HEALTH AND HUMAN SERVICES AGENCY OSH-FD-759 (REV 12/16/15)

Page 2 of 3

Seismic Parameters
Design in accordance with ASCE 7-10 Chapter 13: ⊠ Yes □ No
Design Basis of Equipment or Components (F <sub>p</sub> /W <sub>p</sub> ) = 1.88
$S_{DS}$ (Design spectral response acceleration at short period, g) = $\underline{2.50 \text{ g}}$
a <sub>p</sub> (In-structure equipment or component amplification factor) = 2.5
R <sub>p</sub> (Equipment or component response modification factor) = 6.0
$\Omega_0$ (System overstrength factor) = $2.0$
I <sub>p</sub> (Importance factor) = 1.5
z/h (Height factor ratio) = 1.0
Equipment or Component Natural Frequencies (Hz) = See attachment
Overall dimensions and weight (or range thereof) = See attachment
Equipment or Components @ grade designed in accordance with ASCE 7-10 Chapter 15:   Yes   No
Design Basis of Equipment or Components (V/W) =
S <sub>DS</sub> (Design spectral response acceleration at short period, g) =
S <sub>D1</sub> (Design spectral response acceleration at 1 second period, g) =
R (Response modification coefficient) ¥ : <u>Ali Sumer</u>
$\Omega_0$ (System overstrength factor) =
C <sub>d</sub> (Deflection amplification factor) = DATE: 05/07/2019
I <sub>p</sub> (Importance factor) = 1.5
Height to Center of Gravity above base =
Equipment or Component Natural Frequencies (Hz) =
Overall dimensions and weight (or range thereof) = DING
Tank(s) designed in accordance with ASME BPVC, 2015: ☐ Yes ☒ No
List of Attachments Supporting Special Seismic Certification
OSHPD Approval (For Office Use Only) – Approval Expires on December 31, 2022
A ———
Signature: Date: May 6, 2019
Print Name: Ali Sumer Title: DSE
Special Seismic Certification Valid Up to : S <sub>DS</sub> (g) =2.5 z/h =1.0
Condition of Approval (if applicable):

"Access to Safe, Quality Healthcare Environments that Meet California's Diverse and Dynamic Needs"

05/07/2019





### **Table 1 - Certified Components**

Manufacturer: Johnson Controls, Inc. (Sold as Tyco Security Products, Inc.)

Model Line	Model Number	Ма	x. Dimensions	(in)	Max. Weight	Mounting	Unit
Model Line	Model Number	Depth	Width	Height	(lb)	Mounting	Onit
	STAR008W-64A NPS	4.0	16.5	24.3	20.9	Rigid Wall	Extrapolated
Tyco iSTAR Pro	STAR016W-64A NPS	4.0	16.5	24.3	21.7	Rigid Wall	Extrapolated
Tyco ISTAN FIO	STAR008W-64A	4.0	16.5	24.3	22.5	Rigid Wall	Extrapolated
	STAR016W-64A	F 04.0	OD 16.5 C	24.3	23.3	Rigid Wall	UUT 1
Tyco iSTAR Ultra	USTAR008	5.0	22.3	25.3	25.6	Rigid Wall	Interpolated
	USTAR016	5.0	22.3	25.3	27.3	Rigid Wall	UUT 2
	USTAR008-SE-NPS	4.0	16.5	24.3	20.9	Rigid Wall	Extrapolated 1,2,3
Tyco iSTAR Ultra SE	USTAR016-SE-NPS	:A4.01 S	ume.50	24.3	21.7	Rigid Wall	Extrapolated 1,2,3
	USTAR008-SE	TE: 4.0 05/0	7/2019	24.3 9	22.5	Rigid Wall	Extrapolated 1,2,3
	USTAR016-SE	4.0	16.5	24.3	23.3	Rigid Wall	Extrapolated 1,2,3

#### Notes:

<sup>1.</sup> iSTAR Ultra SE uses the same enclosure as iSTAR Pro

<sup>2.</sup> iSTAR Ultra SE uses the same GCM as used in the iSTAR Ultra

<sup>3.</sup> iSTAR Ultra SE uses ACMs that are reduced feature boards of the iSTAR Ultra ACM boards

### **Table 2 - Certified Subcomponents**

Manufacturer: Johnson Controls, Inc. (Sold as Tyco Security Products, Inc.)


Subcomponent	Model Number	Description	Material	Unit
General Control Module	STARGV-64MBA	iSTAR Pro GCM Board	PCB	UUT 1
General Control Wodule	USTAR-GCM	iSTAR Ultra GCM Board	PCB	UUT 2
Access Control Module	STAR-ACM8-WA	iSTAR Pro ACM Board, Qty 2	PCB	UUT 1
Access Control Module	USTAR-ACM	iSTAR Ultra ACM Board, Qty 2	PCB	UUT 2
Power Supply	STAR-PS	100-240 VAC Input, 12 VDC Output	Copper and Plastic	UUT 1&2
Enclosure	STAR-CAN	iSTAR Pro Enclosure	Carbon Steel, NEMA 1	UUT 1
Eliciosure	USTAR-CAN	iSTAR Ultra	Carbon Steel, NEMA 1	UUT 2



# **Table 3 - Tested Units**

Manufacturer: Johnson Controls, Inc. (Sold as Tyco Security Products, Inc.)

Model Number		Dimensions (in)		Weight (lb)	Mounting	Unit
Wodel Nullibel	Depth	Width	Height	weight (ib)	Mounting	Offic
STAR016W-64A	4.0	16.5	24.3	23.3	Rigid Wall	UUT 1
USTAR016	5.0	22.3	25.3	27.3	Rigid Wall	UUT 2



### UUT1

# **UNIT UNDER TEST (UUT) Summary Sheet**



Manufacturer: Johnson Controls, Inc. (Sold as Tyco Security Products, Inc.)

Product Line: Tyco iSTAR Controllers Model Number: STAR016W-64A

Product Construction Summary: 16ga carbon steel enclosure, NEMA 1

Options / Component Summary: General controller module: STARGC-64MBA (Qt. 1). Access Control Module: STAR-ACM8-WA (Qt.

2). Power Supply: STAR-PS input 100 VAC to 240VAC, output 12VDC. Enclosure: STAR-CAN (Qt. 1)

Note: The UUT was operational before and after shaking and was full of operating content during the tests. The structural integrity of the component and attachment system and force-resisting systems was maintained.

#### **UUT Properties**

Operating Weight	D	Dimensions (in)					ency (Hz)
(lb)		Length	Width	Height	Front-Back	Side-Side	Vertical
23.3	UUT1	4.0	16.5	24.3	N/A	N/A	N/A

#### Seismic Test Parameters

Building Code	Test Criteria	Sds (g)	z/h	- Ip	Aflx-H (g)	Arig-H (g)	Aflx-V (g)	Arig-V (g)
CBC 2016	ICC-ES AC156	2.50	1.0	CODI	4.00	3.00	1.67	0.67
CBC 2010	ICC-L3 AC130	2.50	0.0	1.5	4:00	3.00	1.07	0.67

**Unit Mounting Description:** 

UUT-1





UUT 1 was mounted to the wall test fixture with (4) 1/4" Grade 2 bolts with washers. Bolts were spaced approximately 15" horizontally and 23" vertically

### UUT2

# **UNIT UNDER TEST (UUT) Summary Sheet**



Manufacturer: Johnson Controls, Inc. (Sold as Tyco Security Products, Inc.)

Product Line: Tyco iSTAR Controllers

Model Number: USTAR016

Product Construction Summary: 16ga carbon steel enclosure, NEMA 1

Options / Component Summary: General controller module: USTAR-GCM (Qt. 1). Access Control Module: STAR-ACM (Qt. 2).

Enclosure: USTAR-CAN (Qt. 1)

Note: The UUT was operational before and after shaking and was full of operating content during the tests. The structural integrity of the component and attachment system and force-resisting systems was maintained.

#### **UUT Properties**

<b>Operating Weight</b>	D	Lowest N	latural Freque	ency (Hz)			
(lb)		Length	Width	Height	Front-Back	Side-Side	Vertical
27.3	UUT2	5.0	22.3	25.3	N/A	N/A	N/A


#### Seismic Test Parameters

Building Code	Test Criteria	Sds (g)	z/h	lp	Aflx-H (g)	Arig-H (g)	Aflx-V (g)	Arig-V (g)
CBC 2016 ICC-ES AC156	ICC ES AC1E6	2.50	1.0	CODI	4.00	3.00	1.67	0.67
	2.50	0.0		4.00	5.00	1.67	0.67	

**Unit Mounting Description:** 

OSP-0425-10





UUT 2 was mounted to the wall test fixture with (6) 1/4" Grade 2 bolts with washers. Bolts were spaced at approximately 21" horizontally and 12" vertically

05/07/2019 OSP-0425-10 Page 8 of 8