

Title: SE

DEPARTMENT OF HEALTH CARE ACCESS AND INFORMATION OFFICE OF STATEWIDE HOSPITAL PLANNING AND DEVELOPMENT

APPLICATION FOR HCAI SPECIAL SEISMIC	OFFICE USE ONLY
CERTIFICATION PREAPPROVAL (OSP)	APPLICATION #: OSP-0426
HCAI Special Seismic Certification Preapproval (OSP)	
Type: New X Renewal	
Manufacturer Information	
Manufacturer: Active Power Inc	
Manufacturer's Technical Representative: Barry Marks	
Mailing Address: 2128 W Braker, BK12, Austin, TX 78758	
Telephone: (512) 744-9227 Email: bmarks@active	epower.com
Product Information	
Product Name: CleanSource 750HD UPS	Mp
Product Model Number(s): CSHD750 (Active Power Part Number 882065	54)
Product Category: UPS and Batteries	3
Product Sub-Category: Flywheel Energy Storage Systems	in in
General Description: 750 kVA 3-wire, single input flywheel UPS.	rim
Mounting Description: Rigid Base mount.	
Tested Seismic Enhancements: Seismic enhancements made to the te anomalies during the tests shall be income	est units and/or modifications required to address corporated into the production units.
Applicant Information	
Applicant Company Name: EASE	
Contact Person: Jonathan Roberson	
Mailing Address: 5877 Pine Ave, Suite 210, Chino Hills, CA 91709	
Telephone: (909) 606-7622 Email: jon@easeco.cd	om







DEPARTMENT OF HEALTH CARE ACCESS AND INFORMATION OFFICE OF STATEWIDE HOSPITAL PLANNING AND DEVELOPMENT

California Licensed Structural Engineer Responsible for the Engineering and Test Report(s)								
Company Name: EASE LLC								
Name: Jonathan Roberson	California License Number: S4197							
Mailing Address: 5877 Pine Ave.	, Suite 210, Chino Hills, CA 91709							
Telephone: (951) 295-1892	Email: jon@EASECo.com							
Certification Method								
GR-63-Core X	ICC-ES AC156							
Other (Please Specify):								
Testing Laboratory								
Company Name: ENVIRONMEN	TAL TESTING LABORATORIES, INC. (ETL)							
Contact Person: Jeremy Lange								
Mailing Address: 11034 Indian Trail, Dallas TX 75229-3513								
Telephone: (972) 247-9657	Email: Jeremy@etldallas.com							
	O BY: Mohammad Karim							
	DATE: 09/18/2025 PLA BUILDING CODE:							



STATE OF CALIFORNIA - HEALTH AND HUMAN SERVICES AGENCY



DEPARTMENT OF HEALTH CARE ACCESS AND INFORMATION OFFICE OF STATEWIDE HOSPITAL PLANNING AND DEVELOPMENT

Seismic Parameters

Design Basis of Equipment or Components (Fp/Wp) = 1.44 @ SDS = 2.00 / 1.17 @ SDS = 2.60

SDS (Design spectral response acceleration at short period, g) = 2.00 (z/h = 1); 2.60 (z/h = 0)

ap (Amplification factor) = 1

 R_p (Response modification factor) = 2.5

 Ω_0 (System overstrength factor) = 2.0

Ip (Importance factor) = 1.5

z/h (Height ratio factor) = 0 and 1

Natural frequencies (Hz) = See Attachment

Overall dimensions and weight = 132" W x 39" D x 80" H / 11,785 lb.

HCAI Approval (For Office Use Only) - Approval Expires on 09/18/2031

Date: 9/18/2025

Name: Mohammad Karim

Title: Supervisor, Health Facilities

Special Seismic Certification Valid Up to: Sps (g) = 2.0

z/h =

Condition of Approval (if applicable):

DATE: 09/18/2025





STATE OF CALIFORNIA – HEALTH AND HUMAN SERVICES AGENCY



ACTIVE POWER

ATTACHMENT 1: TEST SPECIMEN SUMMARY

ATTACHMENT PAGE | 1 OF 1

UUT-1	CleanSource 750HD 3W (3-wire)				Report No.	Report No.: SQ10-1307-01	
Manufacturer:	Active Power						
Identification:	Model No.: CSHD750 Serial No.: AP01464					T	
Description:	Uninterruptible Power Supply (UPS) 750 kVA UPS 3-wire, single input w/o EXRC Cabine			1			
	connecting mount replaced with 0.25 and compatible he subsequently rele	seismic qualificatio ing base to cabinet or diameter SAE J4. ex nuts. These mod ased as a standard ive Power Part Nur	structure were 29 Grade 5 bolts ifications were manufactured				
Mounting:	Rigid Base (Floor (20) – 5/8" dia GF		R CODE C				
	Dimensions (in	.)		Lowest	ncy (Hz.)		
Width	Depth	Height	Weight (lb.)	Side-Axis	Front-Axis	Vert-Axis	
132	39	80	11,785	5.8	6.6	15.7	
ICC-ES AC156	Shake Table Test P	arameters	DSP_0/26			Code: 2022 CBC	
S _{DS} (G)	z/h	IP	A _{FLX-H} (G)	Arig-H (G)	A _{FLX-V} (G)	Arig-v (G)	
2.0 2.6	1 0	1.5 1.5 M	onamr³.20 Kar	m 2.40	1.74	0.70	
Unit satisfied AC1	56 requirements for stru	ctural integrity and ma	anufacturer requiremen	ts for functionality afte	r AC156 test.		