



OFFICE OF STATEWIDE HEALTH PLANNING AND DEVELOPMENT
FACILITIES DEVELOPMENT DIVISION

APPLICATION FOR OSHPD SPECIAL SEISMIC
CERTIFICATION PREAPPROVAL (OSP)

OFFICE USE ONLY
APPLICATION #: OSP - 0430 - 10

OSHPD Special Seismic Certification Preapproval (OSP)

Type: [ ] New [X] Renewal

Manufacturer Information

Manufacturer: MTE Corporation / TEAL Electronics Corporation

Manufacturer's Technical Representative: Roderick Harvey

Mailing Address: 4350 Executive Dr., Suite 315, San Diego, CA 92121

Telephone: 858.366.7540 Email: roderick.harvey@mtecorp.com

Product Information

Product Name: Siemens PDU Falcon

Product Type: Power Distribution Unit - PDU

Product Model Number: PDU-PDCC - 45kVA
(List all unique product identification numbers and/or part numbers)

General Description: 45kVA Power Distribution Unit. Seismic enhancements made to the test units
and modifications required to address the anomalies observed during the tests shall be incorporated into the production units.

Mounting Description: Rigid Base Mounted

Applicant Information

Applicant Company Name: SEESTudio, Inc.

Contact Person: Dan Junker, SE

Mailing Address: 2655 Camino del Rio N. Suite 100, San Diego, CA 92108


Telephone: 619.606.5058 Email: djunker@seestudioinc.com

I hereby agree to reimburse the Office of Statewide Health Planning and Development review fees in accordance with the California Administrative Code, 2016.

Signature of Applicant: [Handwritten Signature] Date: 12.12.18

Title: Principal Engineer Company Name: SEESTudio, Inc.

\*Access to Safe, Quality Healthcare Environments that Meet California's Diverse and Dynamic Needs\*





**OFFICE OF STATEWIDE HEALTH PLANNING AND DEVELOPMENT  
FACILITIES DEVELOPMENT DIVISION**

**California Licensed Structural Engineer Responsible for the Engineering and Test Report(s)**

Company Name: SEESstudio, Inc.

Name: Dan Junker, SE California License Number: S6178

Mailing Address: 2655 Camino del Rio N. Suite 100, San Diego, CA 92108

Telephone: 619.606.5058 Email: djunker@seestudioinc.com

**Supports and Attachments Preapproval**


Supports and attachments are preapproved under OPM- \_\_\_\_\_  
(Separate application for OSHPD Preapproval of Manufacturer's Certification (OPM) of Supports and attachments is required)

Supports and attachments are not preapproved

**Certification Method**

Testing in accordance with:  ICC-ES AC156

Other (Please Specify): \_\_\_\_\_




**Testing Laboratory**

Company Name: Environmental Testing Laboratory, Inc.

Contact Name: Brady Richard, President

Mailing Address: 11034 Indian Trail, Dallas, TX 75229

Telephone: 972-247-9657 Email: info@etldallas.com





OFFICE OF STATEWIDE HEALTH PLANNING AND DEVELOPMENT
FACILITIES DEVELOPMENT DIVISION

Seismic Parameters

Design in accordance with ASCE 7-10 Chapter 13: [X] Yes [ ] No

Design Basis of Equipment or Components (Fp/Wp) = 1.69

Sds (Design spectral response acceleration at short period, g) = 2.25

ap (In-structure equipment or component amplification factor) = 2.5

Rp (Equipment or component response modification factor) = 6.0

Omega\_0 (System overstrength factor) = 2.0

Ip (Importance factor) = 1.5

z/h (Height factor ratio) = 1

Equipment or Component Natural Frequencies (Hz) = See Attachment

Overall dimensions and weight (or range thereof) = See Attachment

Equipment or Components @ grade designed in accordance with ASCE 7-10 Chapter 15: [ ] Yes [X] No

Design Basis of Equipment or Components (V/W) =

Sds (Design spectral response acceleration at short period, g) =

Sd1 (Design spectral response acceleration at 1 second period, g) =

R (Response modification coefficient) = OSP-0430-10

Omega\_0 (System overstrength factor) =

Cd (Deflection amplification factor) = BY: Ali Sumer

Ip (Importance factor) = 1.5

Height to Center of Gravity above base = DATE: 02/20/2019

Equipment or Component Natural Frequencies (Hz) =

Overall dimensions and weight (or range thereof) =

Tank(s) designed in accordance with ASME BPVC, 2015: [ ] Yes [X] No

List of Attachments Supporting Special Seismic Certification

[X] Test Report(s) [ ] Drawings [ ] Calculations [ ] Manufacturer's Catalog

[X] Other(s) (Please Specify): SEES Certified Component Summary


OSHPD Approval (For Office Use Only) - Approval Expires on December 31, 2022

Signature: [Signature] Date: February 20, 2019

Print Name: Ali Sumer Title: DSE

Special Seismic Certification Valid Up to : Sds (g) = 2.25 z/h = 1.0

Condition of Approval (if applicable):





SPECIAL SEISMIC CERTIFICATION

**CERTIFIED COMPONENTS**

**TABLE 1**

**MANUFACTURER:** MTE Corporation / TEAL Electronics Corporation

**MODEL LINE:** PDU

**TABLE DESCRIPTION:** Power Distribution Unit Enclosure

**CONSTRUCTION SUMMARY:** **CERTIFICATION PARAMETERS:**

Painted 14GA galvanized cold-rolled carbon steel enclosure. Certified unit construction shall be identical to cabinet construction of UUT's.

**Building Code:** CBC 2016

**Component Importance Factor:**  $I_p = 1.5$

**OPTIONS SUMMARY:**

N/A – Single Configuration

**$S_{Ds}$  at  $z/h = 1.0:$**   $S_{Ds} = 2.25g$

**MOUNTING SUMMARY:**

**NOTES:**

Rigid floor mounted. Unit anchorage shall be designed on a project specific basis by SEOR. Installed mounting configuration must be of similar configuration and equivalent strength and stiffness to those tested.

Model Line	Model	Max Dimensions (in)			Weight (lb)	Description	UUT
		Depth	Width	Height			
PDU	PDCC – 45kVA	36.0	44.0	57.5	1215	Test Prototype 1	1
					1225	Test Prototype 2	2

## SPECIAL SEISMIC CERTIFICATION

**CERTIFIED SUB-COMPONENTS**
**TABLE 2**
**MANUFACTURER:** MTE Corporation / TEAL Electronics Corporation

**MODEL LINE:** PDU

**TABLE DESCRIPTION:** All Subcomponents

CONSTRUCTION SUMMARY:	CERTIFICATION PARAMETERS:
<b>OPTIONS SUMMARY:</b>	<b>Building Code:</b> CBC 2016
Enclosure types per Tables 1 & 2 are available as custom units with internal component options available as presented herein.	<b>Component Importance Factor:</b> $I_p = 1.5$
	<b>S<sub>DS</sub> at z/h = 1.0:</b> S <sub>DS</sub> = 2.25g

MOUNTING SUMMARY:	NOTES:
Mounted in component. Certified mounting shall be identical to mounting of sub-component in UUT's.	

Sub-Component	Manufacturer	Model	Description	Notes	UUT
Transformer	Teal Electronics	TK0010	3P Delta-Wye		1,2
Thermal Cutout	Pepi	C-100456	170 degree		1,2
Power Supply	CUI Inc	VOF-30-24	24VDC, 1.3A		1,2
Terminal Block	Siemens	8WH2000-OAK00	65A, 600V 12MM		1,2
		8WH2000-OAF00	20A, 600V 5.2MM		1,2
		8WH2000-OAH00	50A, 600V 8.2MM		1,2
		8WH2000-OAM00	115A, 600V 16MM		1,2
	Marathon	1432559	2 Gang, 600V, 310A		1,2
Relay	ABB	1SVR405611R1000	12A, 24VDC, 2 SPDT, 250VAC		1,2
MOV Module	Phoenix	VAL-MS 500 ST	600V, 10kA	3 tested	1,2
Circuit Breaker	Eaton	EGE3090FFG	3P, 90A, 415/480VAC		1,2
		EGE3070FFG	3P, 70A, 414/480 VAC		1,2
		EGE3030FFG	3P, 30A, 414/480 VAC		1,2
		EGE3060FFG	3P, 60A 415/480 VAC		2
		FAZ-D20/2-NA	2P, 20.0A, 277/480VAC		1,2
Switch	Eaton	M22-YED0055	24V		1,2
UPS	Eaton	9PX5000	5000VA/4500W	2 tested	1,2
Tower Computer	Siemens	IRS-FHU	110-240VAC, 5 - 2 A, 50-60 Hz		1,2
Power Strip	Eaton	EFLXI3000R-PDU1UIEC	110-240VAC, 50-60 Hz, 16 A		1,2
Workstation	Hewlett Packard	Z820	11A / 100-127 VAC, 5.5A / 200-240VAC		1
		Z8G4	11A / 100-127 VAC, 5.5A / 200-240 VAC		2
KVM Module	Digital Multitools	DKX1004	100-240VAC, 50/60 Hz, 0.4A		1,2
Ethernet Switch	NETGEAR	JGS516	16 Port 10/100/1000		1,2
EtherPet Switch	Siemens	10749750	10GbE EtherPET Assembly		2

SPECIAL SEISMIC CERTIFICATION

# UNIT UNDER TEST (UUT) DESCRIPTION

UUT **1**

**MANUFACTURER:** MTE Corporation / TEAL Electronics Corporation

**MODEL LINE:** PDU

**MODEL NUMBER:** PDCC – 45kVA

**CONSTRUCTION SUMMARY:**

Painted galvanized cold-rolled carbon steel enclosure.

**TEST PARAMETERS:**

**Building Code:** CBC 2016

**Component Importance Factor:**  $I_p = 1.5$

**Test Criteria:** AC-156

**OPTIONS SUMMARY:**

**Transformer:** (1) Teal Electronics TK0010 with (1) Pepi C-100456 thermal cutout. **Power Supply:** (1) CUI VOF-30-24. **Terminal Blocks:** (2) Siemens 8WH2000-0AK00, (3) Siemens 8WH2000-0AF00, (1) Siemens 8WH2000-0AH00, (1) Siemens 8WH2000-0AM00. **Relay:** (2) ABB 1SVR405611R1000. **Circuit Breakers:** (2) Eaton FAZ-D20/2-NA, (1) Eaton EGE3030FFG, (1) Eaton EGE3070FFG, (1) Eaton EGE3090FFG. **MOV Module:** (3) Phoenix VAL-MS 500 ST. **Switch:** (1) Eaton M22-YED0055. **UPS:** (2) Eaton 9PX5000. **Tower Computer:** (1) Siemens IRS-FHU. **Power Strip:** (1) Eaton EFLXI3000R-PDU1UIEC. **Workstation:** (1) Hewlett Packard Z820. **KVM Module:** (1) Digital Multitools DKX1004. **Ethernet Switch:** (1) NETGEAR JGS516.


**MOUNTING SUMMARY:**

Rigid floor mounted. Unit mounted to shake table with a total of four (4) 3/8"-11 Gr. 5 bolts.

**NOTES:**

Contents were included in testing per operating conditions.

**UUT IMAGE**



**UUT PROPERTIES**

Dimensions (in)			Weight (lb)	First Natural Frequency (Hz)		
Depth	Width	Height		F-B	S-S	Vert
36.0	44.0	57.5	1,215	13.2	17.3	7.3

**UNIT MAINTAINED STRUCTURAL INTEGRITY AND REMAINED OPERATIONAL**

PER MANUFACTURER REQUIREMENT WHEN SUBJECTED TO THE FOLLOWING TEST PARAMETERS

$S_{Ds}$ (g)	z/h	$A_{FLX-H}$ (g)	$A_{RIG-H}$ (g)	$A_{FLX-V}$ (g)	$A_{RIG-V}$ (g)
2.25	1.0	3.60	2.70	1.50	0.60

## SPECIAL SEISMIC CERTIFICATION

# UNIT UNDER TEST (UUT) DESCRIPTION

 UUT **2**
**MANUFACTURER:** MTE Corporation / TEAL Electronics Corporation

**MODEL LINE:** PDU

**MODEL NUMBER:** PDCC – 45kVA

**CONSTRUCTION SUMMARY:**

Painted galvanized cold-rolled carbon steel enclosure. Positive bolted attachment required at door latches, each side.

**OPTIONS SUMMARY:**
**Transformer:** (1) Teal Electronics TK0010 with (1) Pepi C-100456 thermal cutout. **Power Supply:** (1) CUI VOF-30-24. **Terminal Blocks:** (2) Siemens 8WH2000-0AK00, (3) Siemens 8WH2000-0AF00, (1) Siemens 8WH2000-0AH00, (1) Siemens 8WH2000-0AM00. **Relay:** (2) ABB 1SVR405611R1000. **Circuit Breakers:** (2) Eaton FAZ-D20/2-NA, (1) Eaton EGE3030FFG, (1) Eaton EGE3070FFG, (1) Eaton EGE3090FFG, (1) Eaton EGE3060FFG. **MOV Module:** (3) Phoenix VAL-MS 500 ST. **Switch:** (1) Eaton M22-YED0055. **UPS:** (2) Eaton 9PX5000. **Tower Computer:** (1) Siemens IRS-FHU. **Power Strip:** (1) Eaton EFLXI3000R-PDU1UIEC. **Workstation:** (1) Hewlett Packard Z8G4. **KVM Module:** (1) Digital Multitools DKX1004. **Ethernet Switch:** (1) NETGEAR JGS516, (1) Siemens 10749750.

**TEST PARAMETERS:**
**Building Code:** CBC 2016

**Component Importance Factor:**  $I_p = 1.5$ 
**Test Criteria:** AC-156

**MOUNTING SUMMARY:**

Rigid floor mounted. Unit mounted to shake table with a total of six (6) 3/8"-11 Gr. 5 bolts.

**NOTES:**

Contents were included in testing per operating conditions.

**UUT IMAGE**

**UUT PROPERTIES**

Dimensions (in)			Weight (lb)	First Natural Frequency (Hz)		
Depth	Width	Height		F-B	S-S	Vert
36.0	44.0	57.5	1,225	13.69	4.46	>33.33

**UNIT MAINTAINED STRUCTURAL INTEGRITY AND REMAINED OPERATIONAL**

PER MANUFACTURER REQUIREMENT WHEN SUBJECTED TO THE FOLLOWING TEST PARAMETERS

$S_{Ds}$ (g)	$z/h$	$A_{FLX-H}$ (g)	$A_{RIG-H}$ (g)	$A_{FLX-V}$ (g)	$A_{RIG-V}$ (g)
2.5	1.0	4.0	3.0	1.67	0.67