### OFFICE USE ONLY APPLICATION FOR OSHPD SPECIAL SEISMIC **CERTIFICATION PREAPPROVAL (OSP) APPLICATION #:** OSP - 0437 - 10 **OSHPD Special Seismic Certification Preapproval (OSP)** ☐ New ☐ Renewal **Manufacturer Information KONE** Manufacturer: Manufacturer's Technical Representative: Jorge Torres Mailing Address: 450 Century Parkway, Allen, Texas 75013 Telephone: ON FILE Email: **Product Information** LCE Traction Elevator Logic and Drive Controller w/ KDM 150 Drive Product Type: Elevator Controls Product Model Number: See Attachment 1 (List all unique product identification numbers and/or part numbers) Electronic motion control system for the operation of people-moving elevators. Seismic General Description: enhancements made to the test units and modifications required to address the anomalies observed during the tests shall be incorporated into the production units. Mounting Description: Rigid Base mount **Applicant Information** Applicant Company Name: EASE LLC Contact Person: Jonathan Roberson, S.E. Mailing Address: 5877 Pine Ave, Suite 210, Chino Hills, CA. 91709 Telephone: (909) 606-7622 Email: <u>j.roberson@easeco.com</u> I hereby agree to reimburse the Office of Statewide Health Planning and Development review fees in accordance with the California Administrative Code, 2016. Signature of Applicant: Date: 5/29/2019 Title: Principal Structural Engineer Company Name: **EASE LLC**

"Access to Safe, Quality Healthcare Environments that Meet California's Diverse and Dynamic Needs'





California Licensed Structural Engineer Responsible for the Engineering and Test Report(s)
Company Name: EASE LLC
Name: Jonathan Roberson, S.E. California License Number: S4197
Mailing Address: 5877 Pine Ave, Suite 210, Chino Hills, CA. 91709
Telephone: (909) 606-7622 Email: j.roberson@easeco.com
Supports and Attachments Preapproval
<ul> <li>Supports and attachments are preapproved under OPM-         (Separate application for OSHPD Preapproval of Manufacturer's Certification (OPM) of Supports and attachments is required)</li> <li>Supports and attachments are not preapproved</li> </ul>
Certification Method
<ul> <li>☐ Testing in accordance with:</li> <li>☐ Other (Please Specify):</li> </ul> OSP-0437-10
BY:Timothy J Piland
Testing Laboratory DATE: 01/21/2020
Company Name: Environmental Testing Laboratory, Inc.
Contact Name: Brady Richard
Mailing Address: 11034 Indian Trail, Dallas, TX. 75229-3513
Telephone: (972) 247-9657 Email: <u>brady@etldallas.com</u>



Page 2 of 3



# OFFICE OF STATEWIDE HEALTH PLANNING AND DEVELOPMENT FACILITIES DEVELOPMENT DIVISION

Seismic Parameters
Design in accordance with ASCE 7-10 Chapter 13: ⊠ Yes ☐ No
Design Basis of Equipment or Components (F <sub>p</sub> /W <sub>p</sub> ) = 1.44
S <sub>DS</sub> (Design spectral response acceleration at short period, g) = <b>2.00</b>
a <sub>p</sub> (In-structure equipment or component amplification factor) =1
R <sub>p</sub> (Equipment or component response modification factor) = 2½
$\Omega_0$ (System overstrength factor) =
I <sub>p</sub> (Importance factor) = <b>1.5</b>
z/h (Height factor ratio) = 1
Equipment or Component Natural Frequencies (Hz) = See Attachment 2
Overall dimensions and weight (or range thereof) = See Attachment 1, Table 1
Equipment or Components @ grade designed in accordance with ASCE 7-10 Chapter 15:   Yes  No
Design Basis of Equipment or Components (V/W) =
S <sub>DS</sub> (Design spectral response acceleration at short period, g) =
S <sub>D1</sub> (Design spectral response acceleration at 1 second period, g) =
R (Response modification coefficient) =
Ω <sub>0</sub> (System overstrength factor) = By:Timothy J Piland
C <sub>d</sub> (Deflection amplification factor) =
$I_p$ (Importance factor) = 1.5 DATE: 01/21/2020
Height to Center of Gravity above base =
Equipment or Component Natural Frequencies (Hz) =
Overall dimensions and weight (or range thereof) =
Tank(s) designed in accordance with ASME BPVC, 2015:   Yes No
List of Attachments Supporting Special Seismic Certification
☐ Test Report(s) ☐ Drawings ☐ Calculations ☐ Manufacturer's Catalog
OSHPD Approval (For Office Use Only) – Approval Expires on December 31, 2025
1/1/00
Signature: Date: February 21, 2020
Print Name: Timothy J Piland Title: SSE
Special Seismic Certification Valid Up to: $S_{DS}(g) = \underline{2.00}$ $z/h = \underline{1}$
Condition of Approval (if applicable):
Condition of Approval (if applicable):

"Access to Safe, Quality Healthcare Environments that Meet California's Diverse and Dynamic Needs"

STATE OF CALIFORNIA - HEALTH AND HUMAN SERVICES AGENCY





OSH-FD-759 (REV 12/16/15) 02/21/2020 OSP-0437-10 Page 3 of 9



### ATTACHMENT 1: SEISMIC CERTIFIED COMPONENTS

ATTACHMENT PAGE | 1 OF 2

#### TABLE 1: SEISMIC CERTIFIED COMPONENTS

			DIM	IENSIONS	(IN.)	APPROX.		
COMPONENT	MANUF.	MODEL NO.	W	D	H	WT. (LB.)	MOUNT	BASIS
CE2 LOGIC & DRIVE CONTROLLERS								
ReSolve 400 – LCE2 Traction Elevator Logic Controller	KONE	51086260D20	20.2	14.1	84.5	256	Floor	UUT1
KDM 150 Drive Machine Controller Assembly [2]	KONE	50077900C01	20.5	20.8	73.0	600		
KCM 831 - LCE2 Traction Elevator Logic Controller	KONE	510862 <mark>60D20</mark>	20.2	14.1	84.5	256	Floor	UUT2
KDM 150 Drive Machine Controller Assembly [2]	KONE	50077900C01	20.5	20.8	73.0	600		
XTERNAL MAIN LINE TRANSFORMERS [3]	V/ US:	TPI)	Y,					
110 KVA Transformer 208V-240V	Nova Magnetics	KM785076G09	25.0	14.0	34.0	558	Floor	UUT3
110 KVA Transformer 440V-500V	Nova Magnetics	43 KM785077G09	18.0	16.5	27.5	230	Floor	INT
110 KVA Transformer 575V-600V	Nova Magnetics	KM785078G09	21.0	18.0	31.0	370	Floor	INT
90 KVA Transformer 208V-240V	Nova Magnetics	KM785076G08	25.0	14.0	34.0	360	Floor	INT
90 KVA Transformer 440V-500V	Nova Magnetics	KM785077G08	18.0	16.5	27.5	205	Floor	INT
90 KVA Transformer 575V-600V	Nova Magnetics	KM785078G08	21.0	18.0	31.0	325	Floor	INT
70 KVA Transformer 208V-240V	Nova Magnetics	KM785076G07	21.0	18.0	31.0	320	Floor	INT
70 KVA Transformer 440V-500V	Nova Magnetics	KM785077G07	18.0	16.5	27.5	180	Floor	INT
70 KVA Transformer 575V-600V	Nova Magnetics	M785078G07	18.0	16.5	27.5	265	Floor	INT
55 KVA Transformer 200V - 240V	Nova Magnetics	KM785076G05	17.3	16.0	27.4	281	Floor	UUT5
55 KVA Transformer 440V - 500V	Nova Magnetics	KM785077G05	18.0	16.5	27.5	175	Floor	INT
55 KVA Transformer 575V - 600V	Nova Magnetics	KM785078G05	18.0	16.5	27.5	230	Floor	INT
10 KVA Transformer 200V - 240V	Nova Magnetics	KM785076G06	13.5	13.5	18.0	95	Floor	INT
10 KVA Transformer 440V - 500V	Nova Magnetics	KM785077G06	12.8	13.0	18.0	66	Floor	UUT6
10 KVA Transformer 575V - 600V	Nova Magnetics	KM785078G06	13.5	13.5	18.0	71	Floor	INT

#### ATTACHMENT 1: SEISMIC CERTIFIED COMPONENTS

ATTACHMENT PAGE | 2 OF 2

#### TABLE 2: SEISMIC CERTIFIED SUBCOMPONENTS

SUBCOMPONENT DESCRIPTION	MANUFACTURER	PART NO.	MATERIAL	BASIS
RESOLVE 400 & KCM 831 LOGIC CONTROLLERS	KONE INDUSTRIAL	51086260D20		UUT1 UUT2
TRANSFORMER, CONTROL, POS. 245, 208 - 240VAC, 1350VA	GRAND TRANSFORMERS INC	KM977496G02	Laminated Steel / Copper windings / Varnished / Open Core	UUT1
TRANSFORMER, CONTROL, POS. 245, 420 - 480 VAC, 1350VA	GRAND TRANSFORMERS INC	KM977496G01	Laminated Steel / Copper windings / Varnished / Open Core	UUT2
	POTENTIAL	10		
KONE KDM 150 Drive Controller	KONE INDUSTRIAL	50077900C01		UUT1 UUT2
CABINET MECHANICS	PREMEC OY	KM50057160G02	Galvanized CRS / Painted CRS	UUT1 UUT2
AC DRIVE, VACON KR8 150A		KM50077901G01	Aluminum / Galvanized CRS / FR4 PCB / Plastic / Copper	UUT1 UUT2
Notes  1. BASIS:  • UUT#: Indicates that a test specimen matching the  • INT (Interpolate/Extrapolate): indicates a model that			stablished through evaluation of testing of other,	similar

- INT (Interpolate/Extrapolate): indicates a model that was not specifically tested, and by which seismic certification is established through evaluation of testing of other, similar models in the product line.
- 2. Certification in this table is limited subcomponents identified when installed as part of a complete assembly of the equipment defined in Table 1.
- 3. CRS = Cold-Rolled Sheet-Steel.
- 4. FR4 PCB = Copper-clad, epoxy-fiberglass substrate, printed circuit board (PCB) material.





**ATTACHMENT 2: TEST SPECIMEN SUMMARY** 

ATTACHMENT PAGE | 1 OF 4

UUT- 1	ReSolve 400 I	LCE Logic Drive	Controller As	sembly w/ k	(DM 150 Di	rive	
MANUFACTURER:	KONE Inc.	,		1			<b>!</b>
IDENTIFICATION:	ReSolve 400	KDM 150					
	51086260D20	50077900C0	)1				
DESCRIPTION:	for Induction Motor / Input: 208 - 600 Vac brake/door circuit 23 120/230Vac, 1ph, 50 circuit.  KDM150 Traction E Input: 400 Vac, 3-ph 0 - 400 Vac, 3-ph, 0 kW/93hp at 400V; b hold, Enclosure Typ	Elevator Drive Machina 5,50/60 Hz, 1A; logic circular Elevator Drive Machina 5,50/60 Hz, 125 A; Out 1-250 Hz, 140 A maximular 1,250 Vd	o/60 Hz; Outputs: 6 A; safety circuit its 24 Vdc, 3 A per e Controller: puts: motor circuit um nominal, 69 lc, 8 A pick, 4 A				XDM 150 Solve 400
	<ul> <li>Top of KDM 150 bolts with hex nu</li> <li>Lower edge with</li> </ul> See subcomponent	Drive cabinet with (3) - ts. (2) - M8-8.8 hex head listing in Table 2 for ad	- M8-8.8 hex head bolts with hex nuts				
MOUNTING:	Top of KDM 150 bolts with hex nu Lower edge with See subcomponent Floor mounted using ReSolve 400: (5)	Drive cabinet with (3) - ts. (2) - M8-8.8 hex head listing in Table 2 for ad	- M8-8.8 hex head bolts with hex nuts ditional information				<u>.</u>
MOUNTING: PROPERTIES:	Top of KDM 150 bolts with hex nu Lower edge with See subcomponent Floor mounted using ReSolve 400: (5)	Drive cabinet with (3) – ts. (2) – M8-8.8 hex head listing in Table 2 for ad g: 5) – 3/8" diameter Grade	- M8-8.8 hex head bolts with hex nuts ditional information	nd			
	Top of KDM 150 bolts with hex nu Lower edge with See subcomponent Floor mounted using ReSolve 400: (5)	Drive cabinet with (3) – ts. (2) – M8-8.8 hex head listing in Table 2 for ad g: 5) – 3/8" diameter Grade	- M8-8.8 hex head bolts with hex nuts ditional information	nd Lowe	EST RESONAN	T FREQUENCE	eY (Hz.)
	Top of KDM 150 bolts with hex nur Lower edge with See subcomponent Floor mounted using ReSolve 400: (5 KDM 150: (5	Drive cabinet with (3) – ts. (2) – M8-8.8 hex head listing in Table 2 for ad g: 5) – 3/8" diameter Grade	- M8-8.8 hex head bolts with hex nuts ditional information	LOWE Front-Axis		T FREQUENCE:-Axis	EY (Hz.)  Vertical-Axis
PROPERTIES:	Top of KDM 150 bolts with hex nu Lower edge with See subcomponent Floor mounted using ReSolve 400: (5 KDM 150: (5)  DIMENSIONS (in.)	Drive cabinet with (3) – ts. (2) – M8-8.8 hex head listing in Table 2 for ad g: 5) – 3/8" diameter Grade 5) – 5/8" diameter Grade	bolts with hex nuts ditional information e 8 and 37-10 e 8 bolts.		Side	1	. ,
PROPERTIES: Width	Top of KDM 150 bolts with hex nut. Lower edge with See subcomponent Floor mounted using ReSolve 400: (5 KDM 150: (5)  DIMENSIONS (in.)  Depth	Drive cabinet with (3) – ts. (2) – M8-8.8 hex head listing in Table 2 for ad g: 5) – 3/8" diameter Grade 5) – 5/8" diameter Grade BY:  Height F. O	bolts with hex nuts ditional information e 8 and 37-10 e 8 bolts.  Weight (lb.)	Front-Axis	Side 6	-Axis	Vertical-Axis
PROPERTIES:  Width 20.22 20.43	Top of KDM 150 bolts with hex nu Lower edge with See subcomponent Floor mounted using ReSolve 400: (5 KDM 150: (5)  DIMENSIONS (in.)  Depth 14.1	Drive cabinet with (3) – ts. (2) – M8-8.8 hex head listing in Table 2 for ad g; 5) – 3/8" diameter Grade 5) – 5/8" diameter Grade BY: Improve Height F. (2) 84.51	bolts with hex nuts ditional information e 8 and 37-10 e 8 bolts.  Weight (lb.) 256	Front-Axis 6.2	Side 6	-Axis	Vertical-Axis
PROPERTIES:  Width 20.22 20.43	Top of KDM 150 bolts with hex nu Lower edge with See subcomponent Floor mounted using ReSolve 400: (5 KDM 150: (5 DIMENSIONS (in.) Depth 14.1 20.75	Drive cabinet with (3) – ts. (2) – M8-8.8 hex head listing in Table 2 for ad g; 5) – 3/8" diameter Grade 5) – 5/8" diameter Grade BY: Improve Height F. (2) 84.51	bolts with hex nuts ditional information e 8 and 37 - 10 e 8 bolts.  Weight (lb.)  256  595	Front-Axis 6.2	Side 6	-Axis	Vertical-Axis



#### ATTACHMENT 2: TEST SPECIMEN SUMMARY

ATTACHMENT PAGE | 2 OF 4

UUT- 2	KCM 831 LCE	Logic Drive Co	ntroller Asse	mbly w/ KDN	/ 150 Drive		
MANUFACTURER:	KONE Inc.	,					N
IDENTIFICATION:	KCM 831	KDM 150					10
	51086260D20	50077900C0	01				
DESCRIPTION:	for MX32 Permanen Input: 208 - 600 Vac brake/door circuit 23 120/230Vac, 1ph, 50 circuit.  KDM150 Traction E Input: 400 Vac, 3-ph 0 - 400 Vac, 3-ph, 0 kW/93hp at 400V; b hold, Enclosure Typ  Cabinets are conneted. Top of KDM 150 bolts with hex nuture.	cted at common side:  Drive cabinet with (3)	ations 0/60 Hz; Outputs: 6 A; safety circuit iits 24 Vdc, 3 A per  le Controller: tputs: motor circuit um nominal, 69 dc, 8 A pick, 4 A  M8-8.8 hex head bolts with hex nuts				DM 150 CM 831
MOUNTING:		g: ) – 3/8" di <mark>ameter Grad</mark> 5) – 5/8" diameter Grad			25,840,000		
PROPERTIES:		BY: I im	othy J Pila	and (////////			
	DIMENSIONS (in.)	* W.	10.000000000000000000000000000000000000	LOW	<mark>EST</mark> RESONAN	T FREQUENC	Y (Hz.)
Width	Depth	Height	Weight (lb.)	Front-Axis	Side	-Axis	Vertical-Axis
20.22	14.1	84.51	250	5.6	8	.1	>50
20.43	20.75	73.03	600	5.6	8	.1	>50
SHAKE TABLE TI	EST PARAMETERS	1/2/		4:			
CODE	TEST CRITERIA	S <sub>DS</sub> (g) z/l	h I <sub>P</sub>	A <sub>FLX-H</sub> (g)	A <sub>RIG-H</sub> (g)	A <sub>FLX-V</sub> (g)	A <sub>RIG-V</sub> (g)
CBC 2016	ICC-ES AC156	2.0	0,1.5G	3.2	2.4	1.34	0.54
Unit maintained st	tructural integrity and fu	nctionality after the ICC	C-ES AC 156 test				



**ATTACHMENT 2: TEST SPECIMEN SUMMARY** 

ATTACHMENT PAGE | 3 OF 4

UUT- 3	110 KVA Tran	sformer 200V-	240V				
MANUFACTURER:	Nova Magnetics	/					
IDENTIFICATION:	KM785078G09						27
				TEM SI	TIME		
DESCRIPTION:		CE Elevator Control of 200V-240V dry typoer windings.					
MOUNTING:  PROPERTIES:	Floor mounted using bolts to test fixture.	g (4) – 1/2" diameter					
	DIMENSIONS (in.)	44/ 00	D 0427 1	LOV	VEST RESONAN	IT FREQUENC	Y (Hz.)
Width	Depth	Height	Weight (lb.)	Side -Axis	s Fron	nt-Axis	Vertical-Axis
25.0	14.0	340	558	15.5	4	3.0	31.0
SHAKE TABLE T	EST PARAMETER <mark>S</mark>	BY: I In	nothy J Pili	and WWW			
CODE	TEST CRITERIA	S <sub>DS</sub> (g)	z/h l <sub>P</sub>	A <sub>FLX-H</sub> (g)	A <sub>RIG-H</sub> (g)	A <sub>FLX-V</sub> (g)	A <sub>RIG-V</sub> (g)
CBC 2016	ICC-ES AC156	2.0 DATE: (	10/21/2052	3.2	2.4	1.34	0.54
Unit maintained st	ructural integrity and fu	nctionality after the I	CC-ES AC 156 test	/ a			
		PLAORNIA	BUILDING	CODE JO			



ATTACHMENT 2: TEST SPECIMEN SUMMARY

ATTACHMENT PAGE | 4 OF 4

UUT- 5	55kVa Transformer
MANUFACTURER:	Nova Magnetics
IDENTIFICATION:	Model No.: KM785076G05
DESCRIPTION:	Component of the LCE Elevator Control System Dry type transformer, open core & coil with copper windings.
MOUNTING:	Floor mounted using (4) – 1/2" diameter Grade 8 hex head bolts to test fixture.

10kVa autotransformer | 1

Nova Magnetics

Model No.: KM785077G06



PROPERTIES:			FOK	CODE CO	4			
	DIMENSIONS (in.)	IED			LOW	EST RESONAN	IT FREQUENC	Y (Hz.)
Width	Depth	Height		Weight (lb.)	Front-Axis	Side	-Axis	Vertical-Axis
17.25	16	27.375		281	12.2	1	7.6	46.9
SHAKE TABLE TE	EST PARAMETERS	2/	OSP	-0437-10				
CODE	TEST CRITERIA	S <sub>DS</sub> (g)	z/h	I <sub>P</sub>	A <sub>FLX-H</sub> (g)	A <sub>RIG-H</sub> (g)	A <sub>FLX-V</sub> (g)	A <sub>RIG-V</sub> (g)
CBC 2016	ICC-ES AC156	2.0	1.0	1.5	3.2	2.4	1.34	0.54
Unit maintained str	ructural integrity and fu	nctionality after	the ICC-	ES AC 156 test	nd			

	diameter		ead	LOW	EST RESONAN	IT EDEOLIENC	
DIMENSIONS (in.)  Width Depth H				LOW	EST RESONAN	IT EDEOLIENO	
Width Depth H				LOW	EST RESONAN	IT EDEOLIENC	
						II FREQUENC	Y (Hz.)
12.75 13	ight	Weigh	(lb.)	Side -Axis	Fror	ıt-Axis	Vertical-Axis
	18	66	i	26.6	1	9.3	38.8
SHAKE TABLE TEST PARAMETERS							
CODE TEST CRITERIA S <sub>DS</sub> (g		z/h	l <sub>P</sub>	A <sub>FLX-H</sub> (g)	A <sub>RIG-H</sub> (g)	A <sub>FLX-V</sub> (g)	A <sub>RIG-V</sub> (g)
CBC 2016 ICC-ES AC156 2.0		1.0	1.5	3.2	2.4	1.34	0.54

**UUT- 6**MANUFACTURER:

IDENTIFICATION: