



**OFFICE OF STATEWIDE HEALTH PLANNING AND DEVELOPMENT  
FACILITIES DEVELOPMENT DIVISION**

**APPLICATION FOR OSHPD SPECIAL SEISMIC  
CERTIFICATION PREAPPROVAL (OSP)**

OFFICE USE ONLY	
APPLICATION #:	OSP – 0452 – 10

**OSHPD Special Seismic Certification Preapproval (OSP)**

Type:  New  Renewal

**Manufacturer Information**

Manufacturer: Siemens Industry, Inc.

Manufacturer's Technical Representative: Heath Klein, National Business Development Manager - Automation

Mailing Address: 1000 Deerfield Parkway, Buffalo Grove, IL 60089

Telephone: (847) 970-1165 Email: Heath.klein@siemens.com

**Product Information**

Product Name: Zone Control Unit (ZCU)

Product Type: Mechanical Equipment

Product Model Number: See attachments  
(List all unique product identification numbers and/or part numbers)

General Description: Zone Control Units are plug and play pre-fabricated terminal units, each containing an all-inclusive thermal transfer unit, piping, valves, sound attenuators, controls and sensors. Enclosures are galvanized carbon steel.

Mounting Description: Units are ceiling suspended (without spring isolators).

**Applicant Information**

Applicant Company Name: Dynamic Certification Laboratories

Contact Person: Joseph L. La Brie, S.E.


Mailing Address: 1315 Greg Street, Suite 109

Telephone: (775) 358-5085 Email: labrie@shaketest.com

I hereby agree to reimburse the Office of Statewide Health Planning and Development review fees in accordance with the California Administrative Code, 2013.

Signature of Applicant:  Date: 11/9/15

Title: Partner Company Name: Dynamic Certification Laboratories





**OFFICE OF STATEWIDE HEALTH PLANNING AND DEVELOPMENT  
FACILITIES DEVELOPMENT DIVISION**

**California Licensed Structural Engineer Responsible for the Engineering and Test Report(s)**

Company Name: Dynamic Certification Laboratories

Name: Dr. Ahmad Itani, S.E. California License Number: SE-5220

Mailing Address: 1315 Greg Street, Suite 109, Sparks, NV 89431

Telephone: (775) 358-5085 Itani@shaketest.com

**Supports and Attachments Preapproval**

- Supports and attachments are preapproved under OPM- \_\_\_\_\_  
(Separate application for OSHPD Preapproval of Manufacturer's Certification (OPM) of Supports and attachments is required)
- Supports and attachments are not preapproved

**Certification Method**

- Testing in accordance with:  ICC-ES AC156
- Other (Please Specify): \_\_\_\_\_


**Testing Laboratory**

Company Name: Dynamic Certification Laboratories

Contact Name: Kelly Laplace, Project Manager

Mailing Address: 1315 Greg Street, Suite 109, Sparks, NV 89431

Telephone: (775) 358-5085 Email: kelly@shaketest.com





**OFFICE OF STATEWIDE HEALTH PLANNING AND DEVELOPMENT  
FACILITIES DEVELOPMENT DIVISION**

**Seismic Parameters**

Design in accordance with ASCE 7-10 Chapter 13:  Yes  No

Design Basis of Equipment or Components ( $F_p/W_p$ ) = 1.88

$S_{DS}$  (Design spectral response acceleration at short period, g) = 2.50

$a_p$  (In-structure equipment or component amplification factor) = 2.5

$R_p$  (Equipment or component response modification factor) = 6.0

$\Omega_0$  (System overstrength factor) = 2.0

$I_p$  (Importance factor) = 1.5

$z/h$  (Height factor ratio) = 1.0

Equipment or Component Natural Frequencies (Hz) = See attachments

Overall dimensions and weight (or range thereof) = See attachments

Equipment or Components @ grade designed in accordance with ASCE 7-10 Chapter 15:  Yes  No

Design Basis of Equipment or Components ( $V/W$ ) = \_\_\_\_\_

$S_{DS}$  (Design spectral response acceleration at short period, g) = \_\_\_\_\_

$S_{D1}$  (Design spectral response acceleration at 1 second period, g) = \_\_\_\_\_

$R$  (Response modification coefficient) = \_\_\_\_\_

$\Omega_0$  (System overstrength factor) = \_\_\_\_\_

$C_d$  (Deflection amplification factor) = \_\_\_\_\_

$I_p$  (Importance factor) = 1.5

Height to Center of Gravity above base = \_\_\_\_\_

Equipment or Component Natural Frequencies (Hz) = \_\_\_\_\_

Overall dimensions and weight (or range thereof) = \_\_\_\_\_

Tank(s) designed in accordance with ASME BPVC, 2010:  Yes  No

**List of Attachments Supporting Special Seismic Certification**

Test Report(s)  Drawings  Calculations  Manufacturer's Catalog

Other(s) (Please Specify): \_\_\_\_\_


**OSHPD Approval (For Office Use Only) – Approval Expires on December 31, 2022**

Signature:  Date: December 8, 2015

Print Name: Timothy J. Piland Title: SSE

Special Seismic Certification Valid Up to :  $S_{DS}$  (g) = 2.50  $z/h$  = 1

Condition of Approval (if applicable): \_\_\_\_\_



# Special Seismic Certification Certified Components



**Manufacturer:** SIEMENS Industry, Inc.

**Product Line:** ZCU (Zone Control Unit)

**Product Construction:** 22 gage galvanized carbon steel cabinet with 1.0" closed cell insulation

**Options:** Factory-installed piping, sound attenuator, coils, controls, airflow sensor, temperature sensor

**Mounting Description:** Ceiling suspended

Model Number	Dimensions (in)			Max. Operating Weight (lb)	Coil Rows	Sound Attenuator	Mount	Sds (g), z/h=1	Unit
	Max. Length	Width	Height						
ZH30450x	49.0	18.0	8.0	67	1 to 4	Yes	Ceiling suspended	2.5	Interpolated
ZH30550x	49.0	18.0	8.0	67	1 to 4	Yes			Interpolated
ZH30650x	44.0	18.0	8.0	67	1 to 4	Yes			Interpolated
ZH306504	44.0	18.0	8.0	67	1 to 4	Yes			UUT1
ZH30850x	44.0	18.0	10.0	67 to 160	1 to 4	Yes			Interpolated
ZH31050x	44.0	20.0	12.5		1 to 4	Yes			Interpolated
ZH31250x	44.0	22.0	15.0		1 to 4	Yes			Interpolated
ZH31450x	44.0	26.0	17.5		1 to 4	Yes			Interpolated
ZH31650x	44.0	30.0	18.0		1 to 4	Yes			Interpolated
ZH32050x	42.5	36.0	20.0		1 to 4	Yes			Interpolated
ZH32450x	43.0	44.0	20.0		160	1 to 4			Yes
ZH324504	43.0	44.0	20.0	160	1 to 4	Yes			UUT2

x=Number of coils (1 to 4)

# Special Seismic Certification

## Certified Subcomponents



**Manufacturer:** SIEMENS Industry, Inc.

**Product Line:** ZCU (Zone Control Unit)

**Mounting Description:** Ceiling suspended

### COILS

Component No.	Component Mfg.	Material	Unit
1-4-row, Size 04 to 05	Siemens	Aluminum fin with copper tubes	Extrapolated
1-4-row, Size 06			UUT1
1-4-row, Size 08 to 16			Interpolated
1-4-row, Size 20x16			Interpolated
1-4-row, Size 24x16			UUT2

Note: Coils may be 1 to 4 rows. The worst case (4 rows) was tested.

### CONTROLS

Component No.	Component Mfg.	Description	Material	Unit
550-405	Siemens	ATEC VAV controller	Plastic with carbon steel	UUT1, UUT2
4011MWDH	Intec Controls	120V Transformer		UUT1, UUT2
SSD81U	Siemens	24VAC Actuator		UUT1, UUT2

### AIRFLOW SENSOR

Component No.	Component Mfg.	Description	Material	Unit
Size 04 to 05	Siemens	Airflow sensor	Stainless steel	Extrapolated
Size 06				UUT1
Size 08 to 16				Interpolated
Size 20 x 16				Interpolated
Size 24 x 16				UUT2

### TEMPERATURE SENSOR

Model Number	Component Mfg.	Description	Material	Unit
QAM1035	Siemens	Commissioning Sensor	Zinc-plated carbon steel and plastic	UUT1, UUT2

# Special Seismic Certification



## Tested Components

**Manufacturer:** SIEMENS Industry, Inc.

**Product Line:** ZCU (Zone Control Unit)

**Product Construction:** 22 gage galvanized carbon steel cabinet with 1.0" closed cell insulation

**Options:** Factory-installed piping, sound attenuator, coils, controls, airflow sensor, temperature sensor

**Mounting Description:** Ceiling suspended

Model	Dimensions (in)			Operating Weight (lb)	Coils (4-Row)	Sound Attenuator	Mounting: Ceiling Suspended		Sds (g), z/h=1	Unit
	Length	Width	Height				Threaded Rod Diameter (in)	Maximum Threaded Rod Spacing (in)		
ZH306504	44.0	18.0	8.0	67	Yes	Yes	1/2	26	2.5	UUT1
ZH324504	43.0	44.0	20.0	160	Yes	Yes	1/2	31	2.5	UUT2

# UUT1

## UNIT UNDER TEST (UUT) Summary Sheet

**Manufacturer:** SIEMENS Industry, Inc.

**Product Line:** ZCU (Zone Control Unit)

**Model Number:** ZH306504

**Product Construction Summary:** 22 gage galvanized carbon steel cabinet with 1.0" closed cell insulation

**Options / Component Summary:** Factory-installed piping, sound attenuator, coils, controls, airflow sensor, temperature sensor

**Note:** The UUT was operational before and after shaking and was full of operating content during the tests. The structural integrity of the component attachment system and force-resisting systems was maintained.


### UUT Properties

Operating Weight (lb)	Dimensions (inches)				Lowest Natural Frequency (Hz)		
		Length	Width	Height	Front-Back	Side-Side	Vertical
67	UUT1	44.0	18.0	8.0	N/A	N/A	N/A

### Seismic Test Parameters

Building Code	Test Criteria	Sds (g)	z/h	Ip	Aflx-H (g)	Arig-H (g)	Aflx-V (g)	Arig-V (g)
CBC 2013	ICC-ES AC156	2.5	1.0	1.5	4.00	3.00	1.67	0.67

### Unit Mounting Description:



Overall view of unit



View of bottom strut support

The unit was ceiling-suspended from the DCL shake table interface frame using 1/2-inch diameter all-thread rod spaced at 26" in the long direction of the unit, four manufacturer-provided 12-gage 90-degree brackets (each attached to the unit with four #14 SMS), and a strut frame (attached to the bottom of the unit with #12 SMS at 4" on-center). The all-thread rod length was 18" from the top of the unit to the attachment point at the shake table interface frame. Shear brackets were placed on top of each 12-gage, 90-degree bracket; each shear bracket was attached to the unit with four #14 SMS each. Lateral bracing consisted of 3/16-inch diameter steel cable and four sets of Mason SCBH-2/SSB-2 brackets installed at a 45 degree angle. The Mason brackets were attached to the interface frame with 1/2-inch diameter Grade 5 bolts.

# UUT2

## UNIT UNDER TEST (UUT) Summary Sheet

**Manufacturer:** SIEMENS Industry, Inc.

**Product Line:** ZCU (Zone Control Unit)

**Model Number:** ZH324504

**Product Construction Summary:** 22 gage galvanized carbon steel cabinet with 1.0" closed cell insulation

**Options / Component Summary:** Factory-installed piping, sound attenuator, coils, controls, airflow sensor, temperature sensor

**Note:** The UUT was operational before and after shaking and was full of operating content during the tests. The structural integrity of the component attachment system and force-resisting systems was maintained.

### UUT Properties

Operating Weight (lb)	Dimensions (inches)				Lowest Natural Frequency (Hz)		
		Length	Width	Height	Front-Back	Side-Side	Vertical
160	UUT2	43.0	44.0	20.0	N/A	N/A	N/A


### Seismic Test Parameters

Building Code	Test Criteria	Sds (g)	z/h	Ip	Aflx-H (g)	Arig-H (g)	Aflx-V (g)	Arig-V (g)
CBC 2013	ICC-ES AC156	2.5	1.0	1.5	4.00	3.00	1.67	0.67

### Unit Mounting Description:



Overall view of unit



View of bottom strut support

The unit was ceiling-suspended from the DCL shake table interface frame using 1/2-inch diameter all-thread rod spaced at 31" in the long direction of the unit, four manufacturer-provided 12-gage 90-degree brackets (each attached to the unit with four #14 SMS), and a strut frame (attached to the bottom of the unit with #12 SMS at 4" on-center). The all-thread rod length was 17" from the top of the unit to the attachment point at the shake table interface frame. Shear brackets were placed on top of each 12-gage, 90-degree bracket; each shear bracket was attached to the unit with four #14 SMS each. Lateral bracing consisted of 3/16-inch diameter steel cable and four sets of Mason SCBH-2/SSB-2 brackets installed at a 45 degree angle. The Mason brackets were attached to the interface frame with 1/2-inch diameter Grade 5 bolts.