### OFFICE USE ONLY APPLICATION FOR OSHPD SPECIAL SEISMIC **CERTIFICATION PREAPPROVAL (OSP) APPLICATION #:** OSP - 0462 - 10 **OSHPD Special Seismic Certification Preapproval (OSP)** New □ Renewal **Manufacturer Information** Teal Electronics Corporation Manufacturer: Manufacturer's Technical Representative: Rod Harvey Mailing Address: 10350 Sorrento Valley Road, San Diego, CA 92121 Telephone: 858.366.7540 Email: Rod.harvey@teal.com **Product Information** Product Name: HET Transformers Product Type: Dry-Type Transformer Product Model Number: See Attachment (List all unique product identification numbers and/or part numbers) General Description: 15-300kVA copper winding transformers enclosed in carbon steel cabinets. Seismic enhancements made to the test units and modifications required to address the anomalies observed during the tests shall be incorporated into the production units. Mounting Description: Rigid base mounted. **Applicant Information** Applicant Company Name: TRU Compliance, LLC – A Tobolski Watkins Affiliate Contact Person: Matthew J. Tobolski, Ph.D., S.E. Mailing Address: 960 SW Disk Dr., Ste. 104, Bend, OR 97702 Telephone: 844-878-0200 Email: mtobolski@trucompliance.com I hereby agree to reimburse the Office of Statewide Health Planning and Development review fees in accordance with the California Administrative Code, 2016. Signature of Applicant: Date: 03/18/2016 Company Name: TRU Compliance, LLC Title: President & CEO

"Access to Safe, Quality Healthcare Environments that Meet California's Diverse and Dynamic Needs





Page 1 of 3

California Licensed Structural Engineer Responsible for the Engineering and Test Report(s)	
Company Name: _TRU Compliance, LLC – A Tobolski Watkins Affiliate	
Name: Derek J. Manwill, S.E. California License Number: S6266	
Mailing Address: 960 SW Disk Dr., Ste. 104, Bend, OR 97702	
Telephone: 844-878-0200 Email: dmanwill@trucompliance.com	
Supports and Attachments Preapproval	
<ul> <li>Supports and attachments are preapproved under OPM-         (Separate application for OSHPD Preapproval of Manufacturer's Certification (OPM) of Supports and attachments is required)</li> <li>Supports and attachments are not preapproved</li> </ul>	
Name: Derek J. Manwill, S.E. California License Number: S6266  Mailing Address: 960 SW Disk Dr., Ste. 104, Bend, OR 97702  Telephone: 844-878-0200 Email: dmanwill@trucompliance.com  Supports and Attachments Preapproval  Supports and attachments are preapproved under OPM- (Separate application for OSHPD Preapproval of Manufacturer's Certification (OPM) of Supports and attachments is required)	
Testing Laboratory	
Company Name: Clark Testing	
Contact Name: Robert Francis	
Mailing Address: 1801 Route 51 South, Jefferson Hills, PA 15025	
Telephone: 412.387.1001 Email: rfrancis@clarktesting.com	



Page 2 of 6



## OFFICE OF STATEWIDE HEALTH PLANNING AND DEVELOPMENT FACILITIES DEVELOPMENT DIVISION

Seismic Parameters
Design in accordance with ASCE 7-10 Chapter 13: ⊠ Yes ☐ No
Design Basis of Equipment or Components (F <sub>p</sub> /W <sub>p</sub> ) = 1.44
S <sub>DS</sub> (Design spectral response acceleration at short period, g) = 2.0g (z/h = 1.0); 3.2g (z/h = 0.0)
a <sub>p</sub> (In-structure equipment or component amplification factor) = 1.0
R <sub>p</sub> (Equipment or component response modification factor) =2.5
$\Omega_0$ (System overstrength factor) =2.0
I <sub>p</sub> (Importance factor) = 1.5
z/h (Height factor ratio) = $1.0 (S_{DS} = 2.0g)$ ; $0.0 (S_{DS} = 3.2g)$
Equipment or Component Natural Frequencies (Hz) = See Attachment
Overall dimensions and weight (or range thereof) = See Attachment
Equipment or Components @ grade designed in accordance with ASCE 7-10 Chapter 15:   Yes  No
Design Basis of Equipment or Components (V/W) =
S <sub>DS</sub> (Design spectral response acceleration at short period, g) =
S <sub>D1</sub> (Design spectral response acceleration at 1 second period, g) =
R (Response modification coefficient ) =
$\Omega_0$ (System overstrength factor) =
C <sub>d</sub> (Deflection amplification factor) =
I <sub>p</sub> (Importance factor) = 1.5
Height to Center of Gravity above base =
Equipment or Component Natural Frequencies (Hz) =
Overall dimensions and weight (or range thereof) =
Tank(s) designed in accordance with ASME BPVC, 2015: ☐ Yes ☒ No
List of Attachments Supporting Special Seismic Certification
Other(s) (Please Specify): Attachment A
OSHPD Approval (For Office Use Only) – Approval Expires on December 31, 2022
Signature: Date: April 19, 2016
71-41/200
Print Name: Timothy J. Piland Title: SSE  Special Seismic Certification Valid Up to: S <sub>DS</sub> (g) = See Above z/h = See Above
Condition of Approval (if applicable):
Condition of Approval (ii applicable).

 $\hbox{``Access to Safe, Quality Healthcare Environments that Meet California's Diverse and Dynamic Needs"}$ 





Page 3 of 3

## SPECIAL SEISMIC CERTIFICATION CERTIFIED COMPONENT MATRIX

### **TRU PROJECT NO. 15047**



Manufacturer: Teal Electronics Corporation

Model Line: HET Transformers

TABLE 1

Certified Product Construction Summary:

Carbon steel enlcosure: top - 14 GA.; sides - 12 GA.; base - 7 GA. (15kVA - 10 GA. base allowed), copper windings.

**Certified Options Summary:** 

Carbon steel rain hood.

Mounting Configuration:

Base mounted - rigid

Note: Installed mounting configuration must be of similar configuration and equivalent strength and stiffness to those tested.

Building Code: CBC 2016	Seismic Certification Limits:	$S_{DS} = 2.0$	z/h=1.0	/ <sub>P</sub> = 1.5
Building Code. CBC 2016		$S_{DS} = 3.2$	z/h=0.0	1 p - 1.5

Model Line	Model	Dimensions (in)			Weight	Notes	UUT	
	Model	Depth	Width	Height	(lb)	Notes	001	
	HET-015-480-208	16.0	17.5	25.0	289	15kVA	1	
	HET-030-480-208	17.1	25.0	31.9	500	30kVA		
	HET-045-480-208	17.0	25.0	31.9	625	45kVA		
HET	HET-075-480-208	21.4	26.7	35.0	950	75kVA		
Transformers	HET-112-480-208	22.0	30.5	34.9	1,200	112kVA		
	HET-150-480-208	22.0	30.5	35.0	1,450	150kVA		
	HET-225-480-208	30.0	34.5	44.9	2,050	225kVA		
	HET-300-480-208	30.0	37.0	50.0	2,588	300kVA	2	
						_		
						anliance LLC A Tobolcki Wa		

## UNIT UNDER TEST (UUT) SUMMARY SHEET

### **TRU PROJECT NO. 15047**



**UUT 1** 

**Manufacturer:** Teal Electronics Corporation

Model Line:HET TransformersModel Number:HET-015-480-208Serial Number:463017

**Product Construction Summary:** 

Carbon steel enlcosure: top - 14 GA.; sides - 12 GA.; base - 10 GA., copper windings.

Options/Subcomponent Summary:

15kVA transformer.

UUT Properties											
Weight Dimension (in)					Lowest Natural Frequency (Hz)						
(lb)	Depth	Width	He	ght Front-Back		Side-Side		Vertical			
289	16.0	17.5	2.	25.0		16.7		18.2		15.7	
UUT Highest Passed Seismic Run Information											
Building Code Test Criteria		ia	S <sub>DS (g)</sub>	z/h	I <sub>P</sub>	A <sub>FLX-H</sub>	A <sub>RIG-H</sub>	A <sub>FLX-V</sub>	A <sub>RIG-V</sub>		
CBC 2016		ICC-ES AC156		2.0	1.0	1.5	3.20	2.40	1.33	0.53	
				3.2	0.0	1.5	3.20	1.28	2.13	0.85	

#### Test Mounting Details:





Rigid base moutned to shake table with (4) 3/8" grade 5 bolts.

Unit maintained structural integrity and remained functional per manufacturer requirement.

Contents were included in testing per operating conditions.

# UNIT UNDER TEST (UUT) SUMMARY SHEET

### **TRU PROJECT NO. 15047**



UUT 2

**Manufacturer:** Teal Electronics Corporation

Model Line:HET TransformersModel Number:HET-300-480-208Serial Number: 462863

#### **Product Construction Summary:**

Carbon steel enlcosure: top - 14 GA.; sides - 12 GA.; base - 7 GA., copper windings.

#### Options/Subcomponent Summary:

300kVA transformer, carbon steel rain hood.

UUT Properties											
Weight Dimension (in)					Lowest Natural Frequency (Hz)						
(lb)	Depth	Width	He	eight Fro		Front-Back		Side-Side		Vertical	
2588	30	37	į	50		16.7		11.5		15.8	
	UUT Highest Passed Seismic Run Information										
Building Code		Test Criter	Test Criteria		z/h	I <sub>P</sub>	A <sub>FLX-H</sub>	A <sub>RIG-H</sub>	A <sub>FLX-V</sub>	A <sub>RIG-V</sub>	
CBC 2016		ICC-ES AC156		2.0	1.0	1.5	3.20	2.40	1.33	0.53	
				3.2	0.0	1.5	3.20	1.28	2.13	0.85	

#### Test Mounting Details:





Rigid base moutned to shake table with (4) 1/2" grade 5 bolts.

Unit maintained structural integrity and remained functional per manufacturer requirement.

Contents were included in testing per operating conditions.